

CHARLES D. BAKER Governor

KARYN E. POLITO Lieutenant Governor

The Commonwealth of Massachusetts Executive Office of Health and Human Services Department of Public Health Bureau of Environmental Health Community Sanitation Program 5 Randolph Street, Canton, MA 02021 Phone: 781-828-7700 Fax: 781-828-7703

MARYLOU SUDDERS Secretary

MONICA BHAREL, MD, MPH Commissioner

> Tel: 617-624-6000 www.mass.gov/dph

November 5, 2018

Thomas M. Hodgson, Sheriff
Bristol County Sheriff's Office
Dartmouth I.C.E. Facility
400 Faunce Corner Road
North Dartmouth, MA 02747 (electronic copy)

Re: Facility Inspection - Dartmouth Women's Center, North Dartmouth

Dear Sheriff Hodgson:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 2013 Food Code; 105 CMR 500.000 Good Manufacturing Practices for Food; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Dartmouth Women's Center on October 24, 2018 accompanied by Lieutenant Andrew Mitzan, Environmental Health and Safety Officer. Violations noted during the inspection are listed below including 10 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

Control Room

No Violations Noted

Lobby

No Violations Noted

Visiting Area

No Violations Noted

Staff Break Room

Male Bathroom

No Violations Noted

Female Bathroom

No Violations Noted

Laundry

105 CMR 451.130* Plumbing: Plumbing not maintained in good repair, 3-compartment sink leaking

Janitor's Closet

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, slop sink leaking

Food Service Area

Dining

No Violations Noted

Kitchen

FC 6-501.12(A) Maintenance and Operation; Cleaning: Facility not cleaned properly, ceiling dirty around

ceiling vents

Staff Bathroom

No Violations Noted

A Wing

Bathroom

105 CMR 451.123* Maintenance: Mold on ceiling 105 CMR 451.123 Maintenance: Ceiling vent dusty

Bathroom Janitor's Closet

No Violations Noted

Trauma Room

Unable to Inspect – Locked

Showers

No Violations Noted

Day Room

No Violations Noted

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in all cells

105 CMR 451.353 Interior Maintenance: Mold on ceiling and walls in cell # A1 and A9

B Wing

Bathroom

105 CMR 451.123 Maintenance: Mold on walls

Bathroom Janitor's Closet

No Violations Noted

Showers

105 CMR 451.123 Maintenance: Mold in grout in shower # 1, 2, 3, and 4

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, shower # 1 leaking

Day Room

No Violations Noted

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in all cells

105 CMR 451.353 Interior Maintenance: Mold on ceiling and walls in cell # B13 and B16

C Wing

Bathroom

No Violations Noted

Bathroom Janitor's Closet

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, hot water out-of-order at sink next to

Janitor's Closet

Showers

No Violations Noted

Day Room

105 CMR 451.353 Interior Maintenance: Mold on walls

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in all cells

D Wing

Bathroom

105 CMR 451.123* Maintenance: Mold on walls 105 CMR 451.123 Maintenance: Walls dirty

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, hot water out-of-order at sink # 1

Bathroom Janitor's Closet

No Violations Noted

Showers

105 CMR 451.123* Maintenance: Mold in grout in shower # 1-3 105 CMR 451.123 Maintenance: Mold in grout in shower # 4

Day Room

No Violations Noted

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in all cells

Observations and Recommendations

1. The inmate population was 64 at the time of inspection.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Retail Food". Then under "Regulations" click "2013 Food Code Merged with 105 CMR 590 and 2013 Food Code"

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Processing". Then under "Regulations" click "105 CMR 500.000: Good Manufacturing Practices for Food"

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

Nicholas Gale

Nicholas Mch

Environmental Health Inspector, CSP, BEH

cc: Monica Bharel, MD, MPH, Commissioner, DPH

Jana Ferguson, Director, BEH

Steven Hughes, Director, CSP, BEH

Marylou Sudders, Secretary, Executive Office of Health and Human Services
Thomas Turco, Commissioner, DOC
Steven Sousa, Superintendent
Andrew Mitzan, Lieutenant, EHSO
Christopher Michaud, RS, Health Director, Dartmouth Board of Health
(electronic copy)
(electronic copy)
(electronic copy)
(electronic copy)

Clerk, Massachusetts House of Representatives

Clerk, Massachusetts Senate

Daniel Bennett, Secretary, EOPSS

Nelson Alves, Director, Policy Development and Compliance Unit (electronic copy)