

CHARLES D. BAKER Governor

KARYN E. POLITO Lieutenant Governor

The Commonwealth of Massachusetts Executive Office of Health and Human Services Department of Public Health Bureau of Environmental Health Community Sanitation Program 5 Randolph Street, Canton, MA 02021 Phone: 781-828-7700 Fax: 781-828-7703

MARYLOU SUDDERS Secretary

MONICA BHAREL, MD, MPH Commissioner

> Tel: 617-624-6000 www.mass.gov/dph

June 16, 2021

Thomas M. Hodgson, Sheriff
Bristol County Sheriff's Office
Bristol County Jail and House of Correction
400 Faunce Corner Road
North Dartmouth, MA 02747 (electronic copy)

Re: Facility Inspection - Bristol County Modular Building, North Dartmouth

Dear Sheriff Hodgson:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 2013 Food Code; 105 CMR 500.000 Good Manufacturing Practices for Food; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; the Department's Community Sanitation Program (CSP) conducted an inspection of the Bristol County Modular Building on June 3, 2021 accompanied by Lieutenant Andrew Mitzan, Environmental Health and Safety Officer. Violations noted during the inspection are listed below including 22 repeat violations:

Should you have any questions, please don't hesitate to contact me.

Sincerely,

Nicholas Gale

Environmental Analyst, CSP, BEH

Richard Mala

cc: Monica Bharel, MD, MPH, Commissioner, DPH

Jan Sullivan, Acting Director, BEH Steven Hughes, Director, CSP, BEH

Marylou Sudders, Secretary, Executive Office of Health and Human Services

Carol A. Mici, Commissioner, DOC Thomas Turco, Secretary, EOPSS

Timothy Gotovich, Director, Policy Development and Compliance Unit

Steven Sousa, Superintendent Andrew Mitzan, Lieutenant, EHSO

Christopher Michaud, RS, Health Director, Dartmouth Board of Health

Clerk, Massachusetts House of Representatives

Clerk, Massachusetts Senate

(electronic copy) (electronic copy)

(electronic copy)

(electronic copy)

(electronic copy) (electronic copy)

(electronic copy)

(electronic copy) (electronic copy)

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

Modular Kitchen

FC 6-201.16(A)* Design, Construction, and Installation; Cleanability: Walls not easily cleanable, paint

damaged in several areas

Loading Dock

No Violations Noted

Staff Bathroom# 013 (near Loading Dock)

No Violations Noted

Staff Bathroom # 011

Unable to Inspect – Not Used

Storage Closet # 012A

No Violations Noted

Storage Room # 016A

No Violations Noted

Walk-In Freezer

No Violations Noted

Traulsen Refrigerators

No Violations Noted

1st Floor Medical Room

No Violations Noted

1 West

Staff Bathroom

No Violations Noted

Storage Room

No Violations Noted

Offices

No Violations Noted

Classroom

No Violations Noted

Main Area

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, inadequate water pressure at drinking

fountain

Laundry

No Violations Noted

Janitor's Closet

No Violations Noted

Bathroom 1 (right side)
105 CMR 451.123*

Maintenance: Partition paint damaged in shower # 1 and 2

105 CMR 451.124 Water Supply: Insufficient hot water supply in quantity and pressure at

handwash sink # 3

Bathroom 2 (left side)

105 CMR 451.123 Maintenance: Floor dirty in shower # 7, 8, 9, and 10

105 CMR 451.123* Maintenance: Partition paint damaged in shower # 7, 8, and 9

105 CMR 451.123 Maintenance: Partition paint damaged in shower # 10

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, 1 toilet out-of-order

Dorms

105 CMR 451.322* Cell Size: Inadequate floor space in all dorms 105 CMR 451.101 Blankets: Blanket damaged in cell # 112

1 East

Staff Bathroom

No Violations Noted

Storage

No Violations Noted

Offices

No Violations Noted

Laundry

No Violations Noted

Classroom

No Violations Noted

Main Area

No Violations Noted

Janitor's Closet

No Violations Noted

Bathroom 1 (right side)

105 CMR 451.123* Maintenance: Walls dirty in shower # 1 105 CMR 451.123 Maintenance: Walls dirty in shower # 2

Bathroom 2 (left side)

105 CMR 451.123* Maintenance: Wall vent dusty in shower area 105 CMR 451.123* Maintenance: Floor tiles damaged at entrance 105 CMR 451.123 Maintenance: Walls dirty in shower # 10

105 CMR 451.124 Water Supply: Insufficient water supply in quantity and pressure handwash sink #8, 11,

and 13

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, 1 toilet out-of-order

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, standing water in shower # 9

Dorms

105 CMR 451.322* Cell Size: Inadequate floor space in all dorms

2nd Floor Medical Room

No Violations Noted

2 West

Staff Bathroom

No Violations Noted

Storage

No Violations Noted

Offices

105 CMR 451.353 Interior Maintenance: Ceiling tiles water stained

Classroom

No Violations Noted

Main Area

105 CMR 451.353* Interior Maintenance: Floor surface damaged under water fountain

Janitor's Closet

No Violations Noted

Bathroom 1 (right side)

105 CMR 451.123* Maintenance: Partition paint damaged in shower # 1

105 CMR 451.123 Maintenance: Wall vent dusty

Bathroom 2 (left side)

Unable to Inspect – Showers In Use

Dorms

105 CMR 451.322* Cell Size: Inadequate floor space in all dorms

2 East

Law Library

No Violations Noted

Staff Bathroom

No Violations Noted

Storage

No Violations Noted

Offices

No Violations Noted

Classroom

No Violations Noted

Main Area

No Violations Noted

Janitor's Closet

No Violations Noted

Bathroom 1 (right side)

Unable to Inspect – Showers In Use

Bathroom 2 (left side)	
105 CMR 451.123*	Maintenance: Floor dirty throughout bathroom
105 CMR 451.124*	Water Supply: Insufficient hot water supply in quantity and pressure at sink # 13
105 CMR 451.123*	Maintenance: Partition paint damaged in shower # 8, 9, and 10
105 CMR 451.123	Maintenance: Walls dirty in shower # 10
105 CMR 451.126	Hot Water for Bathing and Hygiene: No hot water supplied to handwash sink # 13
105 CMR 451.123	Maintenance: Floor dirty in shower # 10
103 CIVITC 131.123	Mantenance. I foot anty in shower if 10
Dorms	
105 CMR 451.322*	Cell Size: Inadequate floor space in all dorms
103 CIVIIC 431.322	cen size. madequate noor space in an dorms
Training Area	
Storage Closet # 039	
Storage Closet # 039	No Violations Noted
	NO VIOIATIONS NOTEU
Staff Bathroom # 038	
Staff Bathroom # 038	No Violations Noted
	No violations noted
Staff Bathroom # 037	
00	Hydiana Cymplica at Tailat and Handwash Cinly No nonantawala at handwash ainly
105 CMR 451.110(A)	Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink
Mods Intake Area	
Bathroom # 030	
105 CMR 451.110(A)*	Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink
105 CMR 451.123	Maintenance: Floor dirty
Bathroom # 027	
105 CMR 451.110(A)*	Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink

Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink

Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink 105 CMR 451.110(A)

Maintenance: Floor dirty 105 CMR 451.123

Janitor's Closet

No Violations Noted

Observations and Recommendations

1. The inmate population was 167 at the time of inspection.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment Regulations or download a copy, please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Retail food". Then under DPH Regulations and FDA Code click "Merged Food". Code" or "105 CMR 590.000 - State Sanitary Code Chapter X - Minimum Sanitation Standards for Food Establishments".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Program regulations". Then under Food Processing click "105 CMR 500.000: Good Manufacturing Practices for Food".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

Nicholas Gale

Michalas Mala

Environmental Analyst, CSP, BEH