

780 CMR: MASSACHUSETTS AMENDMENTS TO THE *INTERNATIONAL BUILDING CODE 2009*

**CHAPTER 27: ELECTRICAL**

**2701.1** Replace 'NFPA 70' with '527 CMR 12.00: *2008 Massachusetts Electrical Code (Amendments)*'.

**2702.1** Replace as follows:

**2702.1 Installation.** Emergency and standby power systems required by this code shall be installed in accordance with this code, 527 CMR 12.00, and NFPA 110 and 111.

**2702.1.1.1** Add subsection:

**2702.1.1.1 Air Quality Control.** *See* 310 CMR 7.00: *Air Pollution Control* for regulation on point source generation.

**2702.2.19** Replace as follows:

**2702.2.19 Elevators.** Emergency and standby power for elevators shall be provided as required by 524 CMR.

NON-TEXT PAGE