

CHAPTER 33: SAFEGUARDS DURING CONSTRUCTION

3301.1 Add these two notes at the end of this section:

Note 1. As applicable, Department of Environmental Protection (DEP) Regulations, 310 CMR 7.09: *U Dust, Odor, Construction and Demolition*, and 310 CMR 7.15: *U Asbestos*, DEP Regulations addressing asbestos, and the requirements of M.G.L. c. 111, § 150A, addressing disposal of demolition debris, must be satisfied.

Note 2. As applicable, 527 CMR, in conjunction with M.G.L. c. 148, § 27A must be satisfied if fire protection systems are to be dismantled, shut-off, or modified.

3305.1 Replace ‘the *International Plumbing Code*’ with ‘105 CMR and 248 CMR’

3309.1 Add a note 4.

4. Fire extinguisher requirements of 527 CMR shall also be satisfied.

3309.2 Replace as follows:

3309.2 Fire Hazards. The provisions of this code and the Board of Fire Prevention Regulations at 527 CMR shall be strictly observed to safeguard against all fire hazards attendant upon construction operations. The fire protection *construction documents* shall provide specifications for conformance to this chapter and NFPA-241 listed in Chapter 35 in order to safeguard against fires during construction, alterations and demolition of all buildings and structures regulated by this code.

3313 Add section:

SECTION 3313 DESIGN LOADS ON STRUCTURES DURING CONSTRUCTION

3313.1 Design Loads. The design loads on partially completed structures and temporary structures, including scaffolding, bracing and shoring, shall be in accordance with ASCE 37.

3313.2 Structural Integrity During Construction. The structural integrity of partially completed and temporary structures shall comply with ASCE 37, section 1.3.2.

NON-TEXT PAGE