

CHAPTER 5: GENERAL BUILDING HEIGHTS AND AREAS

501.1 Add two notes as follows:

Note 1. Site plans may be required to contain fire lanes per 527 CMR 10.00: *Fire Prevention, General Provisions*, as may be deemed necessary by the head of the fire department.

Note 2. In this chapter, requirements for unsprinklered buildings may be overridden by sprinkler requirements of M.G.L. c. 148.

503.1.3.1 Add subsection:

503.1.3.1 Hospital Construction. M.G.L. c. 111, § 51 requires hospitals to be constructed of at least Type IB construction.

504.1 Add a last sentence to the exception: Also see 527 CMR 10.00: *Fire Prevention, General Provisions* for fire lane requirements.

504.2 Add a last sentence as follows:

Also see automatic sprinkler system requirements for R-Use buildings in Table 903.2 note a.

507.4 Two Story. Reserved.

507.9 Add a last sentence to the exception: Also see 527 CMR 10.00: *Fire Prevention, General Provisions* for fire lane requirements.

NON-TEXT PAGE