

Correction-Sheet NFPA 1 Fire Code 2015 Edition issued on January 1, 2018

***Note:** Please note that BFPR staff has identified the following transcription errors in the revised code 527 CMR 1.00:

- (a) An ^E ahead of a section, heading, title, identifies that there is an error
- (b) A highlighted **GRAY** area shows the actual correction.

Correction No: 1-15-1 Table (NOTE State-document and strikeout document)

Revise Table 11.2.8.50. entitled Quantities, Permits and License Requirements Table as provided below by removing text as identified by a line through the text identifying each note as Note 1 through Note 3 as shown below.

Materials	Quantities	Permit	License
Class I liquids Note 1: No permit needed for storing less than 7 gallons of gasoline in one or more approved containers when stored in any building not used for habitation nor frequented by the public. Gasoline may be used, kept, or stored in any building not used for habitation nor frequented by the public, ≤ 7 gallons and provided the gasoline is stored in one or more approved containers without permit. Note 2: See alcohol based hand rub Table 1.12.8.1. Note 3: no permit or license needed when stored in containers of 60 gallons capacity or less or Note 4: no permit or license needed when stored in in portable tanks over 60 gallons capacity not intended for fixed use, including intermediate bulk containers (IBCs) designed for mechanical handling.	< 793 gallons*	yes	no
	≥ 793 gallons	yes	yes

Correction No: 1-15-2 Table (NOTE, State-document only)

Revise Table 11.2.8.50. entitled Quantities, Permits and License Requirements Table as provided below by removing the bottom row and highlighted text.

Materials	Quantities	Permit	License
Small arms ammunition primers [private use]	< 10,000 caps or other small arms primers	<u>no</u>	<u>no</u>
	≥ 10,000 caps or other small arms primers	no	yes
Small arms ammunition primers [commercial use]	< 100,000 caps or other small arms primers	yes	no
	≥ 100,000 caps or other small arms primers caps or other small arms primers	no	yes
	< 100,000 caps or other small arms primers	yes	no

* NOTE: It is planned that these will be corrected, in coordination with the Secretary of State's Office and will be made official as of the original effective date of January 1, 2018.

Correction-Sheet NFPA 1 Fire Code 2015 Edition issued on January 1, 2018

Correction No: 1-15-3 Table (NOTE, state document and strikeout document)

Revise Table 11.2.8.50. entitled Quantities, Permits and License Requirements Table as provided below by adding separate rows for quantities, permit and license as provided below

Materials	Quantities	Permit	License
Smokeless propellants [private and commercial] <i>Note 1: Persons under 18 years of age may not keep or store smokeless propellants.</i> <i>Note 2: Not more than two pounds of such propellant shall be stored in a multiple family dwelling or a building of public access.</i>	< 16 lbs	no	no
Smokeless propellants [private]	≥ 16 lbs. through 47 lbs	yes	no
	≥48	no	yes
Smokeless propellants [commercial]	≥ 16 .lbs to ≤99 lbs.	yes	no
	≥ 100 lbs	no	yes
Black powder [private and commercial] <i>Note Persons under 18 years of age may not keep or store any amount of black powder.</i>	< 2 lbs.	no	no
	≤ 5lbs.	yes	no
	> 5 lbs.	no	yes
Black powder [commercial] See Section 1.12.8.39.2.5.1 for permit exemption individual	< 50 lbs.	yes	no
	≥ 50 lbs.	no	yes

Correction No: 10-15-1 (NOTE, State-document and strikeout document)

- Revise Table 10.10.6. entitled Appliance Cooking/Heating Table as provided below by replacing 10.10.^E3.2(2) with the highlighted area in 10.10.^E6.2(2)

Balcony See ^E 10.10.6.2(2)	Deck, Porch. Patio. See 10.10.6.2(3)
*NOT Permitted under overhangs, roofs or enclosed in by walls or within 10' of a building ¹ ; unless sprinklered pursuant to the Building Code.	

Correction No: 13-15-1 (NOTE, State-document and strikeout document)

- Replace **13.3.2.8.2**. Delete. As provided below:
13.3.2.8.2^E through **13.3.2.22.1.2** Delete.

Correction No: 26-15-1 (NOTE, State-document and strikeout document)

- Add 26.4.

^E Add 26.4

^E 26.4 Installations made in accordance with the applicable requirements of the following standards shall be deemed to be in compliance with this Code except that the maximum allowable quantities of hazardous materials are limited to the quantities listed in the Building Code and Table 60.4.2.1.1.3 of this Code.

* NOTE: It is planned that these will be corrected, in coordination with the Secretary of State's Office and will be made official as of the original effective date of January 1, 2018.

Correction-Sheet NFPA 1 Fire Code 2015 Edition issued on January 1, 2018

Correction No: 41-15-1 (NOTE, State-document only)

1. Revise **41.7.1** by inserting ahead of the opening paragraph the following:

^EAs of July 1, 2018. So that **41.7** will read as follows:

41.7 Qualifications.

41.7.1. through **41.7.1 (5).** Add

41.7.1 ^EAs of July 1, 2018, an individual to be qualified to be a PAI, perform fire watches, perform, supervise or delegate any activities of hot work as defined in this chapter shall first provide documentation that he or she has successfully completed training approved by the State Fire Marshal in the following areas: Successfully completed as used here means an education program covering materials provided in 41.7(1) through (5) further, the material was completed by the individual within the past 12 months; and that a certificate of completion has been issued to the individual with the date of completion on the certificate and a provider's/ instructor's signature acknowledging such individual attended and completed the program containing all of the following subject matter;

- (1)** Massachusetts Comprehensive Fire Safety Code, 527 CMR: 1.00 Chapter 41, Hot Work Operations
- (2)** 29 CFR 1910.252 Subpart Q-Welding, cutting and brazing
- (3)** NFPA 51B Standard for Fire Prevention During Welding, Cutting, and Other Hot Work, 2014 edition
- (4)** NFPA 241, Standard for Safeguarding Construction, Alteration, and Demolition operations, 2013 edition.
- (5)** ANSI Z49, Safety in Welding, Cutting, and Allied Processes, 2012 edition

Correction No: 42-15-1 (NOTE, State-document and strikeout document)

1. Revise **42.9.9.8 (4)** insert in 119 gallons thereby replaces 110 gallons:

(4) The tank is securely mounted to the vehicle body or truck bed and its capacity does not exceed ^E 119 gallons.

Correction No: 42-15-2 (NOTE, State-document and strikeout document)

1. Revise **42.15.2 (1)** insert in 119 gallons thereby replaces 110 gallons:

42.15 Transportation by Transfer Tanks.

42.15.2 The vehicle shall be approved for the transportation of the combustible liquid provided that:

(1) The tank is securely mounted to the vehicle body or truck bed and its capacity does not exceed ^E 119 gallons;