



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
5 Randolph Street, Canton, MA 02021
Phone: 781-828-7700 Fax: 781-828-7703

CHARLES D. BAKER
Governor

KARYN E. POLITO
Lieutenant Governor

MARYLOU SUDDERS
Secretary

MONICA BHAREL, MD, MPH
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

November 21, 2016

Thomas M. Hodgson, Sheriff
Bristol County Sheriff's Office
Dartmouth Women's Center
400 Faunce Corner Road
North Dartmouth, MA 02747

Re: Facility Inspection - Dartmouth Women's Center, North Dartmouth

Dear Sheriff Hodgson:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Dartmouth Women's Center on November 8, 2016 accompanied by Lieutenant Andrew Mitzan, EHSO. Violations noted during the inspection are listed below including 11 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

Visiting Area

No Violations Noted

Lobby

No Violations Noted

Control Room

105 CMR 451.200

Food Storage, Preparation and Service: Food preparation not in compliance with 105 CMR 590.000, interior of microwave oven dirty

Staff Breakroom

No Violations Noted

Male Bathroom

No Violations Noted

Female Bathroom

No Violations Noted

Laundry

105 CMR 451.130*

Plumbing: Plumbing not maintained in good repair, 3-bay sink leaking

Janitor's Closet

No Violations Noted

Food Service Area*Dining*

No Violations Noted

Kitchen

FC 4-903.11(A)(2)*

Protection of Clean Items, Storing: Single-service items not protected from contamination, utensils left uncovered under serving line

FC 5-205.15(B)

Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, hot water out-of-order at handwash sink

Staff Bathroom

No Violations Noted

A Wing*Bathroom*

105 CMR 451.123

Maintenance: Ceiling vent dusty

Bathroom Janitor's Closet

No Violations Noted

Showers

105 CMR 451.123*

Maintenance: Ceiling vent dusty in all showers

Day Room

No Violations Noted

Cells

105 CMR 451.321*

Cell Size: Inadequate floor space in all cells

B Wing*Bathroom*

105 CMR 451.123

Maintenance: Appearance of mold on walls

Bathroom Janitor's Closet

No Violations Noted

Showers

105 CMR 451.123

Maintenance: Walls dirty in all showers

105 CMR 451.123

Maintenance: Floor dirty in all showers

Day Room

No Violations Noted

Cells

105 CMR 451.321*

Cell Size: Inadequate floor space in all cells

C Wing

Bathroom

105 CMR 451.123* Maintenance: Ceiling vent dusty

Bathroom Janitor's Closet

No Violations Noted

Shower

105 CMR 451.123* Maintenance: Ceiling vent dusty in shower # 1, 2, and 3
105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, shower # 1 leaking

Day Room

No Violations Noted

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in all cells

D Wing

Bathroom

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, sink # 1 out-of-order

Bathroom Janitor's Closet

No Violations Noted

Showers

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, shower # 3 leaking
105 CMR 451.123 Maintenance: Walls dirty in shower # 3

Day Room

No Violations Noted

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in all cells

Observations and Recommendations

1. The inmate population was 96 at the time of inspection.
2. During the inspection, the Department recommended that all showers and cells be identified with a numbering system. This will assist the Department and correctional employees to better recognize where issues exist.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X - Minimum Sanitation Standards for Food Establishments" and "[1999 Food Code](#)".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Nicholas Gale
Environmental Health Inspector, CSP, BEH

cc: Jan Sullivan, Acting Director, BEH
Steven Hughes, Director, CSP, BEH
Timothy Miley, Director of Government Affairs
Marylou Sudders, Secretary, Executive Office of Health and Human Services
Thomas Turco, Commissioner, DOC
Steven Sousa, Superintendent
Andrew Mitzan, Lieutenant, EHSO
Christopher Michaud, RS, Health Director, Dartmouth Board of Health
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Daniel Bennett, Secretary, EOPSS
Jennifer Gaffney, Director, Policy Development and Compliance Unit