

Distribute Energy Resources Interconnection Seminar Station / Experience Process


December 10, 2024

Thank you for joining us.

The presentation will begin at 9:00am.

Please mute your phones to avoid any feedback.

Thank you.



Holiday safety tip:

Some holiday plants can be toxic to household pets. Keep mistletoe, holly berries, lilies, daffodils, Juncus, amaryllis away from animals. Christmas Cactus and Poinsettias can cause intestinal distress like diarrhea, vomiting, which leads to dehydration.

Introductions & Agenda

- PowerPoint
- Expedited/ Standard Interconnection Process
- DG Interconnection Documentation Requirements
- Engineering Design of Pre-Construction
- Distribution Group Studies
- Effective Grounding Requirements
- RTAC Requirements
- Transmission Group ASO Studies
- FERC Order 2023 Intro
- Questions



EXPEDITED

Interconnection Contacts

Eversource Energy Eastern MA DG

Smart

- mail: SMART@eversource.com
- Toll Free Number: 844-726-7573

- Brandon Natale:
 - Email: brandon.natale@eversource.com
- Evan Melillo:
 - Email: evan.melillo@eversource.com
- Kelly Musto:
 - Email: kelly.musto@eversource.com
- Melanie Khederian:
 - Email: melanie.khederian@eversource.com
- Zach Tedford:
 - Email: zachary.tedford@eversource.com

POWER CLERK EPE APPLICATIONS

APPLICATION FEES CAN NOW BE PAID ONLINE

- Systems greater than 15 kW AC single phase or greater than 25 kW AC three phase
- System configuration does not correspond with the service configuration (such as using single phase inverters on a three-phase service)
- System includes non-inverter-based generator, co-generator, wind, hydro or other facility
- System is on a radial distribution circuit

Proposed generation equipment must meet IEEE 1547.1 standards.

Expedited/Standard application fee = \$4.50 per kW (minimum fee of \$300; maximum of \$7,500)


You will be prompted to submit a pre-app if you are installing a generation facility of 250 kW AC or greater. Pre-App fees are \$250 for projects up to 500 kW and \$750 for projects over 500kW.

Contractors/Installers

Please login to Eversource.com and register for the access

Customers

Request read/write access from your installer



[Eversource](#) | [PowerClerk Log In](#)

One Line Diagram (SLD)

- Requires Stamp
- Existing metering and proposed meter/interconnection
- Point of common coupling with Interconnecting Device, please note existing pole number
- Size of main breaker
- External disconnect switch needs to be lockable in the open position and accessible by the utility 24/7 at all times of the year
- Generator connection point, breaker and size
- kW rating needs to match application (name plate)
- Interconnecting customer transformer configuration (if applicable) and impedance must match application.
- Cold Sequence Metering Required (Customer equipment – Disconnect Switch – meter)
- Recloser Required for 500 kW C (Recloser – primary meter – Customer equipment)
- Title block with customer name, address, date, drawing number and revision number
- Inverter settings in table form
- Definitive relay settings in table form, relay(s), PT's and T's

Site Plan

- Must show property/lot lines, street names
- Interconnecting Pole Numbers
- Must show revenue meter location, location of inverter(s) and/or generators and disconnect
- Must show production meter if Net Metered
- Does not need to be PE Stamped
- Must be a plan form view i.e. vertical
- NOT “bird’s eye”, isometric, 3/4 view, google maps
- Title block with Customer name, address, date, drawing number and revision number

Spec Sheet a e equ e fo l ve te a Batte e - If ve te ba e a how that t UL1741-SB

<http://www.eversource.com/content/oc/default-content/bulletin-contact/default-eee1547-2018-ettg-equeme-t-ue.pfv?fv=160fb8312>

Effective Grounding Overview

*See definition of Significant Adverse Impact in ISO-NE's *Transmission Planning Technical Guide*: https://www.iso-ne.com/static-assets/documents/2017/03/transmission_planning_technical_guide_rev6.pdf

Effective Grounding

If effective grounding is required, the customer's site must meet the effective grounding requirement of X0/X1 at the PCC below 3 when disconnected from the Eversource system. Eversource will review a customer's site effective grounding by modeling the site ASPEN and evaluating the X0/X1 at the PCC.

For customers with separate PCC for the PV and BESS systems, they will need to achieve effective grounding the following three categories: 1) PV only, 2) BESS only, 3) PV and BESS.

Effective grounding shall be required for all DER connections where any of the following is true:

- The fault current at the point of common coupling (PCC) caused to exceed by at least 10 percent of the existing value.
- Area where fault current may already be deemed excessive.
- DER connections equal to or larger than 1MW.
- Anywhere there may exist a potential for ground-to-ground or ground-to-load.

DER that require effective grounding shall use one of the following methods:

- A GSU with a reactively grounded neutral on the high (utility) wye-connected area and delta configuration on the low (generator) side.
- A GSU with a grounded wye / grounded wye configuration and a grounded delta for one end of the GSU.
- A delta high (utility) end GSU configuration and a grounded delta for one end of the high (utility) side.

DER that do NOT require effective grounding shall use:

- A GSU with delta winding on the high (utility) end of the GSU connected with a customer provided 59N (3V0) chemically bonded PT on the high (utility) end of the GSU.

Please see Section 2.8 for the Information and Technical Requirements for more information.

P&C Common Comments on SLD

- On-line relays must have the IEEE1547 protective effect, and the Ride-Through capability of the inverter. See Table I-V from ISO New England outline the IEEE1547 table.
- The voltage pickup value shall be 1.1 volt (per phase / 0.95 pu value).
- The PCC correct with should not be a future correct. If a future we are to blow, a phase correct would exist, and the time may expect to balance the rate of a expected possible future of a case.
- For inverter-based over 500kW, the inverter must have a fault to allow utility relay with 27, 59, **59N**, 81U and 81O relay functionally.
- The customer's dedicated utility grade relay/protection shall be located at the PCC.

Table I: DER response (shall trip) to abnormal frequencies-Category I, Category II and Category III

Shall Trip Function	Required Settings		Comparison to default IEEE Std. 1547-2018 for Category I, II, III		
	Frequency (Hz)	Clearing Time(s)*	Frequency	Clearing Time (s)	Within Ranges of Allowable settings?
OF2	62.0	0.16	Identical	Identical	Yes
OF1	61.2	300.0	Identical	Identical	Yes
UF1	58.5	300.0	Identical	Identical	Yes
UF2	56.5	0.16	Identical	Identical	Yes

Table II: Frequency ride-through requirements for DER of abnormal operating performance-Category I, Category II, and Category III

Frequency Range (Hz)	Operating Mode	Comparison to IEEE Std. 1547-2018 for Category I, II, III
$f > 62.0$	No ride-through requirements apply to this range	Identical
$61.2 < f \leq 61.8$	Mandatory Operation	Identical
$58.8 \leq f \leq 61.2$	Continuous Operation	Identical
$57.0 \leq f < 58.8$	Mandatory Operation	Identical
$f < 57.0$	No ride-through requirements apply to this range	Identical

Table IV: Certified inverter response (shall trip) to abnormal voltages -Category III

Shall Trip Function	Required Settings		Comparison to default IEEE Std. 1547-2018 (as amended by IEEE-1547a-2020) for Category III		
	Voltage (p.u. of nominal voltage)	Clearing Time(s)*	Voltage	Clearing Time (s)	Within ranges of allowable settings?
OV2	1.20	0.16	Identical	Identical	Yes
OV1	1.10	2.0	Identical	Much shorter (default is 13 s)	Yes
UV1	0.88	3.0	Identical	Much shorter (default is 21 s)	Yes
UV2	0.50	1.1	Identical	Shorter (default is 2 s)	Yes

Table V: Voltage ride-through requirements for certified inverter abnormal operating performance-Category III

Voltage Range (p.u.)	Operating Mode/ Response	Comparison to IEEE Std. 1547-2018 for Category III
$V > 1.20$	Cease to Energize	Identical
$1.10 < V \leq 1.20$	Momentary Cessation	Identical
$0.88 \leq V < 1.10$	Continuous Operation	Identical
$0.5 \leq V < 0.88$	Mandatory Operation	Identical
$V < 0.50$	Momentary Cessation	Identical




RTAC Overview

*See definition of Significant Adverse Impact in ISO-NE's *Transmission Planning Technical Guide*: https://www.iso-ne.com/static-assets/documents/2017/03/transmission_planning_technical_guide_rev6.pdf

DER SCADA Monitoring & Control Requirements

- New standard D EM 19.065 DER SCADA Monitoring and Control
- Applicable to all DER facilities >500 kW
- Based on DER Gateway to Power Plant Controller (PPC)
 - supports future flexible dispatch limiting interconnection schedules
 - supports future real-time operating envelope dispatch with DERM S
- Eversource supplied DER Gateway (RTAC 3350)
- Customer provides PPC
 - May use RTAC 3350 or similar controller for PPC
- Technical support available from Schweitzer Engineering Laboratories (SEL)

DER Gateway high level overview



Transmission Studies Overview

- Volume of DER applications seeking to interconnect has resulted in the need to ensure that DER projects do not cause adverse impacts* to the network.
- Eversource in coordination with ISO-NE will now assess each DER application and perform a ASO Impact Screen to determine if the facility may result in adverse impact to the system and the correct path of study.
- Level 0/1 studies
 - At a minimum, generally consist of a transfer limit assessment to ensure no degradation of ISO-NE Interface Limits. If adverse impacts found, a Level 3 ASO study will be required.
 - Some Level 0/1's may require more detailed analysis
- Level 3 studies
 - Conduct thermal and voltage steady state, short circuit, stability analysis
 - PSCAD analyses will be required as per ISO-NE PP5-6 requirements
 - Technical data will be requested from projects and is required to start studies

*See definition of Significant Adverse Impact in ISO-NE's *Transmission Planning Technical Guide* https://www.iso-ne.com/static-assets/documents/2017/03/transmission_planning_technical_guide_rev6.pdf

Capital Investment Project (CIP)- Distribution Group Studies

- Eversource is performing distribution group studies in Massachusetts to efficiently process and analyze distributed generation (DG) applications that allow complementary group solutions to be shared by DG customers. The group study looks at the collective impact on the system to understand what system modifications would be required to support these DG projects when interconnected.
- Customer's that are connecting to stations associated with the group will be required to pay a cost per kW AC to interconnect.

Distribution Group Studies Process and CIP Schedule

Group	Final SIS Date +/- 25% Cost Estimate	Customer Notification (10 business days after completion)	CIP Proposal Deadline (40 business days after completion)	CIP Fee (Dollars/kW)
Marion-Fairhaven	Completed on 3/29/2022	Completed on 3/28/2022	Approved 12/31/2022	\$370/kW
Plymouth	Completed on 4/19/2022	Completed on 4/19/2022	Approved 6/4/2024	\$224/kW
Cape	Completed on 4/25/2022	Completed on 4/25/2022	Approved 6/4/2024	\$357/kW
Freetown	Completed on 4/1/2022	Completed on 4/1/2022	Submitted 4/29/2022	\$490/kW
Dartmouth Westport	Completed on 4/8/2022	Completed on 4/8/2022	Approved 6/4/2024	\$387/kW
New Bedford	Completed on 5/11/2022	Completed on 5/11/2022	Eversource will not be filing a CIP Proposal for the New Bedford Group Study	N/A
Plainfield Blandford	Completed on 4/4/2022	Completed on 4/4/2022	Approved 6/4/2024	\$498/kW

Capital Investment Project (CIP)- Distribution Group Studies- Continued

- To identify individual connections associated with the group studied, please utilize our household map. We have included the location for each group in the table on our right. This information is also posted on our website.

Group Name	Substation Name
Plymouth	Brook St 727
	Manomet 721
	Tremont 713
	Valley 715
	Wareham 714
	West Pond 737
	Kingston 735
Freetown	Assonet 647
Marion-Fairhaven	Arsene St 654
	Crystal Springs 646
	Rochester 745
	Wing Lane 624
Cape	Falmouth 933
	Harwich 968
	Hatchville 936
	Hyannis Jnc 961
	Sandwich 916
	Oak St 920
	Mashpee 946
	Otis 915
Dartmouth-Westport	Cross Rd 651
	Fisher Rd 657
Blandford	Blandford 19J

Summary of Resources Available

Mass Distribution, Interconnections & Net Metering

<https://www.eversource.com/content/ema-c/about/about-us/doing-business-with-us/builders-contractors/interconnections/massachusetts>

ASO Impact Screening Flow Diagram

https://www.eversource.com/content/docs/default-source/builders-contractors/aso-impact-screen-diagram.pdf?sf_rsn=551cdd62_2

Technical Data Request List for Level 3 ASO Transmission Studies

https://www.eversource.com/content/docs/default-source/builders-contractors/aso-technical-data-request.pdf?sf_rsn=2d53d562_0

Hosting Capacity Maps

<https://www.eversource.com/content/ema-c/about/about-us/doing-business-with-us/builders-contractors/interconnections/massachusetts/hosting-capacity-map>

Distribution

https://www.eversource.com/content/docs/default-source/builders-contractors/distributed-generation-guidelines-interconnection.pdf?sf_rsn=5432d062_2

SMART Installers

<https://www.eversource.com/content/ema-c/about/about-us/doing-business-with-us/builders-contractors/interconnections/massachusetts/smart-solar-program-installers>

Distribution Group Studies

<https://www.eversource.com/content/residential/about/doing-business-with-us/interconnections/massachusetts/distribution-group-studies>

Host Capacity Map

<https://eversource.maps.arcgis.com/apps/webappviewer/index.html?id=7b13d31f908243e49406f198b359aa71>

Distribution Energy Resource (DER) Projects Costs

www.eversource.com/content/residential/about/doing-business-with-us/interconnections/massachusetts/distributed-energy-resources-project-costs



THANK YOU!!

