

## **Self-Audit Safety Checklist for DPW Garage**

## Purpose:

This checklist is a guide to assist public employers provide a safe workplace and reduce the risk of work-related injuries. This is not a complete list, but includes some key items needed to initiate a safety program at your workplace. Refer to the actual standards for a more detailed description.

Building Name:	 Date:	
Address:	 <u> </u>	
Conducted by:	 	

Facility Inspection – DPW Garage	Standard	Υ	N	Correction Required
Electrical	000000000	-		11000
Electrical outlets and switches– cover plates installed.	1910.305(b)			1
Receptacles are grounded.	1910.304(b)(2)(i)			
Receptacles in kitchens and wet locations have GFCI.	1910.304(b)			
Extension cords are not used for permanent wiring.	1910.305(g)(1)(ii)			
Power cords - Electrical grounding pins (3-prong) intact	1910.335(a)(3)(i)			
Power strips are not piggybacked.	1910.303(b)(2)			
Circuit panels have circuits labeled.	1910.303(f)(2)			
Circuit panels and boxes - unused openings are covered.	1910.305(b)(1)(ii)			
Circuit panels – access to panels is kept clear.	1910.303(g)(1)			
Fire Prevention				
Fire extinguishers–monthly visual check conducted.	1910.157(e)(2)			
Fire extinguishers–annual maintenance check	1910.157(e)(3)			
Flammables stored away from ignition sources.	1910.106(d)(5)(iii)			
Sprinkler heads – items not hung or obstructing sprinklers.	1910.159(c)(10)			
Floor Condition				
Floors kept clean and dry.	1910.22(a)(2)			
Broken, damaged floor or stair treads repaired.	1910.22(d)(1)			
Protruding object, loose boards, spills cleaned/repaired.	1910.28(b)(3)(ii)			
Hazardous Chemicals				
Containers kept closed, labeled.	1910.1200(f)(6)			
Safety Data Sheet available for each product.	1910.1200(g)(8)			
Eyewash is provided if chemical products are corrosive.	1910.151(c)			
Housekeeping				
Aisles clear, areas kept clean, dry and free of pests.	1910.141(a)			
Ladders				
Ladders are inspected before each initial use.	1910.23(b)(9)			
Ladders are used according to purpose for which it is designed.	1910.23(b)(8)			
Lockout-Tagout				
Power is shut off before equipment maintenance (ie HVAC,	1910.333(a)(1);			
appliances, lighting)	1910.333(b)(2)			
Lockout-tagout equipment is available: tags, locks	1910.333(b)(2)(iii)			

Facility Inspection – DPW Garage	Standard	Υ	N	Correction Required
Material Storage				
Stored material is secure and stable.	1910.176(b)			
Stored material does not create a trip, fire, or pest hazard.	1910.176(c)			
Mezzanines – railing if more than 4ft above next level.	1910.28(b)(1)(i)			
Shelves – item height is at least 18 in below sprinkler heads	1910.159(c)(10)			
Heavy items stored in manner to reduce lifting injury	(5)(a)(1)			
Mechanics				
Vehicle pits >10 ft deep: markings to reduce fall hazard.	1910.28(b)(8)			
Mechanics trained to operate hydraulic vehicle lifts.	(5)(a)(1)			
Personal Protective Equipment (PPE)				
Gloves, goggles, ear plugs, overboots are supplied for tasks with potential exposure to chemicals or particulates.	1910.132(a)			
Roof				
Skylights are protected by guardrail, cage, or net.	1910.23(a)(4)			
Workers on roof for maintenance activity are protected from falling off roof. Designated areas and training required.	1910.28(b)(13)			
Stairs				
Handrail and railing on stairs and exposed landings.	1910.25(b)(1)			
Stairs kept clear. Storage is not allowed on stairs or egress.	1910.176(c)			
Platform provided when a door opens directly onto a stairway.	1910.25(b)(5)			
Tools and Equipment				
Power tools inspected before use.	1910.242(a)			
Power tools- electrical cords are 3-prong or double insulated.	1910.334(a)			
Snowblowers: machine guards and push sticks available.	1910.243(e)			
Saws have machine guards, push sticks, and anti-kickback.	1910.213			
Lawnmowers: machine guards. Ride-on mowers have ROPS and seatbelts.	1910.243(e)			
Mobile scaffolds: workers trained on use and stability.	1910.29(e)			
Abrasive wheels adjusted for work rest and tongue guard.	1910.215 (a)(4)			
Machines designed for fixed location are securely anchored to prevent walking or moving.	1910.212(b)			
Welding				
Compressed gas cylinders capped and secured.	1910.101(b)			
Oxygen is not stored adjacent to acetylene, except when in use.	1910.253(b)			
Flashback and backflow protection	1910.253 (e)			

Required Training – DPW Garage	Standard	Initial	Refresher
Emergency action plan for all employees in facility.	1910.38(f)	Yes	Performance Based
Fire extinguisher, if employees expected to use.	1910.157(g)(2)	Yes	Performance Based
Hazard communication for custodial/facility workers.	1910.1200(h)	Yes	Performance Based
Hydraulic vehicle lifts, operator training.	5(a)(1)	Yes	Performance Based
Ladder training for custodial/facility workers.	1910.26(b)(3)	Yes	Performance Based
Lockout Tagout for custodial/facility workers.	1910.332(a)-(c)	Yes	Performance Based
Personal Protective Equipment	1910.132	Yes	Performance Based
Roof activity – designated areas for fall protection	1910.28(b)(13)	Yes	Performance Based
Staff trained in the use of equipment (snow blowers, chainsaws, mobile scaffolds, mowers, saws, etc.) Follow <i>Owner's Manual</i> .	1910.242(a)	Yes	Performance Based