

GoNetspeed Appendix 5

Pre-Filed Testimony of Dr. Lawrence M. Slavin on Behalf of CRC
Communications LLC, D/B/A OTELCO

*CRC Communications LLC, d/b/a OTELCO, Complainant, v.
Massachusetts Electric Company d/b/a National Grid, and
Verizon New England Inc., D.T.C. 22-4, July 11, 2022*

**COMMONWEALTH OF MASSACHUSETTS
DEPARTMENT OF TELECOMMUNICATIONS AND CABLE**

CRC Communications LLC, d/b/a OTELCO,

Complainant,

v.

Massachusetts Electric Company d/b/a National
Grid, and Verizon New England Inc.,

Respondents.

D.T.C. 22-4

**PRE-FILED TESTIMONY OF
DR. LAWRENCE M. SLAVIN
ON BEHALF OF
CRC COMMUNICATIONS LLC, d/b/a OTELCO**

July 11, 2021

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

4879-9035-2424v.1 0119280-000001

1 **COMMONWEALTH OF MASSACHUSETTS**
2 **DEPARTMENT OF TELECOMMUNICATIONS AND CABLE**

3
4 **PRE-FILED TESTIMONY OF**
5 **LAWRENCE M. SLAVIN, PH. D.**
6 **ON BEHALF OF**
7 **CRC COMMUNICATIONS LLC, d/b/a OTELCO**
8
9

10 **I. INTRODUCTION**

11 **A. WITNESS IDENTIFICATION**

12 **Q. Please state your name, title and business address.**

13 A. My name is Dr. Lawrence M. Slavin. I am the principal of Outside Plant Consulting
14 Services, Inc., a private practice specializing in standards, guidelines, and construction
15 methods for outside plant facilities in the telecommunications and power industries. My
16 address is Outside Plant Consulting Services, Inc., 15 Lenape Avenue, Rockaway, NJ
17 07866.

18 **Q. Please summarize your educational and professional experience and qualifications.**

19 A. I received a B.S. in Mechanical Engineering from The Cooper Union for the Advancement
20 of Science and Art. I then pursued an M.S. in Engineering Mechanics at New York
21 University, where I also received my Ph.D. in Mechanical Engineering. My professional
22 background includes a wide range of consulting experiences in various roles in the
23 telecommunications industry, including investigation of issues related to the power
24 industry. Among my many activities, I have provided technical support for American
25 Society of Civil Engineers (ASCE) Manual No. 111, "Pole Reliability Based Design of
26 Utility Pole Structures."

1 I currently represent the national telephone industry, via the Alliance for
2 Telecommunications Industry Solutions, on the National Electrical Safety Code (NESC)
3 Committee. I actively participate on various NESC subcommittees, including the relevant
4 Subcommittee 4 (Overhead Lines – Clearances) and Subcommittee 5 (Overhead Lines –
5 Strength & Loading), as well as on Subcommittee 7 (Underground Lines), Interpretations
6 Subcommittee, Executive Subcommittee and Main Committee. I also serve on Accredited
7 Standards Committee 05, responsible for several utility standards, including the relevant
8 *ANSI O5.1, Wood Poles, Specifications and Dimensions*.

9 Additionally, I have written several articles in industry journals and publications,
10 including recently in IAEI (International Association of Electrical Inspector) Magazine,
11 *Highlights of the next edition of the National Electrical Safety Code*, and have chaired
12 panel sessions for the benefit of the industry on behalf of the NESC. I am author of the
13 recently published book *Overhead Distribution Lines – Design and Applications*, by
14 Wiley–IEEE, and am a contributor to the *Telcordia Blue Book – Manual of Construction*
15 *Procedures*. Additional details summarizing my background, training, and professional
16 activities are attached to my testimony as Exhibit A.

17 In addition to my work on the NESC Committee, I have been, and/or continue to
18 be, involved in several state regulatory commission proceedings involving various aspects
19 of pole attachments and clearance and loading requirements, including matters arising in
20 Florida, Connecticut, Georgia, and California.

21 **B. PURPOSE OF TESTIMONY**

1 **Q. Please explain the purpose of your testimony.**

2 A. I was asked by representatives of OTELCO to discuss the practice of pole “boxing” (or
3 “opposite side” construction), as it relates to efficient construction techniques for overhead
4 communication lines and compliance with appropriate safety codes and industry practices.
5 The ability to use this method, as opposed to the installation of a new, larger pole, increases
6 the feasibility of providing broadband services to the public. Verizon and National Grid,
7 however, have disallowed this practice to OTELCO, resulting in this formal complaint
8 proceeding. In their responses, Verizon and National Grid claim there are issues related to
9 boxing, including safety and complications to future work. My testimony addresses these
10 issues.

11 **C. SUMMARY OF TESTIMONY**

12 **Q. Would you briefly summarize the areas upon which you are testifying?**

13 A. My testimony addresses:

- 14 (1) The benefits of using boxing (or opposite side construction) to avoid costly make-
15 ready, including pole replacements;
- 16 (2) The concerns raised by Verizon and National Grid pertaining to boxing (or opposite
17 side construction), including potentially more complicated pole removal and issues related
18 to climbing and safety; and
- 19 (3) Technical issues pertaining to attaching communications lines below Verizon.

1 **III. TESTIMONY**

2 **Q. Could you explain how the NESC and safety considerations apply generally to pole**
3 **attachments?**


4 **A. Yes. As stated in the Abstract of the NESC (2017):**

5 This Code covers basic provisions for safeguarding of persons from hazards arising
6 from the installation, operation, or maintenance of (1) conductors and equipment in
7 electric supply stations, and (2) overhead and underground electric supply and
8 communication lines.

9 The NESC is widely recognized as a “basic” safety code. While a utility may decide to
10 exceed the rules of the NESC in order to create an even “safer” environment, it is also
11 recognized that it is necessary to balance various issues when attempting to provide
12 essential (lifeline) services to the public. Such services include electric supply and
13 communications, including the increasing need for broadband. Accordingly, the use of
14 joint-use construction is, and always has been, a balance between the need to provide as
15 safe a working environment as possible and the ability to practically deliver critical electric
16 supply and communications services. Indeed, it would be considerably “safer” to utilize
17 separate structures for delivering these two types of services, rather than combine them on
18 the same structure. However, in most cases having two separate structures for electric and
19 communications facilities is not a viable solution, as evidenced by the extensive joint-use
20 of poles throughout the country.

21 **Q. Please explain the meaning of a “boxing” or “opposite side” construction.**

1 A. The practice of pole boxing refers to the installation of cables or wires running in the
2 longitudinal direction, along the line, on opposite sides of the pole, as illustrated in Figure
3 1:



4
5 **Figure 1**

6 Because of the potential benefits in its usage to an attacher, albeit with possible
7 inconveniences to both the party using it as well as other parties, including the pole owner,
8 this practice has been somewhat controversial.


9 **Q. What are the benefits of opposite side construction?**

10 A. The installation of longitudinal runs of cables on opposite sides of the poles – i.e., boxing –
11 is an efficient, cost-effective means of adding communications cables to existing poles, and

1 may be used to avoid the immediate need for an expensive pole replacement operation. The
2 procedure is consistent with the safety rules of the NESC, as well as the industry practices
3 provided in the Telcordia *Blue Book – Manual of Construction Procedures*. It is recognized
4 that future pole replacements, as *may* occur at some time in the future, *may* be more difficult
5 – and possibly more expensive – to accomplish. If and when that happens, it would be
6 incumbent upon the cost-causer (the party utilizing this practice) to incur the related
7 incremental expenses, with an additional obligation to facilitate the operation, possibly by
8 temporarily detaching its lines from pole(s), as necessary.

9 **Q. In National Grid’s Response to the Complaint, they argue that “boxing” would**
10 **require “implementing a significant modification to National Grid’s construction**
11 **policies which are essential to preserving system reliability and worker and public**
12 **safety.” (See National Grid Response at p. 22.) I will ask you to address each of the**
13 **points National Grid and Verizon raise concerning the practice of “boxing,” but first,**
14 **is “boxing” or “opposite side” construction consistent with the NESC?**

15 **A.** Yes. The use of boxing is consistent with the safety rules of the NESC, as well as the
16 industry practices provided in the Telcordia *Blue Book – Manual of Construction*
17 *Procedures*. For instance, the 2017 edition of the *Blue Book* illustrates recommended
18 spacings and clearances when cables are placed on opposite sides of the pole:



Boxing is therefore an accepted procedure and entirely appropriate when it facilitates delivery of advanced communication services, without which the provision of such services may not be feasible.

Q. Do you consider “boxing” or “opposite side” construction to be an important construction alternative for deployment of competitive broadband services?

A. Yes. As the communications industry evolves, accompanied by the increasing need for and deployment of broadband services, the ability to install the associated cables on existing infrastructure is becoming increasingly difficult. A commonly encountered issue is that of insufficient space on the utility poles, consistent with industry requirements and practices. The available space for additional communications cables on an existing pole is limited by the clearances to the ground below, required separation between communications lines and from the electric supply lines above. Within these constraints,

1 however, it is possible to place cables, including support messenger/strand, on opposite
2 sides of the pole (“boxing”), as illustrated in Figure 1. This procedure may be the most
3 practical, efficient, and cost-effective means of adding the new facilities, avoiding the
4 considerably more difficult, time consuming and costly alternative of a pole replacement.
5 The latter procedure encompasses the detachment of existing facilities, including electric
6 supply and other communication lines, removal of the existing, presumably healthy, pole
7 and the installation of a new, larger pole, followed by the reattachment of all the previously
8 removed facilities, and finally by the installation of the originally requested lines. This
9 pole replacement alternative is therefore a relatively complicated, expensive task, in
10 comparison to placing the additional communications lines on the opposite side of the pole.
11 Notably, Verizon recognizes that boxing can be an appropriate option on joint-use poles,
12 particularly “when the use of any other available method(s) would be unreasonably costly
13 to one or both Parties.” (*See* Wolanin Affidavit Exhibit D ¶ 1.) Indeed, this is the situation
14 presently being addressed, for which OTELCO requests such consideration.

15 **Q. The potential for interference with the climbing space is one of the primary**
16 **arguments National Grid and Verizon give against the practice of “boxing.” For**
17 **instance, National Grid states that “[t]he use of “boxing” techniques will usually make**
18 **a pole unclimbable by electric utility workers.” (*See* National Grid Response at p.**
19 **22.) How do you respond to these concerns?**

20 **A.** Unfortunately, the practice of “boxing” has had negative connotations and is sometimes
21 disallowed as an otherwise viable option for third-party attachers for the placement of their
22 additional lines. However, the possible obstruction of the climbing space on the otherwise

1 unoccupied side of the pole is irrelevant in most cases due to the wide-spread usage of
2 aerial lifts or bucket trucks, or the use of ladders in rare cases when poles are not as
3 accessible. For example, the Maine Public Utilities Commission considers the following
4 as an unreasonable restriction for the joint-use of utility poles:

5 **Boxing.** A prohibition on boxing poles (i.e., placing cables on both the road
6 side and the field side of a pole) which can be safely accessed by emergency
7 equipment and bucket trucks or ladders provided that such technique
8 complies with the requirements of *applicable codes*. [italics added]

9 Interestingly, the practice of boxing is compliant with the most appropriate “applicable
10 code” – the NESC – independent of the possible use of bucket trucks or ladders. Although
11 the NESC is not formally adopted in every state, it is generally recognized or reflected in
12 the industry practices throughout most of the country, including territories. Rule 236G of
13 the NESC addresses “Climbing space past longitudinal runs not on support arms,” referring
14 to cable installations as illustrated in Figure 1, and states (NESC-2017):

15 Longitudinal runs on racks, or cables on messengers, are not considered as
16 obstructing the climbing space if the location, size, and quantity of the
17 cables permit qualified workers to climb past them.

18 Prior to the 2007 edition, this sentence had language that required the wires to be covered
19 with rubber protective equipment or be otherwise guarded, before climbing past them.
20 However, as explained in the formal response to NESC Interpretation Request 563:

1 For your information, the change was made to reflect common work
2 practices. *For the most part, workers were not covering communication*
3 *cables when climbing past them and it was determined that such action was*
4 *not a safety issue.* Note that energized electric facilities must be covered in
5 accordance with Part 4 Rules for the Operation of Electric Supply and
6 Communications Lines and Equipment. [Italics added]

7 It is noted that the Telcordia *Blue Book – Manual of Construction Procedures* (2017)
8 clearly shows the use of boxing in its Figure 3-1 (Clearance Between Licensee-Owned and
9 Communications Company), as illustrated above, as an accepted practice, referring to
10 third-party attachments on poles, albeit with a 4-inch minimum vertical spacing between
11 strand mounting bolts. Indeed, the *Blue Book* illustrates (Figure 5-4) an appropriate
12 (double ended) suspension bolt for facilitating such an operation, presumably for the
13 convenience of the ILECs (Incumbent Local Exchange Carrier) utilizing boxing for their
14 own purposes. (Several examples of boxing by ILECs or other parties on Verizon-
15 occupied poles are shown in the declaration of David Allen, although apparently not using
16 this type of hardware.) The *Blue Book* is a well-respected, widely-used document in the
17 communications industry and may be referenced in pole attachment agreements – including
18 in the agreement in question with Verizon.

19 Q. **Is the use of “boxing” consistent with the clearance requirements of the NESC?**

20 A. Yes. Not only is the practice of boxing compliant with the rules for climbing space as
21 specified in the NESC (Rule 236G) and the installation practices of the Telcordia Blue

1 Book, the resultant installation is also consistent with the clearance requirements of the
2 NESC, regarding the separation between cables in the communication space. NESC Rule
3 235H does stipulate a 12-inch spacing between messengers at the pole (but can be reduced
4 by agreement of the parties), which is properly interpreted as applying in the vertical
5 direction. However, Rule 235D indicates that the separation must satisfy either the vertical
6 clearance or horizontal clearance, but not both simultaneously. While this rule is not
7 necessarily directly applicable to communication lines, the combination of NESC Rule
8 012C (“accepted good practice” in the absence of “particulars not specified”), NESC Table
9 235-1 (6-inch horizontal clearance between open communication conductors), the
10 clearance envelope of NESC Figure 235-1, and a typical local pole diameter of
11 approximately 10-inches (based on the ANSI O5.1 wood pole standard), indicates the
12 resulting separations are NESC-compliant.

13 Figure 3-1 of the *Blue Book* is somewhat more conservative than the NESC,
14 requiring a 12-inch clearance between the cables on opposite sides of the pole, although
15 measured in a diagonal (radial) direction. This requirement would also be satisfied,
16 considering the typical local pole diameter (10-inches), the required minimum 4-inch
17 vertical bolt spacing for a third-party attachment, and gaps between the cables and the pole
18 surface, ensured by the third-party’s mounting bracket, as necessary.

19 Neither the NESC nor the Blue Book address the pole replacement process, but it
20 may be assumed that reasonable precautions will be taken, as described above, possibly by
21 temporarily detaching the lines installed on the opposite side of the pole, as necessary.

1 Such precautions would also presumably apply to Verizon-occupied poles already utilizing
2 this procedure in the examples shown in the declaration of David Allen.

3 **Q. In its Response, National Grid states that “[e]xisting communications attachments**
4 **placed on one face of a pole are installed with a spacing of 12 inches from center-to-**
5 **center,” and argues that “[i]nstalling an additional attachment on the opposite side**
6 **of the pole requires an additional hole in the pole in line with the existing holes,**
7 **creating a weak spot in the pole ...” (See National Grid Response at 22.) Do you**
8 **agree with National Grid’s assessment?**

9 A. No. As I stated above, the *Blue Book* considers the boxing of third-party attachments to
10 be an accepted practice on poles where there is a minimum 4-inch vertical spacing
11 between strand mounting bolts. In fact, Verizon’s guidelines permit strand mounting
12 bolts to be as close as four inches. (See Affidavit of David L. Wolanin at Ex. B, § 3.2.3.)
13 Notably, National Grid does not include a reference to a specification that requires a
14 minimum spacing of 12 inches between bolt holes for attachments. The NESC, similarly,
15 does not contain such a requirement. This is likely because the greatest bending loads and
16 associated stresses for a distribution pole typically occur at or near the ground line, and
17 not in the vicinity of the attachments or their bolt holes. Thus, bolt holes in the
18 communications space are generally not a significant or critical issue.

19 **Q. Another argument typically given against “boxing” – and one that both National**
20 **Grid and Verizon put forth in their responses to OTELCO’s Complaint (see, e.g.,**

1 **National Grid Response at p. 22; Verizon Response at p. 10) – is that it complicates**
2 **the future pole replacement process. Can you respond to this criticism?**

3 A. Yes. It is recognized that the process of boxing a pole may result in a potentially more
4 complicated, more costly pole replacement process. Such a process, however, may occur
5 many years in the future, and may never be an issue, depending upon other events that
6 may occur prior to that time (e.g., undergrounding). In any case, it would be reasonable
7 to require that the “cost-causer” (third-party attacher) reimburse the pole owner(s) for any
8 incremental expenses, with an additional obligation to facilitate the operation, possibly by
9 temporarily detaching its lines from pole(s), and lowering or diverting them, as
10 necessary. On balance, this would represent a much more reasonable and equitable
11 alternative than imposing the major delay and cost of replacing an existing, otherwise
12 healthy pole.

13 **Q. In the Affidavit of David L. Wolanin, he claims that “[n]one of the poles identified**
14 **by Otelco in Exhibit E to the Allen Declaration is suitable for boxing,” and attaches**
15 **his “assessment of the circumstances of each of those poles on a pole-by-pole basis**
16 **...” (See Affidavit of David L. Wolanin, ¶ 11 and Ex. E.) Can you respond to Mr.**
17 **Wolanin’s assessment?**

18 A. Yes. Regarding the 14 “boxing” examples in Exhibits E to the Allan and Wolanin
19 declarations, my responses fall into several categories:

- 20 • Examples No. 1, 6, 8, 12: Wolanin claims these are “complicated” poles and
21 “boxing” would add additional difficulties to future work on the poles, including

1 “climbing” and/or pole replacement. While it is possible that some poles may not
2 be accessible by bucket truck, it does not necessarily preclude access by other
3 means, such as using a ladder. To the extent that a subsequent pole replacement
4 may be more difficult, the previous discussion regarding the obligation of the
5 attacher to facilitate the operation by temporarily detaching its lines from pole(s),
6 and lowering or diverting them, as necessary, would apply. In any case, for such
7 difficult situations, the immediate make-ready alternatives, possibly requiring a
8 pole replacement, may be similarly problematic, rendering boxing as the most
9 practical solution – consistent with Verizon’s “practicable” criteria. (*See* Wolanin
10 Affidavit Exhibit D ¶ 1.)

- 11 • Examples No. 2, 3, 4, 10, and 14: Wolanin claims the make-ready is “not overly-
12 complicated,” and the apparently little expense of make-ready work (typically
13 \$1,450) does not justify the possible additional difficulty of boxing. However, it is
14 not clear on what basis he makes this economic decision; OTELCO would
15 seemingly be in the best position to evaluate the impact of make-ready charges
16 especially factoring in all of the poles in a given project.
- 17 • Examples No. 5, 9, 13, and 14: Wolanin considers the additional pull due to a boxed
18 cable to be problematic on these poles. However, the tension due to an additional
19 cable – regardless of which side of the pole it is mounted – will have a similar effect
20 on the tendency to pull the pole over, which condition is restrained by the guying
21 system. The guying system, however, may be checked to confirm it is sufficient for

1 the additional attachment, and may be strengthened, as necessary. This would be
2 considerably more reasonable and cost-effective than replacing the pole and still
3 having to install an appropriate guying system.

- 4 • Example No. 7: Wolanin concedes that the pole in question is already boxed, but
5 that “[u]pon further review,” “lowering the current attachment of the cable
6 company and one of Verizon MA’s facilities would create enough room for
7 Otelco’s attachment ... without the need to replace the pole.” However, Wolanin
8 does not indicate what the cost would be to OTELCO or how much time it would
9 take to lower the existing facilities, as compared to boxing, which would require no
10 make-ready work.

- 11 • Examples No. 11 and 13: Wolanin claims that no make-ready work is required by
12 Verizon, and therefore the pole should not be boxed, However, Wolanin’s response
13 ignores the fact that costly make-ready work may be required of other entities with
14 facilities attached to the pole.

15 **Q. In Exhibit. B, Section 3.1 Make-Ready Alternatives, of the Affidavit of David L.**
16 **Wolanin, it states: “There are several reasons why Verizon will not allow Licensees**
17 **to attach their facilities below Verizon facilities on a pole”, for which the sag**
18 **characteristics of Verizon’s typically heavier copper cables are proposed as a factor.**
19 **Do you agree with this rationale?**

20 **A.** No. While there are various reasons for the Verizon to retain the lowest position on the
21 pole, the heavier weight of their cables should not be one of them. A company attaching a
22 lighter weight cable below can add sufficient sag in its line to account for that of the heavier

1 line above. Nor should weather be a problem. In particular, the related Response of
2 Verizon to the Pole Attachment Complaint, as submitted by Alexander Moore, states:

3 “... allowing much lighter third-party attachments below Verizon MA’s
4 heavy copper cables on the pole can result in facilities crossing each other
5 at the mid-span between poles, because the heavier copper cables will sag
6 more than the lighter facilities, including in response to *changing weather*
7 *conditions.*” [Italics added]

8 The incremental increase in sag due to severe (i.e., NESC specified) weather conditions,
9 including ice or high temperature, depending upon the specific details of the installations
10 (span length, messengers, sizes of the cables, ...), may be essentially the same, or even
11 less, for an already installed heavy copper cables than that of a smaller, lighter fiber cable.
12 Thus, if a fiber cable installed below the Verizon cable would have (1) sufficient clearance
13 above the surfaces below, under NESC conditions (½ inch radial ice or 120° F), and (2)
14 initially (at installation) meet the minimum 4-inch mid-span clearance to the Verizon cable
15 above, the installation would be NESC-compliant. Furthermore, the mid-span clearances
16 between the cables may actually increase under the severe weather conditions, making
17 “crossover” less, not more, likely to occur.

18 **IV. CONCLUSION**


19 **Q. Do you swear that your testimony is true and accurate to the best of your knowledge?**

20 A. Yes.

21 **Q. Does this conclude your pre-filed testimony?**

22 A. Yes.

EXHIBIT A



ABOUT OUTSIDE PLANT CONSULTING SERVICES, INC. (OPCS)

Dr. Lawrence M. Slavin

Outside Plant Consulting Services, Inc. (OPCS) was established in the year 2002 to help meet the needs of the telecommunications and power industries in establishing standards, guidelines and practices for outside plant facilities and products. The OPCS Group provides related support services for field deployment, and product evaluation and analysis. Dr. Lawrence (Larry) M. Slavin, Principal of OPCS, has extensive experience and expertise in such activities, based upon his many years of service at AT&T/Lucent Bell Telephone Laboratories (Distinguished Member of Technical Staff) in telecommunications product design and development, followed by a career at Telcordia Technologies (Bellcore) in its research and professional service organizations. (See attached Experience and Education.)

As Principal Consultant and Manager/Director of the Network Facilities, Components, and Energy Group at Telcordia, Dr. Slavin was responsible for professional services related to the telecommunications industry. These activities included technical leadership in developing installation practices and “generic requirements” documents, introducing new construction methods, and performing analyses on a wide variety of technologies and products (poles, duct, wire and cable, electronic equipment cabinets, flywheel energy storage systems, turbine-generators, ...). Throughout his long career, he has had a leading role in the evolution of many telecommunications related fields and disciplines -- including aerial and buried plant design and reliability; advanced construction and cable and duct placement techniques; copper pair, coaxial, and fiber-optic technology; flywheel energy storage systems; physical design and development of hardware and electronic and electro-optic systems (“SLC 96” digital loop carrier, ...); cable media and equipment reliability studies; exploratory fiber-optic hardware development; and systems engineering.

Dr. Slavin has been a member of numerous industry and professional committees and organizations, often in a leadership position (see attached Industry Activities). He is the author of numerous industry technical papers, reports or documents (partial Bibliography attached, with resume), as well as the editor and primary author of ASCE Manual No. 118, *Belowground Pipeline Networks for Utility Cables*, published by the American Society of Civil Engineers. Dr. Slavin is also author of the recently published book ***Overhead Distribution Lines – Design and Applications***, by Wiley–IEEE, and is a contributor to the ***Telcordia Blue Book - Manual of Construction Procedures***.

Dr. Lawrence M. Slavin
Outside Plant Consulting Services, Inc.
15 Lenape Avenue
Rockaway , NJ 07866
Phone: 1-973-983-0813 (office/fax)
1-973-979-1942 (cell)
E-Mail: lslavin@ieee.org
www.outsideplantconsulting.com

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 18

Industry Activities (Present and Past)

- **National Electrical Safety Code Committee**
 - Represents the national telephone industry, via Alliance for Telecommunications Industry Solutions, ATIS
 - Executive Subcommittee
 - Main Committee
 - Interpretations Subcommittee
 - Subcommittee 4 (Overhead Lines – Clearances)
 - Subcommittee 5 (Overhead Lines – Strength & Loading)
 - Subcommittee 7 (Underground Lines)
- **Accredited Standards Committee ASC-O5**
 - *ANSI O5.1, Wood Poles, Specifications and Dimensions*
 - *ANSI O5.2, Wood Products, Structural Glued Laminated Timber for Utility Structures*
 - *ANSI O5.3, Wood Products, Solid Sawn-Wood Products and Braces*
- **ASCE 7 Icing Subcommittee**
- **ASCE Utility As-Built Standards Committee**
- **Transportation Research Board**
 - Utilities Committee, AFB70
- **Pole Reliability Based Design (RBD) Committee, ASCE**
 - *Reliability-Based Design of Utility Pole Structures*
- **ASCE Journal of Pipeline Systems Engineering and Practice, Associate Editor**
- **Committee F17 on Plastic Piping Systems, ASTM**
 - **Subcommittee F17.67 on Trenchless Plastic Pipeline Technology**
 - **Task Group Leader for development of HDD Standard ASTM F1962**
 - *ASTM F1962, Standard Guide for Use of Maxi-Horizontal Directional Drilling for Placement of Polyethylene Pipe or Conduit Under Obstacles, Including River Crossings*
- **Trenchless Installation of Pipelines (TIPS) Committee, ASCE**
 - *Manual of Practice No. 118 for Belowground Pipeline Networks for Utility Cables, Chair*
 - *Manual of Practice No. 115 for Pipe Ramming Projects, Vice-Chair*
 - *Manual of Practice No. 112 for Pipe Bursting Projects*
- **Plastics Pipe Institute (PPI)**
 - Municipal Advisory Board
 - *TR-46, Guidelines for Use of Mini-Horizontal Directional Drilling for Placement of High Density Polyethylene Pipe*
- **Center for Underground Infrastructure Research and Education (CUIRE)**

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 19

- Industry Advisory Board
- North American Society for Trenchless Technology (NASTT)
 - Charter Member
 - Chair of Directional Drilling Subcommittee
- Trenchless Technology Center, Louisiana Tech University
 - Industry Advisory Board
- Missouri Western State College
 - HDD Steering Committee

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 20

Bibliography

Highlights of the next edition of the National Electrical Safety Code, IAEI Magazine, International Association of Electrical Inspectors, May 2022.

Overhead Distribution Lines – Design and Applications, Wiley–IEEE, 2021

NESC clearances are a matter of fact: Designed for worker and public safety, they offer a factual foundation in disputes, IAEI Magazine, International Association of Electrical Inspectors, October 2020

How the NESC® Provides for Multiple Stakeholders on the Utility Pole, Energy Central Magazine, May 2015

Don't Be Up In The Air or Under-Informed (Proposed Changes in the 2017 Edition NESC® Overhead and Belowground Distribution Plant), Outside Plant Magazine, February 2015

Steady Current (Keeping the National Electrical Safety Code Relevant for All Utility Workers), Utility Products, September 2014

Panel Session on 2017 Edition of ASC C2 National Electrical Safety Code (NESC), Co-Chair, IEEE Power & Engineering Society Meeting, July 2014

Which Method to Use When Estimating Maxi-HDD Installation Loads –ASTM F 1962 or the PRCI Method?, ASCE International Pipelines Conference 2014

Repair of In-Service HDPE Water Distribution Pipe, ASCE International Pipelines Conference 2014

Effect of Pipe Stiffness on Maxi-HDD Pull, *Journal of Pipeline Systems Engineering and Practice*, February 2012

Maxi-HDD Pull Loads for Entry and Exit Points at Different Elevations, International Conference on Pipelines and Trenchless Technology 2011, Beijing

Maxi-HDD Pull Loads for Non-Level Grade for Polyethylene Pipe, *Journal of Pipeline Systems Engineering and Practice*, May 2011

Guidelines for Use of Mini-Horizontal Directional Drilling for Placement of HDPE Pipe, Trenchless Technology Magazine, January 2011

Parametric Dependency and Trends of HDD Pull Loads, *Journal of Pipeline Systems Engineering and Practice*, May 2010

Discussion of ASTM F 1962 or “How Are The Pulling Load Formulas Derived and How are they Used?”, North American NO-DIG 2010

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 21

ASCE Manual of Practice No. 118 for Belowground Pipeline Networks for Utility Cables, Underground Construction Technology Conference, 2010

Pipeline Network Maximizes Sustainability of Buried Cable Infrastructure, ASCE International Pipelines Conference 2009

Buried Duct Network for Upgrading, Maintaining Utility Cables -- Results of Recent Field Trials at the University of Texas-Arlington, Underground Construction Magazine, March 2009

Belowground Pipeline Networks for Utility Cables, ASCE Manuals and Reports on Engineering Practice No. 118, 2009

Joint-Use Buried Duct Network for Upgrading and Maintaining Utility Cables, 2008 Damage Prevention Conference

Buried Pipeline Network for Facilitating Installation of Utility Cables along Roads and Highways, 10th International Conference on Applications of Advanced Technologies in Transportation, 2008

Foresight is More Than 20/20, Preventive OpEx Strategy, Buried Duct Networks, OSP Magazine, May 2008

Utility Asset Management through a Joint-Use Pipeline Network for Cables, ASCE International Pipelines Conference 2008

Joint-Use Buried Pipeline for Utility Cables & "Freight Transportation", 5th International Symposium on Underground Freight Transportation by Capsule Pipelines and Other Tube/Tunnel Systems, 2008

Joint-Use Buried Duct/Pipeline Network for Facilitating Installation and Maintenance of Utility Cables along Roads and Highways, Transportation Research Board 87th Annual Meeting 2008

Joint-Use Buried Duct Network for Upgrading, Maintaining Utility Cables, Underground Construction Magazine, December 2007

Simplified Method for Estimating Pull Force on Polyethylene Pipe for Mini-HDD Applications, International Conference on Geological Engineering in 2007

Simplified Methodology for Selecting Polyethylene Pipe for Mini (or Midi) – HDD Applications, ASCE International Pipelines Conference 2007

Panel Session: NESC 2007 Panel Session (Strength & Loading), Chair, Towers, Poles & Conductors Meeting, Power Engineering Society, January 2007

Panel Session: Structural Reliability-Based Design of Utility Poles and the National Electrical Safety Code, Chair, 2003 Transmission & Distribution Conference and Exposition, 2003

Panel Session on National Electrical Safety Code (NESC), 2002 Edition, ANSI C2, Chair, 2001 Transmission & Distribution Conference and Exposition

Standard Guide for Use of Maxi-Horizontal Directional Drilling for Placement of Polyethylene Pipe or Conduit Under Obstacles, Including River Crossings, ASTM F1962, 1999

Fiberglass Reinforced Aerial Service Wire, Mechanical Behavior and Installation Guidelines, International Wire and Cable Symposium, 1999

January 1998 Ice Storm Analysis for Bell Atlantic, Utility Pole Symposium, Jacksonville, FL 1999

Fiber-to-the-Home (FTTH) Upgrades in Existing Communities with Buried Plant, Bellcore Report, 1997

Storing Energy, Containing Power, Bellcore Exchange, Spring 1997

Using Trenchless Technology for Installing an Information Superhighway, NO-DIG Engineering, 1996

Making a Smooth Lawn out of a Molehill, Bellcore Exchange, Spring 1996

The Establishment of Coaxial Cable Prototype Test Route at the Environmental Test Facility at Phoenix, AZ, Twelfth Annual National Fiber Optic Engineers Conference, 1996

Using Trenchless Technology for Installing an "Information Superhighway" in Bell Atlantic, North American NO-DIG '95, 1995

Buried Plant – Placement of Coaxial Distribution and Service Cable, Bellcore Practice, 1995

Experiments Pulling Coaxial Cable into Buried Innerduct, and Other Interesting Experiences, Eleventh Annual National Fiber Optic Engineers Conference, 1995

Coaxial Cable Installation Tests in Innerduct, Bellcore Report, 1995

The Application of Trenchless Technology for Fiber-in-the-Loop Upgrades of Telecommunications Facilities, North American NO-DIG '94, 1994

Direct-Buried Innerduct, Local Distribution Plant Engineering and Construction Guidelines, Bellcore Practice, 1994

High Air-Speed Blown-Cable Fiber Installation System, Bellcore Practice, 1994

The Application of Trenchless Technology for Fiber-in-the-Loop Upgrades in Bell Atlantic, Tenth Annual National Fiber Optic Engineers Conference, 1994

The Use of the High Air-Speed Blown-Cable System for Placing Optical-Fiber Cables in Innerduct, Tenth Annual National Fiber Optic Engineers Conference, 1994

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 23

Establishment of an Environmental Test Facility for Fiber-Optic Components at Morgan-City-Amelia, LA, Tenth Annual National Fiber Optic Engineers Conference, 1994

The Use of Direct-Buried Semi-Flexible Duct (Innerduct) to Create an Upgradeable Loop Distribution Plant , Bellcore Report, 1994

The Application of Trenchless Technology for Fiber-in-the-Loop Upgrades of Telecommunications Facilities, Bellcore Report, 1994

The Effect of Innerduct Design on the High Air-Speed Blown-Cable Technique, Bellcore Report, 1993

The Use of Direct-Buried Semi-Flexible Duct (Innerduct) for Distribution Applications, Bellcore Report, 1993

Cable Installation Tests in Direct-Buried Innerduct, Bellcore Report, 1992

Removing the Copper Pairs of Telecommunications Cables to Facilitate Fiber-in-the-Loop Upgrades, International NO-DIG '92, 1992

Proposed Generic Requirements and Practices Compatible with High Air-Speed Blown-Cable Installation Systems, Bellcore Report, 1992

Fiber-to-the-Home Evolving in Telephone Local Networks, Underground Focus, Jan./Feb.1992

“Quiet Evolution” Promises All-Fiber Phone Lines, Pipeline & Utilities Construction, Dec.1992

Temperature Cycling Tests on Fiber Drop in Flooded Flexible Duct, Bellcore Report, 1991

The Use of Flexible Duct for Buried Drops, Bellcore Report, 1991

New Cable Installation Methods for FITL Upgrades in Established Areas with Buried Plant, Bellcore Report, 1991

The Use of Small Lawn Plows to Install Buried Drops for FITL Upgrades, Bellcore Report, 1990

Education

Ph.D. - Mechanical Engineering, New York University, 1969

Master of Science - Engineering Mechanics, New York University, 1963

Bachelor of Science - Mechanical Engineering, The Cooper Union, 1961

Awards

- ASCE Outstanding Reviewer, Journal of Pipeline Systems Engineering and Practice, 2013
- Best Paper Award, *Maxi-HDD Pull Loads for Entry and Exit Points at Different Elevations*, International Conference on Pipelines and Trenchless Technology, Beijing 2011 (ICPTT 2011)
- ASCE Outstanding Reviewer, Journal of Pipeline Systems Engineering and Practice, 2010, 2013, 2016
- Certificate of Recognition, Sigma Xi - The Scientific Research Society, The Picatinny Chapter, *Flywheel Energy Storage Systems for the Telephone Outside Plant*, 1996
- 1983 Bell Laboratories Distinguished Technical Staff Award for Sustained Achievement

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 25

Experience

Experience 1990 – 2001 (Reverse Chronological Order)

Telcordia: Network Reliability, Operations and Deployment

- Principal Consultant representing the telecommunications industry on various professional organizations and forums. Has been a key member of the **National Electric Safety Code Committee (NESC)**, responsible for specifying safety standards for aerial and buried telecommunications and power facilities in the United States. (Had a leading role in the development of the 2002 edition of the NESC.) Has also been an important member on the ANSI-05 (Wood Poles) standards committee, as well as an active participant in training and certification activities for the directional drilling industry.

Telcordia: Physical Network and Product Integrity and Reliability

- Director of the Network Facilities, Components, and Energy Group. Managed large group (12 engineers) responsible for developing requirements, testing, and analysis of outside plant media, components, and powering for telecommunications applications, including installation guidelines, including *Blue Book – Manual of Construction Procedures*.
- Investigation of physical characteristics and related requirements of fiberglass reinforced aerial service wire to prevent problems such as previously experienced during severe winter storm.

Telcordia: Applied Research

- Development and deployment of low-cost utility construction and cable installation techniques to facilitate introduction of the “information superhighway” for the Regional Bell Operating Companies (RBOCs). Instrumental in introducing blown-cable installation technology in United States. Served as chairman of the Directional Drilling subcommittee of the North American Society for Trenchless Technology (NASTT), and was responsible for developing directional drilling standards for the American Society for Testing & Materials (ASTM).
- Investigation of feasibility of electro-mechanical (flywheel) energy storage systems, including containment studies, creation of industry specifications, evaluation of seismic implications, and coordination of industry-wide flywheel safety forum.
- Design and installation of full-scale environmental test facilities across the country for evaluating reliability of fiber-optic and coaxial transmission media and components.

Experience 1961 – 1989 (Reverse Chronological Order)

Bell Laboratories: Loop Transmission Systems

Has had numerous design and/or coordination responsibilities during this decade of rapid growth in metallic- and fiber-optic-based digital loop carrier systems. The following is only a partial list:

D.T.C. 22-4

Pre-filed Testimony of Dr. Lawrence M. Slavin
on Behalf of CRC Communications LLC d/b/a OTELCO

Page 26

- Design and development of customer-premises remote terminal electronic cabinets, including cabinet design, integration of complex digital telecommunications equipment, addressing thermal design issues, and meeting Underwriters Laboratories (UL) and FCC requirements.
- Design and development of “Lightguide Distributing Unit” concept (received original patent).
- Exploring feasibility of optical data links for broadcasting video channels, including the design of the system architecture, overall analysis, and subsequent construction of working electronic/fiber-optic models.
- Planning and installation of metallic and fiber-optic cable and hardware facilities at the Bell Laboratories Lightwave Facility at Chester, NJ -- the showcase of AT&T/Lucent digital and optical networks and hardware systems.
- Physical design of SLC 96 digital loop carrier system
- Ensuring reliability of SLC 96 digital loop carrier systems, including coordination of field tracking and factory studies, and implementation of analytical techniques.

Bell Laboratories: Main Distributing Frame Systems & Hardware

The lack of understanding of this important interface between the central office and outside plant facilities led to numerous, widespread crises in the larger telephone exchanges throughout the country in the 1970s. Has had a leading role in advancing the state-of-the-art and general understanding of MDF systems, including:

- Coordinating design and development of various MDF protector and terminal block hardware.
- Establishing tools and methods for MDF rehabilitation.
- Producing the *MDF Planning and Engineering Guidelines*.

Bell Laboratories: Engineering Analysis & Applied Mechanics

Provided consultation services for numerous projects requiring expertise in engineering mechanics. The investigations included mathematical and computer modeling, as well as laboratory and field experiments, for investigating the following areas:

- Vulnerability of communications cables to nuclear attack.
- Buried waveguide systems, including potential hazards of earthquakes and the design optimization of welded waveguide couplings.
- Dynamic response of missile structures.

Bell Laboratories: Computer Program Systems Studies

- Developed various computer program systems for the AT&T Telstar project and US Navy applications.