

CHARLES D. BAKER Governor

KARYN E. POLITO Lieutenant Governor

The Commonwealth of Massachusetts Executive Office of Health and Human Services Department of Public Health Bureau of Environmental Health Community Sanitation Program 5 Randolph Street, Canton, MA 02021 Phone: 781-828-7700 Fax: 781-828-7703

MARYLOU SUDDERS Secretary

MONICA BHAREL, MD, MPH Commissioner

> Tel: 617-624-6000 www.mass.gov/dph

December 15, 2016

Michael A. McCormack, Sheriff Dukes County Jail and House of Correction P.O. Box 252 Edgartown, MA 02539

Re: Facility Inspection - Dukes County Jail and House of Correction, Edgartown

Dear Sheriff McCormack:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Dukes County Jail and House of Correction on December 9, 2016 accompanied by Greg Arpin, EHSO. Violations noted during the inspection are listed below including 36 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

POLICE LOCK-UP AREA

Hallway

No Violations Noted

Booking Area

105 CMR 451.350* Structural Maintenance: Ceiling cracking

Male Holding Cell

105 CMR 451.320* Cell Size: Inadequate floor space

Female/Juvenile Holding Cell

105 CMR 451.341* Natural Light in Cell: No natural light source in cells

105 CMR 451.321* Cell Size: Inadequate floor space

105 CMR 451.353* Interior Maintenance: Wall surface damaged

HOUSE OF CORRECTIONS

Control Area

No Violations Noted

Visit Room

No Violations Noted

Food Service Area

Office

No Violations Noted

Kitchen

3-Compartment Sink

No Violations Noted

Mechanical Warewashing Machine

No Violations Noted

Stove and Hood

No Violations Noted

Prep Table and Sink

No Violations Noted

Coffee Station and Small Refrigerator

No Violations Noted

Handwash Sink

No Violations Noted

Back Room

No Violations Noted

Pantry

No Violations Noted

Dining Room

No Violations Noted

First Floor Units

Administrative Segregation Unit

Cells

105 CMR 451.320* Cell Size: Inadequate floor space in cell # 2 and 3

105 CMR 451.113 Toilet and Handwashing Sink in Locked Cells: No hot running water in locked cell # 2

Janitor's Closet

No Violations Noted

Hallway

105 CMR 451.353* Interior Maintenance: Wires exposed

Pre-Release Unit

Laundry Area

No Violations Noted

Bathroom

105 CMR 451.126 Hot Water: Hot water temperature recorded at 100°F at handwash sink

Showers

105 CMR 451.123* Maintenance: Missing curtain in shower # 1

Day Room

105 CMR 451.353* Interior Maintenance: Door casing damaged

Hallway

No Violations Noted

Cells

105 CMR 451.321 Cell Size: Inadequate floor space in all cells

Canteen Room

105 CMR 451.353* Interior Maintenance: Light shield missing

Property Room

No Violations Noted

Unit#1

Cells

105 CMR 451.321* Cell Size: Inadequate floor space in cell # 1-3
105 CMR 451.353* Interior Maintenance: Floor paint peeling in cell # 1-3
105 CMR 451.353 Interior Maintenance: Ceiling paint peeling in cell # 2

Shower Stall

105 CMR 451.123* Maintenance: Metal surfaces rusted in shower stall 105 CMR 451.123* Maintenance: Wall paint peeling above stall 105 CMR 451.123* Maintenance: Mold on ceiling outside shower stall

Laundry Area

No Violations Noted

Unit #2

Dorm Room

105 CMR 451.321* Cell Size: Inadequate floor space in dorm

Dorm Shower

105 CMR 451.123* Maintenance: Floor grout damaged in shower # 1
105 CMR 451.123* Maintenance: Ceiling paint peeling in shower # 2
105 CMR 451.123* Maintenance: Ceiling paint peeling outside showers

Dorm Bathroom

No Violations Noted

Dorm Day Room

No Violations Noted

Chemical Closet

No Violations Noted

Second Floor Units

Main Hallway

105 CMR 451.141 Screens: Screen damaged in window

Education Room

No Violations Noted

Nurse's Office

No Violations Noted

Unit#3

Hallway

105 CMR 451.353 Interior Maintenance: Floor paint peeling
105 CMR 451.353 Interior Maintenance: Radiator paint peeling

Cells

105 CMR 451.320* Cell Size: Inadequate floor space in cell # 1-3

105 CMR 451.350* Structural Maintenance: Ceiling left unfinished from repair in cell # 1 and 3

105 CMR 451.353* Interior Maintenance: Floor paint peeling in cell # 3

105 CMR 451.353 Interior Maintenance: Floor paint peeling in cell # 1 and 2

Shower Stall

105 CMR 451.123 Maintenance: Ceiling paint peeling in shower stall

105 CMR 451.123 Maintenance: Caulking moldy

Unit#4

Hallway

105 CMR 451.353 Interior Maintenance: Radiator paint peeling

105 CMR 451.353 Interior Maintenance: Floor threshold damaged at entrance to hallway

105 CMR 451.353 Interior Maintenance: Floor paint peeling

Cells

105 CMR 451,320* Cell Size: Inadequate floor space in cell # 3

105 CMR 451.353* Interior Maintenance: Floor paint peeling in cell # 1-3

Shower Stall

105 CMR 451.123* Maintenance: Ceiling paint peeling

Administration Area

Human Services

No Violations Noted

Staff Bathroom

105 CMR 451.123 Maintenance: Unlabeled chemical bottle

3rd Floor

No Violations Noted

Office Bathroom

105 CMR 451.123 Maintenance: Wall vent fan dusty

Hallway

No Violations Noted

Outside Areas

Outside Gym Area

No Violations Noted

Training Building

105 CMR 451.353* Interior Maintenance: Light shields missing

Staff Bathroom

No Violations Noted

Human Resource Building

No Violations Noted

Staff Bathroom

No Violations Noted

Civil Process Building

No Violations Noted

Staff Bathroom

No Violations Noted

Observations and Recommendations

1. The inmate population was 22 at the time of inspection.

2. At the time of inspection, the Department recommended that all cells be identified with a numbering system. This will assist the Department and correctional employees to better recognize where issues exist.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

Nicholas Gale

Environmental Health Inspector, CSP, BEH

Ruhlas St

cc: Jan Sullivan, Acting Director, BEH

Steven Hughes, Director, CSP, BEH

Timothy Miley, Director of Government Affairs

Marylou Sudders, Secretary, Executive Office of Health and Human Services

Thomas Turco, Commissioner, DOC

Robert Ogden, Superintendent

Greg Arpin, EHSO

Matthew Poole, Health Agent, Edgartown Health Department

Clerk, Massachusetts House of Representatives

Clerk, Massachusetts Senate

Daniel Bennett, Secretary, EOPSS

Jennifer Gaffney, Director, Policy Development and Compliance Unit