

Attachment A1: Table 4: Proposed ERP Activities with Energy Reductions

Attachment A1: Table 4: Proposed ERP Activities with Energy Reductions

Table 4 - Town of Framingham Energy Reduction Plan												
Energy Conservation Measures Data												
Measure		Status	Energy Data			Financial Data					Reference Data	
Category/Building	Energy Conservation Measure	Status (Completed with month/year or planned Qtr/year)	Projected Annual Electricity Savings (kWh)	Projected Annual Natural Gas Savings (therms)	Projected Annual Cost Savings (\$)	Total Installed Cost (\$)	Green Community Grant (\$)	Utility Incentives (\$)	Other Grants (\$)	Net Town Cost (\$)	Funding Source(s) for Other Grants and Net Town Costs	Source for Projected Savings
Juniper ES	DDC controls	2011	13,074	3,747	Not available	Not available		\$7,016		Not available		NSTAR incentive applications
King Administration	DDC controls	2011	47,340	4,742	Not available	Not available		\$16,577		Not available		NSTAR incentive applications
McCarthy ES	DDC controls	2011	106,679	7,319	Not available	Not available		\$33,989		Not available		NSTAR incentive applications
Framingham HS	Lighting upgrades in gym and café	2011	80,100		Not available	Not available		\$20,025		Not available		NSTAR incentive applications
Framingham HS	Lighting upgrades (reflex lighting project)	2012	24,436		Not available	Not available		\$4,100		Not available		NSTAR incentive applications
Fuller MS	Lighting upgrades (Public Access TV)	2012	26,470		Not available	Not available		\$6,618		Not available		NSTAR incentive applications
Barbieri ES	DDC controls	2012	20,950	7,411	Not available	Not available		\$16,056		Not available		NSTAR incentive applications
Potter ES	DDC controls	2012	24,972	2,978	Not available	Not available		\$10,842		Not available		NSTAR incentive applications
Brophy ES	DDC controls	2012	24,972	537	Not available	Not available		\$7,790		Not available		NSTAR incentive applications
Sanitation Dept	Lighting upgrades	2012	28,151		Not available	Not available		\$7,038		Not available		NSTAR incentive applications
Memorial Building	Lighting upgrades	2013	28,698		Not available	Not available		\$7,174		Not available		NSTAR incentive applications
Juniper ES	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
Barbieri ES	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
King Administration	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
Brophy ES	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
Cameron MS	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
Hemenway ES	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
Potter ES	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$750		Not available		NSTAR incentive applications
Wilson ES	Lighting conversions from incand. To LED	2012	17,936		Not available	Not available		\$751		Not available		NSTAR incentive applications
Dunning ES	Lighting conversions from incand. To LED	2012	29,894		Not available	Not available		\$1,250		Not available		NSTAR incentive applications
McCarthy ES	Lighting conversions from incand. To LED	2012	29,894		Not available	Not available		\$1,251		Not available		NSTAR incentive applications
Fuller MS	Lighting conversions from incand. To LED	2012	59,787		Not available	Not available		\$2,500		Not available		NSTAR incentive applications
Walsh MS	Lighting conversions from incand. To LED	2012	59,787		Not available	Not available		\$2,501		Not available		NSTAR incentive applications
Framingham HS	Lighting conversions from incand. To LED	2013	11,794		Not available	Not available		\$1,500		Not available		NSTAR incentive applications
McCarthy ES	Exterior pole lights conversion fr HPS to LED	2014	18,912		Not available	Not available		Not available		Not available		NSTAR incentive applications
Wilson ES	Exterior pole lights conversion fr HPS to LED	2014	7,893		Not available	Not available		Not available		Not available		NSTAR incentive applications
Dunning ES	Exterior pole lights conversion fr HPS to LED	2014	5,072		Not available	Not available		Not available		Not available		NSTAR incentive applications
Barbieri ES	Rooftop unit replacements	2011	25,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Barbieri ES	Addition of drives to RTU motors	2012	44,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Potter ES	Installation of drives on HW pumps	2012	4,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Brophy ES	Installation of drives on HW pumps	2012	4,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
King Administration	Installation of drives on HW pumps	2012	2,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Dunning ES	Installation of drives on HW pumps	2012	4,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Hemenway ES	Installation of drives on HW pumps	2012	4,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Juniper ES	Installation of drives on HW pumps	2012	2,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
Barbieri ES	Installation of drives on HW pumps	2012	3,000		Not available	Not available		Not available		Not available		PEG estimates post-installation
All Schools	Misc O&M improvements	2011 - 2014	143,850	13,402	Not available	Not available		Not available		Not available		
All Town buildings	Misc O&M improvements	2011 - 2014	75,322	5,482	Not available	Not available		Not available		Not available		
Barbieri ES	Replace CRT Computer Screens	2015/2016	4,000	-70	\$900	\$6,100		\$0		\$6,100		Peregrine Bdg Assessments
Barbieri ES	Lighting Controls	2015/2016	9,000	-100	\$1,000	\$40,000		\$6,000		\$34,000		Peregrine Bdg Assessments
Barbieri ES	Recommission / Adjust Control Systems	2015/2016	12,000	1,000	\$2,600	\$24,500		\$0		\$24,500		Peregrine Bdg Assessments
Barbieri ES	Schedule Domestic Hot Water	2015/2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Barbieri ES	Install Fan VFD	2015/2016	9,600	0	\$1,200	\$30,000		\$8,000		\$22,000		Peregrine Bdg Assessments
Barbieri ES	Walk-in Evaporator Control & ECM Motors	2015/2016	3,000	0	\$500	\$6,000		\$0		\$6,000		Peregrine Bdg Assessments
Barbieri ES	Reduce Airflow (Reseal and/or New Motor)	2015/2016	900	600	\$800	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Barbieri ES	Infiltration Reductions	2015/2016	15	900	\$991	\$9,048		\$0		\$9,048		Ameresco IGA
Barbieri ES	Transformers	2015/2016	45,920	0	\$6,489	\$53,291		\$6,667		\$46,625		Ameresco IGA
Barbieri ES	Lighting System Improvements	2015/2016	63,882	-557	\$11,364	\$84,321		\$23,600		\$60,721		Ameresco IGA
Brophy ES	Replace CRT Computer Screens	2015/2016	600	-10	\$100	\$900		\$0		\$900		Peregrine Bdg Assessments
Brophy ES	Replace Refrigerator(s)	2015/2016	800	0	\$100	\$1,000		\$0		\$1,000		Peregrine Bdg Assessments
Brophy ES	Lighting Controls	2015/2016	7,000	-100	\$800	\$30,000		\$4,500		\$25,500		Peregrine Bdg Assessments
Brophy ES	Recommission / Adjust Control Systems	2015/2016	3,000	900	\$1,400	\$25,000		\$0		\$25,000		Peregrine Bdg Assessments
Brophy ES	Expand Central DDC Controls	2015/2016	1,000	300	\$500	\$55,000		\$0		\$55,000		Peregrine Bdg Assessments
Brophy ES	Schedule Domestic Hot Water	2015/2016	300	200	\$300	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Brophy ES	Interlock Dishwasher EF	2015/2016	300	400	\$500	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Brophy ES	Update Pipe Insulation	2015/2016	0	300	\$300	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Brophy ES	Replace Motor	2015/2016	400	0	\$70	\$750		\$0		\$750		Peregrine Bdg Assessments
Brophy ES	Install 2-Way Valves	2015/2016	2,700	0	\$300	\$8,000		\$0		\$8,000		Peregrine Bdg Assessments
Brophy ES	Demand Control Ventilation	2015/2016	1,980	611	\$935	\$12,256		\$675		\$11,581		Ameresco IGA
Brophy ES	Infiltration Reductions	2015/2016	50	3,499	\$3,855	\$21,787		\$0		\$21,787		Ameresco IGA
Brophy ES	Lighting System Improvements	2015/2016	21,966	0	\$3,372	\$32,279		\$3,150		\$29,129		Ameresco IGA

Attachment A1: Table 4: Proposed ERP Activities with Energy Reductions

Table 4 - Town of Framingham Energy Reduction Plan												
Energy Conservation Measures Data												
Measure		Status	Energy Data			Financial Data					Reference Data	
Category/Building	Energy Conservation Measure	Status (Completed with month/year or planned Qtr/year)	Projected Annual Electricity Savings (kWh)	Projected Annual Natural Gas Savings (therms)	Projected Annual Cost Savings (\$)	Total Installed Cost (\$)	Green Community Grant (\$)	Utility Incentives (\$)	Other Grants (\$)	Net Town Cost (\$)	Funding Source(s) for Other Grants and Net Town Costs	Source for Projected Savings
Cameron MS	Replace CRT Computer Screens	2015 / 2016	2,000	-30	\$400	\$3,500		\$0		\$3,500		Peregrine Bdg Assessments
Cameron MS	Lighting Controls	2015 / 2016	11,000	-200	\$1,100	\$40,000		\$6,000		\$34,000		Peregrine Bdg Assessments
Cameron MS	Recommission / Adjust Control Systems	2015 / 2016	2,000	140	\$400	\$25,000		\$0		\$25,000		Peregrine Bdg Assessments
Cameron MS	Schedule Domestic Hot Water	2015 / 2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Cameron MS	Install Pump VFD	2015 / 2016	22,000	0	\$2,700	\$42,400		\$16,200		\$26,200		Peregrine Bdg Assessments
Cameron MS	Walk-in Evaporator Control & ECM Motors	2015 / 2016	3,000	0	\$500	\$6,000		\$0		\$6,000		Peregrine Bdg Assessments
Cameron MS	Integrated and New Energy Management Systems	2015 / 2016	1,000	100	\$200	\$121,603		\$0		\$121,603		Ameresco IGA
Cameron MS	Demand Control Ventilation	2015 / 2016	2,124	1,176	\$1,536	\$16,324		\$675		\$15,649		Ameresco IGA
Cameron MS	Infiltration Reductions	2015 / 2016	31	323	\$358	\$3,279		\$0		\$3,279		Ameresco IGA
Cameron MS	Variable Frequency Drives For HW Pumps	2015 / 2016	21,908	0	\$2,498	\$42,447		\$16,200		\$26,247		Ameresco IGA
Cameron MS	Transformers	2015 / 2016	39,254	0	\$5,560	\$43,005		\$7,677		\$35,328		Ameresco IGA
Cameron MS	Lighting System Improvements	2015 / 2016	44,273	-354	\$8,539	\$124,465		\$10,325		\$114,140		Ameresco IGA
Dunning ES	Lighting Controls	2015 / 2016	7,000	-100	\$800	\$40,000		\$6,000		\$34,000		Peregrine Bdg Assessments
Dunning ES	Recommission / Adjust Control Systems	2015 / 2016	1,000	2,000	\$2,300	\$20,000		\$0		\$20,000		Peregrine Bdg Assessments
Dunning ES	Add Demand Control Ventilation	2015 / 2016	500	300	\$400	\$8,200		\$450		\$7,750		Peregrine Bdg Assessments
Dunning ES	Schedule Domestic Hot Water	2015 / 2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Dunning ES	Update Pipe Insulation	2015 / 2016	0	150	\$170	\$2,500		\$0		\$2,500		Peregrine Bdg Assessments
Dunning ES	Integrated and New Energy Management Systems	2015 / 2016	500	400	\$500	\$55,190		\$0		\$55,190		Ameresco IGA
Dunning ES	Infiltration Reductions	2015 / 2016	0	1,263	\$1,390	\$7,854		\$0		\$7,854		Ameresco IGA
Dunning ES	Demand Control Ventilation	2015 / 2016	490	312	\$408	\$8,211		\$450		\$7,761		Ameresco IGA
Framingham HS	Change Operating Policy for Fume Hoods	2015 / 2016	15,000	3,200	\$6,000	\$0		\$0		\$0		Peregrine Bdg Assessments
Framingham HS	Close Doors to Conditioned Space	2015 / 2016	4,000	0	\$1,200	\$0		\$0		\$0		Peregrine Bdg Assessments
Framingham HS	Replace CRT Computer Screens	2015 / 2016	2,000	0	\$600	\$4,500		\$0		\$4,500		Peregrine Bdg Assessments
Framingham HS	Lighting Controls	2015 / 2016	24,000	-400	\$2,500	\$100,000		\$15,000		\$85,000		Peregrine Bdg Assessments
Framingham HS	Recommission / Adjust Control Systems	2015 / 2016	18,000	3,500	\$7,600	\$75,000		\$0		\$75,000		Peregrine Bdg Assessments
Framingham HS	Add HHW Reset	2015 / 2016	0	1,100	\$1,200	\$15,000		\$0		\$15,000		Peregrine Bdg Assessments
Framingham HS	Add Kitchen Exhaust Fan Control	2015 / 2016	300	1,100	\$1,300	\$20,000		\$0		\$20,000		Peregrine Bdg Assessments
Framingham HS	Schedule Domestic Hot Water	2015 / 2016	300	400	\$500	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Framingham HS	Install Fan VFD	2015 / 2016	11,000	0	\$2,400	\$30,000		\$2,000		\$28,000		Peregrine Bdg Assessments
Framingham HS	Vending Machine Controller	2015 / 2016	2,800	0	\$500	\$2,000		\$0		\$2,000		Peregrine Bdg Assessments
Framingham HS	Walk-in Evaporator Control & ECM Motors	2015 / 2016	3,000	0	\$500	\$6,000		\$0		\$6,000		Peregrine Bdg Assessments
Framingham HS	Integrated and New Energy Management Systems	2015 / 2016	5,000	500	\$1,200	\$329,310		\$0		\$329,310		Ameresco IGA
Framingham HS	Demand Control Ventilation	2015 / 2016	2,251	1,477	\$1,881	\$16,492		\$900		\$15,592		Ameresco IGA
Framingham HS	Infiltration Reductions	2015 / 2016	9	6,480	\$7,129	\$62,743		\$0		\$62,743		Ameresco IGA
Framingham HS	Transformers	2015 / 2016	87,168	0	\$12,356	\$80,714		\$15,253		\$65,462		Ameresco IGA
Framingham HS	Lighting System Improvements	2015 / 2016	109,000	-1,164	\$23,931	\$193,954		\$50,405		\$143,549		Ameresco IGA
Fuller MS	Construction of new replacement building	2016	124,651	45,867	\$50,453					\$0		PEG estimate of 20% elec and 40% gas reduction
Hemenway ES	PC Load Management	2015 / 2016	3,000	-30	\$300	\$4,500		\$0		\$4,500		Peregrine Bdg Assessments
Hemenway ES	Lighting Controls	2015 / 2016	6,000	-100	\$600	\$40,000		\$6,000		\$34,000		Peregrine Bdg Assessments
Hemenway ES	Recommission / Adjust Control Systems	2015 / 2016	4,000	1,600	\$2,300	\$21,100		\$0		\$21,100		Peregrine Bdg Assessments
Hemenway ES	Schedule Domestic Hot Water	2015 / 2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Hemenway ES	Update Pipe Insulation	2015 / 2016	0	150	\$200	\$2,500		\$0		\$2,500		Peregrine Bdg Assessments
Hemenway ES	Convert Electric Heating to Gas	2015 / 2016	22,000	-900	\$2,500	\$150,000		\$0		\$150,000		Peregrine Bdg Assessments
Hemenway ES	Demand Control Ventilation	2015 / 2016	862	436	\$594	\$8,205		\$450		\$7,755		Ameresco IGA
Hemenway ES	Infiltration Reductions	2015 / 2016	20	1,345	\$1,482	\$9,234		\$0		\$9,234		Ameresco IGA
Hemenway ES	Lighting System Improvements	2015 / 2016	20,389	-228	\$4,724	\$36,659		\$7,135		\$29,524		Ameresco IGA
Juniper ES	Replace Refrigerator(s)	2015 / 2016	2,400	0	\$360	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Juniper ES	Lighting Controls	2015 / 2016	6,000	-100	\$600	\$35,000		\$5,300		\$29,700		Peregrine Bdg Assessments
Juniper ES	Recommission / Adjust Control Systems	2015 / 2016	500	2,400	\$2,700	\$21,100		\$0		\$21,100		Peregrine Bdg Assessments
Juniper ES	Schedule Domestic Hot Water	2015 / 2016	300	400	\$500	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Juniper ES	Update Pipe Insulation	2015 / 2016	0	300	\$300	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Juniper ES	Install Boiler Isolation Valves	2015 / 2016	0	400	\$400	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Juniper ES	Demand Control Ventilation	2015 / 2016	662	231	\$329	\$4,086		\$225		\$3,861		Ameresco IGA
Juniper ES	Infiltration Reductions	2015 / 2016	0	381	\$419	\$2,523		\$0		\$2,523		Ameresco IGA
Juniper ES	Lighting System Improvements	2015 / 2016	31,656	-155	\$5,143	\$50,735		\$6,565		\$44,170		Ameresco IGA
King Administration	Replace Refrigerator(s)	2015 / 2016	800	0	\$100	\$1,000		\$0		\$1,000		Peregrine Bdg Assessments
King Administration	Lighting Controls	2015 / 2016	6,000	-100	\$600	\$35,000		\$5,300		\$29,700		Peregrine Bdg Assessments
King Administration	Recommission / Adjust Control Systems	2015 / 2016	11,000	1,200	\$2,700	\$21,200		\$0		\$21,200		Peregrine Bdg Assessments
King Administration	Schedule Domestic Hot Water	2015 / 2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
King Administration	Update Pipe Insulation	2015 / 2016	0	30	\$30	\$500		\$0		\$500		Peregrine Bdg Assessments
King Administration	Install Boiler Isolation Valves	2015 / 2016	0	400	\$440	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
King Administration	Demand Control Ventilation	2015 / 2016	1,203	610	\$877	\$8,220		\$450		\$7,770		Ameresco IGA
King Administration	Infiltration Reductions	2015 / 2016	30	194	\$218	\$1,873		\$0		\$1,873		Ameresco IGA
King Administration	Lighting System Improvements	2015 / 2016	9,308	0	\$1,906	\$22,509		\$700		\$21,809		Ameresco IGA

Attachment A1: Table 4: Proposed ERP Activities with Energy Reductions

Table 4 - Town of Framingham Energy Reduction Plan												
Energy Conservation Measures Data												
Measure		Status	Energy Data			Financial Data					Reference Data	
Category/Building	Energy Conservation Measure	Status (Completed with month/year or planned Qtr/year)	Projected Annual Electricity Savings (kWh)	Projected Annual Natural Gas Savings (therms)	Projected Annual Cost Savings (\$)	Total Installed Cost (\$)	Green Community Grant (\$)	Utility Incentives (\$)	Other Grants (\$)	Net Town Cost (\$)	Funding Source(s) for Other Grants and Net Town Costs	Source for Projected Savings
McCarthy ES	Lighting Controls	2015 / 2016	10,000	-200	\$1,000	\$60,000		\$9,000		\$51,000		Peregrine Bdg Assessments
McCarthy ES	Recommission / Adjust Control Systems	2015 / 2016	32,000	-40	\$3,900	\$40,900		\$0		\$40,900		Peregrine Bdg Assessments
McCarthy ES	Schedule Domestic Hot Water	2015 / 2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
McCarthy ES	Update Pipe Insulation	2015 / 2016	0	300	\$300	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
McCarthy ES	Demand Control Ventilation	2015 / 2016	1,297	1,340	\$1,621	\$8,147		\$450		\$7,697		Ameresco IGA
McCarthy ES	Infiltration Reductions	2015 / 2016	261	2,907	\$3,227	\$18,693		\$0		\$18,693		Ameresco IGA
McCarthy ES	Variable Frequency Drives For HW Pumps	2015 / 2016	11,395	0	\$1,299	\$17,940		\$6,300		\$11,640		Ameresco IGA
McCarthy ES	Transformers	2015 / 2016	66,948	0	\$9,481	\$85,115		\$9,596		\$75,519		Ameresco IGA
McCarthy ES	Lighting System Improvements	2015 / 2016	55,029	-495	\$9,981	\$81,099		\$12,400		\$68,699		Ameresco IGA
McCarthy ES	Integrated and New Energy Management Systems	2015 / 2016	31,958	-35	\$3,605	\$40,891		\$0		\$40,891		Ameresco IGA
Potter ES	Integrated and New Energy Management Systems	2015 / 2016	2,664	549	\$958	\$54,418		\$0		\$54,418		Ameresco IGA
Potter ES	Infiltration Reductions	2015 / 2016	0	906	\$997	\$11,602		\$0		\$11,602		Ameresco IGA
Potter ES	Lighting System Improvements	2015 / 2016	8,252	0	\$1,281	\$13,756		\$900		\$12,856		Ameresco IGA
Potter ES	Lighting Controls	2015 / 2016	0	0	\$0	\$17,471		\$0		\$17,471		Ameresco IGA
Potter ES	Demand Control Ventilation	2015 / 2016	2,093	280	\$586	\$12,485		\$675		\$11,810		Ameresco IGA
Stapleton ES	Demand Control Ventilation	2015 / 2016	1,047	262	\$427	\$4,090		\$225		\$3,865		Ameresco IGA
Stapleton ES	Lighting System Improvements	2015 / 2016	31,661	-303	\$6,891	\$70,173		\$7,210		\$62,963		Ameresco IGA
Stapleton ES	Recommission / Adjust Control Systems	2015 / 2016	1,866	1,690	\$2,106	\$21,078		\$0		\$21,078		Ameresco IGA
Thayer Alt. HS	Infiltration Reductions	2015 / 2016	0	311	\$350	\$3,617		\$0		\$3,617		Ameresco IGA
Thayer Alt. HS	Lighting System Improvements	2015 / 2016	7,025	-45	\$1,553	\$11,661		\$1,905		\$9,756		Ameresco IGA
Thayer Alt. HS	Steam Trap Replacements	2015 / 2016	0	563	\$632	\$11,523		\$1,100		\$10,423		Ameresco IGA
Walsh MS	Shutdown Boiler Plant at Night	2015 / 2016	0	1,300	\$1,400	\$0		\$0		\$0		Peregrine Bdg Assessments
Walsh MS	Recommission / Adjust Control Systems	2015 / 2016	6,000	2,300	\$3,300	\$51,000		\$0		\$51,000		Peregrine Bdg Assessments
Walsh MS	Add Kitchen Exhaust Fan Control	2015 / 2016	200	800	\$900	\$20,000		\$0		\$20,000		Peregrine Bdg Assessments
Walsh MS	Schedule Domestic Hot Water	2015 / 2016	300	300	\$400	\$3,000		\$0		\$3,000		Peregrine Bdg Assessments
Walsh MS	Update Pipe Insulation	2015 / 2016	0	75	\$80	\$500		\$0		\$500		Peregrine Bdg Assessments
Walsh MS	Replace Motor	2015 / 2016	1,600	0	\$200	\$2,500		\$0		\$2,500		Peregrine Bdg Assessments
Walsh MS	Replace Domestic Hot Water System	2015 / 2016	0	600	\$700	\$35,000		\$0		\$35,000		Peregrine Bdg Assessments
Walsh MS	Seal Windows	2015 / 2016	0	500	\$600	\$10,000		\$0		\$10,000		Peregrine Bdg Assessments
Walsh MS	Demand Control Ventilation	2015 / 2016	5,620	5,331	\$6,505	\$29,104		\$900		\$28,204		Ameresco IGA
Walsh MS	Lighting System Improvements	2015 / 2016	22,347	0	\$3,108	\$43,473		\$1,725		\$41,748		Ameresco IGA
Wilson ES	Recommission / Adjust Control Systems	2015 / 2016	3,700	400	\$900	\$25,000		\$0		\$25,000		Peregrine Bdg Assessments
Wilson ES	Schedule Domestic Hot Water	2015 / 2016	300	400	\$500	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Wilson ES	Install Pump VFD	2015 / 2016	4,800	0	\$600	\$40,700		\$15,000		\$25,700		Peregrine Bdg Assessments
Wilson ES	Integrated and New Energy Management Systems	2015 / 2016	1,000	200	\$300	\$121,603		\$0		\$121,603		Ameresco IGA
Wilson ES	Demand Control Ventilation	2015 / 2016	1,172	1,091	\$1,334	\$12,284		\$675		\$11,609		Ameresco IGA
Wilson ES	Infiltration Reductions	2015 / 2016	153	1,406	\$1,564	\$15,667		\$0		\$15,667		Ameresco IGA
Wilson ES	Variable Frequency Drives For HW Pumps	2015 / 2016	16,157	0	\$1,842	\$40,728		\$15,000		\$25,728		Ameresco IGA
Wilson ES	Transformers	2015 / 2016	32,849	0	\$4,659	\$32,881		\$6,061		\$26,821		Ameresco IGA
Wilson ES	Lighting System Improvements	2015 / 2016	72,312	-675	\$13,712	\$99,089		\$16,115		\$82,974		Ameresco IGA
Academy Building	Infiltration Reductions	2015 / 2016	28	107	\$126	\$1,710		\$0		\$1,710		Ameresco IGA
Academy Building	Roof Insulation	2015 / 2016	41	214	\$249	\$4,105		\$0		\$4,105		Ameresco IGA
Animal Control	PC Load Management	2015 / 2016	186	-4	\$33	\$46		\$0		\$46		Ameresco IGA
Animal Control	Programmable Thermostats	2015 / 2016	2,302	233	\$718	\$1,266		\$25		\$1,241		Ameresco IGA
DPW_Garage	Infiltration Reductions	2015 / 2016	10	180	\$199	\$1,553		\$0		\$1,553		Ameresco IGA
DPW_Garage	PC Load Management	2015 / 2016	4,927	-108	\$535	\$1,214		\$0		\$1,214		Ameresco IGA
DPW_Garage	Transformers	2015 / 2016	15,394	0	\$2,527	\$17,381		\$2,121		\$15,260		Ameresco IGA
DPW_Garage	Lighting System Improvements	2015 / 2016	47,710	-254	\$9,133	\$65,419		\$8,260		\$57,159		Ameresco IGA
DPW_Office	PC Load Management	2015 / 2016	1,496	-30	\$165	\$344		\$0		\$344		Ameresco IGA
DPW_Office	Lighting System Improvements	2015 / 2016	2,922	-31	\$754	\$5,411		\$1,355		\$4,056		Ameresco IGA
Old Edgell Library (Hist. Ctr.)	Oil to Gas Conversion	2015 / 2016	0	-6,793	\$9,508	\$27,220		\$0		\$27,220		Ameresco IGA
Old Edgell Library (Hist. Ctr.)	New HVAC Systems	2015 / 2016	0	-6,793	\$9,508	\$73,288		\$0		\$73,288		Ameresco IGA
Old Edgell Library (Hist. Ctr.)	Lighting System Improvements	2015 / 2016	2,323	0	\$491	\$5,576		\$675		\$4,901		Ameresco IGA
Old Edgell Library (Hist. Ctr.)	Programmable Thermostats	2015 / 2016	2,683	0	\$3,602	\$1,872		\$50		\$1,822		Ameresco IGA
Fire_1	Vending Misers	2015 / 2016	1,332	-28	\$146	\$456		\$115		\$341		Ameresco IGA
Fire_1	Lighting System Improvements	2015 / 2016	6,686	-51	\$1,320	\$10,928		\$1,230		\$9,698		Ameresco IGA
Fire_5	Boiler Replacements	2015 / 2016	0	666	\$748	\$115,329		\$4,000		\$111,329		Ameresco IGA
Fire_5	Lighting System Improvements	2015 / 2016	6,462	-27	\$1,119	\$9,704		\$275		\$9,429		Ameresco IGA
Fire_7	Lighting System Improvements	2015 / 2016	2,859	-9	\$624	\$5,898		\$90		\$5,808		Ameresco IGA
Fire_HQ	Integrated and New Energy Management Systems	2015 / 2016	27,482	3,355	\$7,336	\$71,064		\$2,700		\$68,364		Ameresco IGA
Fire_HQ	Infiltration Reductions	2015 / 2016	192	819	\$926	\$11,647		\$0		\$11,647		Ameresco IGA
Fire_HQ	Vending Misers	2015 / 2016	2,006	-42	\$220	\$451		\$115		\$336		Ameresco IGA
Fire_HQ	PC Load Management	2015 / 2016	1,049	-22	\$115	\$294		\$0		\$294		Ameresco IGA
Fire_HQ	Transformers	2015 / 2016	11,834	0	\$1,943	\$13,025		\$1,616		\$11,408		Ameresco IGA
Fire_HQ	New HVAC Systems	2015 / 2016	7,000	600	\$1,500	\$242,885		\$0		\$242,885		Ameresco IGA
Fire_HQ	Lighting System Improvements	2015 / 2016	31,742	-164	\$6,050	\$54,356		\$8,825		\$45,531		Ameresco IGA
Fire_HQ	Demand Control Ventilation	2015 / 2016	788	321	\$458	\$25,749		\$450		\$25,299		Ameresco IGA
Fire_HQ	Variable Frequency Drives For HW Pumps	2015 / 2016	5,395	0	\$716	\$16,588		\$1,200		\$15,388		Ameresco IGA

Attachment A1: Table 4: Proposed ERP Activities with Energy Reductions

Table 4 - Town of Framingham Energy Reduction Plan												
Energy Conservation Measures Data												
Measure		Status	Energy Data			Financial Data					Reference Data	
Category/Building	Energy Conservation Measure	Status (Completed with month/year or planned Qtr/year)	Projected Annual Electricity Savings (kWh)	Projected Annual Natural Gas Savings (therms)	Projected Annual Cost Savings (\$)	Total Installed Cost (\$)	Green Community Grant (\$)	Utility Incentives (\$)	Other Grants (\$)	Net Town Cost (\$)	Funding Source(s) for Other Grants and Net Town Costs	Source for Projected Savings
Henry St. Garage	Lighting System Improvements	2015 / 2016	3,607	-40	\$603	\$4,936		\$1,200		\$3,736		Ameresco IGA
Main Library	Schedule Domestic Hot Water	2015 / 2016	300	400	\$500	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Main Library	Update Pipe Insulation	2015 / 2016	0	50	\$60	\$500		\$0		\$500		Peregrine Bdg Assessments
Main Library	Replace Motor	2015 / 2016	700	0	\$130	\$4,500		\$0		\$4,500		Peregrine Bdg Assessments
Main Library	Replace Boiler Plant	2015 / 2016	0	2,100	\$2,300	\$253,300		\$15,000		\$238,300		Peregrine Bdg Assessments
Main Library	Integrated and New Energy Management Systems	2015 / 2016	66,895	3,106	\$10,941	\$353,193		\$13,500		\$339,693		Ameresco IGA
Main Library	Infiltration Reductions	2015 / 2016	107	329	\$374	\$2,908		\$0		\$2,908		Ameresco IGA
Main Library	Boiler Replacements	2015 / 2016	0	2,147	\$2,362	\$253,321		\$15,000		\$238,321		Ameresco IGA
Main Library	PC Load Management	2015 / 2016	9,562	-193	\$863	\$2,397		\$0		\$2,397		Ameresco IGA
Main Library	Lighting System Improvements	2015 / 2016	19,908	-183	\$3,375	\$26,807		\$400		\$26,407		Ameresco IGA
Main Library	Variable Frequency Drives For HW Pumps	2015 / 2016	10,079	0	\$1,134	\$22,996		\$6,900		\$16,096		Ameresco IGA
McAuliffe Library	Construction of new replacement building	2016	13,019	1,137						\$0		PEG estimate of 20% elec and 40% gas reduction
Memorial Hall	Schedule Domestic Hot Water	2015 / 2016	300	400	\$500	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Memorial Hall	Update Pipe Insulation	2015 / 2016	0	150	\$170	\$5,000		\$0		\$5,000		Peregrine Bdg Assessments
Memorial Hall	Convert to Hot Water Heating System	2015 / 2016	-5,000	2,200	\$1,800	\$750,000		\$0		\$750,000		Peregrine Bdg Assessments
Memorial Hall	Seal Shaft / Fireplace	2015 / 2016	0	50	\$60	\$500		\$0		\$500		Peregrine Bdg Assessments
Memorial Hall	Insulate Attic, Misc	2015 / 2016	0	300	\$300	\$20,000		\$0		\$20,000		Peregrine Bdg Assessments
Memorial Hall	Integrated and New Energy Management Systems	2015 / 2016	5,979	8,161	\$9,771	\$53,037		\$2,250		\$50,787		Ameresco IGA
Memorial Hall	Infiltration Reductions	2015 / 2016	19	124	\$139	\$1,162		\$0		\$1,162		Ameresco IGA
Memorial Hall	Vending Misers	2015 / 2016	7,844	-167	\$857	\$1,339		\$390		\$949		Ameresco IGA
Memorial Hall	PC Load Management	2015 / 2016	15,385	-327	\$1,682	\$3,625		\$0		\$3,625		Ameresco IGA
Memorial Hall	Steam Trap Replacements	2015 / 2016	0	2,676	\$2,944	\$114,304		\$9,800		\$104,504		Ameresco IGA
Park and Rec Office	PC Load Management	2015 / 2016	987	-20	\$108	\$227		\$0		\$227		Ameresco IGA
Park and Rec Office	Transformers	2015 / 2016	6,639	0	\$1,090	\$8,356		\$1,010		\$7,345		Ameresco IGA
Park and Rec Office	Lighting System Improvements	2015 / 2016	6,277	0	\$952	\$8,821		\$525		\$8,296		Ameresco IGA
Park and Rec Office	Infiltration Reductions	2015 / 2016	41	94	\$111	\$2,766		\$0		\$2,766		Ameresco IGA
Pearl St. Garage	Lighting System Improvements	2015 / 2016	31,157	0	\$4,452	\$28,808		\$4,570		\$24,238		Ameresco IGA
Police HQ	Add Occupancy Based HVAC Control	2015 / 2016	5,000	500	\$1,200	\$10,000		\$0		\$10,000		Peregrine Bdg Assessments
Police HQ	Install Fan VFD	2015 / 2016	40,000	0	\$4,900	\$10,000		\$0		\$10,000		Peregrine Bdg Assessments
Police HQ	Replace Motor	2015 / 2016	800	0	\$120	\$2,500		\$0		\$2,500		Peregrine Bdg Assessments
Police HQ	Add / Replace Door Seals & Align Doors	2015 / 2016	50	100	\$120	\$1,500		\$0		\$1,500		Peregrine Bdg Assessments
Police HQ	Attention to Overhead Door Seals	2015 / 2016	0	100	\$110	\$500		\$0		\$500		Peregrine Bdg Assessments
Police HQ	Integrated and New Energy Management Systems	2015 / 2016	59,108	1,784	\$9,805	\$196,935		\$0		\$196,935		Ameresco IGA
Police HQ	Infiltration Reductions	2015 / 2016	51	186	\$211	\$1,965		\$0		\$1,965		Ameresco IGA
Police HQ	Vending Misers	2015 / 2016	616	-13	\$68	\$452		\$115		\$337		Ameresco IGA
Police HQ	PC Load Management	2015 / 2016	4,187	-87	\$460	\$1,585		\$0		\$1,585		Ameresco IGA
Police HQ	Roof Insulation	2015 / 2016	166	261	\$309	\$7,996		\$0		\$7,996		Ameresco IGA
Police HQ	New HVAC Systems	2015 / 2016	700	50	\$140	\$48,652		\$0		\$48,652		Ameresco IGA
Police HQ	Lighting System Improvements	2015 / 2016	72,151	-730	\$13,177	\$71,179		\$7,590		\$63,589		Ameresco IGA
Police HQ	Variable Frequency Drives For HW Pumps	2015 / 2016	8,932	0	\$1,185	\$47,745		\$9,300		\$38,445		Ameresco IGA
Sanitation Dept., Lower	Lighting System Improvements	2015 / 2016	24,151	-33	\$3,986	\$37,002		\$3,425		\$33,577		Ameresco IGA
Sanitation Dept., Upper	Lighting System Improvements	2015 / 2016	2,816	0	\$1,009	\$6,063		\$1,405		\$4,658		Ameresco IGA
Callahan Senior Ctr	Vending Misers	2015 / 2016	2,645	-52	\$294	\$454		\$115		\$339		Ameresco IGA
Callahan Senior Ctr	PC Load Management	2015 / 2016	757	-15	\$84	\$182		\$0		\$182		Ameresco IGA
Callahan Senior Ctr	Airflow Corrections	2015 / 2016	0	10	\$11	\$520		\$0		\$520		Ameresco IGA
Callahan Senior Ctr	Lighting System Improvements	2015 / 2016	28,381	-147	\$5,927	\$53,555		\$10,015		\$43,540		Ameresco IGA
BUILDINGS SUBTOTAL			3,047,612	169,862	\$466,372	\$6,917,426	\$0	\$625,328	\$0	\$6,444,326		
TOTAL BUILDING MMBtu SAVINGS			28866.92746	10398.45045	16986.20665							
Street	Street Lighting Improvements	2015 / 2016	919,905	0	\$141,408	\$1,686,017		\$229,976		\$1,456,040		Siemens analysis of savings potential
STREET AND TRAFFIC LIGHTS SUBTOTAL			919,905	0	\$141,408	\$1,686,017	0	\$229,976	0	\$1,456,040		
TOTAL STREET AND TRAFFIC LIGHT MMBtu SAVINGS			3138.71586	3138.71586	0							
Parks	Lighting conversions to LED	2015 / 2016	60,000									LA Case Study; ERP Appendix B
Park buildings	improved operations and maintenance practices	2015 / 2016		729.6								Included in 5% estimates
OPEN SPACE SUBTOTAL			60,000	730	0	0	0	0	0	0		
TOTAL OPEN SPACE MMBtu SAVINGS			277.68	204.72	72.96							
Water and sewer pumping	Improved O&M	2011-2013	60,568	489								MEI Table 3
Water and sewer pumping	pump station heating system upgrades	2011-2013		489								MEI Table 3
Water and sewer pumping	Installation of drives	2011-2013	45,427									MEI Table 3
Water and sewer pumping	Improved O&M	2014 - 2016	30,284	489								Included in 5% estimates
Water and sewer pumping	pump station heating system upgrades	2015 / 2016		489								Included in 5% estimates
Water and sewer pumping	Installation of drives	2015 / 2016	45,427									Included in 5% estimates
WATER/SEWER/PUMPING SUBTOTAL			181,706	1,956	\$0	\$0	\$0	\$0	\$0	\$0		
TOTAL PUMPING MMBtu SAVINGS			815.580872	619.980872	195.6							
Vehicles	purchase of more efficient vehicles	2014 - 2016										FuelEconomy.gov; ERP Appendix B
Vehicles	improved operations and maintenance practices	2014 - 2016										FuelEconomy.gov; ERP Appendix B
VEHICLES SUBTOTAL			620	196	\$0	\$0	\$0	\$0	\$0	\$0		
TOTAL VEHICLE MMBtu SAVINGS			7009.804375	2,115374735	19.56							
TOTAL			4,209,842	172,743	\$607,780	\$8,603,443	\$0	\$855,304	\$0	\$7,900,366		
TOTAL FRAMINGHAM MMBtu SAVINGS			40108.70857	14363.98256	17274.32665							

Attachment A2: MEI Energy Use FY11 vs FY13 -

**MEI Table 3 Comparison FY2011 vs. FY2013 (MMBTUs Used)  
showing effects of ECMs installed**

								Percent	2011 to 2013 improvements
		2011 Electric	2011 Gas	2011 Total	2013 Electric	2013 Gas	2013 Total	Reduction	
<b>Buildings</b>	<b>Barbieri ES</b>	3,143	3,993	7,136	3,160	2,874	6,033	<b>15.46%</b>	DDC controls; LED lighting; new RTUs; drives
	<b>Walsh MS</b>	1,954	8,277	10,231	1,807	7,230	9,037	<b>11.67%</b>	LED lighting
	<b>Mary E Stapleton ES</b>	561	3,886	4,447	600	3,371	3,972	<b>10.68%</b>	O&M
	<b>Cameron MS</b>	2,192	3,610	5,801	2,075	3,480	5,555	<b>4.24%</b>	LED lighting
	<b>Potter Road ES</b>	579	1,756	2,334	459	2,455	2,914	<b>-24.85%</b>	DDC controls; LED lighting; drives
	<b>Brophy ES</b>	816	3,079	3,895	709	2,718	3,427	<b>12.02%</b>	DDC controls; LED lighting; drives
	<b>Woodrow Wilson ES</b>	1,766	3,625	5,391	1,652	3,360	5,012	<b>7.03%</b>	LED lighting
	<b>Hemenway ES</b>	588	3,378	3,967	596	3,233	3,829	<b>3.48%</b>	LED lighting; drives
	<b>Framingham HS</b>	7,803	13,180	20,983	7,197	11,735	18,931	<b>9.78%</b>	Lighting upgrades; LED lighting
	<b>Charlotte A Dunning ES</b>	479	3,179	3,658	560	2,964	3,524	<b>3.66%</b>	LED lighting; drives
	<b>Miriam F McCarthy ES</b>	2,138	5,105	7,243	2,143	3,137	5,280	<b>27.10%</b>	DDC controls; LED lighting
	<b>Memorial Building</b>	1,928	3,839	5,767	1,820	2,630	4,450	<b>22.84%</b>	Lighting upgrades; O&M
	<b>Main Library</b>		2,223	2,223		1,937	1,937	12.87%	
	<b>Station 1</b>	344	1,068	1,412	343	983	1,326	6.09%	
	<b>Station 5</b>	237	751	988	236	764	1,000	-1.21%	
	<b>Station 7</b>	96	398	494	92	374	466	5.67%	
	<b>Station 2</b>	117	1,142	1,258	113	970	1,083	13.91%	
	<b>DPW Headquarters</b>	1,993	3,805	5,798	2,134	2,743	4,877	<b>15.88%</b>	O&M
	<b>Callahan Senior Center</b>	712	1,001	1,713	651	816	1,467	<b>14.36%</b>	O&M
	<b>Juniper Hill</b>	395	2,479	2,873	395	2,365	2,760	<b>3.93%</b>	DDC controls; LED lighting; drives
	<b>Cushing Memorial Chapel</b>		340	340		304	304	10.59%	
	<b>Loring Arena</b>	2,020	2,180	4,200	1,948	2,071	4,019	4.31%	
	<b>Academy Building</b>	1	274	275	0	207	207	24.73%	
	<b>Village Hall</b>	18		18	17		17	5.56%	
	<b>Pearl Street Garage</b>	389		389	374		374	3.86%	
	<b>Park &amp; Recreation Office</b>	52	276	327		280	280	14.37%	
	<b>Framingham Alternative High School</b>	68	515	583	79	478	557	4.46%	
	<b>Fire Department HQ</b>	893	2,078	2,971	912	1,489	2,401	19.19%	
	<b>Police HQ</b>	1,966	1,601	3,568	2,035	1,839	3,874	-8.58%	
	<b>Henry St. Garage</b>	155	755	910	151	650	800	12.09%	
	<b>Sanitation Department</b>	865	150	1,015		461	461	<b>54.58%</b>	Lighting upgrades
	<b>King Admin Bdg (School Dept)</b>	637	4,849	5,487	591	3,057	3,648	<b>33.52%</b>	DDC controls; LED lighting; drives
	<b>Athenaeum Hall</b>	0		0	1		1	<b>Mothballed</b>	
	<b>Old Edgell Library</b>	76		76	68		68	10.53%	
	<b>Police Kennel</b>	58	163	221	59	160	219	0.90%	
	<b>Building Total</b>	<b>35,039</b>	<b>82,955</b>	<b>117,992</b>	<b>32,977</b>	<b>71,135</b>	<b>104,110</b>	<b>11.77%</b>	
<b>Open Space</b>	<b>Cushing Academy Building #3</b>	44	101	145	44	93	137	5.52%	

**MEI Table 3 Comparison FY2011 vs. FY2013 (MMBTUs Used)  
showing effects of ECMs installed**

		2011 Electric	2011 Gas	2011 Total	2013 Electric	2013 Gas	2013 Total	Percent Reduction	2011 to 2013 improvements
	Cushing Middle Building #2	20	385	405	13	381	394	2.72%	
	Cushing Building #1	33		33	21		21	36.36%	
	Shops and Play Group								
	Farm Pond Park	110		110	90		90	18.18%	
	Cushing Memorial Park	89		89	59		59	33.71%	
	Winch Park	43		43	38		38	11.63%	
	Beaver St Park	28		28	26		26	7.14%	
	Bowditch Field	62		62	61		61	1.61%	
	Victory Field	0		0	0		0	#DIV/0!	
	Learned Park	14		14	7		7	50.00%	
	Butterworth Park	0		0	0		0	#DIV/0!	
	Reardon Park	7		7	7		7	0.00%	
	Saxonville Beach	1		1	2		2	-100.00%	
	Longs Playground	14		14	19		19	-35.71%	
	Edgell Grove Cemetery	26		26	15		15	42.31%	
	<b>Open Space Total</b>	<b>489</b>	<b>486</b>	<b>976</b>	<b>402</b>	<b>474</b>	<b>875</b>	<b>10.35%</b>	
<b>Water/Sewer</b>	1179 Grove- Doeskin	110	27	137	142	29	171	-24.82%	
	3 Speen Street Sewer Station	295	74	368		78	78	78.80%	
	68 Florita Sewer Station	194		194	230		230	-18.56%	
	26 Arsenal Rd	50	1	50		0	0	<b>closed</b>	
	801 Pleasant Sewer	102		102	84		84	17.65%	
	New York Avenue Sewer Station	205		205	171		171	16.59%	
	1011 Pleasant St	2,048	256	2,304	1,821	72	1,893	17.84%	
	16 Gate St Sewer Station	135	39	174	121	37	158	9.20%	
	300 Winter St Water Station	47		47	58		58	-23.40%	
	Other Pumping Accounts	0	62	62		55	55	11.29%	
	68R Hemenway - New Building	422		422	467		467	-10.66%	
	139 Elm St	567	216	783	569	161	731	6.64%	
	529 Grove St	1,049	71	1,120	682	200	881	21.34%	
	700-742 Worcester Road	499	62	560	383	131	514	8.21%	
	663 Edgel Rd Water Pumping Sta	1,770	168	1,937	1,703	182	1,885	2.68%	
	Goodnow Lane PS (water)	114		114	136		136	-19.30%	
	Shady Lane Pump Station	14		14	14		14	0.00%	
	Lomas Sewer Pumping	46		46	43		43	6.52%	
	Perry Henderson Sewer Pumping	13		13	18		18	-38.46%	
	Flanagan Sewer Pumping	30		30	60		60	-100.00%	
	Lavelle Sewer Pumping	29		29	30		30	-3.45%	
	McQuin Sewer Pumping	29		29	20		20	31.03%	

**MEI Table 3 Comparison FY2011 vs. FY2013 (MMBTUs Used)  
showing effects of ECMs installed**

	2011 Electric	2011 Gas	2011 Total	2013 Electric	2013 Gas	2013 Total	Percent Reduction	2011 to 2013 improvements
Sage Sewer Pumping	4		4	3		3	25.00%	
Victor Pump Station	22		22	13		13	40.91%	
Brownlea Pump Station	29		29	26		26	10.34%	
Larnis Sewer Pumping	33		33	29		29	12.12%	
Overlook Pump Station	3		3	4		4	-33.33%	
Little Farms Sewer Pumping	18		18	36		36	-100.00%	
Lowther Pump Station	7		7	8		8	-14.29%	
Nine Ninety Pump Station	9		9	10		10	-11.11%	
Watson Place Pump Station	1,237		1,237	1,088		1,088	12.05%	
Indian Head Tank	38		38	42		42	-10.53%	
Eaton Road Pump Station	25		25	58		58	-132.00%	
Nob Hill Pump Station	55		55	17		17	69.09%	
Garvey Sewer Pump Station	18		18	14		14	22.22%	
Bebee Tank	20		20	37		37	-85.00%	
Blackberry Sewer Pumping	28		28	23		23	17.86%	
Oakcrest Pump Station	278	5	282	294	1	295	-4.61%	
Checkerberry Tank	20		20	25		25	-25.00%	
WJH	95		95	81		81	14.74%	
Salem End Pump Station	43		43	39		39	9.30%	
Goodnow Tank	53		53	35		35	33.96%	
Edgewater 1 Sewer Pump	6		6	8		8	-33.33%	
Fenelon Sewer Pump	11		11	7		7	36.36%	
Cypress St Pump Station	20		20	25		25	-25.00%	
Weld Sewer Pumping	35		35	32		32	8.57%	
Carter Drive Pump	54		54	64		64	-18.52%	
A Street Pump Station				1,133	1,542	2,676	opened 2012	
Fenwick sewer pumping	262		262	290	5	295	-12.60%	
Kittridge Rd	49		49	43		43	12.24%	
<b>Water/Sewer Total</b>	<b>10,240</b>	<b>978</b>	<b>11,219</b>	<b>10,238</b>	<b>2,493</b>	<b>12,730</b>	<b>-13.47%</b>	
<b>Grand Total</b>	<b>45,768</b>	<b>84,419</b>	<b>130,187</b>	<b>43,617</b>	<b>74,102</b>	<b>117,715</b>	<b>9.58%</b>	

**NOTE:** Shaded cell indicates data problem

## Appendix A1: BOS letter



## TOWN OF FRAMINGHAM

Memorial Building, 150 Concord Street, Room 121, Framingham, MA 01702  
508-532-5400 | 508-532-5409 (fax) | [selectmen@framinghamma.gov](mailto:selectmen@framinghamma.gov) | [www.framinghamma.gov](http://www.framinghamma.gov)

**Town Manager**  
Robert J. Halpin

**Assistant Town Manager**  
Jennifer L. Thompson

**Board of Selectmen**  
Dennis L. Giombetti, Chair  
Laurie Lee, Vice Chair  
Michael J. Bower, Clerk  
Charles J. Sisitsky  
Jason A. Smith

October 23, 2013

Ms. Jan Pfister, Grant Coordinator  
Massachusetts Department of Energy Resources  
Green Communities Division  
100 Cambridge Street, Suite 1020  
Boston, MA 02114

Ms. Pfister:

Framingham's Board of Selectmen met on October 8, 2013 and, as part of the agenda at that public meeting, reviewed and considered the Energy Reduction Plan being proposed by the Town of Framingham as part of our Green Community Application.

Framingham will be establishing FY2011 as its baseline year to capture energy reductions implemented over the last two years. We have developed a plan to achieve the remainder of our 20% reduction by the end of FY2016.

The Board of Selectmen endorsed and adopted this Energy Reduction Plan at the October 8, 2013 meeting and has authorized me to submit the plan as part of Framingham's Green Community Application.

We look forward to working with the Department of Energy Resources as we move forward with energy reduction plan implementation and other Green Community activities.

Sincerely,

  
Robert Halpin  
Town Manager

**Attendance:** Laurie Lee, Vice Chair; Michael J. Bower, Clerk; Charles J. Sisitsky, Member; Jason Smith, Member

**Absent:** Dennis L. Giombetti, Chair

**Staff:** Robert Halpin, Town Manager; Jennifer L. Thompson, Assistant Town Manager; Alice Clapper, Administrative Assistant

In Mr. Giombetti's absence, Ms. Lee called the meeting to order at 7:00 p.m. and read the agenda for open session into the record.

Public Participation:

No public participation.

Town Manager's Report

Mr. Halpin reported on the following: Comcast I-Net Negotiations; MetroWest RTA Groundbreaking; Cushing Memorial Park Master Plan and Emeritus at Farm Pond; Transportation and Development at Tech Park/9-90 Corporate Center; Risk Assessment Audit Recommendation; Chapter 43 D Approval; TJX 2012 TIF Report; Ashland Medical Marijuana District; Meeting with DEP regarding General Chemical. A copy is available in the Board of Selectmen/Town Manager's Office for review. Ms. Lee asked if the placement of marijuana districts near Framingham's boundaries is a trend of other abutting towns. The Town needs to be watchful of this matter. The Town Manager commented that he and Natick officials have been working collaboratively on this issue.

Ms. Clapper noticed that Mr. Joel Winett used the Open Meeting Documents Book. This was the first time ever anyone, but Ms. Clapper has touched that book.

Public Hearings

*Consideration of Amendment to Entertainment License & Sunday Entertainment License – Tropical Café, 85 Hollis Street (continued from 10/01/2013)*

Ms. Lee stated this was continued from the October 1, 2013 meeting because additional information was requested with regard to the floor plans. She stated the request for a change in hours was denied on October 1, 2013. A letter from the applicant's attorney stated a requested to have this matter continued until October 22, 2013.

Move: to continue the hearing until October 22, 2013 at 7:00 p.m.  
Motion: Mr. Smith                                      Second: Mr. Bower  
Vote: 4-0-0

*Consideration of Carnival License @ Pinefield Plaza – Cushing Amusements/Rotary Club*

Attorney Matt Jones, Rotary Club President Elect, stated the Rotary Club is partnering with Cushing Amusements in requesting a Carnival License at the Pinefield Plaza to run

1 starting October 18, 2013 to October 20, 2013. The Police and Fire Department  
2 requirements were noted for the record. Mr. Jones reviewed the incident of earlier this  
3 year (possible playing of offensive music) and assured the Board that the carnival will be  
4 run with the highest of standards.

5  
6 Move: to approve

7 Motion: Mr. Smith                      Second: Mr. Bower

8 Vote: 4-0-0  
9

10 *Consideration of Change of Manager & Assistant Manager - All Alcohol Restaurant*  
11 *License & Common Victualer License – 99 Restaurant & Pub, 659 Worcester Road*  
12 Operations Director, Stephen McGovern reviewed the request and introduced Mr. Paul  
13 Panarelli and Ms. Elizabeth Lee who were requesting the changes in manager and  
14 assistant manager, respectively. It was noted a Police Department approval was pending  
15 for each to register with the PD for their alcohol server ID's. The applicants stated that  
16 they would be receiving their TIP certification from the FPD on Thursday October 10.

17  
18 Move: to approve Paul Panarelli as Manager

19 Motion: Mr. Smith                      Second: Mr. Bower

20 Vote: 4-0-0  
21

22 Move: to approve Elizabeth Lee as Assistant Manager

23 Motion: Mr. Smith                      Second:

24 Vote:  
25

26 Long Range Financial Presentation

27 Ms. Mary Ellen Kelley, Chief Financial Officer, reviewed the Long Range Financial Plan  
28 in a PowerPoint presentation, which included: Overview; Base Forecast; FY15-19  
29 Projected Budget Expenditures and Revenues; Consequence of Debt Service Limit;  
30 Health Insurance costs (no change); Reducing the Levy; Reducing the Levy (2%);  
31 Reducing the Levy (1.5%); Reducing Health Insurance Costs; Forecast with Reduced  
32 Health Insurance; Other Post-Employment Benefits (OPEB); OPEB Funding Schedules  
33 Over Time; Funding OPEB; Reduce Health Insurance & Fund OPEB; and Pensions.

34  
35 A brief discussion ensued.

36  
37 Mr. Bower requested that the Water and Sewer Enterprise Long Range Plans along with  
38 the projected 5 to 10 year growth rates in water and sewer rates be provided to the board  
39 before the tax rate hearing in December.

40  
41 Mr. Smith commented that he was concerned about the taxpayers and the increases they  
42 have faced in previous years.

43  
44 Mr. Smith and Mr. Sisitsky asked for clarifications on the tax rate hearing in December.

45  
46 Mr. Sisitsky questioned how the \$409,000 in surplus revenue will be handled. Would it  
47 be used to alleviate the tax liability? Would it be spent?

1  
2 Mr. Bower commended the past boards and past and current administrations for their  
3 outstanding efforts in creating a coordinated, centralized and prioritized approach to  
4 capital project planning. He asked the CFO to emphasize in her presentation to Town  
5 Meeting the fact that the Fuller Middle School replacement project should be handled as  
6 a debt exclusion so as to not undermine the outstanding capital program in place.  
7

8 Article #9 Energy Services Contract and Green Communities Energy Reduction Plan

9 Mr. Halpin gave a brief statement with regard to the terms of the energy contract and  
10 Town Meeting must vote to waive the restriction for a contract being more than five  
11 years. A proposed contract will be brought to a future Town Meeting for discussion and  
12 review. It was confirmed Town Counsel will review the contract.  
13

14 Mr. Bower asked the administration to emphasize in their presentation to Town Meeting  
15 the comments contained in the backup materials for the Town Meeting: "In seeking  
16 approval to extend the term of the contract beyond 5 years to not more than 20 years, it is  
17 completely understood that the Annual Town Meeting in 2014 will have the final say on  
18 whether to approve the actual contract and to appropriate the required funding to  
19 implement it."  
20

21 Move: to support

22 Mr. Sisitsky                      Mr. Bower

23 Vote: 4-0-0  
24

25 Mr. Steve Wiseman, Town's Owner Agent, Vice President, Peregrine Energy Group, Inc.  
26 presented an overview of Green Communities Energy Reduction Plan that included:  
27 Purpose of Presentation; Criteria 3: Energy Reduction Plan; Framingham Energy Use  
28 Baseline; Framingham FY11 Energy Use; Energy Reduction since FY11; Proposed Town  
29 Building Reductions; Proposed School Building Reductions; Proposed Vehicle Fuel  
30 Reductions; Proposed Street Lighting Reductions; Proposed Pumping Reductions;  
31 Energy Reduction Summary.  
32  
33

34 Move: to support Article #9 and to authorize the Town Manager to submit the plan as  
35 part of Framingham's Green Community Application

36 Motion: Mr. Sisitsky                      Second: Mr. Bower

37 Vote: 4-0-0  
38

39 Review of Fall Special Town Meeting Warrant Articles:

40 Article #7 Appropriation of Mitigation Funds

41 Ms. Kelley stated Article #7 was for an appropriation of \$1,574,000 mitigation funds for  
42 traffic improvements for 2 School Street and Danforth Green that was part of the  
43 Planning Board decisions.  
44

45 Move: to support Article #7

46 Motion: Mr. Sisitsky                      Second: Mr. Bower

47 Vote: 4-0-0

1  
2 *Article #15 Route 126 Highway Alterations*

3 Mr. William Sedewitz, P.E., Chief Engineer, DPW reviewed the project and stated that  
4 this was for Town Meeting to vote to hear a report from the BoS relative to the laying out  
5 of Concord Street, Hollis Street, Waverly Street, Howard Street and Union Avenue.  
6

7 Mr. Sedewitz stated that of the 12 easements approved, 11 were for private property.  
8

9 Move: to make a report to Town Meeting

10 Motion: Mr. Sisitsky                      Second: Mr. Bower

11 Vote: 4-0-0  
12

13 *Article #18 Amend General Bylaws: Article 1§5.10 Regarding Committee Meeting*  
14 *Minutes*

15 Mr. Winett, Rules Committee Chair, reviewed the purpose of the amendment to the  
16 General Bylaws with regard to meetings and minutes for Standing Committees.  
17

18 Mr. Winett requested that the Board of Selectmen include a similar mandate for the  
19 production of meeting minutes to its appointed committees.

20 Mr. Sisitsky and Ms. Lee explained that the board typically takes no action on matters  
21 pertaining to the governance of Town Meeting.

22 Move: to take no position on Article #18

23 Motion: Mr. Sisitsky                      Second: Mr. Smith

24 Vote: 4-0-0  
25

26 *Article #19 Amend General Bylaws, Article V, §21: Demolition Delay Bylaw*

27 Dr. Frederick Wallace, Town Historian, and Chair of Historical Commission gave a brief  
28 history of the demolition delay bylaw and the purpose of the amendment to the same.  
29

30 Move: to support

31 Motion: Mr. Sisitsky                      Second: Mr. Smith

32 Vote: 4-0-0  
33

34 Approval of Minutes:

35 09/24/2013 Executive Session

36 Move: to approve but not release

37 Motion: Mr. Smith                      Second: Mr. Bower

38 Vote: 4-0-0  
39

40 09/24/2013 Open Session

41 Move: to approve

42 Motion: Mr. Smith                      Second: Mr. Bower

43 Vote: 4-0-0  
44

45 Selectmen Reports

46 Mr. Bower stated that Government Study Committee voted to refer back the donation  
47 bins and is calling a meeting on Monday. Ms. Lee said she will be in attendance at that

1 meeting. Mr. Halpin stated he had a meeting with Town Counsel who will be clarifying  
2 some of the issues raised and will be attending additional meetings with other  
3 committees. Mr. Bower stated he doesn't want to have it referred back because it would  
4 be an additional six months before the matter could go before Town Meeting and  
5 additional donation bins could be added in Town.

6  
7 Mr. Sisitsky reminded viewers about the upcoming Special Election next Tuesday and  
8 reviewed changes within some of the polling location buildings.

9  
10 Move: to adjourn at 8:40 p.m.

11 Motion: Mr. Smith                      Second: Mr. Sisitsky

12 Vote: 4-0-0

13  
14 Respectfully submitted,  
15 Alice Clapper

16  
17 Reviewed by,  
18 Michael J. Bower, Clerk

19  
20 Please note that streaming video of this meeting can be found at:

21 <http://www.framinghamtv.com/streaming2.htm>

22 Delay in posting of Board of Selectmen videos may occur due to technical issues.

23  
24 The following agenda item documents were included in the Board of Selectmen's packets  
25 or were presented during the meeting and are available in the Board of Selectmen's office  
26 upon request.

- 27  
28 1. Town Manager's Report  
29 2. Email regarding the Consideration of Amendment to Entertainment License &  
30 Sunday Entertainment License – Tropical Café, 85 Hollis Street – Continued from  
31 10/1/13  
32 3. Application for Consideration of Carnival License @ Pinefield Plaza – Cushing  
33 Amusements/Rotary Club  
34 4. Application for Consideration of Change of Manager & Assistant Manager - All  
35 Alcohol Restaurant License & Common Victualer License – 99 Restaurant &  
36 Pub, 659 Worcester Road  
37 5. Long Range Financial Presentation  
38 6. Article #9 Energy Services Contract and Green Communities Energy Reduction  
39 Plan Presentations  
40 7. Article #7 Appropriation of Mitigation Funds  
41 8. Article #15 Route 126 Highway Alterations  
42 9. Article #18 Amend General Bylaws: Article 1§5.10 Regarding Committee  
43 Meeting Minutes  
44 10. Article #19 Amend General Bylaws, Article V, §21: Demolition Delay Bylaw  
45 11. Approval of Meeting Minutes - Open Session 09/24/2013, Executive Session  
46 09/24/2013

Appendix A2: School committee letter -



# Framingham Public Schools

King Administration Building

454 Water Street

Framingham, Massachusetts 01701

Telephone: 508-626-9117 Fax: 508-877-4240

Stacy L. Scott, Ed.D., Superintendent of Schools

October 24, 2013

Ms. Jan Pfister, Grant Coordinator  
Massachusetts Department of Energy Resources  
Green Communities Division  
100 Cambridge Street, Suite 1020  
Boston, MA 02114

Dear Ms. Pfister:

Framingham's School Committee met on October 22, 2013 and, as part of the agenda at that public meeting, reviewed and considered the Energy Reduction Plan being proposed by the Town of Framingham as part of our Green Community Application.

Framingham will be establishing FY2011 as its baseline year to capture energy reductions implemented over the last two years. We have developed a plan to achieve the remainder of our 20% reduction by the end of FY2016.

The School Committee endorsed and adopted this Energy Reduction Plan at the October 22, 2013 meeting and has authorized me to submit the plan as part of Framingham's Green Community Application.

We look forward to working with the Department of Energy Resources as we move forward with energy reduction plan implementation and other Green Community activities.

Sincerely,

A handwritten signature in black ink, appearing to read "Stacy L. Scott", is written over a horizontal line.

Dr. Stacy L. Scott  
Superintendent of Schools

SLS/JT/np

## **SCHOOL COMMITTEE**

FRAMINGHAM PUBLIC SCHOOLS

## ***ACTIONS***

FRAMINGHAM, MASSACHUSETTS

School Committee Office

October 28, 2013

*On Tuesday, October 22, 2013, the School Committee held its regular meeting in the Blumer Room of the Memorial Building with all members present. The following actions were taken:*

**VOTE TO ENDORSE TOWN OF FRAMINGHAM'S ENERGY REDUCTION PLAN:** Moved by Ms. Phalen, seconded by Dr. Silverman, that the School Committee vote to accept Town of Framingham's Energy Reduction Plan and the Town's proposal to seek designation of Framingham as a Green Community by the Commonwealth of Massachusetts. Vote in favor was 7-0, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Mr. Miles, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor.

**REVISED POLICY ACAB (POLICY AND GRIEVANCE PROCEDURES FOR DISCRIMINATION INCLUDING HARASSMENT AND RETALIATION – FIRST READING:** Moved by Mr. Limeri, seconded by Ms. Phalen, that the School Committee approve revised Policy ACAB (Policy and Grievance Procedures for Discrimination Including Harassment and Retaliation) for a first reading. Vote in favor was 7-0, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Mr. Miles, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor.

**REVISED POLICY JICFB (BULLYING PREVENTION) – FIRST READING:** Moved by Mr. Limeri, seconded by Ms. Phalen, that the School Committee approve revised Policy JICFB (Bullying Prevention) for a first reading. Vote in favor was 7-0, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Mr. Miles, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor.

**MINUTES FOR APPROVAL:** Moved by Ms. Phalen, seconded by Mr. Taggart, that the School Committee vote to approve the minutes of October 1, 2013, with revisions to page two, line 70. Vote in favor was 6-0-1, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor; Mr. Miles abstaining.

Moved by Ms. Phalen, seconded by Mr. Limeri, that the School Committee approve the executive session minutes of October 1, 2013. Vote in favor was 6-0-1, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor; Mr. Miles abstaining.

Moved by Ms. Phalen, seconded by Mr. Taggart, that the School Committee approve the open session minutes of October 8, 2013, with a revision to page one, line 31. Vote in favor was 7-0, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Mr. Miles, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor.

**ADJOURNMENT:** Moved by Mr. Taggart, seconded by Mr. Miles, that the School Committee adjourn. Vote in favor was 7-0, with Ms. Connolly, Ms. Hugo, Mr. Limeri, Mr. Miles, Ms. Phalen, Dr. Silverman and Mr. Taggart in favor.

### **Upcoming Regular Meetings**

**Tuesday, November 5**

**Tuesday, November 19**

## Appendix C1: Ameresco Building Assessment

## Executive Summary

The Metropolitan Area Planning Council (MAPC) issued a Request for Qualifications (RFQ) to Energy Service Companies (ESCOs) to provide for Comprehensive Energy Management Services for 14 of its member communities. Ameresco submitted a proposal and was subsequently awarded the contract.

The program utilizes a multiple step design/development process beginning with a Preliminary Energy Audit (PEA) and followed by a refined and detailed Investment Grade Audit (IGA). This IGA is a key step in developing a successful energy savings and infrastructure improvement project focusing on the exact needs and desires of the Town. The purpose of the IGA is to analyze and quantify the feasibility of installing certain improvements or energy conservation measures (ECMs) throughout the Town of Framingham. The IGA will form the basis for the subsequent Energy Services Agreement (ESA) which will enable the design and construction phase.

This IGA quantifies how the Town will be able to reduce utility costs by well over \$300,000 annually, through the acquisition of approximately \$3.6 million dollars in capital improvements. This investment however, will be budget-neutral to the Town. The Town will achieve these improvements via a Performance Contract designed to extract energy inefficiencies in the current utility operating budgets to self-fund the project from future energy savings. Payment will be made over time utilizing Ameresco's guaranteed annual energy savings for security.

Table ES.1

Financing Term (after construction)	12 years
Estimated Tax-exempt Interest Rate	3.00%
Total Project Cost	\$3,657,429
Estimated Utility Rebates	\$327,305
Net Assumed Capital Cost	\$3,330,124
Guaranteed Cost Savings / Year 1	\$341,623
Net Excess Cumulative Cash Flow	\$386,915

In collaboration with and by direction of the Town, Ameresco has conducted an IGA on the buildings below. The table provides the square footage for each building analyzed, along with the energy performance of each building, in terms of fossil fuel and electricity usage per square foot. Energy performance is the ratio of yearly energy use by square footage and is a good indicator of how well a building performs.

Facility Name	Gross Square Feet	Fuel MBTU / g.s.f.	Electric MBTU / g.s.f.	Total EUI MBTU / g.s.f.
Memorial Building	76,453	50.2	25.2	75.4
Main Library Building	53,000	41.9	36.0	77.9
Fire Department Headquarters	24,829	83.7	36.0	119.7
Engine #1	8,516	125.4	40.4	165.8
Engine #2	5,332	54.4	21.9	76.2
Engine #5	11,616	64.6	20.4	85.1
Engine #7	4,404	90.4	21.9	112.3
Police Station	42,336	37.8	46.4	84.3
Callahan Senior Center	24,724	40.5	28.8	69.3
Pearl Street Garage	24,000	0.0	16.2	16.2
Animal Control Building	1,300	125.3	44.6	169.9
Old Edgell Library	4,500	180.3	17.0	197.3
Academy Building	4,515	60.7	11.6	72.3
Park Department Headquarters	6,500	42.4	25.5	67.9
Barbieri Elementary School	112,000	35.6	28.1	63.7
Brophy Elementary School	68,000	45.3	12.0	57.3
Cameron Middle School	114,000	31.7	19.2	50.9
Dunning Elementary School	61,500	51.7	7.8	59.5
Framingham High School	396,000	33.3	19.7	53.0
Hemenway Elementary School	61,500	54.9	9.6	64.5
Juniper Hill Elementary School	44,300	55.9	8.9	64.9
King Administration Building	50,000	97.0	12.7	109.8
McCarthy Elementary School	95,936	53.2	22.3	75.5
Potter Road Elementary School	63,600	27.6	9.1	36.7
Stapleton Elementary School	59,600	65.2	9.4	74.6
Thayer Campus of FHS	10,800	47.7	6.3	54.0
Walsh Middle School	201,000	41.2	9.7	50.9
Woodrow Wilson Elementary	140,695	25.8	12.8	38.6
DPW Headquarters	73,638	51.7	31.0	82.7
Henry Street Garage	6,134	123.1	23.6	146.7
Sanitation Department - Upper	4,950	30.3	174.8	205.1
Sanitation Department - Lower	6,720	0.0	0.0	0.0
DPW Office	5,040	0.0	0.0	0.0
<b>Totals</b>	<b>1,867,438</b>			

Ameresco developed a comprehensive baseline for each facility, the details of which can be found in Section 1. The total amount of utility usage for the Fiscal Year 2011 was 10,371,681 kWh, 795,830 Therms of natural gas, and 5,850 gallons of #2 fuel oil.

A wide-range of energy conservation measures (ECMs) were identified, evaluated, and presented for consideration. The comprehensive development process of the IGA included input from Town personnel in order to refine the ECMs and overall scope of the project to match the infrastructure need of the facilities. This IGA outlines and describes 16 distinct ECMs across all facilities as listed in the matrix on the following page. The subsequent page lists the cost and savings for each of the measures across all facilities.

Table ES.2: ECM Matrix

Town of Framingham																
Energy Conservation Measures (ECMs)																
Facility	1	2	3	4	5	6	8	9	11	14	15	17	18	19	23	25
Memorial Building	X		X			X				X	X		X			
Main Library Building	X	X	X			X	X			X	X					
Fire Department Headquarters	X	X	X	X		X				X	X			X		
Engine #1	X									X						
Engine #2	X	X														
Engine #5	X						X									
Engine #7	X															
Police Station	X	X	X			X				X	X	X				
Callahan Senior Center	X	X								X	X					X
Pearl Street Garage	X															
Animal Control Building				X							X					
Old Edgell Library	X			X				X								
Academy Building						X						X				
Park Department Headquarters	X	X									X			X		
Barbican Elementary School	X					X								X	X	
Brophy Elementary School	X			X		X								X	X	
Canton Middle School	X			X	X	X			X					X		
Dunning Elementary School	X				X	X									X	
Framingham High School	X				X	X								X		
Henrievay Elementary School	X			X	X	X									X	
Juniper Hill Elementary School	X			X	X	X									X	
King Administration Building	X			X	X	X									X	
McCarthy Elementary School	X			X	X	X			X					X	X	
Peterson Elementary School	X			X	X	X										
Stapleton Elementary School	X			X	X										X	
Thayer Campus of FHS	X				X	X										
Walsh Middle School				X											X	
Woodrow Wilson Elementary	X			X	X	X			X					X		
DPW Headquarters	X	X									X			X		
Herry Street Garage	X	X														
Sanitation Department - Upper	X	X														
Sanitation Department - Lower	X	X														
DPW Office	X										X					

ECM #	ECM Name	Annual kW	Total kWh	Natural Gas (Therms)	#2 Fuel Oil (Gallons)	Energy Savings	O&M Savings	Total Project Savings	Total Project Costs	SPB
1	Lighting System Improvements	2,238.7	813,269	(5,687)	(8)	\$ 141,394	\$ 11,435	\$ 152,829	\$ 1,312,810	8.59
2	Lighting Controls	-	19,908	(209)	-	\$ 2,327	\$ -	\$ 2,327	\$ 24,164	10.39
3	Integrated and New Energy Management Systems	-	159,464	16,406	-	\$ 37,853	\$ -	\$ 37,853	\$ 889,015	23.49
4	Programmable Thermostats	-	4,984	233	877	\$ 4,320	\$ -	\$ 4,320	\$ 3,139	0.73
5	Demand Control Ventilation	-	21,592	13,478	-	\$ 17,493	\$ -	\$ 17,493	\$ 166,008	9.49
6	Infiltration Reductions	-	976	21,659	-	\$ 23,956	\$ -	\$ 23,956	\$ 186,994	7.81
8	Boiler Replacements	-	-	2,813	-	\$ 3,110	\$ -	\$ 3,110	\$ 322,236	103.60
9	Oil to Gas Conversion	-	-	(6,793)	4,898	\$ 9,508	\$ -	\$ 9,508	\$ 21,856	2.30
11	Variable Frequency Drives For HW Pumps	-	49,461	-	-	\$ 5,639	\$ -	\$ 5,639	\$ 101,093	17.93
14	Vending Misers	-	14,444	(302)	-	\$ 1,585	\$ -	\$ 1,585	\$ 3,155	1.99
15	PC Load Management	-	38,536	(805)	-	\$ 4,046	\$ -	\$ 4,046	\$ 9,923	2.45
17	Roof Insulation	-	207	475	-	\$ 558	\$ -	\$ 558	\$ 12,117	21.72
18	Nevins Hall AHU Rehabilitation	-	(4,522)	(622)	-	\$ (1,284)	\$ -	\$ (1,284)	\$ 26,733	(20.81)
19	Transformers	420.1	306,006	-	-	\$ 44,104	\$ -	\$ 44,104	\$ 333,617	7.56
23	Retrocommissioning	-	72,211	15,071	-	\$ 25,619	\$ -	\$ 25,619	\$ 244,049	9.53
25	Airflow Corrections	-	-	10	-	\$ 11	\$ -	\$ 11	\$ 520	46.26
		2,659	1,496,536	55,728	5,766	\$ 320,238	\$ 11,435	\$ 331,672	\$ 3,657,429	11.03

Table ES.4: Project Pro-Forma

<b>Town of Framingham - Pro-Forma</b>												
<b>Initial Project Costs:</b>												
Implementation costs	\$	3,657,429										
<b>Total Initial Project Costs</b>	<b>\$</b>	<b>3,657,429</b>										
Utility Rebates	\$	327,305										
<b>Total Rebates</b>	<b>\$</b>	<b>327,305</b>										
<b>Net Project Costs after rebates</b>	<b>\$</b>	<b>3,330,124</b>										
<b>Pro-forma</b>												
	Initial Values	1	2	3	4	5	6	7	8	9	10	
1 Annual energy costs without improvements	\$ 2,380,362	\$ 2,451,773	\$ 2,525,326	\$ 2,601,086	\$ 2,679,119	\$ 2,759,492	\$ 2,842,277	\$ 2,927,545	\$ 3,015,372	\$ 3,105,833	\$ 3,199,008	
2 Annual energy costs with improvements	\$ 2,060,125	\$ 2,121,928	\$ 2,185,586	\$ 2,251,154	\$ 2,318,688	\$ 2,388,249	\$ 2,459,897	\$ 2,533,693	\$ 2,609,704	\$ 2,687,995	\$ 2,768,635	
3 Annual energy cost savings (1-2)	\$ 320,238	\$ 329,845	\$ 339,740	\$ 349,932	\$ 360,430	\$ 371,243	\$ 382,381	\$ 393,852	\$ 405,668	\$ 417,838	\$ 430,373	
4 O&M Savings	\$ 11,435	\$ 11,778	\$ 12,131	\$ 12,495	\$ 12,870	\$ 13,256	\$ 13,654	\$ 14,063	\$ 14,485	\$ 14,920	\$ 15,367	
5 Total Project Savings	\$ 331,672	\$ 341,623	\$ 351,871	\$ 362,427	\$ 373,300	\$ 384,499	\$ 396,034	\$ 407,915	\$ 420,153	\$ 432,757	\$ 445,740	
6 Payments for financing equipment	\$ 289,589	\$ 289,589	\$ 299,244	\$ 309,189	\$ 319,432	\$ 329,982	\$ 340,849	\$ 352,041	\$ 363,570	\$ 375,444	\$ 387,675	
7 Payments for Ongoing Services	\$ 19,214	\$ 19,791	\$ 20,384	\$ 20,996	\$ 21,626	\$ 22,275	\$ 22,943	\$ 23,631	\$ 24,340	\$ 25,070	\$ 25,822	
8 Net annual benefits	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	
9 Cumulative cash flow	\$ 386,915	\$ 32,243	\$ 64,486	\$ 96,729	\$ 128,972	\$ 161,215	\$ 193,458	\$ 225,700	\$ 257,943	\$ 290,186	\$ 322,429	
10 <b>Net Present Value of cash flow</b>	<b>\$ 320,946</b>											
11 Interest Rate	3.00%											
12 Discount Rate	3.00%											
<b>Totals</b>												
1	\$ 3,294,978	\$ 3,393,827	\$ 3,479,537	\$ 3,558,822	\$ 3,632,245	\$ 3,700,492	\$ 3,763,381	\$ 3,820,745	\$ 3,872,545	\$ 3,918,750	\$ 3,959,340	
2	\$ 2,851,694	\$ 2,937,245	\$ 3,011,470	\$ 3,074,882	\$ 3,127,919	\$ 3,170,144	\$ 3,201,245	\$ 3,220,945	\$ 3,239,045	\$ 3,255,445	\$ 3,270,045	
3	\$ 443,284	\$ 456,582	\$ 468,167	\$ 478,245	\$ 486,919	\$ 494,245	\$ 500,245	\$ 505,045	\$ 508,745	\$ 511,445	\$ 514,145	
4	\$ 15,828	\$ 16,303	\$ 16,752	\$ 17,182	\$ 17,592	\$ 17,982	\$ 18,352	\$ 18,702	\$ 19,032	\$ 19,342	\$ 19,632	
5	\$ 459,112	\$ 472,886	\$ 484,319	\$ 494,544	\$ 503,644	\$ 511,644	\$ 518,544	\$ 524,344	\$ 529,044	\$ 532,744	\$ 535,444	
6	\$ 400,272	\$ 413,248	\$ 424,534	\$ 434,245	\$ 442,445	\$ 449,145	\$ 454,445	\$ 458,445	\$ 461,145	\$ 463,745	\$ 465,345	
7	\$ 26,597	\$ 27,395	\$ 28,080	\$ 28,662	\$ 29,142	\$ 29,522	\$ 29,802	\$ 30,082	\$ 30,262	\$ 30,442	\$ 30,622	
8	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	\$ 32,243	
9	\$ 354,672	\$ 386,915										
10												
11												
12												

Notes:

1 This Proforma Cash Flow reflects an estimated tax exempt lease rate of 3%. The actual rate will increase or decrease based on market conditions and customer credit rating at the time of lease funding.

2 Savings are based on current utility rate structures and usage information provided for purposes of this project.

Investment Grade Audit

"Page content is subject to Confidentiality Restrictions"

This page is intentionally left blank.

## Energy Conservation Measures

The following ECM descriptions are intended to provide a high level overview. In general the ECMs are designed to deliver many technical, financial, and environmental benefits to the Town of Framingham that include:

- Better learning and working environment for students and staff;
- Improved energy efficiency and operation of existing systems;
- New energy efficient equipment and systems;
- Performance Guarantee of energy savings; and
- Reduction of Greenhouse gasses and emissions.

## ECM 1: Lighting System Improvements

Ameresco proposes to install a state-of-the-art lighting system for the Town of Framingham. The project replaces or upgrades approximately 9,700 existing fixtures and will enhance the quality, consistency, and color rendering of the lighting system, while meeting all applicable codes and standards.

Our in-house lighting experts completed a survey of your facilities. We identified over 17,000 different lamp/ballast/fixture combinations, the majority of which are linear fluorescent, which provide general lighting in key areas such as classrooms, offices & halls. Approximately 61% of linear fluorescent fixtures use standard-grade T8s on electronic ballasts with a mixture of ballast factors. In addition to standard grade T8 lamps, a significant amount of energy efficient lamps were found throughout the Town of Framingham buildings. 25% of the linear fluorescent lamps were found to be either 30w or 28w energy efficient lamps on a mixture of ballast factors. High-intensity discharge (HID) lamps are used in some repair garages such as those found at the DPW Headquarters as well as for exterior lighting throughout the town. Color rendition is fair to poor depending on lamp quality and age, which unfortunately can be a characteristic of HID lamps.

Although the lighting system is generally performing as designed, improvements are possible.



Figure 1.1: New light fixtures will improve aesthetics and provide substantial energy savings.

## ECM 2: Lighting Controls

Ameresco proposes to install new lighting controls in the Town buildings to ensure that lighting does not operate unnecessarily. Energy waste occurs when a fixture is energized but not used and when illuminance exceeds what is necessary for task performance. Ameresco noted that some occupants are not careful about turning off lights when they leave the room, making automated controls advantageous.

Ameresco proposes to install 122 local lighting controls employing a variety of strategies, each of which was customized to the unique space. We selected appropriate areas that contain several controllable fixtures, which have intermittent occupancy, and where a safety hazard will not be created if the sensor inadvertently turns the lights off. Applicable areas include offices, baths, cafeterias, and libraries.



Figure 2.1: Ceiling mounted occupancy sensors such as this one will be employed in a number of areas. These type of sensors significantly reduce run hours and provide substantial energy savings.


Bathrooms or other areas without direct line-of-sight to the sensor, will receive dual-technology sensors that “listen” for activity in addition to “looking” for motion. The fluorescent high-bays in garage areas will each have motion sensors, allowing each one to operate independently for maximum savings and flexibility. For some mechanical spaces, programmable timers will be installed. Staff will simply push the button to receive a preset amount of time. They can see the time running as it counts down on the display. Before the time runs out, the lights will flash, indicating that the occupant has a few minutes before the timer automatically turns off the lights.

### ECM 3: Integrated and New Energy Management Systems

Ameresco proposes to update the existing EMS systems installed in Memorial Hall, Fire Department Headquarters and Police Station and add new EMS systems to the Main Library Building.

The proposed EMS would be “open protocol” and “interoperable” with other manufacturer’s products. This feature would allow products from any vendor to be installed as the system is maintained or expanded in the future. The recommended EMS would be password accessible from any Internet-enabled personal computer with web browsing software and would provide reduced energy consumption, increase system reliability and improve occupant comfort. The proposed EMS will provide dynamic systems control and utility consumption reporting capabilities for the entire Town.

Under the proposed EMS, Ameresco would install a new open protocol EMS that would be installed on top of existing pneumatic controls for the air handling units and other control valves, as well as exhaust fans and circulator pumps. All existing pneumatic logic controllers will be removed with the exception of existing pneumatic thermostats controlling unit ventilators and cabinet heaters. All pneumatic controls in the boiler rooms will be replaced with only the pneumatic valve actuators being reused.



existing

## ECM 4: Programmable Thermostats

Ameresco identified two (2) non-programmable thermostats at Old Edgell Library. Each thermostat controls a hot water heated, DX-cooled Fan Coil Unit in the attic space. Ameresco identified two (2) thermostats at the Animal Control Building. One controls a gas-fired Roof Top Unit (RTU) that serves the kennel area and is programmable. The other controls the RTU serving the office space and is non-programmable. The thermostats are set to maintain one temperature at all times, and need to be turned down manually to get any night setback savings.



Figure 4.1: Existing Mercury Non-programmable thermostat in the Old Edgell Library

Ameresco proposes to install and program new 7-day programmable thermostats at the Old Edgell Library and Animal Control Building to replace existing thermostats. Energy will be saved by setting back temperatures at night when the buildings are unoccupied. Ameresco will work with the Framingham Historical Society to find a suitable setback temperature to preserve the art collections. The old thermostats will be properly disposed of.

## ECM 5: Demand Controlled Ventilation

Ameresco identified energy saving opportunities in a number of buildings through the installation of demand control ventilation (DCV) controls. DCV controls modulate the amount of outdoor air supplied to a space to maintain a required ventilation rate (CFM per person) based on the actual occupancy at that time. This strategy saves energy by reducing the amount of outdoor air that is conditioned during low occupancy periods.

Ameresco identified thirty-five (35) pieces of air handling equipment at School buildings and eight (8) at the Fire Headquarters that can be upgraded with DCV controls.

All spaces have a high occupant density that varies throughout the day and all spaces are supplied with a large volume of air. These units currently use a mix of variable air volume and constant air volume strategies.

There are concerns at the Fire Headquarters that too much outdoor air is being brought into the building. This is thought to contribute somewhat to the high humidity problems the building has experienced.

CO<sub>2</sub> sensors will be installed to monitor CO<sub>2</sub> levels in the spaces and control ventilation rates for each occupied space according to ASHRAE Standard 62 requirements. The sensors will be wired back to existing AHU controllers. The existing controls will be modified and programmed to control the outdoor air dampers via CO<sub>2</sub> levels. The new sensors will have the capability to override the outdoor air dampers based on CO<sub>2</sub> control algorithm.



Figure 5.1: Existing Air Handling Unit serving Cameron Middle School

## ECM 6: Infiltration Reductions

The buildings throughout the Town were built at various times. Construction and energy standards have changed significantly through the years. One of the most common areas for air infiltration is where the outside walls connect with the roof. This intersection was typically not sealed during construction before energy codes began calling for it. Other sources of infiltration typically include poor weatherstripping of doors and windows and wall and roof penetrations.



ry School

Ameresco proposes to reduce the infiltration of outside air and the leaking of conditioned air by performing weatherization techniques throughout most of the heated and cooled buildings across town. The reduction of outdoor air infiltrating occupied conditioned space will improve occupant comfort and will reduce heating and cooling costs.

## ECM 8: Boiler Improvements

The Main Library is heated by a circa 1978 Cleaver Brooks CB-200-60 firetube hot water boiler. The boiler serves VAV box reheat coils and perimeter heating throughout the building. Fire Engine #5 is served by a Weil-McLain LGB-6 hot water boiler built in 1987. The boiler provides hot water to three different zones. The boilers installed are near the end of their useful lives and will require expensive repairs in the near future.



at

Ameresco proposes replacing the existing boilers at the Main Library and at Fire Engine #5 with new, more efficient, condensing, gas-fired hot water boilers.

The new condensing boilers will be much smaller and significantly more efficient than the existing boilers. The new boilers have a much wider range of modulation, minimizing cycling during shoulder months. The two boiler system for the Library will also provide redundancy and deliver heat even if one boiler is down for maintenance.

### ECM 9: Oil to Gas Conversion

The Old Edgell Library is heated by an American Standard cast-iron hot water boiler with a Beckett oil burner. The building was originally heated by radiators throughout, but now hot air is supplied by two Fan Coil Units (FCU) in the attic space. These FCUs have hot water coils that are fed from the existing boiler. Ameresco proposes to replace the burners and convert heating fuel from oil to gas to take advantage of lower fuel costs in terms of cost per BTU. The existing boiler will be reused and retrofit with a new Carlin (or similar), single nozzle, air-atomizing burner. In addition, the fire box in the existing boiler will be rebuilt as part of this measure.



Figure 9.1: Existing oil burner installed in the Old Edgell Library

### ECM 11: Variable Frequency Drives

Ameresco identified pumps located at the Cameron Middle School, McCarthy Elementary School and Wilson Elementary School are good candidates for variable frequency drives (VFDs). The installation of VFDs and controls will motors to modulate with varying load more efficiently than the existing methods of control, which will reduce electrical energy and to improve system efficiency. Ameresco proposes to install ten (10) VFDs and integrate their control to the existing EMS system. The VFD's will also provide the motors with soft-start capability, which will help to decrease spikes in power draw and decrease mechanical stress to equipment. Electric energy savings will be realized because of the reduced power consumption of the motors controlled by the VFDs.



Figure 11.1: Existing Pump located at the Cameron Middle School

### ECM 14: Vending Machine Controls

Vending machines were found throughout the Town's buildings. The vending machines are typically stocked with soda, juice and sport/energy drinks and are cooled and illuminated year-round regardless of occupancy. Snack vending machines were also found in the same areas. Ameresco proposes to install 8 occupancy sensing, plug load controllers to reduce the unnecessary operation of the Town's vending machines during unoccupied periods. Each vending machine controller will save energy used by the refrigerated vending machine during unoccupied hours without compromising product quality. The controller will use a sensor to detect when the space is unoccupied and turn off the vending machine. Existing non-refrigerated snack machines will also be controlled. As reported by the American Council for an Energy Efficient Economy (ACEEE), the 2.5 million vending machines operating in the U.S. consume nearly \$600 million in energy and demand costs. Since Town buildings are not constantly occupied, the Town's refrigerated vending machines consume more energy than needed.




Figure 14.2: Beverage and Snack Vending Machine located at the Memorial Building

## ECM 15: PC Load Management

Most Town employees use personal computers for their daily work. Some of these computers are left on even when the user is not present.

Ameresco proposes to install a client/server software application that will manage the power consumption of computers located throughout the Town of Framingham buildings. Ameresco identified 436 Windows-based personal computers (PCs) of various models located at a number of Town buildings. This software will save energy and money by reducing the time the computers spend in higher power modes while not in use. These packages are easy-to-deploy software utilities that address network energy waste and reduce operating costs without impacting computer users. The applications manage and minimize the energy consumed by the network's clients through one centralized interface.

The software is fully configurable by Information Technology (IT) personnel and provides a means to schedule software updates as well as to reduce energy and power consumption. The software detects user presence by tracking inputs such as mouse movement or use of the keyboard. During unoccupied periods the software resets parameters to reduce lower power consumption after a period of time specified by the IT department.



Figure 15.1: Energy Star qualified products such as Power Save can help meet the strict energy efficiency guidelines set by the U.S. EPA and U.S. DOE.

## ECM 17: Roof Insulation

Ameresco proposes increasing existing attic insulation above sections of the Police Station and Academy Building to reduce the conduction of heat out of the building during the heating season. This will reduce the amount of heat that is required from the heating system to keep interior spaces at a comfortable temperature. This increase in thermal resistance will have a similar benefit during the cooling season.

The identified sections at the Police Station are on top of flat attic section above original armory building section and the Academy building on top of flat attic section. The sections are believed to have little or no existing attic insulation, based on conversations with building staff and on the age of the building. The attic spaces are naturally ventilated, and so remain at roughly outdoor air temperatures. The lack of insulation allows heat to escape the building through these areas.



Figure 17.1: Police Station

## ECM 18: Nevins Hall AHU Rehabilitation

When originally built, Nevins Hall received fresh outdoor air through several sidewall diffusers supplied by a large Air Handling Unit (AHU). This same unit also provided air to sidewall diffusers serving the basement level Banquet Hall. Building air from these two halls was exhausted through an exhaust plenum penthouse located near the projection booth. These systems would run to bring in ventilation air to the spaces while maintaining a slightly positive pressure in the building.

Presently, the basement Banquet Hall has been sectioned into office and meeting space. The large air handler has been fitted with a new motor and modern DDC controls and the ductwork has been cleaned, but the unit has not been turned on. There is still concern over the amount of dust in the system, and temporary filters have been placed over all of the air diffusers in the basement and Nevins Hall.

Ameresco proposes to recommission HV-1 and its associated exhaust fan back into working order. The return and outdoor air dampers will be replaced and minor damage to existing ductwork will be repaired. The fan motor will be reconnected to provide the correct amount of outdoor air during events in Nevins Hall.

Ameresco proposes performing mechanical work necessary to startup and use the Nevins Hall AHU. Inoperable Outdoor Air and Return Air dampers will be replaced and new belts will be installed on both the AHU supply fan and exhaust fan. Supply air will be cut-off from the basement level using existing dampers in the ductwork in order to direct all of the supply air into Nevins Hall. Once startup of the AHU and exhaust fan has been completed and the air is determined to be sufficiently clean, the temporary air filters on the diffusers will be removed.

Ameresco proposes to install demand control ventilation (DCV) on the Nevins Hall AHU. New CO<sub>2</sub> sensors will be located in the occupied space, and the outdoor air damper actuator will be tested for proper operation (modulating). New CO<sub>2</sub> sensors will be installed to monitor CO<sub>2</sub> levels in the space and control ventilation rates for the occupied space according to ASHRAE Standard 62 requirements. The sensors will be wired back to the existing AHU controller. The existing controls will be modified and programmed to control the outdoor air damper via CO<sub>2</sub> levels. The new sensors will have the capability to override the outdoor air dampers based on CO<sub>2</sub> control algorithm.



Figure 18.1: Existing return air damper in HV-1 Mixed Air plenum

## ECM 19: Transformer Replacement

Most transformers in use today in the Town are estimated to be loaded at about 5% - 30% of their total capacity which is typical of other buildings. These loadings are based on spot measurements taken during the audit. These transformers are designed to be able to transform the electricity up to design ratings and are most efficient at or around the design rating. Operating at low levels for normal transformers is inefficient. The standard low voltage step-down transformer is widely considered a commodity and as such the only perceived differentiator is price – lowest purchase cost typically wins. Commercial transformer specifications rarely require a minimum efficiency. As one would expect, building a less efficient transformer is cheaper than building a more efficient one, so a typical low-first-cost transformer will have a low up-front cost but high operating cost, with the lifetime cost of the operating losses exceeding the purchase cost many times over.

The standard transformer is built to deliver its nameplate kVA rating under linear load only and is UL listed on this basis. As it has the lower purchase price on the market, it represents the majority of transformer purchases across the country. Along with the high operating cost goes substantial lost capacity and distortion of the voltage to connected equipment. Most of the transformers are oversized. Some of the transformers installed in schools, such as Barbieri, are not code compliant.

Ameresco proposes to replace a total of thirty-six (36) existing step-down transformers with new energy-efficient transformers throughout the Town. All of the transformers are dry-type indoor transformers that step-down 480 volt power to 208Y/120 volt power. Ameresco proposes to replace these transformers with new premium efficiency units that will reduce the electric losses and lower the cooling load of some of the equipment rooms.




Figure 19.1: New energy efficient transformers will be installed in place of existing standard efficiency transformers

## ECM 23: Retrocommissioning

Ameresco proposes to recommission the existing EMS systems installed at the School Buildings.

The School Buildings have a comprehensive Energy Management System, manufactured by AEM. Based on Ameresco's review of measured space temperatures and occupancy schedules, there appear to be opportunities to further optimize the operation of the EMS. Heating schedules start well before students arrive and continue after the end of class, indicating that optimal start/stop is not being utilized. Also, nighttime temperatures can be set back further, increasing energy savings. These schedules and setpoints have most likely been set to mitigate occupant complaints, but a comprehensive review and resetting of all control systems will help to generate further savings.



S.

Ameresco proposes recommissioning the School Buildings' existing Tridium Niagara<sup>AX</sup> systems. This work includes performing a full point to point checkout and generating a commissioning report on the condition of existing control equipment. All sequences, schedules, and occupied and unoccupied temperature setpoints will be evaluated and modified to increase energy efficiency while maintaining occupant comfort. Optimum Start/Stop will be utilized wherever appropriate to minimize heating during unoccupied hours while still assuring that temperatures are at an acceptable level by the time staff and students arrive.

## ECM 25: Airflow Corrections

A RTU serves the first floor kitchen area, the main entry lobby and a second floor mezzanine, open to the lobby. Thermostats controlling the temperature of supply air to these spaces are located on the first floor. The mezzanine area is chronically overheated, consistently staying between 85°F-90°F during the heating season. This is due to warm air from the lobby rising into the mezzanine area but also because of a large supply diffuser located at the mezzanine. Because this diffuser is located closest to the RTU, it receives the highest pressure air and there is a large amount of warm air blowing into the space, even with a face damper closed. Ameresco proposes to optimize the duct layout of the Roof Top Unit (RTU) serving the entry lobby and 2<sup>nd</sup> floor mezzanine of the Senior Center. This will be done to cut off supply of air to the mezzanine and increase airflow to the lobby area in order to remediate the extreme overheating of the mezzanine area.




## Solar PV

Ameresco proposes two options to design, construct, operate and maintain solar PV systems in the Town of Framingham. Option 1 includes (4) four solar PV installations: on the land adjacent to the Walsh Middle School, the roof of DPW Facility, the roof of the Callahan Senior Center, and on the light poles around the Walsh Middle School. Option 2 includes (5) five solar PV installations: the same locations as Option 1 plus the roof of the Walsh Middle School.

The solar PV systems provide the following benefits: a) immediate electricity cost savings without capital investment from the Town; b) a hedge against future electricity price volatility, c) a solar learning center with educational information and a viewing area.

Section 8 of this IGA will form the basis for the subsequent Power Purchase Agreement (PPA) which will enable the design and construction phase.



Walsh Middle School roof. The pink sections show the location of the solar PV array.

### Option 1

- **System size:** 749 kW solar PV
- **First Year Power Price:** \$0.0809/kWh
- **Capital cost:** \$0 with a PPA
- **Operating cost savings:** \$76,155 in year 1
- **Cumulative 20-year savings:** \$1,759,243

### Option 2

- **System size:** 1,204 kW solar PV
- **First Year Power Price:** \$0.0706/kWh
- **Capital cost:** \$0 with a PPA
- **Operating cost savings:** \$134,508 in year 1
- **Cumulative 20-year savings:** \$3,107,256

## Summary

Ameresco has presented a complete and comprehensive IGA that addresses the needs of the Town and provides realistic solutions. The ECMs identified present very viable and needed solutions for the continued effective operations of the Town and School facilities. The final accepted IGA will form the basis for the scope-of-work under the subsequent ESA, whereby Ameresco will provide design, acquisition, installation, modification, commissioning and training for the ECMs as presented herein.

This is an important project for the Town and one that requires an Energy Services Company (ESCO) with significant expertise. The Ameresco team has extensive experience with Performance Contracting projects in municipalities and school districts in the Boston metropolitan area, throughout the Commonwealth and North America. We have the proven commitment, experience, resources, technical expertise and financial capability out of our corporate headquarters in nearby Framingham, to successfully execute this project over the full contract term. We are ready and eager to begin implementation so that the Town may secure current low cost financing and realize the overall benefit of improved facilities within the next 12 months.

## Section 1: Baseline

### Overview

Ameresco performed an Investment Grade Audit (IGA) for the Town of Framingham, Massachusetts. The Town of Framingham is located in Eastern Massachusetts, West of Boston. The Town buildings are comprised of schools, fire and police stations, a library, an animal control center, historic buildings, a senior center, public works buildings, and the Town Hall.

Ameresco performed a Preliminary Energy Audit (PEA) for the Town of Framingham on approximately thirty-eight (38) buildings throughout the Town, including fourteen (14) school buildings and twenty-four (24) Town facilities. The total area of building space audited was approximately 1,923,500 square feet. After review of the facilities with Town personnel, the Town narrowed down the list to thirty-three (33) facilities to focus on during the Investment Grade Audit (IGA) phase. The list consisted of fourteen (14) school buildings and nineteen (19) Town facilities. The area of building space included the IGA phase is approximately 1,867,438 square feet.



As part of the IGA, Ameresco developed a baseline model for each facility. A breakout of demand, on-peak and off-peak charges was not available for school buildings, only total usage and cost. The baseline developed for each building is based on fiscal year 2011 (FY11) utility data. The total amount of utility usage for the Fiscal Year 2011 was 10,371,681 kWh, 795,830 Therms of natural gas, and 5,850 gallons of #2 fuel oil. The total utility cost for this time period was \$2,743,492.

The baseline utility cost shown in the proforma located in Section 4 is based on current utility rates and does not include customer charges. Further, many of the tariffs the buildings receive electricity and natural gas under include block rate structures. These structures charge different rates depending on how much is used. Ameresco is only including rates that reflect blocks that will be affected by the ECMs. These rates are shown in Section 7 in the Utility Rate Table. The baseline utility cost shown in the proforma located in Section 4 is the product of the baseline utility energy units multiplied by the utility rates shown in Section 7.

Table 1 gives the square footage for each facility analyzed, along with the energy performance of each building, in terms of fossil fuel and electricity usage per square foot. Energy performance is the ratio of yearly energy use by square footage and is a good indicator of how well a building performs. The energy performance of each of the municipal and school buildings was calculated from the utility information provided by Town personnel and directly from the utility companies.

The total mbtu/gsf represents the total energy usage for the entire facility on a square foot basis. The total energy usage for the entire facility on a square foot basis is the addition of both electrical and fossil fuel performance (mbtu/gsf) if applicable. In most of the buildings evaluated, the primary source for space heating is either natural gas or # 2 fuel oil. Electric heating is used at a few locations. Electric cooling is utilized to varying degree in all municipal buildings, either via central chillers or local space coolers. Buildings with larger central cooling systems operate at a higher annual electrical mbtu/gsf.

*Table 1: List of Audited Buildings and Energy Performance*

Facility Name	Gross Square Feet	Fuel MBTU / g.s.f.	Electric MBTU / g.s.f.	Total EUI MBTU / g.s.f.
Memorial Building	76,453	50.2	25.2	75.4
Main Library Building	53,000	41.9	36.0	77.9
Fire Department Headquarters	24,829	83.7	36.0	119.7
Engine #1	8,516	125.4	40.4	165.8
Engine #2	5,332	54.4	21.9	76.2
Engine #5	11,616	64.6	20.4	85.1
Engine #7	4,404	90.4	21.9	112.3
Police Station	42,336	37.8	46.4	84.3
Callahan Senior Center	24,724	40.5	28.8	69.3
Pearl Street Garage	24,000	0.0	16.2	16.2
Animal Control Building	1,300	125.3	44.6	169.9
Old Edgell Library	4,500	180.3	17.0	197.3
Academy Building	4,515	60.7	11.6	72.3
Park Department Headquarters	6,500	42.4	25.5	67.9
Barbieri Elementary School	112,000	35.6	28.1	63.7
Brophy Elementary School	68,000	45.3	12.0	57.3
Cameron Middle School	114,000	31.7	19.2	50.9
Dunning Elementary School	61,500	51.7	7.8	59.5
Framingham High School	396,000	33.3	19.7	53.0
Hemenway Elementary School	61,500	54.9	9.6	64.5
Juniper Hill Elementary School	44,300	55.9	8.9	64.9
King Administration Building	50,000	97.0	12.7	109.8
McCarthy Elementary School	95,936	53.2	22.3	75.5
Potter Road Elementary School	63,600	27.6	9.1	36.7
Stapleton Elementary School	59,600	65.2	9.4	74.6
Thayer Campus of FHS	10,800	47.7	6.3	54.0
Walsh Middle School	201,000	41.2	9.7	50.9
Woodrow Wilson Elementary	140,695	25.8	12.8	38.6
DPW Headquarters	73,638	51.7	31.0	82.7
Henry Street Garage	6,134	123.1	23.6	146.7
Sanitation Department - Upper	4,950	30.3	174.8	205.1
Sanitation Department - Lower <sup>1</sup>	6,720	0.0	0.0	0.0
DPW Office <sup>2</sup>	5,040	0.0	0.0	0.0
<b>Totals</b>	<b>1,867,438</b>			

Using information from the energy performance table along with investigating the existing conditions of equipment and systems, Ameresco has identified several key opportunities to reduce utility costs for each

<sup>1</sup> Sanitation Department Upper and Lower buildings utilities are fed from same meter

<sup>2</sup> DPW Office utilities are supplied from DPW Headquarters

facility. Many of those savings opportunities have been captured in the Energy Conservation Measures (ECM) and are detailed in Section 3.

## Baseline Information

The baseline utility data for this Investment Grade Audit is based on the Fiscal 2011 energy data (*July 2010 through June 2011*). Complete information was available for fiscal year 2012 however this year had an unusually low number of annual heating degree days (HDD), which would require a large weather adjustment in order to match 30-year average weather conditions for Framingham, Massachusetts. Instead fiscal year 2011 was used since its annual (HDD) closely matched the 30-year average weather conditions and we believe it still closely represents current operational conditions. For annual energy usage see the table at the end of this section.

Utilities are supplied through a number of different providers. At present, NStar provides delivery services while TransCanada provides commodity (supply) for electricity. Natural Gas is delivered by NStar and supplied by Spark Energy for all buildings except the Animal Control Building and Henry Street Garage, where it is supplied by NStar. Fuel Oil is supplied to the Old Edgell Library by Holliston Oil. For annual energy usage at each facility, see Table 2.

*Table 2: Annual Energy Use by Facility*

Facility Name	Natural Gas Usage (Therms)	#2 Fuel Oil Usage (Gallons)	Electric Usage (kWh)	Annual Electric Demand (kW)
Memorial Building	38,392	0	564,960	1,640.4
Main Library Building	22,226	0	558,300	1,663.0
Fire Department Headquarters	20,776	0	261,840	636.0
Engine #1	10,679	0	100,875	227.9
Engine #2	2,898	0	34,163	18.0
Engine #5	7,506	0	69,581	221.3
Engine #7	3,980	0	28,245	0
Police Station	16,011	0	576,000	1,264.8
Callahan Senior Center	10,013	0	208,720	830.4
Pearl Street Garage	0	0	114,120	180.8
Animal Control Building	1,629	0	16,987	0
Old Edgell Library	0	5,850	22,398	0
Academy Building	2,742	0	15,351	0
Park Department Headquarters	2,759	0	48,568	203.4
Barbieri Elementary School	39,925	0	921,240	0
Brophy Elementary School	30,790	0	239,256	0
Cameron Middle School	36,097	0	642,312	0
Dunning Elementary School	31,793	0	140,440	0
Framingham High School	131,795	0	2,286,960	0
Hemenway Elementary School	33,783	0	172,441	0
Juniper Hill Elementary School	24,785	0	115,749	0
King Administration Building	48,513	0	186,784	0
McCarthy Elementary School	51,047	0	626,712	0
Potter Road Elementary School	17,559	0	169,560	0
Stapleton Elementary School	38,862	0	164,288	0
Thayer Campus of FHS	5,153	0	19,800	0
Walsh Middle School	82,771	0	572,604	0

Woodrow Wilson Elementary	36,246	0	527,660	0
DPW Headquarters	38,053	0	669,752	1,915.4
Henry Street Garage	7,549	0	42,455	116.7
Sanitation Department	1,498	0	253,560	502.0
<b>Totals</b>	<b>795,830</b>	<b>5,850</b>	<b>10,371,681</b>	<b>9,420.1</b>

Each ECM presented in this audit was explicitly “baselined” by a “temperature bin” analysis for temperature variant loads and by a fixed baseline for constant loads. Straightforward electrical saving ECMs such as lighting retrofits and motor replacements were analyzed by a combination of known operating hours, field measurements and engineering calculations. The baseline operating hours for each location or a portion thereof was determined from information from the Town and review of metered data acquired during the Investment Grade Audit. Energy cost savings for each ECM was calculated with the energy rates outlined in this section.

## Electricity

The buildings receive electricity supply from TransCanada at a price of \$0.09755 per kWh. NStar electricity delivery is charged to the Town according to five delivery rates. Each delivery rate plus the supply cost is displayed in Table 3.

*Table 3: Electric Rates (includes Supply and Delivery)*

Electricity Charges	On-Peak (kWh)	Off-Peak (kWh)	Electric Demand (kW)
A9 – General (without a demand meter)	\$0.1985	\$0.1985	\$0.00
B1 – General (with a demand meter)	\$0.1717	\$0.1717	\$0.00 <sup>3</sup>
B2 – General	\$0.1327	\$0.1327	\$22.94
B3 – Time of Use	\$0.1125	\$0.1125	\$21.05
B7 – Time of Use	\$0.1140	\$0.1140	\$20.17

*Table 4: Electric Rates by Building*

Facility	A9	B1	B2	B3, G6	B7, B8
Memorial Building			X		
Main Library Building				X	
Fire Department Headquarters			X		
Engine #1			X		
Engine #2	X				
Engine #5			X		
Engine #7	X				
Police Station			X		
Callahan Senior Center			X		
Pearl Street Garage			X		
Animal Control Building	X				
Old Edgell Library	X				
Academy Building	X				
Park Department Headquarters			X		

<sup>3</sup> Charge for demand over 10.0 kW per month only

Facility	A9	B1	B2	B3, G6	B7, B8
Barbieri Elementary School				X	
Brophy Elementary School			X		
Cameron Middle School					X
Dunning Elementary School			X		
Framingham High School					X
Hemenway Elementary School			X		
Juniper Hill Elementary School					X
King Administration Building		X			
McCarthy Elementary School					X
Potter Road Elementary School			X		
Stapleton Elementary School			X		
Thayer Campus of FHS			X		
Walsh Middle School					X
Woodrow Wilson Elementary					X
DPW Headquarters			X		
Henry Street Garage		X			
Sanitation Department - Upper			X		
Sanitation Department - Lower			X		
DPW Office			X		

## Natural Gas

Natural gas is supplied by Sparks Energy and delivered to the buildings by NStar, except for at the Animal Control Building and Henry Street Garage where it is both supplied and delivered by NStar. Each delivery rate plus the supply cost is displayed in Table 5.

*Table 5: Gas Rates (includes Supply and Delivery)*

Natural Gas Charges	Delivery (\$/Therm)	Supply (\$/Therm)	Total Cost
G-41 – Low Load Factor General Service Small	\$0.3538	\$0.7700	\$1.1238
G-42 – Low Load Factor General Service Medium	\$0.3300	\$0.7700	\$1.1000

*Table 6: Gas Rates by Building*

Facility	G-41	G-42
Memorial Building		X
Main Library Building		X
Fire Department Headquarters		X
Engine #1		X
Engine #2	X	
Engine #5	X	
Engine #7	X	
Police Station		X
Callahan Senior Center		X
Pearl Street Garage	X	
Animal Control Building	X	
Old Edgell Library	X	
Academy Building	X	
Athenaeum Hall	X	
Park Department Headquarters	X	
Barbieri Elementary School		X
Brophy Elementary School		X
Cameron Middle School		X

Facility	G-41	G-42
Dunning Elementary School		X
Framingham High School		X
Hemenway Elementary School		X
Juniper Hill Elementary School		X
King Administration Building		X
McCarthy Elementary School		X
Potter Road Elementary School		X
Stapleton Elementary School		X
Thayer Campus of FHS	X	
Walsh Middle School		X
Woodrow Wilson Elementary		X
DPW Headquarters		X
Henry Street Garage	X	
Sanitation Department - Upper	X	
Sanitation Department - Lower	X	
DPW Office		X

## Fuel Oil

#2 Fuel Oil is delivered to the Old Edgell Library by Holliston Oil and the Fiscal 2011 average cost per gallon was roughly \$3.500.

## Water & Sewer Usage

Water and sewer service is provided to the Town and School buildings by the Town. Water consumption is recorded semi-annually. The Town is paying a very low bulk rate for both Water and Sewer usage and so no water conservation measures are proposed at this time.

## End-Use Breakdown

A baseline model was developed for each audited building. Fiscal year 2011 utility data as previously described was used to calibrate the model(s). The energy end-use breakdown for natural gas, fuel oil and electricity was calculated from inventoried equipment ratings, local bin weather data, operational characteristics obtained from personnel, and building envelope characteristics. Where equipment data could not be obtained, engineering experience and judgment was used. The major fuel heating end-uses found in the municipal and school buildings audited includes Space Heating, (which consist of mechanical ventilation, conduction, and infiltration), Domestic Hot Water Usage, and Cooking. Electrical usage includes Lighting, Space Cooling, HVAC Fan/Pumps, Kitchen Equipment (includes cooking appliances, refrigeration, etc.), and Office Equipment (includes computers, copiers, etc.). The remaining energy was placed in the category of “Miscellaneous Loads” and includes other plug loads.

## End-Use Graphs

This page is intentionally left blank.

## End-Use Information

### Memorial Building


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: GLACIAL ENERGY  
Electricity Accounts: 2654 296 1003

Fiscal Year 2011 Electrical Demand Consumption:	1,640 kW
Fiscal Year 2011 Electrical Energy Consumption:	564,960 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>564,960 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 103,553
Most Recent Year Blended Rate:	\$ 0.183 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: Direct Energy  
Natural Gas Accounts: 1092 025 0015

Fiscal Year 2011 Natural Gas Consumption:	38,392 / Therms
Incremental Consumption:	50.2 MBTU / SF

Fiscal Year 2011 Cost:	\$ 41,217
Fiscal Year 2011 Blended Rate:	\$ 1.074 / Therms

#### Natural Gas End-Use



## End-Use Information

### Main Library Building


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: GLACIAL ENERGY  
Electricity Accounts: 2654 293 1006

Fiscal Year 2011 Electrical Demand Consumption:	1,663 kW
Fiscal Year 2011 Electrical Energy Consumption:	558,300 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>558,300 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 100,191
Most Recent Year Blended Rate:	\$ 0.179 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: Direct Energy  
Natural Gas Accounts: 1092 189 0017

Fiscal Year 2011 Natural Gas Consumption:	22,226 / Therms
Incremental Consumption:	41.9 MBTU / SF

Fiscal Year 2011 Cost:	\$ 23,707
Fiscal Year 2011 Blended Rate:	\$ 1.067 / Therms

#### Fuel Oil End-Use



## End-Use Information

### Fire Department Headquarters


#### *Electricity*

Electricity Delivery: NSTAR  
Electricity Supply: GLACIAL ENERGY  
Electricity Accounts: 2654 352 1004

Fiscal Year 2011 Electrical Demand Consumption:	636 kW
Fiscal Year 2011 Electrical Energy Consumption:	261,840 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>261,840 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 44,447
Most Recent Year Blended Rate:	\$ 0.170 / kWh

#### **Electricity End-Use**




#### *Natural Gas*

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: Direct Energy  
Natural Gas Accounts: 1601 0720 015

Fiscal Year 2011 Natural Gas Consumption:	20,776 / Therms
Incremental Consumption:	83.7 MBTU / SF

Fiscal Year 2011 Cost:	\$ 22,260
Fiscal Year 2011 Blended Rate:	\$ 1.071 / Therms

#### **Natural Gas End-Use**



## End-Use Information

### Engine #1


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: GLACIAL ENERGY  
Electricity Accounts: 1098 822 1023

Fiscal Year 2011 Electrical Demand Consumption:	228 kW
Fiscal Year 2011 Electrical Energy Consumption:	100,875 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>100,875 kWh Total</b>

Most Recent Fiscal Year Cost:	\$	15,527
Most Recent Year Blended Rate:	\$	0.154 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: Direct Energy  
Natural Gas Accounts: 1098 822 0017

Fiscal Year 2011 Natural Gas Consumption:	10,679 / Therms
Incremental Consumption:	125.4 MBTU / SF

Fiscal Year 2011 Cost:	\$	11,541
Fiscal Year 2011 Blended Rate:	\$	1.081 / Therms

#### Natural Gas End-Use



## End-Use Information

### Engine #2


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 189 1003

Fiscal Year 2011 Electrical Demand Consumption:	18 kW
Fiscal Year 2011 Electrical Energy Consumption:	34,163 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>34,163 kWh Total</u>

Most Recent Fiscal Year Cost:	\$	6,718
Most Recent Year Blended Rate:	\$	0.197 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1091 980 0010

Fiscal Year 2011 Natural Gas Consumption:	2,898 / Therms
Incremental Consumption:	54.4 MBTU / SF

Fiscal Year 2011 Cost:	\$	3,325
Fiscal Year 2011 Blended Rate:	\$	1.147 / Therms

#### Fuel Oil End-Use



## End-Use Information

### Engine #5


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 1091 021 1027

Fiscal Year 2011 Electrical Demand Consumption:	221 kW
Fiscal Year 2011 Electrical Energy Consumption:	69,581 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>69,581 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 11,584
Most Recent Year Blended Rate:	\$ 0.166 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1091 021 0011

Fiscal Year 2011 Natural Gas Consumption:	7,506 / Therms
Incremental Consumption:	64.6 MBTU / SF

Fiscal Year 2011 Cost:	\$ 8,307
Fiscal Year 2011 Blended Rate:	\$ 1.107 / Therms

#### Natural Gas End-Use



## End-Use Information

### Engine #7


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 227 1007

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	28,245 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>28,245 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 5,466
Most Recent Year Blended Rate:	\$ 0.194 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1088 579 0013

Fiscal Year 2011 Natural Gas Consumption:	3,980 / Therms
Incremental Consumption:	90.4 MBTU / SF

Fiscal Year 2011 Cost:	\$ 4,487
Fiscal Year 2011 Blended Rate:	\$ 1.128 / Therms

#### Natural Gas End-Use



## End-Use Information

### Police Station


#### *Electricity*

Electricity Delivery: NSTAR  
Electricity Supply: GLACIAL ENERGY  
Electricity Accounts: 2824 029 0016

Fiscal Year 2011 Electrical Demand Consumption:	1,265 kW
Fiscal Year 2011 Electrical Energy Consumption:	576,000 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>576,000 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 94,719
Most Recent Year Blended Rate:	\$ 0.164 / kWh

#### Electricity End-Use




#### *Natural Gas*

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1092 022 0026

Fiscal Year 2011 Natural Gas Consumption:	16,011 / Therms
Incremental Consumption:	37.8 MBTU / SF

Fiscal Year 2011 Cost:	\$ 17,248
Fiscal Year 2011 Blended Rate:	\$ 1.077 / Therms

#### Natural Gas End-Use



## End-Use Information

### Callahan Senior Center


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: GLACIAL ENERGY  
Electricity Accounts: 2647 326 1035

Fiscal Year 2011 Electrical Demand Consumption:	830 kW
Fiscal Year 2011 Electrical Energy Consumption:	208,720 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>208,720 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 43,015
Most Recent Year Blended Rate:	\$ 0.206 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1093 029 0050

Fiscal Year 2011 Natural Gas Consumption:	10,013 / Therms
Incremental Consumption:	40.5 MBTU / SF

Fiscal Year 2011 Cost:	\$ 10,939
Fiscal Year 2011 Blended Rate:	\$ 1.092 / Therms

#### Natural Gas End-Use



## End-Use Information

### Pearl Street Garage


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 295 1004

Fiscal Year 2011 Electrical Demand Consumption:	181 kW
Fiscal Year 2011 Electrical Energy Consumption:	114,120 kWh On-Peak
	+ N/A kWh Off-Peak
	<hr/> 114,120 kWh Total

Most Recent Fiscal Year Cost:	\$	15,911
Most Recent Year Blended Rate:	\$	0.139 / kWh

#### Electricity End-Use



## End-Use Information

### Animal Control Building


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2687 763 0017

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	16,987 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>16,987 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 3,381
Most Recent Year Blended Rate:	\$ 0.199 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 2691 289 0014

Fiscal Year 2011 Natural Gas Consumption:	1,629 / Therms
Incremental Consumption:	125.3 MBTU / SF

Fiscal Year 2011 Cost:	\$ 1,993
Fiscal Year 2011 Blended Rate:	\$ 1.223 / Therms

#### Natural Gas End-Use



## End-Use Information

### Old Edgell Library


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 248 1002

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	22,398 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>22,398 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 4,366
Most Recent Year Blended Rate:	\$ 0.195 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 0

Fiscal Year 2011 Natural Gas Consumption:	- / Therms
Incremental Consumption:	180.3 MBTU / SF

Fiscal Year 2011 Cost:	\$ -
Fiscal Year 2011 Blended Rate:	#DIV/0! / Therms

#### Natural Gas End-Use



## End-Use Information

### Academy Building


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2370 263 1005

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	15,351 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>15,351 kWh Total</u>

Most Recent Fiscal Year Cost:	\$	4,364
Most Recent Year Blended Rate:	\$	0.284 / kWh

#### Electricity End-Use




#### Fuel Oil

Fuel Oil Delivery: 0

Fiscal Year 2011 Fuel Oil Consumption:	N/A Gallons
Incremental Consumption:	0 MBTU / SF

Most Recent Fiscal Year Cost:	\$	-
Most Recent Year Blended Rate:		#DIV/0! / gallon

#### Fuel Oil End-Use



## End-Use Information

### Park Department Headquarters


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2859 329 0019

Fiscal Year 2011 Electrical Demand Consumption:	203 kW
Fiscal Year 2011 Electrical Energy Consumption:	48,568 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>48,568 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 9,477
Most Recent Year Blended Rate:	\$ 0.195 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1093 019 0011

Fiscal Year 2011 Natural Gas Consumption:	2,759 / Therms
Incremental Consumption:	42.4 MBTU / SF

Fiscal Year 2011 Cost:	\$ 3,166
Fiscal Year 2011 Blended Rate:	\$ 1.148 / Therms

#### Natural Gas End-Use



## End-Use Information

### Barbieri Elementary School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 322 1001

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	921,240 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>921,240 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 184,700
Most Recent Year Blended Rate:	\$ 0.200 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1091 716 0011

Fiscal Year 2011 Natural Gas Consumption:	39,925 / Therms
Incremental Consumption:	35.6 MBTU / SF

Fiscal Year 2011 Cost:	\$ 30,742
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Brophy Elementary School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 239 1003

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	239,256 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>239,256 kWh Total</u>

Most Recent Fiscal Year Cost:	\$	45,087
Most Recent Year Blended Rate:	\$	0.188 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1624 244 0010

Fiscal Year 2011 Natural Gas Consumption:	30,790 / Therms
Incremental Consumption:	45.3 MBTU / SF

Fiscal Year 2011 Cost:	\$	23,708
Fiscal Year 2011 Blended Rate:	\$	0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Cameron Middle School


#### *Electricity*

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 180 1002

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	642,312 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>642,312 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 158,900
Most Recent Year Blended Rate:	\$ 0.247 / kWh

#### Electricity End-Use




#### *Natural Gas*

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1094 031 0039

Fiscal Year 2011 Natural Gas Consumption:	36,097 / Therms
Incremental Consumption:	31.7 MBTU / SF

Fiscal Year 2011 Cost:	\$ 27,795
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Dunning Elementary School


#### *Electricity*

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 211 1005

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	140,440 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>140,440 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 25,419
Most Recent Year Blended Rate:	\$ 0.181 / kWh

#### Electricity End-Use




#### *Natural Gas*

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1072 862 0021

Fiscal Year 2011 Natural Gas Consumption:	31,793 / Therms
Incremental Consumption:	51.7 MBTU / SF

Fiscal Year 2011 Cost:	\$ 24,481
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Framingham High School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2711 840 0012, 2711 839 0015

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	2,286,960 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>2,286,960 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 464,158
Most Recent Year Blended Rate:	\$ 0.203 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 2721 466 0014

Fiscal Year 2011 Natural Gas Consumption:	131,795 / Therms
Incremental Consumption:	33.3 MBTU / SF

Fiscal Year 2011 Cost:	\$ 101,482
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Hemenway Elementary School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 220 1004

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	172,441 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>172,441 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 32,942
Most Recent Year Blended Rate:	\$ 0.191 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1661 210 0012

Fiscal Year 2011 Natural Gas Consumption:	33,783 / Therms
Incremental Consumption:	54.9 MBTU / SF

Fiscal Year 2011 Cost:	\$ 26,013
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Juniper Hill Elementary School


#### *Electricity*

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 199 1001

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	115,749 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>115,749 kWh Total</u>

Most Recent Fiscal Year Cost:	\$	23,571
Most Recent Year Blended Rate:	\$	0.204 / kWh

#### Electricity End-Use




#### *Natural Gas*

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1094 649 0017

Fiscal Year 2011 Natural Gas Consumption:	24,785 / Therms
Incremental Consumption:	55.9 MBTU / SF

Fiscal Year 2011 Cost:	\$	19,084
Fiscal Year 2011 Blended Rate:	\$	0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### King Administration Building


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 215 1001

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	186,784 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>186,784 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 37,785
Most Recent Year Blended Rate:	\$ 0.202 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1094 109 0010

Fiscal Year 2011 Natural Gas Consumption:	48,513 / Therms
Incremental Consumption:	97.0 MBTU / SF

Fiscal Year 2011 Cost:	\$ 37,355
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### McCarthy Elementary School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 286 1005

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	626,712 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>626,712 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 120,935
Most Recent Year Blended Rate:	\$ 0.193 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1602 914 0023

Fiscal Year 2011 Natural Gas Consumption:	51,047 / Therms
Incremental Consumption:	53.2 MBTU / SF

Fiscal Year 2011 Cost:	\$ 39,306
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information


### Potter Road Elementary School

#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 176 1008

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	169,560 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>169,560 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 32,681
Most Recent Year Blended Rate:	\$ 0.193 / kWh




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1616 376 0016

Fiscal Year 2011 Natural Gas Consumption:	17,559 / Therms
Incremental Consumption:	27.6 MBTU / SF

Fiscal Year 2011 Cost:	\$ 13,520
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Stapleton Elementary School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 182 1000

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	164,288 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>164,288 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 32,984
Most Recent Year Blended Rate:	\$ 0.201 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1092 468 0019

Fiscal Year 2011 Natural Gas Consumption:	38,862 / Therms
Incremental Consumption:	65.2 MBTU / SF

Fiscal Year 2011 Cost:	\$ 29,924
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Thayer Campus of FHS


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 373 1009

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	19,800 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>19,800 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 3,693
Most Recent Year Blended Rate:	\$ 0.187 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1089 479 0020

Fiscal Year 2011 Natural Gas Consumption:	5,153 / Therms
Incremental Consumption:	47.7 MBTU / SF

Fiscal Year 2011 Cost:	\$ 3,968
Fiscal Year 2011 Blended Rate:	\$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Walsh Middle School


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 208 1000

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	572,604 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>572,604 kWh Total</u>

Most Recent Fiscal Year Cost: \$ 112,853  
Most Recent Year Blended Rate: \$ 0.197 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1072 868 0025

Fiscal Year 2011 Natural Gas Consumption:	82,771 / Therms
Incremental Consumption:	41.2 MBTU / SF

Fiscal Year 2011 Cost: \$ 63,734  
Fiscal Year 2011 Blended Rate: \$ 0.770 / Therms

#### Natural Gas End-Use



## End-Use Information

### Woodrow Wilson Elementary


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 355 1001

Fiscal Year 2011 Electrical Demand Consumption:	N/A kW
Fiscal Year 2011 Electrical Energy Consumption:	527,660 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>527,660 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 127,553
Most Recent Year Blended Rate:	\$ 0.242 / kWh

#### Electricity End-Use




#### Fuel Oil

Fuel Oil Delivery: 0

Fiscal Year 2011 Fuel Oil Consumption:	N/A Gallons
Incremental Consumption:	0 MBTU / SF

Most Recent Fiscal Year Cost:	\$ -
Most Recent Year Blended Rate:	#DIV/0! / gallon

#### Fuel Oil End-Use



## End-Use Information

### DPW Headquarters


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 1613 2741 030, 2842 705 0027

Fiscal Year 2011 Electrical Demand Consumption:	1,915 kW
Fiscal Year 2011 Electrical Energy Consumption:	669,752 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>669,752 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 125,617
Most Recent Year Blended Rate:	\$ 0.188 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1613 274 0024

Fiscal Year 2011 Natural Gas Consumption:	38,053 / Therms
Incremental Consumption:	51.7 MBTU / SF

Fiscal Year 2011 Cost:	\$ 40,517
Fiscal Year 2011 Blended Rate:	\$ 1.065 / Therms

#### Natural Gas End-Use



## End-Use Information

### Henry Street Garage


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2654 314 1001

Fiscal Year 2011 Electrical Demand Consumption:	117 kW
Fiscal Year 2011 Electrical Energy Consumption:	42,455 kWh On-Peak
	+ N/A kWh Off-Peak
	<b>42,455 kWh Total</b>

Most Recent Fiscal Year Cost:	\$ 7,399
Most Recent Year Blended Rate:	\$ 0.174 / kWh

#### Electricity End-Use




#### Natural Gas

Natural Gas Delivery Provider: National Grid  
Natural Gas Supplier: National Grid  
Natural Gas Accounts: 1092 2340 012

Fiscal Year 2011 Natural Gas Consumption:	7,549 / Therms
Incremental Consumption:	123.1 MBTU / SF

Fiscal Year 2011 Cost:	\$ 14,155
Fiscal Year 2011 Blended Rate:	\$ 1.875 / Therms

#### Natural Gas End-Use



## End-Use Information

### Sanitation Department - Upper


#### Electricity

Electricity Delivery: NSTAR  
Electricity Supply: DIRECT ENERGY  
Electricity Accounts: 2879 624 0019

Fiscal Year 2011 Electrical Demand Consumption:	502 kW
Fiscal Year 2011 Electrical Energy Consumption:	253,560 kWh On-Peak
	+ N/A kWh Off-Peak
	<u>253,560 kWh Total</u>

Most Recent Fiscal Year Cost:	\$ 47,712
Most Recent Year Blended Rate:	\$ 0.188 / kWh

#### Electricity End-Use



## IGA Baseline Information

This page is intentionally left blank.

Town of Framingham  
Utility Data Summary  
Fiscal 2011

Facility Name	ID	GSE Area (SF)	Cost		Annual Electric				Annual Fossil Fuel			Performance		Rates								
			Annual Cost (\$)	Unit Cost (\$/SF)	Demand (kW)	Energy Consump (Peak kW/h)	Peak Energy Cost \$	Total Cost	W/Sqft	kWh/Sqft	Natural Gas (Therms)	Natural Gas Cost \$	#2 Oil (Gallons)	#2 Oil Cost \$	Total MMBtu	kWh/Sqft	Fossil Fuel (MMBtu/Sqft)	Annual EUI (MMBtu/Sqft)	\$/kWh Peak	\$/Therm	Gas	\$/Gallons
Memorial Building		76,453	\$144,770	\$1.89	1,640.4	\$66,960	\$103,555	\$103,555	1.8	7.4	38,392	\$41,217			3,839	7.4	50.2	75.4	\$0.1833	\$1.074		\$0.000
Main Library Building		24,598	\$123,898	\$2.34	1,665.0	\$58,340	\$100,191	\$100,191	2.6	0.5	22,226	\$25,707			2,223	10.5	41.9	77.9	\$0.1795	\$1.067		\$0.000
Fire Department Headquarters		24,598	\$66,077	\$2.69	636.0	\$61,840	\$34,447	\$34,447	2.1	0.5	20,776	\$25,260			2,078	10.5	41.9	77.9	\$0.1697	\$1.071		\$0.000
Engine #1		8,516	\$27,067	\$3.18	227.9	\$10,875	\$15,527	\$15,527	2.2	1.8	10,776	\$11,541			1,088	11.8	125.4	165.8	\$0.1539	\$1.081		\$0.000
Engine #2		5,332	\$10,043	\$1.88	181.0	\$34,163	\$6,718	\$6,718	0.3	6.4	2,898	\$5,325			290	6.4	64.6	76.2	\$0.1967	\$1.147		\$0.000
Engine #5		11,616	\$9,951	\$1.71	271.3	69,581	\$11,584	\$11,584	1.6	6.0	7,906	\$8,807			751	6.0	60.4	85.1	\$0.1665	\$1.107		\$0.000
Engine #7		4,404	\$9,953	\$2.26	1,264.8	\$28,235	\$5,466	\$5,466	0.0	6.4	3,980	\$4,467			398	6.4	64.6	121.2	\$0.1935	\$1.128		\$0.000
Police Station		42,336	\$11,967	\$2.64	1,264.8	\$76,000	\$94,719	\$94,719	2.5	3.6	16,011	\$1,248			1,601	3.6	37.8	84.3	\$0.1644	\$1.077		\$0.000
Callahan Senior Center		27,724	\$53,954	\$2.18	830.4	\$28,720	\$43,015	\$43,015	2.8	8.4	10,013	\$10,939			1,001	8.4	40.5	69.3	\$0.2061	\$1.092		\$0.000
Pearl Street Garage		2,000	\$15,511	\$7.76	180.8	\$11,420	\$15,911	\$15,911	0.6	4.8	1,629	\$1,993			163	4.8	10.0	16.2	\$0.1394	\$1.000		\$0.000
Animal Control Building		1,400	\$5,573	\$4.13		16,987	\$5,381	\$5,381	0.0	13.1					0	13.1	125.3	169.2	\$0.1990	\$2.223		\$0.000
Edgell Library		4,500	\$23,131	\$5.14		22,398	\$1,366	\$1,366	0.0	5.0					811	5.0	180.3	197.3	\$0.1949	\$2.000		\$3.208
Academy Building		4,515	\$7,517	\$1.66		15,351	\$4,364	\$4,364	0.0	3.4					274	3.4	60.7	72.3	\$0.1951	\$1.150		\$0.000
Park Department Headquarters		6,800	\$12,643	\$1.86	203.4	48,508	\$9,477	\$9,477	2.6	7.5	2,759	\$3,166			276	7.5	42.4	67.9	\$0.1951	\$1.148		\$0.000
Barbieri Elementary School		11,200	\$215,442	\$1.92		92,1240	\$184,700	\$184,700	0.0	8.2	39,925	\$33,732			3,993	8.2	35.6	63.7	\$0.2005	\$2.000		\$0.000
Brophy Elementary School		68,000	\$68,706	\$1.01		239,256	\$45,087	\$45,087	0.0	3.5	30,790	\$25,708			3,079	3.5	45.3	57.3	\$0.1884	\$2.000		\$0.000
Cameron Middle School		114,000	\$186,694	\$1.64		642,112	\$158,900	\$158,900	0.0	5.6	36,097	\$27,795			3,610	5.6	31.7	50.9	\$0.2044	\$2.000		\$0.000
Dunning Elementary School		61,500	\$49,899	\$0.81		140,440	\$25,419	\$25,419	0.0	2.3	31,793	\$24,481			3,179	2.3	51.7	59.5	\$0.1810	\$2.000		\$0.000
Framingham High School		396,000	\$565,640	\$1.43		2,286,960	\$464,138	\$464,138	0.0	5.8	131,795	\$101,482			13,180	5.8	33.3	51.7	\$0.2030	\$2.000		\$0.000
Henriway Elementary School		61,500	\$58,655	\$0.96		172,441	\$35,942	\$35,942	0.0	2.8	33,783	\$26,013			3,378	2.8	26.9	44.5	\$0.1910	\$2.000		\$0.000
Jupiter Hill Elementary School		44,300	\$27,665	\$0.62		115,749	\$25,571	\$25,571	0.0	2.6	24,785	\$19,984			2,479	2.6	25.9	36.9	\$0.2036	\$2.000		\$0.000
King Administration Building		50,000	\$75,141	\$1.50		186,784	\$37,785	\$37,785	0.0	3.7	48,513	\$37,555			4,851	3.7	67.0	109.8	\$0.2023	\$2.000		\$0.000
McCarty Elementary School		55,516	\$160,241	\$1.67		626,712	\$120,935	\$120,935	0.0	6.2	51,047	\$39,306			5,105	6.2	52.2	72.5	\$0.1930	\$2.000		\$0.000
Peter Road Elementary School		65,600	\$46,602	\$0.73		169,560	\$32,681	\$32,681	0.0	2.7	17,559	\$13,520			1,756	2.7	27.6	36.7	\$0.1927	\$2.000		\$0.000
Shapleton Elementary School		57,600	\$62,948	\$1.06		164,288	\$32,684	\$32,684	0.0	2.8	38,862	\$29,624			3,886	2.8	65.2	74.6	\$0.2008	\$2.000		\$0.000
Thayer Elementary School		10,800	\$17,661	\$0.71		19,800	\$5,693	\$5,693	0.0	1.8	5,153	\$3,988			515	1.8	47.7	50.0	\$0.1865	\$2.000		\$0.000
Walsh Middle School		201,000	\$176,587	\$0.88		552,604	\$12,853	\$12,853	0.0	2.8	82,771	\$55,754			8,277	2.8	41.2	50.9	\$0.1971	\$2.000		\$0.000
Woodrow Wilson Elementary		14,695	\$155,446	\$1.10		22,660	\$12,553	\$12,553	0.0	3.8	36,246	\$27,499			3,625	3.8	25.8	38.6	\$0.2047	\$2.000		\$0.000
DPW Headquarters		72,658	\$166,139	\$2.26	1,915.4	669,732	\$125,507	\$125,507	2.2	9.1	35,053	\$30,517			3,505	9.1	51.7	82.7	\$0.1876	\$1.165		\$0.000
Henry Street Garage		6,134	\$21,554	\$3.51	1,167.1	42,455	\$7,399	\$7,399	1.6	6.9	7,549	\$14,155			750	6.9	123.1	146.7	\$0.1745	\$1.875		\$0.000
Sanitation Department - Upper		7,220	\$40,664	\$10.24			\$47,712	\$47,712	8.5	51.2	1,498	\$2,983			0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
Sanitation Department - Lower		7,220	\$40,664	\$10.24			\$47,712	\$47,712	8.5	51.2	1,498	\$2,983			0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
Sanitation Department - Lower		7,220	\$40,664	\$10.24			\$47,712	\$47,712	8.5	51.2	1,498	\$2,983			0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0	0.0	\$0.1852	\$3.992		\$0.000
DPW Office		5,040	\$10,000	\$2.00			\$10,000	\$10,000	0.0	0.0					0	0.0	0.0					

## Utility Baseline Backup Information

This page is intentionally left blank.



**Town of Framingham**  
Utility Data Summary

Fiscal Year 2011

		Weather		Electric										#2 Fuel Oil				Natural Gas			Total	
Date	HDD	kW	Peak kWh	Off-Peak kWh	Total kWh	Deliv \$	Sup \$	Off-Peak \$	Total \$	\$/Peak kWh	Off-Peak kWh	\$/kWh Blended	Gallons	\$	\$/Gal	Therms	\$	\$/Therm	MMBtu	Total	Total	
Jul-10	2	911	677,738	47,163	724,901	42,814	127,435	4,601	\$174,849	\$0.1880	\$0.0976	\$0.2412	0	\$0	\$0.0000	3,272	\$2,996	0.9157	327	\$177,845	\$	
Aug-10	3	885	653,098	31,489	684,587	45,888	111,589	3,072	\$160,549	\$0.1709	\$0.0976	\$0.2345	0	\$0	\$0.0000	3,153	\$2,865	0.9087	315	\$163,414	\$	
Sep-10	34	901	802,053	31,324	833,377	48,846	156,590	3,056	\$208,491	\$0.1952	\$0.0976	\$0.2502	0	\$0	\$0.0000	4,038	\$3,591	0.8892	404	\$212,082	\$	
Oct-10	211	743	841,616	29,751	871,367	33,779	145,457	2,902	\$182,138	\$0.1728	\$0.0976	\$0.2090	289	\$783	\$2.7060	25,041	\$20,324	0.8116	2,544	\$203,245	\$	
Nov-10	466	705	862,942	35,879	898,821	26,011	135,916	3,500	\$165,426	\$0.1575	\$0.0976	\$0.1840	519	\$1,449	\$2.7895	67,176	\$55,199	0.8217	6,790	\$222,073	\$	
Dec-10	955	719	901,969	39,108	941,077	23,576	132,055	3,815	\$159,446	\$0.1464	\$0.0976	\$0.1694	1,194	\$3,429	\$2.8727	138,067	\$115,859	0.8392	13,972	\$278,734	\$	
Jan-11	1,033	752	848,028	40,557	888,585	26,859	127,351	3,926	\$158,166	\$0.1502	\$0.0976	\$0.1780	1,061	\$3,233	\$3.0468	165,986	\$142,150	0.8564	16,746	\$303,549	\$	
Feb-11	1,185	735	958,982	40,244	999,226	27,901	140,429	3,956	\$172,256	\$0.1464	\$0.0976	\$0.1724	1,006	\$3,243	\$3.3215	161,234	\$139,150	0.8630	16,263	\$314,748	\$	
Mar-11	826	700	854,607	42,113	896,720	25,195	128,257	4,108	\$157,560	\$0.1501	\$0.0976	\$0.1757	1,116	\$3,997	\$3.5825	116,369	\$99,883	0.8583	11,792	\$261,440	\$	
Apr-11	599	688	896,848	31,082	927,930	25,065	132,366	3,032	\$160,452	\$0.1476	\$0.0976	\$0.1729	386	\$1,477	\$3.8260	73,810	\$63,318	0.8579	7,435	\$225,248	\$	
May-11	344	753	745,836	21,899	767,735	24,887	122,111	2,136	\$149,134	\$0.1637	\$0.0976	\$0.1943	279	\$1,055	\$3.7830	29,548	\$25,491	0.8627	2,993	\$175,680	\$	
Jun-11	62	927	906,463	30,892	937,355	37,668	157,559	3,014	\$198,241	\$0.1738	\$0.0976	\$0.2115	0	\$0	\$0.0000	8,136	\$7,194	0.8842	814	\$205,435	\$	
Totals	5,719	9,420	9,950,180	421,501	10,371,681	\$388,478	\$1,617,113	\$41,117	\$2,046,709	\$0.1625	\$0.0976	\$0.1973	5,850	\$18,764	\$3.2075	795,830	\$678,019	\$0.8520	80,394	\$2,743,492	\$	



**Town of Framingham**  
Utility Data Summary - Town Buildings

Fiscal Year 2011

Date	Weather		Electric					#2 Fuel Oil			Natural Gas			Total	Total
	HDD	kW	Peak kWh	Off-Peak kWh	Total kWh	Deliv \$	Sup \$	Off-Peak \$	Total \$	\$/kWh Blended	Gallons	\$	\$/Therm	MMBtu	\$
Jul-10	2	911	294,627	47,163	341,790	33,168	28,741	4,601	\$66,510	\$0.1946	0	\$0	\$0.0000	77	\$67,578
Aug-10	3	885	304,617	31,489	336,106	36,219	29,715	3,072	\$69,006	\$0.2053	0	\$0	\$0.0000	54	\$69,861
Sep-10	34	901	268,675	31,324	299,999	35,493	26,209	3,056	\$64,758	\$0.2159	0	\$0	\$0.0000	80	\$65,858
Oct-10	211	743	225,645	29,751	255,396	23,442	22,012	2,902	\$48,356	\$0.1893	289	\$783	\$2.7060	448	\$53,323
Nov-10	466	705	243,737	35,879	279,616	18,344	23,777	3,500	\$45,621	\$0.1632	519	\$1,449	\$2.7895	1,242	\$59,554
Dec-10	955	719	246,076	39,108	285,184	18,210	24,005	3,815	\$46,030	\$0.1614	1,194	\$3,429	\$2.8727	3,071	\$81,380
Jan-11	1,033	752	279,808	40,557	320,365	20,609	27,295	3,956	\$51,861	\$0.1619	1,061	\$3,233	\$3.0468	4,254	\$101,055
Feb-11	1,185	735	278,717	40,244	318,961	20,755	27,189	3,926	\$51,870	\$0.1626	1,006	\$3,342	\$3.3215	4,335	\$102,515
Mar-11	826	700	246,623	42,113	288,736	18,967	24,058	4,108	\$47,133	\$0.1632	1,116	\$3,997	\$3.5825	2,940	\$82,857
Apr-11	599	688	266,738	31,082	297,820	19,032	26,020	3,032	\$48,084	\$0.1615	386	\$1,477	\$3.8260	1,729	\$68,948
May-11	344	753	222,464	21,899	244,363	18,972	21,701	2,136	\$42,810	\$0.1752	279	\$1,055	\$3.7830	972	\$53,788
Jun-11	62	927	286,647	30,892	317,539	30,432	27,962	3,014	\$61,408	\$0.1934	0	\$0	\$0.0000	280	\$64,493
<b>Totals</b>	<b>5,719</b>	<b>9,420</b>	<b>3,164,374</b>	<b>421,501</b>	<b>3,585,875</b>	<b>\$293,645</b>	<b>\$308,685</b>	<b>\$41,117</b>	<b>\$643,447</b>	<b>\$0.1794</b>	<b>5,850</b>	<b>\$18,764</b>	<b>\$3.2075</b>	<b>19,483</b>	<b>\$871,209</b>

## Town of Framingham

### Utility Data Summary - School Buildings

Fiscal Year 2011

Date	Weather		Electric		Natural Gas			Total	Total
	HDD	Total kWh	Total \$	\$/kWh Blended	Therms	\$	\$/Therm	MMBtu	\$
Jul-10	2	383,111	\$ 108,339	\$0.2828	2,504	\$ 1,928	0.7700	250	\$110,267
Aug-10	3	348,481	\$ 91,543	\$0.2627	2,611	\$ 2,010	0.7700	261	\$93,553
Sep-10	34	533,378	\$ 143,733	\$0.2695	3,234	\$ 2,490	0.7700	323	\$146,223
Oct-10	211	615,971	\$ 133,782	\$0.2172	20,960	\$ 16,139	0.7700	2,096	\$149,921
Nov-10	466	619,205	\$ 119,806	\$0.1935	55,473	\$ 42,714	0.7700	5,547	\$162,520
Dec-10	955	655,893	\$ 113,416	\$0.1729	109,011	\$ 83,938	0.7700	10,901	\$197,355
Jan-11	1,033	568,220	\$ 106,305	\$0.1871	124,921	\$ 96,189	0.7700	12,492	\$202,494
Feb-11	1,185	680,265	\$ 120,386	\$0.1770	119,282	\$ 91,847	0.7700	11,928	\$212,233
Mar-11	826	607,984	\$ 110,426	\$0.1816	88,515	\$ 68,157	0.7700	8,852	\$178,583
Apr-11	599	630,110	\$ 112,368	\$0.1783	57,054	\$ 43,932	0.7700	5,705	\$156,300
May-11	344	523,372	\$ 106,325	\$0.2032	20,217	\$ 15,567	0.7700	2,022	\$121,892
Jun-11	62	619,816	\$ 136,832	\$0.2208	5,337	\$ 4,109	0.7700	534	\$140,942
<b>Totals</b>	<b>5,719</b>	<b>6,785,806</b>	<b>\$1,403,262</b>	<b>\$0.2068</b>	<b>609,119</b>	<b>\$469,022</b>	<b>\$0.7700</b>	<b>60,912</b>	<b>\$1,872,283</b>



**Town of Framingham**  
**Utility Data Summary - Memorial Building**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	166	48,240	\$6,369	\$4,706	\$11,075	\$0.23	189	\$206	\$1.09	19	\$11,281
Aug-10	3	151	52,680	\$6,083	\$5,139	\$11,222	\$0.21	0	\$30	\$0.00	0	\$11,252
Sep-10	34	154	47,400	\$6,026	\$4,624	\$10,650	\$0.22	0	\$30	\$0.00	0	\$10,680
Oct-10	211	126	42,600	\$3,959	\$4,156	\$8,115	\$0.19	208	\$224	\$1.08	21	\$8,338
Nov-10	466	126	44,880	\$2,838	\$4,378	\$7,216	\$0.16	2,218	\$2,261	\$1.02	222	\$9,477
Dec-10	955	131	45,360	\$2,919	\$4,425	\$7,344	\$0.16	7,853	\$8,267	\$1.05	785	\$15,612
Jan-11	1,033	150	50,880	\$3,435	\$4,963	\$8,399	\$0.17	9,310	\$9,985	\$1.07	931	\$18,383
Feb-11	1,185	131	48,840	\$3,219	\$4,764	\$7,983	\$0.16	9,505	\$10,276	\$1.08	951	\$18,259
Mar-11	826	121	44,160	\$2,942	\$4,308	\$7,250	\$0.16	5,734	\$6,211	\$1.08	573	\$13,461
Apr-11	599	113	58,800	\$3,251	\$5,736	\$8,987	\$0.15	3,347	\$3,638	\$1.09	335	\$12,625
May-11	344	113	34,200	\$2,528	\$3,336	\$5,864	\$0.17	28	\$58	\$2.07	3	\$5,922
Jun-11	62	160	46,920	\$4,871	\$4,577	\$9,448	\$0.20	0	\$30	\$0.00	0	\$9,478
<b>Totals</b>	<b>5,719</b>	<b>1,640</b>	<b>564,960</b>	<b>\$48,441</b>	<b>\$55,112</b>	<b>\$103,553</b>	<b>\$0.18</b>	<b>38,392</b>	<b>\$41,217</b>	<b>\$1.07</b>	<b>3,839</b>	<b>\$144,770</b>



**Town of Framingham**  
**Utility Data Summary - Main Library Building**

Fiscal Year 2011

Date	Weather		Electric						Natural Gas		Total	Total
	HDD	kW	Peak kWh	Off-Peak kWh	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	MMBtu	\$
Jul-10	2	169	27,647	40,273	67,920	\$5,319	\$2,697	\$11,944	\$0.18	0	0	\$11,975
Aug-10	3	170	25,117	25,043	50,160	\$5,189	\$2,450	\$10,082	\$0.20	0	0	\$10,112
Sep-10	34	171	24,302	24,478	48,780	\$5,212	\$2,371	\$9,971	\$0.20	0	0	\$10,001
Oct-10	211	154	29,053	23,207	52,260	\$4,067	\$2,834	\$9,165	\$0.18	1,264	126	\$10,373
Nov-10	466	127	28,756	20,024	48,780	\$3,180	\$2,805	\$7,939	\$0.16	2,159	216	\$10,135
Dec-10	955	111	22,157	16,843	39,000	\$2,798	\$2,161	\$6,602	\$0.17	3,739	374	\$10,554
Jan-11	1,033	105	21,831	17,649	39,480	\$2,789	\$2,130	\$6,640	\$0.17	4,467	447	\$11,438
Feb-11	1,185	103	21,870	17,490	39,360	\$2,572	\$2,133	\$6,412	\$0.16	4,206	421	\$10,976
Mar-11	826	99	22,372	19,328	41,700	\$2,530	\$2,182	\$6,598	\$0.16	3,127	313	\$9,999
Apr-11	599	98	21,815	16,525	38,340	\$2,465	\$2,128	\$6,205	\$0.16	1,991	199	\$8,382
May-11	344	146	25,691	15,169	40,860	\$3,675	\$2,506	\$7,661	\$0.19	851	85	\$8,546
Jun-11	62	210	27,845	23,815	51,660	\$5,933	\$2,716	\$10,972	\$0.21	422	42	\$11,408
<b>Totals</b>	<b>5,719</b>	<b>1,663</b>	<b>298,456</b>	<b>259,844</b>	<b>558,300</b>	<b>\$45,729</b>	<b>\$29,114</b>	<b>\$100,191</b>	<b>\$0.18</b>	<b>22,226</b>	<b>2,223</b>	<b>\$123,898</b>



**Town of Framingham**  
**Utility Data Summary - Fire Department Headquarters**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	61	25,040	\$2,342	\$2,443	\$4,784	\$0.19	129	\$150	\$1.17	13	\$4,935
Aug-10	3	63	27,280	\$2,518	\$2,661	\$5,179	\$0.19	110	\$133	\$1.21	11	\$5,312
Sep-10	34	64	24,560	\$2,474	\$2,396	\$4,870	\$0.20	144	\$164	\$1.14	14	\$5,035
Oct-10	211	58	19,200	\$1,695	\$1,873	\$3,568	\$0.19	511	\$506	\$0.99	51	\$4,074
Nov-10	466	50	19,360	\$1,094	\$1,889	\$2,982	\$0.15	1,341	\$1,379	\$1.03	134	\$4,361
Dec-10	955	42	20,240	\$1,001	\$1,974	\$2,975	\$0.15	2,983	\$3,159	\$1.06	298	\$6,135
Jan-11	1,033	49	22,320	\$1,200	\$2,177	\$3,378	\$0.15	4,081	\$4,381	\$1.07	408	\$7,759
Feb-11	1,185	49	22,480	\$1,257	\$2,193	\$3,450	\$0.15	4,286	\$4,650	\$1.08	429	\$8,100
Mar-11	826	44	18,960	\$1,084	\$1,850	\$2,934	\$0.15	3,334	\$3,624	\$1.09	333	\$6,558
Apr-11	599	41	19,440	\$1,052	\$1,896	\$2,948	\$0.15	2,247	\$2,452	\$1.09	225	\$5,401
May-11	344	55	19,840	\$1,272	\$1,935	\$3,208	\$0.16	1,332	\$1,363	\$1.02	133	\$4,571
Jun-11	62	62	23,120	\$1,914	\$2,255	\$4,170	\$0.18	278	\$297	\$1.07	28	\$4,467
<b>Totals</b>	<b>5,719</b>	<b>636</b>	<b>261,840</b>	<b>\$18,905</b>	<b>\$25,542</b>	<b>\$44,447</b>	<b>\$0.17</b>	<b>20,776</b>	<b>\$22,260</b>	<b>\$1.07</b>	<b>2,078</b>	<b>\$66,707</b>



**Town of Framingham**  
**Utility Data Summary - Engine #1**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	24	11,170	\$772	\$1,090	\$1,862	\$0.17	93	\$117	\$1.26	9	\$1,979
Aug-10	3	22	11,256	\$752	\$1,098	\$1,850	\$0.16	93	\$117	\$1.26	9	\$1,967
Sep-10	34	23	9,827	\$735	\$959	\$1,694	\$0.17	136	\$157	\$1.15	14	\$1,851
Oct-10	211	19	7,848	\$475	\$766	\$1,241	\$0.16	502	\$498	\$0.99	50	\$1,738
Nov-10	466	18	7,546	\$333	\$736	\$1,070	\$0.14	882	\$912	\$1.03	88	\$1,981
Dec-10	955	16	7,247	\$304	\$707	\$1,011	\$0.14	1,570	\$1,677	\$1.07	157	\$2,688
Jan-11	1,033	19	7,900	\$380	\$771	\$1,151	\$0.15	1,708	\$1,854	\$1.09	171	\$3,005
Feb-11	1,185	17	7,923	\$363	\$773	\$1,136	\$0.14	2,115	\$2,310	\$1.09	212	\$3,446
Mar-11	826	17	6,957	\$345	\$679	\$1,024	\$0.15	1,302	\$1,434	\$1.10	130	\$2,457
Apr-11	599	17	7,425	\$349	\$724	\$1,073	\$0.14	1,338	\$1,473	\$1.10	134	\$2,546
May-11	344	16	7,363	\$341	\$718	\$1,059	\$0.14	741	\$772	\$1.04	74	\$1,831
Jun-11	62	21	8,413	\$535	\$821	\$1,355	\$0.16	199	\$221	\$1.11	20	\$1,577
<b>Totals</b>	<b>5,719</b>	<b>228</b>	<b>100,875</b>	<b>\$5,686</b>	<b>\$9,840</b>	<b>\$15,527</b>	<b>\$0.15</b>	<b>10,679</b>	<b>\$11,541</b>	<b>\$1.08</b>	<b>1,068</b>	<b>\$27,067</b>



**Town of Framingham**  
**Utility Data Summary - Engine #2**

Fiscal Year 2011

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	1	4,798	\$530	\$468	\$998	\$0.21	29	\$44	\$1.52	3	\$1,042
Aug-10	3	1	3,323	\$377	\$324	\$701	\$0.21	24	\$39	\$1.63	2	\$740
Sep-10	34	1	2,713	\$312	\$265	\$576	\$0.21	29	\$44	\$1.52	3	\$620
Oct-10	211	1	2,616	\$258	\$255	\$513	\$0.20	46	\$61	\$1.32	5	\$574
Nov-10	466	1	2,326	\$205	\$227	\$432	\$0.19	173	\$195	\$1.13	17	\$627
Dec-10	955	0	2,795	\$242	\$273	\$515	\$0.18	417	\$463	\$1.11	42	\$977
Jan-11	1,033	2	2,967	\$264	\$289	\$553	\$0.19	596	\$665	\$1.12	60	\$1,218
Feb-11	1,185	1	2,862	\$260	\$279	\$539	\$0.19	707	\$794	\$1.12	71	\$1,334
Mar-11	826	1	2,574	\$236	\$251	\$487	\$0.19	476	\$540	\$1.13	48	\$1,027
Apr-11	599	2	2,314	\$214	\$226	\$440	\$0.19	262	\$304	\$1.16	26	\$744
May-11	344	3	2,428	\$224	\$237	\$461	\$0.19	102	\$123	\$1.21	10	\$584
Jun-11	62	3	2,447	\$264	\$239	\$503	\$0.21	37	\$53	\$1.44	4	\$556
<b>Totals</b>	<b>5,719</b>	<b>18</b>	<b>34,163</b>	<b>\$3,386</b>	<b>\$3,333</b>	<b>\$6,718</b>	<b>\$0.20</b>	<b>2,898</b>	<b>\$3,325</b>	<b>\$1.15</b>	<b>290</b>	<b>\$10,043</b>



**Town of Framingham**  
**Utility Data Summary - Engine #5**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	25	9,827	\$776	\$959	\$1,735	\$0.18	46	\$61	\$1.32	5	\$1,796
Aug-10	3	26	10,308	\$834	\$1,006	\$1,839	\$0.18	39	\$54	\$1.38	4	\$1,893
Sep-10	34	24	7,950	\$707	\$776	\$1,482	\$0.19	55	\$70	\$1.27	6	\$1,552
Oct-10	211	17	4,744	\$333	\$463	\$795	\$0.17	185	\$199	\$1.07	19	\$994
Nov-10	466	16	4,375	\$227	\$427	\$654	\$0.15	679	\$722	\$1.06	68	\$1,376
Dec-10	955	15	4,297	\$218	\$419	\$637	\$0.15	1,124	\$1,221	\$1.09	112	\$1,858
Jan-11	1,033	16	4,992	\$253	\$487	\$739	\$0.15	1,505	\$1,657	\$1.10	151	\$2,397
Feb-11	1,185	17	4,848	\$282	\$473	\$754	\$0.16	1,611	\$1,790	\$1.11	161	\$2,545
Mar-11	826	15	4,100	\$223	\$400	\$623	\$0.15	1,214	\$1,353	\$1.11	121	\$1,976
Apr-11	599	18	4,250	\$269	\$415	\$684	\$0.16	720	\$809	\$1.12	72	\$1,492
May-11	344	14	3,900	\$210	\$380	\$590	\$0.15	216	\$242	\$1.12	22	\$833
Jun-11	62	21	5,990	\$465	\$584	\$1,049	\$0.18	112	\$130	\$1.16	11	\$1,179
<b>Totals</b>	<b>5,719</b>	<b>221</b>	<b>69,581</b>	<b>\$4,797</b>	<b>\$6,788</b>	<b>\$11,584</b>	<b>\$0.17</b>	<b>7,506</b>	<b>\$8,307</b>	<b>\$1.11</b>	<b>751</b>	<b>\$19,891</b>

**Town of Framingham**  
**Utility Data Summary - Engine #7**

Fiscal Year 2011

Date	Weather		Electric				Natural Gas			Total	
	HDD	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total
Jul-10	2	3,538	\$384	\$345	\$729	\$0.21	26	\$41	\$1.58	3	\$770
Aug-10	3	3,080	\$339	\$300	\$639	\$0.21	26	\$41	\$1.58	3	\$680
Sep-10	34	2,757	\$304	\$269	\$573	\$0.21	24	\$39	\$1.63	2	\$612
Oct-10	211	2,035	\$194	\$199	\$392	\$0.19	113	\$127	\$1.13	11	\$519
Nov-10	466	2,017	\$168	\$197	\$365	\$0.18	303	\$330	\$1.09	30	\$695
Dec-10	955	2,147	\$179	\$209	\$388	\$0.18	591	\$649	\$1.10	59	\$1,037
Jan-11	1,033	2,393	\$204	\$233	\$438	\$0.18	824	\$913	\$1.11	82	\$1,351
Feb-11	1,185	2,273	\$199	\$222	\$421	\$0.19	837	\$938	\$1.12	84	\$1,358
Mar-11	826	2,037	\$179	\$199	\$378	\$0.19	590	\$665	\$1.13	59	\$1,043
Apr-11	599	2,022	\$178	\$197	\$375	\$0.19	416	\$474	\$1.14	42	\$849
May-11	344	1,630	\$145	\$159	\$304	\$0.19	157	\$181	\$1.15	16	\$484
Jun-11	62	2,316	\$238	\$226	\$464	\$0.20	73	\$90	\$1.23	7	\$554
<b>Totals</b>	<b>5,719</b>	<b>28,245</b>	<b>\$2,711</b>	<b>\$2,755</b>	<b>\$5,466</b>	<b>\$0.19</b>	<b>3,980</b>	<b>\$4,487</b>	<b>\$1.13</b>	<b>398</b>	<b>\$9,953</b>



**Town of Framingham**  
**Utility Data Summary - Police Station**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	149	67,440	\$2,528	\$6,579	\$9,106	\$0.14	84	\$108	\$1.29	8	\$9,215
Aug-10	3	149	71,760	\$6,495	\$7,000	\$13,495	\$0.19	74	\$99	\$1.34	7	\$13,594
Sep-10	34	151	60,960	\$6,296	\$5,947	\$12,243	\$0.20	145	\$165	\$1.14	15	\$12,408
Oct-10	211	96	45,600	\$3,305	\$4,448	\$7,753	\$0.17	305	\$314	\$1.03	31	\$8,067
Nov-10	466	84	40,320	\$2,119	\$3,933	\$6,052	\$0.15	868	\$903	\$1.04	87	\$6,955
Dec-10	955	91	37,680	\$2,156	\$3,676	\$5,831	\$0.15	2,442	\$2,592	\$1.06	244	\$8,423
Jan-11	1,033	67	37,680	\$1,882	\$3,676	\$5,558	\$0.15	3,140	\$3,388	\$1.08	314	\$8,946
Feb-11	1,185	72	38,640	\$2,068	\$3,769	\$5,837	\$0.15	3,544	\$3,850	\$1.09	354	\$9,688
Mar-11	826	72	34,560	\$1,948	\$3,371	\$5,319	\$0.15	2,367	\$2,582	\$1.09	237	\$7,901
Apr-11	599	72	39,360	\$2,089	\$3,840	\$5,929	\$0.15	1,739	\$1,905	\$1.10	174	\$7,834
May-11	344	127	44,160	\$3,029	\$4,308	\$7,337	\$0.17	1,008	\$1,028	\$1.02	101	\$8,365
Jun-11	62	134	57,840	\$4,615	\$5,642	\$10,258	\$0.18	295	\$314	\$1.06	30	\$10,571
<b>Totals</b>	<b>5,719</b>	<b>1,265</b>	<b>576,000</b>	<b>\$38,530</b>	<b>\$56,189</b>	<b>\$94,719</b>	<b>\$0.16</b>	<b>16,011</b>	<b>\$17,248</b>	<b>\$1.08</b>	<b>1,601</b>	<b>\$111,967</b>



**Town of Framingham**  
**Utility Data Summary - Callahan Senior Center**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	106	19,520	\$3,716	\$1,904	\$5,621	\$0.29	21	\$50	\$2.37	2	\$5,670
Aug-10	3	88	19,920	\$3,149	\$1,943	\$5,092	\$0.26	2	\$32	\$16.05	0	\$5,124
Sep-10	34	98	18,080	\$3,445	\$1,764	\$5,209	\$0.29	48	\$75	\$1.56	5	\$5,284
Oct-10	211	77	14,800	\$2,051	\$1,444	\$3,494	\$0.24	194	\$211	\$1.09	19	\$3,705
Nov-10	466	52	14,960	\$1,017	\$1,459	\$2,477	\$0.17	775	\$808	\$1.04	78	\$3,284
Dec-10	955	51	15,760	\$1,026	\$1,537	\$2,563	\$0.16	1,468	\$1,570	\$1.07	147	\$4,133
Jan-11	1,033	46	18,160	\$1,053	\$1,772	\$2,824	\$0.16	1,871	\$2,027	\$1.08	187	\$4,851
Feb-11	1,185	50	18,960	\$1,177	\$1,850	\$3,026	\$0.16	2,356	\$2,570	\$1.09	236	\$5,596
Mar-11	826	50	16,880	\$1,104	\$1,647	\$2,751	\$0.16	1,585	\$1,739	\$1.10	159	\$4,490
Apr-11	599	65	18,240	\$1,364	\$1,779	\$3,143	\$0.17	1,028	\$1,138	\$1.11	103	\$4,282
May-11	344	59	15,040	\$1,189	\$1,467	\$2,656	\$0.18	445	\$478	\$1.07	45	\$3,134
Jun-11	62	87	18,400	\$2,363	\$1,795	\$4,158	\$0.23	220	\$242	\$1.10	22	\$4,399
<b>Totals</b>	<b>5,719</b>	<b>830</b>	<b>208,720</b>	<b>\$22,654</b>	<b>\$20,361</b>	<b>\$43,015</b>	<b>\$0.21</b>	<b>10,013</b>	<b>\$10,939</b>	<b>\$1.09</b>	<b>1,001</b>	<b>\$53,954</b>

**Town of Framingham**  
**Utility Data Summary - Pearl Street Garage**

**Fiscal Year 2011**

Date	Weather		Electric					Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	\$	
Jul-10	2	14	8,480	\$393	\$827	\$1,220	\$0.14	\$1,220	
Aug-10	3	13	8,760	\$387	\$855	\$1,242	\$0.14	\$1,242	
Sep-10	34	14	8,800	\$401	\$858	\$1,260	\$0.14	\$1,260	
Oct-10	211	15	8,880	\$390	\$866	\$1,256	\$0.14	\$1,256	
Nov-10	466	16	9,960	\$373	\$972	\$1,344	\$0.13	\$1,344	
Dec-10	955	16	9,840	\$370	\$960	\$1,330	\$0.14	\$1,330	
Jan-11	1,033	16	10,280	\$395	\$1,003	\$1,397	\$0.14	\$1,397	
Feb-11	1,185	17	10,320	\$437	\$1,007	\$1,443	\$0.14	\$1,443	
Mar-11	826	16	9,280	\$389	\$905	\$1,294	\$0.14	\$1,294	
Apr-11	599	16	10,240	\$417	\$999	\$1,416	\$0.14	\$1,416	
May-11	344	15	9,800	\$392	\$956	\$1,348	\$0.14	\$1,348	
Jun-11	62	15	9,480	\$435	\$925	\$1,360	\$0.14	\$1,360	
<b>Totals</b>	<b>5,719</b>	<b>181</b>	<b>114,120</b>	<b>\$4,778</b>	<b>\$11,132</b>	<b>\$15,911</b>	<b>\$0.14</b>	<b>\$15,911</b>	

**Town of Framingham**  
**Utility Data Summary - Animal Control Building**

Fiscal Year 2011

Date	Weather		Electric				Natural Gas			Total	
	HDD	Peak kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total
Jul-10	2	3,218	\$351	\$314	\$665	\$0.21	0	\$15	\$0.00	0	\$680
Aug-10	3	2,602	\$288	\$254	\$541	\$0.21	0	\$15	\$0.00	0	\$557
Sep-10	34	2,038	\$227	\$199	\$426	\$0.21	0	\$15	\$0.00	0	\$441
Oct-10	211	1,097	\$106	\$107	\$213	\$0.19	27	\$27	\$1.00	3	\$239
Nov-10	466	924	\$82	\$90	\$172	\$0.19	117	\$118	\$1.00	12	\$289
Dec-10	955	964	\$85	\$94	\$179	\$0.19	262	\$311	\$1.19	26	\$490
Jan-11	1,033	974	\$88	\$95	\$183	\$0.19	366	\$435	\$1.19	37	\$618
Feb-11	1,185	1,052	\$96	\$103	\$199	\$0.19	357	\$429	\$1.20	36	\$628
Mar-11	826	1,002	\$92	\$98	\$190	\$0.19	273	\$332	\$1.21	27	\$522
Apr-11	599	887	\$83	\$87	\$169	\$0.19	184	\$229	\$1.24	18	\$398
May-11	344	818	\$77	\$80	\$157	\$0.19	33	\$44	\$1.34	3	\$201
Jun-11	62	1,411	\$150	\$138	\$288	\$0.20	10	\$23	\$2.27	1	\$310
<b>Totals</b>	<b>5,719</b>	<b>16,987</b>	<b>\$1,723</b>	<b>\$1,657</b>	<b>\$3,381</b>	<b>\$0.20</b>	<b>1,629</b>	<b>\$1,993</b>	<b>\$1.22</b>	<b>163</b>	<b>\$5,373</b>

## Town of Framingham Utility Data Summary - Old Edgell Library

Fiscal Year 2011

Date	Weather		Electric					#2 Fuel Oil			Total
	HDD	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Gallons	\$	\$/Gal	\$	\$
Jul-10	2	3,562	\$387	\$347	\$734	\$0.21	0	\$0	\$0.0000	\$734	\$734
Aug-10	3	2,745	\$303	\$268	\$571	\$0.21	0	\$0	\$0.0000	\$571	\$571
Sep-10	34	1,872	\$209	\$183	\$392	\$0.21	0	\$0	\$0.0000	\$392	\$392
Oct-10	211	842	\$85	\$82	\$167	\$0.20	289	\$783	\$2.7060	\$950	\$950
Nov-10	466	1,287	\$110	\$126	\$236	\$0.18	519	\$1,449	\$2.7895	\$1,684	\$1,684
Dec-10	955	1,839	\$154	\$179	\$334	\$0.18	1,194	\$3,429	\$2.8727	\$3,762	\$3,762
Jan-11	1,033	2,146	\$184	\$209	\$393	\$0.18	1,061	\$3,233	\$3.0468	\$3,626	\$3,626
Feb-11	1,185	2,134	\$187	\$208	\$395	\$0.19	1,006	\$3,342	\$3.3215	\$3,737	\$3,737
Mar-11	826	1,759	\$156	\$172	\$327	\$0.19	1,116	\$3,997	\$3.5825	\$4,324	\$4,324
Apr-11	599	1,439	\$129	\$140	\$269	\$0.19	386	\$1,477	\$3.8260	\$1,746	\$1,746
May-11	344	914	\$85	\$89	\$174	\$0.19	279	\$1,055	\$3.7830	\$1,229	\$1,229
Jun-11	62	1,859	\$193	\$181	\$374	\$0.20	0	\$0	\$0.0000	\$374	\$374
<b>Totals</b>	<b>5,719</b>	<b>22,398</b>	<b>\$2,181</b>	<b>\$2,185</b>	<b>\$4,366</b>	<b>\$0.19</b>	<b>5,850</b>	<b>\$18,764</b>	<b>\$3.2075</b>	<b>\$23,131</b>	<b>\$23,131</b>

**Town of Framingham**  
**Utility Data Summary - Academy Building**

**Fiscal Year 2011**

Date	Weather		Electric				Natural Gas				Total	
	HDD	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total	Total
Jul-10	2	2,860	\$566	\$279	\$845	\$0.30	5	\$20	\$4.04	1		\$865
Aug-10	3	2,208	\$434	\$215	\$649	\$0.29	5	\$20	\$4.04	1		\$669
Sep-10	34	1,994	\$392	\$195	\$587	\$0.29	4	\$19	\$4.80	0		\$606
Oct-10	211	1,305	\$238	\$127	\$366	\$0.28	61	\$76	\$1.24	6		\$441
Nov-10	466	699	\$123	\$68	\$191	\$0.27	260	\$285	\$1.10	26		\$477
Dec-10	955	713	\$126	\$70	\$195	\$0.27	437	\$484	\$1.11	44		\$679
Jan-11	1,033	759	\$133	\$74	\$207	\$0.27	548	\$612	\$1.12	55		\$819
Feb-11	1,185	834	\$145	\$81	\$226	\$0.27	550	\$621	\$1.13	55		\$848
Mar-11	826	749	\$131	\$73	\$204	\$0.27	422	\$480	\$1.14	42		\$685
Apr-11	599	857	\$149	\$84	\$233	\$0.27	321	\$369	\$1.15	32		\$602
May-11	344	951	\$164	\$93	\$257	\$0.27	100	\$121	\$1.21	10		\$378
Jun-11	62	1,422	\$264	\$139	\$403	\$0.28	29	\$45	\$1.55	3		\$448
<b>Totals</b>	<b>5,719</b>	<b>15,351</b>	<b>\$2,866</b>	<b>\$1,497</b>	<b>\$4,364</b>	<b>\$0.28</b>	<b>2,742</b>	<b>\$3,153</b>	<b>\$1.15</b>	<b>274</b>		<b>\$7,517</b>

**Town of Framingham**  
**Utility Data Summary - Park Department Headquarters**

Fiscal Year 2011

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Peak kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total
Jul-10	2	21	4,493	\$570	\$438	\$1,008	\$0.22	38	\$53	\$1.39	4	\$1,061
Aug-10	3	22	5,355	\$624	\$522	\$1,146	\$0.21	33	\$48	\$1.45	3	\$1,194
Sep-10	34	21	3,872	\$548	\$378	\$926	\$0.24	38	\$53	\$1.39	4	\$978
Oct-10	211	21	2,304	\$420	\$225	\$645	\$0.28	61	\$76	\$1.24	6	\$721
Nov-10	466	14	3,750	\$912	\$366	\$1,277	\$0.34	178	\$201	\$1.13	18	\$1,478
Dec-10	955	15	4,511	\$222	\$440	\$662	\$0.15	401	\$445	\$1.11	40	\$1,108
Jan-11	1,033	14	4,856	\$227	\$474	\$701	\$0.14	548	\$613	\$1.12	55	\$1,314
Feb-11	1,185	15	5,213	\$266	\$509	\$775	\$0.15	572	\$646	\$1.13	57	\$1,420
Mar-11	826	13	3,697	\$182	\$361	\$543	\$0.15	440	\$500	\$1.14	44	\$1,043
Apr-11	599	12	3,683	\$173	\$359	\$533	\$0.14	280	\$324	\$1.16	28	\$856
May-11	344	14	3,127	\$187	\$305	\$492	\$0.16	117	\$138	\$1.18	12	\$630
Jun-11	62	21	3,707	\$408	\$362	\$769	\$0.21	53	\$69	\$1.31	5	\$839
<b>Totals</b>	<b>5,719</b>	<b>203</b>	<b>48,568</b>	<b>\$4,739</b>	<b>\$4,738</b>	<b>\$9,477</b>	<b>\$0.20</b>	<b>2,759</b>	<b>\$3,166</b>	<b>\$1.15</b>	<b>276</b>	<b>\$12,643</b>

**Town of Framingham**  
**Utility Data Summary - Barberi Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric			Natural Gas			Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total	Total \$
Jul-10	2	55,440	\$15,054	\$0.27	180	\$139	\$0.77	18		\$15,192
Aug-10	3	52,440	\$14,784	\$0.28	164	\$126	\$0.77	16		\$14,911
Sep-10	34	74,040	\$20,575	\$0.28	210	\$162	\$0.77	21		\$20,737
Oct-10	211	70,920	\$17,256	\$0.24	1,528	\$1,177	\$0.77	153		\$18,432
Nov-10	466	68,400	\$14,339	\$0.21	3,034	\$2,336	\$0.77	303		\$16,675
Dec-10	955	76,680	\$12,846	\$0.17	6,660	\$5,128	\$0.77	666		\$17,974
Jan-11	1,033	82,920	\$14,339	\$0.17	8,068	\$6,212	\$0.77	807		\$20,551
Feb-11	1,185	116,160	\$18,477	\$0.16	8,159	\$6,282	\$0.77	816		\$24,760
Mar-11	826	93,360	\$15,335	\$0.16	5,927	\$4,564	\$0.77	593		\$19,899
Apr-11	599	78,720	\$13,702	\$0.17	4,330	\$3,334	\$0.77	433		\$17,036
May-11	344	57,240	\$11,499	\$0.20	1,358	\$1,046	\$0.77	136		\$12,544
Jun-11	62	94,920	\$16,495	\$0.17	307	\$236	\$0.77	31		\$16,731
<b>Totals</b>	<b>5,719</b>	<b>921,240</b>	<b>\$184,700</b>	<b>\$0.20</b>	<b>39,925</b>	<b>\$30,742</b>	<b>\$0.77</b>	<b>3,993</b>		<b>\$215,442</b>

**Town of Framingham**  
**Utility Data Summary - Brophy Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu
Jul-10	2	8,168	\$2,924	\$0.36	90	\$69	\$0.77	9
Aug-10	3	5,768	\$1,174	\$0.20	67	\$52	\$0.77	7
Sep-10	34	12,008	\$3,528	\$0.29	134	\$103	\$0.77	13
Oct-10	211	18,608	\$3,812	\$0.20	1,053	\$811	\$0.77	105
Nov-10	466	24,608	\$3,991	\$0.16	3,228	\$2,486	\$0.77	323
Dec-10	955	25,088	\$4,153	\$0.17	5,413	\$4,168	\$0.77	541
Jan-11	1,033	26,048	\$4,444	\$0.17	5,231	\$4,028	\$0.77	523
Feb-11	1,185	27,968	\$4,802	\$0.17	6,055	\$4,662	\$0.77	606
Mar-11	826	23,288	\$4,104	\$0.18	4,000	\$3,080	\$0.77	400
Apr-11	599	26,768	\$4,458	\$0.17	3,678	\$2,832	\$0.77	368
May-11	344	21,008	\$3,588	\$0.17	1,489	\$1,147	\$0.77	149
Jun-11	62	19,928	\$4,109	\$0.21	352	\$271	\$0.77	35
<b>Totals</b>	<b>5,719</b>	<b>239,256</b>	<b>\$45,087</b>	<b>\$0.19</b>	<b>30,790</b>	<b>\$23,708</b>	<b>\$0.77</b>	<b>3,079</b>
								<b>\$68,796</b>

**Town of Framingham**  
**Utility Data Summary - Cameron Middle School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	MMBtu	\$
Jul-10	2	42,504	\$14,926	\$0.35	134	\$103	13	\$15,029
Aug-10	3	38,520	\$11,545	\$0.30	154	\$119	15	\$11,664
Sep-10	34	58,992	\$18,812	\$0.32	188	\$145	19	\$18,957
Oct-10	211	62,472	\$16,575	\$0.27	1,256	\$967	126	\$17,542
Nov-10	466	60,168	\$15,201	\$0.25	3,681	\$2,834	368	\$18,035
Dec-10	955	59,160	\$10,885	\$0.18	6,197	\$4,772	620	\$15,656
Jan-11	1,033	46,536	\$9,785	\$0.21	6,609	\$5,089	661	\$14,874
Feb-11	1,185	54,216	\$11,019	\$0.20	8,131	\$6,261	813	\$17,280
Mar-11	826	51,048	\$9,920	\$0.19	4,605	\$3,546	461	\$13,466
Apr-11	599	54,864	\$10,712	\$0.20	4,257	\$3,278	426	\$13,989
May-11	344	44,952	\$11,823	\$0.26	587	\$452	59	\$12,275
Jun-11	62	68,880	\$17,698	\$0.26	298	\$229	30	\$17,927
<b>Totals</b>	<b>5,719</b>	<b>642,312</b>	<b>\$158,900</b>	<b>\$0.25</b>	<b>36,097</b>	<b>\$27,795</b>	<b>3,610</b>	<b>\$186,694</b>

# **Town of Framingham** **Utility Data Summary - Dunning Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas			Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	5,080	\$1,606	\$0.32	53	\$41	\$0.77	5	\$1,647
Aug-10	3	4,560	\$692	\$0.15	2	\$2	\$0.77	0	\$694
Sep-10	34	7,560	\$2,130	\$0.28	135	\$104	\$0.77	14	\$2,234
Oct-10	211	11,400	\$2,327	\$0.20	551	\$424	\$0.77	55	\$2,751
Nov-10	466	13,360	\$2,180	\$0.16	2,626	\$2,022	\$0.77	263	\$4,202
Dec-10	955	14,960	\$2,377	\$0.16	5,948	\$4,580	\$0.77	595	\$6,957
Jan-11	1,033	16,000	\$2,518	\$0.16	6,110	\$4,705	\$0.77	611	\$7,223
Feb-11	1,185	16,520	\$2,675	\$0.16	6,519	\$5,020	\$0.77	652	\$7,694
Mar-11	826	13,720	\$2,283	\$0.17	4,640	\$3,573	\$0.77	464	\$5,856
Apr-11	599	14,840	\$2,392	\$0.16	3,645	\$2,807	\$0.77	365	\$5,199
May-11	344	10,760	\$1,909	\$0.18	1,249	\$962	\$0.77	125	\$2,870
Jun-11	62	11,680	\$2,329	\$0.20	315	\$243	\$0.77	32	\$2,571
<b>Totals</b>	<b>5,719</b>	<b>140,440</b>	<b>\$25,419</b>	<b>\$0.18</b>	<b>31,793</b>	<b>\$24,481</b>	<b>\$0.77</b>	<b>3,179</b>	<b>\$49,899</b>

## Town of Framingham

### Utility Data Summary - Framingham High School

Fiscal Year 2011

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu
Jul-10	2	127,680	\$34,666	\$0.27	749	\$577	\$0.77	75
Aug-10	3	119,440	\$31,346	\$0.26	765	\$589	\$0.77	77
Sep-10	34	178,240	\$45,534	\$0.26	980	\$755	\$0.77	98
Oct-10	211	217,320	\$44,278	\$0.20	4,491	\$3,458	\$0.77	449
Nov-10	466	205,440	\$38,092	\$0.19	13,504	\$10,398	\$0.77	1,350
Dec-10	955	231,720	\$39,600	\$0.17	24,236	\$18,662	\$0.77	2,424
Jan-11	1,033	183,840	\$35,256	\$0.19	28,586	\$22,011	\$0.77	2,859
Feb-11	1,185	223,200	\$39,559	\$0.18	25,774	\$19,846	\$0.77	2,577
Mar-11	826	206,960	\$37,480	\$0.18	19,721	\$15,185	\$0.77	1,972
Apr-11	599	212,280	\$38,128	\$0.18	9,378	\$7,221	\$0.77	938
May-11	344	184,120	\$36,385	\$0.20	2,444	\$1,882	\$0.77	244
Jun-11	62	196,720	\$43,835	\$0.22	1,167	\$899	\$0.77	117
<b>Totals</b>	<b>5,719</b>	<b>2,286,960</b>	<b>\$464,158</b>	<b>\$0.20</b>	<b>131,795</b>	<b>\$101,482</b>	<b>\$0.77</b>	<b>13,180</b>
								<b>\$565,640</b>

**Town of Framingham**  
**Utility Data Summary - Hemenway Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	Total
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	MMBtu	\$
Jul-10	2	6,475	\$2,000	\$0.31	189	\$146	19	\$2,146
Aug-10	3	2,977	\$454	\$0.15	182	\$140	18	\$594
Sep-10	34	8,998	\$2,569	\$0.29	227	\$175	23	\$2,743
Oct-10	211	13,888	\$2,838	\$0.20	853	\$657	85	\$3,495
Nov-10	466	16,743	\$2,877	\$0.17	2,795	\$2,152	280	\$5,030
Dec-10	955	18,693	\$3,264	\$0.17	5,732	\$4,414	573	\$7,678
Jan-11	1,033	22,940	\$3,929	\$0.17	7,184	\$5,532	718	\$9,461
Feb-11	1,185	23,317	\$3,978	\$0.17	6,718	\$5,173	672	\$9,151
Mar-11	826	13,791	\$2,657	\$0.19	4,862	\$3,744	486	\$6,400
Apr-11	599	17,309	\$3,034	\$0.18	3,450	\$2,657	345	\$5,691
May-11	344	13,000	\$2,405	\$0.18	1,117	\$860	112	\$3,265
Jun-11	62	14,310	\$2,937	\$0.21	474	\$365	47	\$3,302
<b>Totals</b>	<b>5,719</b>	<b>172,441</b>	<b>\$32,942</b>	<b>\$0.19</b>	<b>33,783</b>	<b>\$26,013</b>	<b>3,378</b>	<b>\$58,955</b>

**Town of Framingham**  
**Utility Data Summary - Juniper Hill Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	MMBtu	\$
Jul-10	2	9,640	\$2,591	\$0.27	107	\$82	11	\$2,673
Aug-10	3	8,364	\$2,143	\$0.26	99	\$76	10	\$2,219
Sep-10	34	8,900	\$2,565	\$0.29	114	\$88	11	\$2,653
Oct-10	211	8,123	\$1,588	\$0.20	551	\$424	55	\$2,012
Nov-10	466	9,622	\$1,678	\$0.17	2,120	\$1,632	212	\$3,311
Dec-10	955	11,804	\$1,921	\$0.16	4,509	\$3,472	451	\$5,393
Jan-11	1,033	10,336	\$1,756	\$0.17	4,402	\$3,390	440	\$5,145
Feb-11	1,185	11,304	\$1,942	\$0.17	5,227	\$4,025	523	\$5,966
Mar-11	826	11,637	\$1,996	\$0.17	3,600	\$2,772	360	\$4,768
Apr-11	599	10,325	\$1,838	\$0.18	2,980	\$2,295	298	\$4,133
May-11	344	7,728	\$1,487	\$0.19	807	\$621	81	\$2,108
Jun-11	62	7,966	\$2,068	\$0.26	269	\$207	27	\$2,275
<b>Totals</b>	<b>5,719</b>	<b>115,749</b>	<b>\$23,571</b>	<b>\$0.20</b>	<b>24,785</b>	<b>\$19,084</b>	<b>2,479</b>	<b>\$42,655</b>

## Town of Framingham

### Utility Data Summary - King Administration Building

Fiscal Year 2011

Date	Weather		Electric			Natural Gas			Total	Total
	HDD	Total kWh	Total \$	\$/kWh	Blended	Therm	\$	\$/Therm	MMBtu	\$
Jul-10	2	12,972	\$3,946		\$0.30	7	\$5	\$0.77	1	\$3,951
Aug-10	3	14,052	\$3,668		\$0.26	29	\$22	\$0.77	3	\$3,691
Sep-10	34	14,652	\$4,647		\$0.32	15	\$12	\$0.77	2	\$4,659
Oct-10	211	13,572	\$2,757		\$0.20	1,672	\$1,287	\$0.77	167	\$4,044
Nov-10	466	17,532	\$2,747		\$0.16	4,189	\$3,226	\$0.77	419	\$5,972
Dec-10	955	16,972	\$2,734		\$0.16	7,721	\$5,945	\$0.77	772	\$8,679
Jan-11	1,033	16,932	\$2,691		\$0.16	10,245	\$7,889	\$0.77	1,025	\$10,579
Feb-11	1,185	18,012	\$2,901		\$0.16	8,904	\$6,856	\$0.77	890	\$9,758
Mar-11	826	15,612	\$2,611		\$0.17	7,670	\$5,906	\$0.77	767	\$8,517
Apr-11	599	17,412	\$2,855		\$0.16	2,419	\$1,863	\$0.77	242	\$4,718
May-11	344	13,092	\$2,237		\$0.17	5,052	\$3,890	\$0.77	505	\$6,127
Jun-11	62	15,972	\$3,991		\$0.25	590	\$454	\$0.77	59	\$4,445
<b>Totals</b>	<b>5,719</b>	<b>186,784</b>	<b>\$37,785</b>		<b>\$0.20</b>	<b>48,513</b>	<b>\$37,355</b>	<b>\$0.77</b>	<b>4,851</b>	<b>\$75,140</b>

## Town of Framingham Utility Data Summary - McCarthy Elementary School

Fiscal Year 2011

Date	Weather		Electric		Natural Gas		Total	Total
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu
Jul-10	2	44,136	\$9,802	\$0.22	204	\$157	\$0.77	20
Aug-10	3	39,744	\$8,796	\$0.22	176	\$136	\$0.77	18
Sep-10	34	53,352	\$11,735	\$0.22	219	\$169	\$0.77	22
Oct-10	211	57,432	\$10,926	\$0.19	2,230	\$1,717	\$0.77	223
Nov-10	466	59,976	\$10,334	\$0.17	6,162	\$4,745	\$0.77	616
Dec-10	955	57,240	\$9,827	\$0.17	8,560	\$6,591	\$0.77	856
Jan-11	1,033	47,592	\$8,788	\$0.18	9,602	\$7,394	\$0.77	960
Feb-11	1,185	52,992	\$9,483	\$0.18	9,826	\$7,566	\$0.77	983
Mar-11	826	53,952	\$9,784	\$0.18	5,691	\$4,382	\$0.77	569
Apr-11	599	53,616	\$9,994	\$0.19	6,646	\$5,117	\$0.77	665
May-11	344	53,376	\$10,208	\$0.19	1,476	\$1,137	\$0.77	148
Jun-11	62	53,304	\$11,259	\$0.21	255	\$196	\$0.77	26
<b>Totals</b>	<b>5,719</b>	<b>626,712</b>	<b>\$120,935</b>	<b>\$0.19</b>	<b>51,047</b>	<b>\$39,306</b>	<b>\$0.77</b>	<b>5,105</b>
								<b>\$160,241</b>

**Town of Framingham**  
**Utility Data Summary - Potter Road Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	MMBtu	\$
Jul-10	2	6,360	\$2,235	\$0.35	75	\$58	8	\$2,293
Aug-10	3	4,440	\$709	\$0.16	77	\$59	8	\$768
Sep-10	34	9,240	\$2,765	\$0.30	114	\$88	11	\$2,853
Oct-10	211	14,280	\$3,109	\$0.22	698	\$537	70	\$3,646
Nov-10	466	18,120	\$3,032	\$0.17	1,902	\$1,465	190	\$4,496
Dec-10	955	17,880	\$3,019	\$0.17	3,264	\$2,513	326	\$5,533
Jan-11	1,033	17,280	\$2,963	\$0.17	236	\$182	24	\$3,144
Feb-11	1,185	17,400	\$3,019	\$0.17	2,161	\$1,664	216	\$4,683
Mar-11	826	16,080	\$2,887	\$0.18	4,153	\$3,198	415	\$6,084
Apr-11	599	18,720	\$3,204	\$0.17	3,537	\$2,723	354	\$5,928
May-11	344	14,880	\$2,682	\$0.18	1,062	\$818	106	\$3,500
Jun-11	62	14,880	\$3,058	\$0.21	280	\$216	28	\$3,273
<b>Totals</b>	<b>5,719</b>	<b>169,560</b>	<b>\$32,681</b>	<b>\$0.19</b>	<b>17,559</b>	<b>\$13,520</b>	<b>1,756</b>	<b>\$46,202</b>

**Town of Framingham**  
**Utility Data Summary - Stapleton Elementary School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	Total
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu
Jul-10	2	6,104	\$2,480	\$0.41	116	\$89	\$0.77	12
Aug-10	3	3,944	\$587	\$0.15	119	\$92	\$0.77	12
Sep-10	34	9,624	\$2,922	\$0.30	141	\$109	\$0.77	14
Oct-10	211	15,704	\$3,308	\$0.21	1,164	\$896	\$0.77	116
Nov-10	466	16,584	\$2,883	\$0.17	3,157	\$2,431	\$0.77	316
Dec-10	955	16,984	\$2,932	\$0.17	7,704	\$5,932	\$0.77	770
Jan-11	1,033	15,864	\$2,919	\$0.18	7,037	\$5,418	\$0.77	704
Feb-11	1,185	16,344	\$2,995	\$0.18	8,096	\$6,234	\$0.77	810
Mar-11	826	14,584	\$2,713	\$0.19	5,775	\$4,447	\$0.77	578
Apr-11	599	18,024	\$3,150	\$0.17	4,060	\$3,126	\$0.77	406
May-11	344	14,984	\$2,764	\$0.18	1,289	\$993	\$0.77	129
Jun-11	62	15,544	\$3,332	\$0.21	204	\$157	\$0.77	20
<b>Totals</b>	<b>5,719</b>	<b>164,288</b>	<b>\$32,984</b>	<b>\$0.20</b>	<b>38,862</b>	<b>\$29,924</b>	<b>\$0.77</b>	<b>3,886</b>
								<b>\$62,908</b>

**Town of Framingham**  
**Utility Data Summary - Thayer Campus of FHS**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	MMBtu	\$
Jul-10	2	1,120	\$297	\$0.27	3	\$2	0	\$300
Aug-10	3	920	\$264	\$0.29	3	\$2	0	\$266
Sep-10	34	1,800	\$504	\$0.28	5	\$4	1	\$508
Oct-10	211	2,080	\$481	\$0.23	131	\$101	13	\$581
Nov-10	466	1,800	\$252	\$0.14	416	\$320	42	\$572
Dec-10	955	1,840	\$257	\$0.14	925	\$712	93	\$969
Jan-11	1,033	1,720	\$245	\$0.14	1,037	\$798	104	\$1,043
Feb-11	1,185	1,640	\$238	\$0.14	1,159	\$892	116	\$1,130
Mar-11	826	1,520	\$222	\$0.15	789	\$608	79	\$829
Apr-11	599	1,880	\$270	\$0.14	483	\$372	48	\$642
May-11	344	1,520	\$222	\$0.15	152	\$117	15	\$339
Jun-11	62	1,960	\$443	\$0.23	50	\$39	5	\$482
<b>Totals</b>	<b>5,719</b>	<b>19,800</b>	<b>\$3,693</b>	<b>\$0.19</b>	<b>5,153</b>	<b>\$3,968</b>	<b>515</b>	<b>\$7,661</b>

**Town of Framingham**  
**Utility Data Summary - Walsh Middle School**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu
Jul-10	2	25,212	\$4,524	\$0.18	565	\$435	\$0.77	57
Aug-10	3	24,252	\$4,568	\$0.19	733	\$564	\$0.77	73
Sep-10	34	49,572	\$10,979	\$0.22	681	\$524	\$0.77	68
Oct-10	211	57,852	\$11,192	\$0.19	3,804	\$2,929	\$0.77	380
Nov-10	466	57,132	\$10,433	\$0.18	5,965	\$4,593	\$0.77	597
Dec-10	955	59,712	\$10,835	\$0.18	15,610	\$12,020	\$0.77	1,561
Jan-11	1,033	43,332	\$9,024	\$0.21	24,063	\$18,529	\$0.77	2,406
Feb-11	1,185	49,512	\$9,847	\$0.20	14,043	\$10,813	\$0.77	1,404
Mar-11	826	50,232	\$10,016	\$0.20	11,603	\$8,934	\$0.77	1,160
Apr-11	599	52,812	\$10,285	\$0.19	3,881	\$2,988	\$0.77	388
May-11	344	49,512	\$9,790	\$0.20	1,216	\$936	\$0.77	122
Jun-11	62	53,472	\$11,358	\$0.21	607	\$467	\$0.77	61
<b>Totals</b>	<b>5,719</b>	<b>572,604</b>	<b>\$112,853</b>	<b>\$0.20</b>	<b>82,771</b>	<b>\$63,734</b>	<b>\$0.77</b>	<b>8,277</b>
								<b>\$176,587</b>

**Town of Framingham**  
**Utility Data Summary - Woodrow Wilson Elementary**

**Fiscal Year 2011**

Date	Weather		Electric		Natural Gas		Total	
	HDD	Total kWh	Total \$	\$/kWh Blended	Therm	\$	MMBtu	\$
Jul-10	2	32,220	\$11,289	\$0.35	32	\$25	3	\$11,313
Aug-10	3	29,060	\$10,813	\$0.37	41	\$32	4	\$10,845
Sep-10	34	46,400	\$14,467	\$0.31	71	\$55	7	\$14,522
Oct-10	211	52,320	\$13,338	\$0.25	978	\$753	98	\$14,091
Nov-10	466	49,720	\$11,767	\$0.24	2,694	\$2,074	269	\$13,842
Dec-10	955	47,160	\$8,767	\$0.19	6,532	\$5,030	653	\$13,796
Jan-11	1,033	36,880	\$7,650	\$0.21	6,511	\$5,013	651	\$12,663
Feb-11	1,185	51,680	\$9,451	\$0.18	8,510	\$6,553	851	\$16,004
Mar-11	826	42,200	\$8,419	\$0.20	5,479	\$4,219	548	\$12,637
Apr-11	599	52,540	\$8,346	\$0.16	4,310	\$3,319	431	\$11,665
May-11	344	37,200	\$9,326	\$0.25	919	\$708	92	\$10,033
Jun-11	62	50,280	\$13,921	\$0.28	169	\$130	17	\$14,051
<b>Totals</b>	<b>5,719</b>	<b>527,660</b>	<b>\$127,553</b>	<b>\$0.24</b>	<b>36,246</b>	<b>\$27,909</b>	<b>3,625</b>	<b>\$155,462</b>

## Utility Data Summary - DPW Headquarters

Fiscal Year 2011

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total
Jul-10	2	148	48,697	\$5,955	\$4,750	\$10,705	\$0.22	79	\$104	\$1.31	8	\$10,809
Aug-10	3	153	52,595	\$6,281	\$5,131	\$11,412	\$0.22	112	\$135	\$1.20	11	\$11,546
Sep-10	34	152	46,453	\$6,027	\$4,531	\$10,559	\$0.23	151	\$171	\$1.13	15	\$10,730
Oct-10	211	130	37,101	\$4,034	\$3,619	\$7,653	\$0.21	469	\$467	\$1.00	47	\$8,120
Nov-10	466	141	50,650	\$3,669	\$4,941	\$8,610	\$0.17	1,171	\$1,208	\$1.03	117	\$9,818
Dec-10	955	150	53,019	\$4,040	\$5,172	\$9,212	\$0.17	4,543	\$4,795	\$1.06	454	\$14,008
Jan-11	1,033	188	71,124	\$5,479	\$6,938	\$12,417	\$0.17	10,098	\$10,800	\$1.07	1,010	\$23,217
Feb-11	1,185	186	69,842	\$5,579	\$6,813	\$12,392	\$0.18	9,360	\$10,120	\$1.08	936	\$22,511
Mar-11	826	180	58,262	\$4,875	\$5,683	\$10,558	\$0.18	5,461	\$5,917	\$1.08	546	\$16,475
Apr-11	599	169	64,640	\$4,771	\$6,306	\$11,076	\$0.17	1,767	\$1,935	\$1.10	177	\$13,011
May-11	344	154	46,959	\$3,764	\$4,581	\$8,345	\$0.18	3,856	\$3,889	\$1.01	386	\$12,234
Jun-11	62	164	70,410	\$5,808	\$6,868	\$12,677	\$0.18	986	\$977	\$0.99	99	\$13,654
<b>Totals</b>	<b>5,719</b>	<b>1,915</b>	<b>669,752</b>	<b>\$60,283</b>	<b>\$65,334</b>	<b>\$125,617</b>	<b>\$0.19</b>	<b>38,053</b>	<b>\$40,517</b>	<b>\$1.06</b>	<b>3,805</b>	<b>\$166,134</b>



**Town of Framingham**  
**Utility Data Summary - Henry Street Garage**

**Fiscal Year 2011**

Date	Weather		Electric					Natural Gas			Total	
	HDD	kW	Total kWh	Deliv \$	Sup \$	Total \$	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total
Jul-10	2	9	3,627	\$304	\$354	\$658	\$0.18	27	\$50	\$1.87	3	\$708
Aug-10	3	8	3,314	\$293	\$323	\$616	\$0.19	24	\$46	\$1.94	2	\$662
Sep-10	34	10	2,943	\$272	\$287	\$559	\$0.19	29	\$51	\$1.77	3	\$610
Oct-10	211	7	1,964	\$183	\$192	\$374	\$0.19	135	\$178	\$1.32	14	\$552
Nov-10	466	11	2,702	\$210	\$264	\$474	\$0.18	579	\$952	\$1.64	58	\$1,426
Dec-10	955	10	3,292	\$238	\$321	\$559	\$0.17	1,166	\$2,207	\$1.89	117	\$2,766
Jan-11	1,033	15	6,254	\$433	\$610	\$1,043	\$0.17	1,569	\$2,993	\$1.91	157	\$4,036
Feb-11	1,185	12	6,180	\$394	\$603	\$997	\$0.16	1,677	\$3,216	\$1.92	168	\$4,213
Mar-11	826	13	6,179	\$417	\$603	\$1,020	\$0.17	1,248	\$2,397	\$1.92	125	\$3,417
Apr-11	599	9	2,243	\$180	\$219	\$399	\$0.18	840	\$1,619	\$1.93	84	\$2,017
May-11	344	6	1,573	\$134	\$153	\$288	\$0.18	211	\$364	\$1.73	21	\$652
Jun-11	62	8	2,184	\$199	\$213	\$412	\$0.19	44	\$81	\$1.85	4	\$494
<b>Totals</b>	<b>5,719</b>	<b>117</b>	<b>42,455</b>	<b>\$3,258</b>	<b>\$4,141</b>	<b>\$7,399</b>	<b>\$0.17</b>	<b>7,549</b>	<b>\$14,155</b>	<b>\$1.88</b>	<b>755</b>	<b>\$21,554</b>



**Town of Framingham**  
**Utility Data Summary - Sanitation Department**

Fiscal Year 2011

Date	Weather		Electric										Natural Gas			Total	
	HDD	kW	Peak kWh	Off-Peak kWh	Total kWh	Deliv \$	Sup \$	Off-Peak \$	Total \$	\$/Peak kWh	Off-Peak kW	\$/kWh Blended	Therm	\$	\$/Therm	MMBtu	Total \$
Jul-10	2	19	2,470	6,890	9,360	\$1,907	\$241	\$672	\$2,820	\$0.0976	\$0.2721	\$0.30	2	\$18	\$8.92	0	\$2,838
Aug-10	3	19	2,314	6,446	8,760	\$1,875	\$226	\$629	\$2,729	\$0.0976	\$0.2717	\$0.31	0	\$15	\$0.00	0	\$2,745
Sep-10	34	18	2,154	6,846	9,000	\$1,903	\$210	\$668	\$2,781	\$0.0976	\$0.3100	\$0.31	1	\$16	\$16.49	0	\$2,797
Oct-10	211	23	3,656	6,544	10,200	\$1,650	\$357	\$638	\$2,645	\$0.0976	\$0.1746	\$0.26	0	\$15	\$0.00	0	\$2,660
Nov-10	466	50	9,225	15,855	25,080	\$1,682	\$900	\$1,547	\$4,129	\$0.0976	\$0.1677	\$0.16	0	\$15	\$0.00	0	\$4,144
Dec-10	955	71	14,215	22,265	36,480	\$2,132	\$1,387	\$2,172	\$5,690	\$0.0976	\$0.1528	\$0.16	60	\$128	\$2.13	6	\$5,818
Jan-11	1,033	66	14,292	22,908	37,200	\$2,210	\$1,394	\$2,235	\$5,839	\$0.0976	\$0.1564	\$0.16	434	\$839	\$1.93	43	\$6,678
Feb-11	1,185	65	14,446	22,754	37,200	\$2,254	\$1,409	\$2,220	\$5,883	\$0.0976	\$0.1537	\$0.16	269	\$529	\$1.97	27	\$6,412
Mar-11	826	60	13,095	22,785	35,880	\$2,133	\$1,277	\$2,223	\$5,633	\$0.0976	\$0.1697	\$0.16	281	\$552	\$1.96	28	\$6,185
Apr-11	599	58	9,083	14,557	23,640	\$1,900	\$886	\$1,420	\$4,206	\$0.0976	\$0.1563	\$0.18	276	\$542	\$1.96	28	\$4,748
May-11	344	31	4,070	6,730	10,800	\$1,556	\$397	\$657	\$2,609	\$0.0976	\$0.1613	\$0.24	134	\$237	\$1.77	13	\$2,846
Jun-11	62	22	2,883	7,077	9,960	\$1,777	\$281	\$690	\$2,749	\$0.0976	\$0.2395	\$0.28	41	\$77	\$1.87	4	\$2,825
Totals	5,719	502	91,903	161,657	253,560	\$22,978	\$8,965	\$15,770	\$47,712	\$0.0976	\$0.0976	\$0.19	1,498	\$2,983	\$1.99	150	\$50,696

## Section 2: Existing Conditions

### Memorial Building

#### Building Characteristics

The Memorial Building, or Framingham Town Hall is old brick construction. It is a large three story building with a basement level and two upper levels. It contains the large Nevins Hall space as well as Municipal Office space. The building is occupied from 8:30 AM to 5:00 PM weekdays. The building encompasses approximately 76,453 square feet of floor space. The walls are furred out drywall over brick wall, although it is doubtful that there is much insulation in the wall. The attic over the rotunda entrance has some recently added cellulose insulation. The building's windows have been retrofitted with wood framed, double glazed upgrades.



#### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by two Smith 28HE-S/W-17 gas-fired steam boilers. The boiler supplies steam to radiators throughout the basement, Nevins Hall, and office spaces. The offices have recently been retrofitted with a variable refrigerant system capable of providing cooling, as well as heat pump heating. An existing Air Handling Unit is designed to bring ventilation air into Nevins Hall, but is no longer in use. All systems, including every radiator valve except for those in Nevins Hall, the basement, and the rotunda, are controlled from the buildings central EMS. Schedules and setpoints can be controlled through a connection to the buildings computer.

#### Energy Management Systems

This building has an existing DDC system that controls the steam boilers and perimeter radiators. It is currently being expanded to include the new variable refrigerant system being installed in office spaces. Office radiators have been updated with DDC actuators and hallway radiators have been fitted with standalone Thermostatic Radiator Valves. A few pneumatically actuated valves remain, on radiators in Nevins Hall, on basement hallway convectors, and on rotunda convectors. Because of the old and leaky pneumatic tubing, the pneumatic compressor runs continuously to try to maintain pressure.

#### Domestic Hot Water Systems

Domestic hot water for the building is provided by five small electric hot water heaters located next to bathrooms. Because of the short distance, no circulation pumps are necessary.

## Lighting Systems

Offices use T12 troffers, standard T8 troffers, wraps, T5 "biax" wall wash fixtures. Halls use standard T8 old surface fixtures, troffers, coves, incandescent decorative fixtures, T12 old surface fixtures, compact fluorescent drums. Auditoriums utilize compact fluorescent decorative fixtures, exits. Storage areas utilize standard T8 troffers, old surface fixtures, wraps, T12 strips, troffers, incandescent surface fixtures. Baths use standard T8 troffers, T12 troffers, boxes. Mechanical areas have T12 old surface fixtures. Perimeters use MH floods, decorative fixtures, exterior fixtures, HPS exterior fixtures, incandescent surface fixtures, old wall mounted fixtures.

## Main Library Building

### Building Characteristics

The Main Library Building sits near the Memorial Building and Police Station, at the heart of Framingham. It is of brick construction and features two large, open levels plus a lower level, totaling approximately 53,000 square feet. The building is open from 9:00 AM to 9:00 PM Monday through Thursday, 9:00 AM to 5:00 PM Friday and Saturday and 1:00 PM to 5:00 PM on Sunday. There is a large garage bay with an overhead door for deliveries that serves as the book sale area.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The library has five large Roof Top Units (RTU) that provide ventilation air and DX cooling to the occupied space. The RTUs supply air to fifty-three (53) Variable Air Volume (VAV) Boxes. Each VAV Box has a damper and hot water reheat coil that modulate to provide the correct amount of heating or cooling air to individual areas. Each RTU has a Variable Frequency Drive (VFD) that modulates the volume of airflow to match the volume required by the VAV Boxes. A Cleaver Brooks CB-200-60 gas-fired hot water boiler provides hot water to the VAV Box reheats and the perimeter baseboard heaters, through two separate loops. Heating hot water is also pumped through a heat exchanger to produce domestic hot water to bathroom use during the heating season.

### Energy Management Systems

This building has an existing Barber-Coleman Pneumatic system that controls fifty-three Variable Air Volume (VAV) Boxes and perimeter baseboard heating. Each VAV box has a pneumatic damper and reheat valve controlled by a local thermostat via a pneumatic controller. A new DDC system was installed with very limited control over the heating and cooling system. It has simple Start/Stop of the Boiler, Pumps and five Roof Top Units, turning them on during occupied hours and allowing the local pneumatic controls to maintain space temperature. During unoccupied hours the EMS shuts off the heating and cooling system, and uses a few digital space temperature sensors to turn the system back on if internal temperature drops below an unoccupied setpoint. No further DDC control of space temperatures is available.

### Domestic Hot Water Systems

Domestic hot water for the building is provided by a 40 gallon electric hot water heater in the basement boiler room. The system features a hot water heat exchanger tied to the heating hot water system, so that

during the heating season domestic hot water can be produced by the gas fired boiler and stored in the electric tank. Hot water is circulated through the system by a small pump.

## Lighting Systems

Libraries use standard T8 boxes, troffers, strips, compact fluorescent cans, exits, MH cans, and incandescent cans. Offices have standard T8 troffers, boxes, valances, strips, compact fluorescent cans, surface fixtures, T12 valances. Storage areas utilize standard T8 strips, troffers, wraps, vapor tight, old surface fixtures, and compact fluorescent surface fixtures. Halls use standard T8 troffers, wraps, valances, compact fluorescent cans, exits, incandescent cans, decorative fixtures. Baths utilize standard T8 valances, vanities, compact fluorescent cans. Mechanical areas employ compact fluorescent surface fixtures, standard T8 wraps, and incandescent surface fixtures. Labs use standard T8 troffers. Kitchens employ standard T8 valances, troffers. Bedrooms have standard T8 valances. Perimeters have compact fluorescent cans, MH floods, HPS exterior fixtures.

## Fire Department Headquarters

### Building Characteristics

The Fire Department Headquarters is a modern building with a block façade which houses offices, an active fire station, and mechanic space for the Town's fleet of fire safety vehicles. The occupied part of the building is two stories, with the Fire Chief office and other office space on the second floor, and the kitchen, dayroom, and sleeping quarters on the first floor. Next to this section is a six bay apparatus floor and mechanic space. The mechanic space has a second story loft. Windows are double pane and operable.

The building has faced an ongoing humidity issue, with a large amount of air leaking into the building and moisture condensing on cooling equipment. Several large areas of infiltration have been sealed, including attic space vents and a walkway overhang. In 2010 a large remediation project was undertaken to remove and replace damaged building material.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

Ventilation and conditioned air is brought into the occupied space by Unit Ventilators (UV) and Fan Coil Units (FCU) above the ceilings. A Weil-McLain 788 gas-fired hot water boiler and Trane packaged rooftop chiller supply hot water and chilled water that flow through separate pipes throughout the building. Two in-line pumps on each system circulate water. Six ducted dehumidifiers have been installed above the ceilings of key areas in an effort to compensate for humidity issues.

### Energy Management Systems

This newer building has an existing Tridium DDC system that controls the existing boiler, pumps, unit ventilators, and fan coil units. High humidity has been an issue in the building, and so six dehumidifiers were installed above the ceiling of key spaces. These are controlled by local humidistats set at various humidity levels and not tied back to the building EMS. Also because of humidity concerns, all heating and cooling

systems have been scheduled for 24/7 operation, even though large portions of the building are office space and only occupied during normal hours.

The building features some remaining pneumatic actuation. In the boiler room, three mixing and differential pressure valves on the hot and chilled water piping are pneumatically actuated. In the mechanic space, decontamination room, and watch's bathroom, fintube radiation is controlled by pneumatic thermostats and valves. In the mechanic space, these thermostats have been removed with either a bypass or nothing left in their place.

## Domestic Hot Water Systems

Domestic hot water for the building is provided by an AO Smith gas-fired 80 gallon hot water heater in the boiler room. Hot water is moved through the system by a small circulator pump.

## Lighting Systems

Halls use standard T8 troffers, compact fluorescent cans, sconces, efficient 4' T8 30w wraps. Offices use efficient 4' T8 30w troffers, standard T8 troffers. Storage areas utilize efficient 4' T8 30w strips, troffers, vapor tights, T12 strips, and standard T8 troffers. Classrooms have efficient 4' T8 30w troffers, incandescent cans, sconces. Parking garages utilize standard T8 industrials. Baths have efficient 4' T8 30w troffers, vapor tights, compact fluorescent cans, and standard T8 troffers. Shops employ standard T8 industrials. Kitchens utilize efficient 4' T8 30w troffers, standard T8 troffers. Gyms use efficient 4' T8 30w troffers. Bedrooms utilize efficient 4' T8 30w troffers. Mechanical areas have efficient 4' T8 30w strips, wraps. Perimeters have HPS old exterior fixtures, cans. Parking lots employ HPS parking/roadway fixtures.

## Fire Station #1

### Building Characteristics

The building is of typical brick construction with a mansard roof and rubber membrane flat portion. The building is two stories, with the living quarters situated above the 1<sup>st</sup> floor apparatus floor. Windows are single glaze. Like most fire stations, the station is staffed 24/7. The apparatus floor has three bays, with glass overhead doors on the front and back of the building.

Behind the station is a shop of garage-like construction. It has one small vehicle bay but consists mostly of shop space.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by a Weil-McLain LGB-7 gas-fired hot water boiler which provides hot water to fintube baseboard throughout the living quarters and ceiling mounted unit heaters in the apparatus floor. The

building also contains a communications room and a server room, which are cooled by Mitsubishi and York split AC systems.

## Energy Management Systems

Heating and cooling for the building is controlled by stand-alone non-programmable thermostats. Thermostats tied to hot water control valves on the fin tube baseboard maintains a heating temperature in the occupied space while two thermostats in the communications room and server room control the AC units for those spaces.

## Domestic Hot Water Systems

Domestic hot water for the building is provided by a Ruud gas-fired 50 gallon hot water heater in the boiler room.

## Lighting Systems

Offices employ incandescent cans, standard T8 troffers, efficient 4' T8 30w troffers, valances. Parking garages employ standard T8 boxes. Baths utilize standard T8 troffers, vanities, strips, incandescent cans, efficient 4' T8 30w wraps, valances, vanities. Bedrooms employ incandescent surface fixtures, cans. Storage areas have standard T8 troffers, efficient 4' T8 30w troffers. Kitchens employ standard T8 troffers, efficient 4' T8 30w troffers, and incandescent cans. Mechanical areas have efficient 4' T8 30w strips. Halls use efficient 4' T8 30w wraps. Perimeters use incandescent cans, HPS exterior fixtures, MH floods.

## Fire Station #2

### Building Characteristics

Fire Station #2 is the oldest of the fire stations and is of a typical brick construction, with likely little or no insulation between the exterior brick and interior plaster walls. The building is two stories, with most of the living quarters above the three bay apparatus floor. It has a flat rubber membrane roof and newer double glassed metal framed windows.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by two ceiling mounted, gas-fired furnaces that provide hot air, one to the apparatus floor and first floor and the other to the second floor. Their returns are connected directly to the interior space and they do not draw in any outdoor air.

## Energy Management Systems

The two furnaces are controlled by two non-programmable thermostats, one on each floor. They maintain a constant temperature 24/7, although they can be manually set back at night.

## Domestic Hot Water Systems

Domestic hot water for the building is provided by a Ruud gas-fired 40 gallon hot water heater in the basement.

## Lighting Systems

Parking garages employ efficient 4' T8 30w strips. Storage areas use efficient 4' T8 30w wraps, strips, incandescent surface fixtures. Offices have efficient 4' T8 30w troffers. Halls use efficient 4' T8 30w troffers, incandescent surface fixtures. Bedrooms utilize efficient 4' T8 30w troffers. Gyms have efficient 4' T8 30w strips. Baths use standard T8 troffers. Kitchens employ efficient 4' T8 30w wraps. Mechanical areas utilize incandescent surface fixtures. Perimeters utilize HPS exterior fixtures, incandescent old wall mounted fixtures.

## Fire Station #5

### Building Characteristics

This fire station is typical brick construction. It is a split level, with living quarters besides and above the apparatus floor. A small watch room sits at the front of the apparatus floor while the boiler room is at the rear, accessible from outside. The building has a flat roof and newer double pane windows.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated with a Weil-McLain LGB-6 gas-fired hot water boiler. The hot water is circulated by three separate pumps to the apparatus floor, 1<sup>st</sup>/2<sup>nd</sup>/3<sup>rd</sup> floors, and Chief's office/dispatch. This water circulates through fintube baseboard around the perimeter of the occupied space as well as through ceiling mounted unit heaters in the apparatus floor.

### Energy Management Systems

The three hot water circulation pumps operate based on Honeywell non-programmable thermostats located throughout the building. The pumps circulate water through their particular area on a call for space heating. Local control of space temperature is provided by thermostatic radiator valves (TRV) on the fintube baseboard piping. The TRVs shut off hot water flow to baseboard heaters once the space has reached its temperature setpoint. Several of thermostatic heads to these TRVs were noticed to be missing or damaged.

## Domestic Hot Water Systems

Domestic hot water for the building is provided by an AO Smith gas-fired 75 gallon hot water heater in the boiler room.

## Lighting Systems

Offices have efficient 4' T8 30w wraps, standard T8 troffers, compact fluorescent drums. Baths utilize compact fluorescent old drums, drums, incandescent cans, standard T8 vanities. Parking garages utilize efficient 4' T8 30w wraps, compact fluorescent drums, sconces. Halls employ compact fluorescent drums, old drums, efficient 4' T8 30w wraps, strips, vapor tights. Bedrooms utilize efficient 4' T8 30w wraps, compact fluorescent old drums, drums. Gyms employ efficient 4' T8 30w wraps, strips, compact fluorescent drums. Storage areas use compact fluorescent surface fixtures, incandescent surface fixtures. Kitchens utilize efficient 4' T8 30w valances, wraps. Shops use efficient 4' T8 30w strips. Walkways employ incandescent surface fixtures. Perimeters use incandescent wall mounted fixtures, decorative fixtures, surface fixtures, MH floods.

## Fire Station #7

### Building Characteristics

This fire station is of brick construction. It is one story, with the living quarters section next to the two-bay apparatus floor. The boiler room is located below grade and is accessible from the side of the building. The roof is flat with a rubber membrane. Windows are aluminum framed and double glazed.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated with a Burnham V905 gas-fired hot water boiler. The hot water is circulated two pumps to the apparatus floor and living quarters. This water circulates through fintube baseboard around the perimeter of the occupied space as well as through ceiling mounted unit heaters in the apparatus floor.

### Energy Management Systems

The two hot water circulation pumps operate based on LUXPro non-programmable thermostats located throughout the building. The pumps circulate water on a call for space heating. Some cooling is provided by window air conditioning units. These are temperature controlled locally

### Domestic Hot Water Systems

Domestic hot water for the building is provided by an AO Smith gas-fired 40 gallon hot water heater in the boiler room.

## Lighting Systems

Parking garages utilize efficient 4' T8 30w strips, compact fluorescent drums. Offices use compact fluorescent drums, old drums, efficient 4' T8 30w wraps. Gyms have incandescent surface fixtures, compact fluorescent surface fixtures. Storage areas employ compact fluorescent surface fixtures, incandescent surface fixtures, efficient 4' T8 30w strips. Halls use compact fluorescent drums. Mechanical areas employ incandescent

surface fixtures, T12 old surface fixtures. Baths have standard T8 boxes, compact fluorescent cans. Bedrooms employ compact fluorescent drums. Kitchens utilize efficient 4' T8 30w wraps. Perimeters use HPS exterior fixtures, floods, incandescent decorative fixtures, wall mounted fixtures.

## Police Station

### Building Characteristics

This building was recently renovated to provide an all new interior while reusing the existing structure and exterior. It is a brick exterior with three floors plus a basement level. The building houses a booking area, holding cells, exercise space, offices, a shooting range, and mechanic garage. It has a sloped attic roof. Some areas of the building are staffed 24/7 while others are only occupied during normal business hours.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

This building is heated, cooled and ventilated primarily by a large Roof Top Unit (RTU). It supplies air to Variable Air Volume (VAV) Boxes, both Fan Powered (FBVAV) and non. There have been numerous and chronic comfort complaints from several areas of the building. These are due to both mechanical and controls issues.

During site visits it was discovered that the RTU Outdoor Air damper was closed, preventing fresh ventilation air from entering the space and disallowing the use of economizer 'free cooling'. This has exacerbated overheating issues in certain spaces, along with a general feeling of stuffiness. It was also discovered that the RTU return fan had been wired backwards, preventing Return Air from getting through the unit and back to the occupied space. With neither fresh Outdoor Air nor Return Air able to get through the RTU, it was unable to provide the proper amount of Supply Air.

### Energy Management Systems

This renovated building has an existing Tridium DDC system that controls the existing boiler, chiller, pumps, RTU, and fan coil units. All of these systems are controlled by the central EMS but because of issues with the RTU, it is difficult to determine how well the sequences and schedules are working. The lack of proper airflow is indicated across all terminal units. A full point to point check of the system is necessary to ensure proper operation.

### Domestic Hot Water Systems

Domestic hot water is generated by a 200MBH AO Smith hot water heater and stored in two 120 gallon tanks. This water is circulated throughout the system by a small circulator pump.

## Lighting Systems

Offices have standard T8 troffers, wraps, compact fluorescent cans. Halls utilize compact fluorescent drums, cans, standard T8 troffers, tubes, and incandescent quartz indirects. Storage areas have standard T8 industrials, secure wraps, troffers, strips, vapor tight, compact fluorescent cans, drums, incandescent quartz floods, incandescent cans. Baths use compact fluorescent drums, squares, cans, standard T8 troffers. Classrooms use compact fluorescent cans, standard T8 indirects. Gyms utilize standard T8 troffers, compact fluorescent cans, MH troffers. Mechanical areas employ standard T8 strips. Shops utilize standard T8 industrials. Parking garages have standard T8 strips. Kitchens employ standard T8 troffers. Perimeters employ compact fluorescent exterior fixtures, MH cans, decorative fixtures, incandescent quartz floods. Parking lots use MH parking/roadway fixtures.

## Callahan Senior Center

### Building Characteristics

This building houses special services and activity space for seniors in the Town of Framingham, as well as offices for administrators. It is of modern block construction, two stories in some portions and single story in others. Most of the building has a flat rubber membrane roof, but some portions have a sloped attic roof. Windows are aluminum frame and double glazed. The batt insulation attached to the underside of the attic roof is not air sealed, and is missing entirely in spots.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated and cooled by seven (7) gas-fired, DX cooled, Roof Top Units (RTU). These RTUs are located on the flat sections of roof and provide ventilation and conditioned air to different spaces at the Senior Center. A small amount of electric baseboard heat is present in the main lobby.

### Energy Management Systems

The seven (7) RTUs and electric baseboard heat are on the Tridium EMS. Thermostats are located throughout the building and their temperature sent back to each RTU to control the temperature of supply air. For RTUs serving multiple spaces with more than one thermostat, an average temperature of all appropriate spaces is calculated. Full scheduling and adjustment of space temperature setpoints is available.

### Domestic Hot Water Systems

Domestic hot water for the building is provided by a small gas-fired hot water heater.

## Lighting Systems

Offices utilize standard T8 troffers, wraps, incandescent cans, compact fluorescent exits. Halls utilize compact fluorescent cans, surface fixtures, standard T8 troffers, wraps. Classrooms utilize standard T8 troffers. Baths have standard T8 troffers, compact fluorescent cans. Auditoriums employ compact fluorescent sconces, cans. Labs employ incandescent cans, standard T8 wraps. Kitchens have standard T8 troffers,

compact fluorescent exits. Storage areas utilize standard T8 strips, wraps, troffers. Perimeters have MH exterior fixtures, compact fluorescent cans. Parking lots employ MH parking/roadway fixtures.

## Pearl Street Garage

### Building Characteristics

The Pearl Street Garage is a multilevel parking garage near the center of Town. It has a small toll attendant booth of concrete construction. The booth is only staffed during weekday mornings as tolls are only collected for the morning influx of commuters.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The booth is heated by a small electric space heater and cooled by a small window air conditioner.

### Energy Management Systems

The heater and AC are controlled by local manual controls.

### Domestic Hot Water Systems

There is no hot water at this facility.

### Lighting Systems

Parking garages employ standard T8 vapor tights, MH parking/roadway fixtures, and incandescent old exterior fixtures. Halls use compact fluorescent squares. Offices employ standard T8 troffers.

## Animal Control Building

### Building Characteristics

The Animal Control Building consists of two sections, office space and the kennel. The office space is a small one story building with vinyl siding, a concrete foundation, double glazed windows and a flat roof. The kennel is of similar construction, but has several vertically sliding doors to allow dogs in and out. It also features a large skylight to allow daylighting.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The offices and kennel are each heated and cooled by a gas-fired DX cooled Roof Top Unit (RTU).

### Energy Management Systems

The kennel RTU is controlled by a programmable thermostat and the office RTU is controlled by a non-programmable thermostat. Both thermostats are set to maintain a constant temperature and must be manually set back in order to achieve nighttime savings.

## Domestic Hot Water Systems

Domestic hot water for the building is provided by an AO Smith gas-fired 80 gallon hot water heater with no circulator pump.

## Lighting Systems

Storage areas utilize standard T8 troffers, vapor tight. Halls use standard T8 troffers. Kitchens employ standard T8 troffers. Offices have standard T8 troffers. Baths use standard T8 troffers. Perimeters utilize compact fluorescent exterior fixtures.

## Old Edgell Library

### Building Characteristics

The Edgell Memorial Library was built in 1872. It has a stone exterior with a plaster wall interior. It stands in the Centre Common and is currently used as a cultural community center by the Framingham History Center. It is used for local exhibitions, storage, and office space. The building's windows have been restored and are scheduled to get new storm windows. The space is mostly one floor with high ceilings. Two side sections are two-story and there is a large attic space above the whole building. There is no insulation in the attic space and the area is not well sealed.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building was originally heated by a boiler in the basement and radiators located throughout the space. This system has been removed and a new hot water boiler was installed in place of the old one. The boiler feeds hot water to two DX cooled Fan Coil Units (FCU) in the attic space. Ductwork runs through the attic space and down to ceiling mounted supply diffusers. There is a long run of refrigerant piping from the FCUs to rooftop mounted condensing units. Because of the high ceilings and lack of insulation, the attic space stays very warm during the heating season while the occupied space below has a difficult time staying warm.

### Energy Management Systems

The two FCUs are controlled by two non-programmable thermostats. These try to maintain a set temperature in the conditioned space, and have to be manually set back in order to achieve nighttime savings.

## Domestic Hot Water Systems

There is no domestic hot water at this facility.

## Lighting Systems

Galleries employ incandescent cans. Offices utilize T12 strips, incandescent old drums. Halls use incandescent cans, drums. Storage areas utilize T12 strips, old surface fixtures. Baths have incandescent surface fixtures. Perimeters use incandescent decorative fixtures, incandescent quartz floods, and HPS old exterior fixtures.

## Academy Building

### Building Characteristics

The Academy Building is another building in the Centre Common and is operated by the Framingham History Center as a museum. It has a stone exterior with a plaster wall interior. The first floor, second floor and basement house exhibit space. There is also some office space on the second floor. There is attic space above the second floor ceiling with little or no insulation.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by a Lennox G11-200 gas-fired furnace in the basement. It supplies heated air through ductwork to all spaces in the building. The unit is also DX cooled and provides cooling to the building.

### Energy Management Systems

The furnace is controlled by a programmable thermostat in the space. The thermostat is set to maintain 70°F 24/7 as a fluctuation in temperature could damage the pieces on display.

### Domestic Hot Water Systems

There is no domestic hot water at this facility.

### Lighting Systems

Parking lots use MH parking/roadway fixtures. Perimeters employ incandescent quartz floods, HPS exterior fixtures.

## Park Department Headquarters

### Building Characteristics

The Park Department Headquarters is located adjacent to Bowditch Field. It is a brick building with a main level and basement. The basement has locker rooms, shop space, and a garage. The main level has office space and showers. Above the first floor is an attic with sloped roof. The locker room and showers were initially designed for use by teams using the Bowditch Field, but are used only occasionally now. The main office space is occupied during normal business hours.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by three small gas-fired air handlers. A Trane air handler in the basement provides heating to that area. Two American Standard air handlers provide heating and DX cooling to the main floor office space. These air handlers sit in the attic and their ductwork runs through the attic to the appropriate spaces.

## Energy Management Systems

The three air handling units are controlled by four programmable thermostats located throughout the building. Three of the thermostats are linked directly to the three air handlers, and the fourth thermostat, located in the conference room, controls a damper supplying air to that space.

## Domestic Hot Water Systems

Domestic hot water is generated by a large 300MBH AO Smith gas-fired hot water heater and stored in a 120 gallon tank. The large capacity was designed for the shower facilities, which are hardly ever used.

## Lighting Systems

Offices have efficient 4' T8 30w wraps, old surface fixtures. Baths employ efficient 4' T8 30w wraps, incandescent cans, compact fluorescent squares. Storage areas use standard T8 industrials, incandescent surface fixtures, efficient 4' T8 30w wraps, old surface fixtures, T5 troffers, compact fluorescent squares, and T12 strips. Halls have efficient 4' T8 30w old surface fixtures, wraps. Perimeters have HPS floods, incandescent old wall mounted fixtures, squares. Parking garages utilize standard T8 industrials. Driveways employ HPS decorative fixtures.

## Department of Public Works Headquarters

### Building Characteristics

This is a large building consisting of large garage and storage space along with office and administrative space. It is a combination of block and garage-style construction with metal siding. It has a flat rubber membrane over the entire building. The center space is office area and the southern garage is mechanic space. The much larger northern garage space is used for vehicle storage. There is a doublewide trailer building behind the headquarters which house exercise space.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by three small gas-fired air handlers. A Trane air handler in the basement provides heating to that area. Two American Standard air handlers provide heating and DX cooling to the main floor office space. These air handlers sit in the attic and their ductwork runs through the attic to the appropriate spaces.

## Energy Management Systems

The three air handling units are controlled by four programmable thermostats located throughout the building. Three of the thermostats are linked directly to the three air handlers, and the fourth thermostat, located in the conference room, controls a damper supplying air to that space.

## Domestic Hot Water Systems

Domestic hot water for the building is provided by two gas-fired hot water heaters. One is a 120 gallon AO Smith hot water heater and the other is a 100 gallon State hot water heater.

## Lighting Systems

Offices use standard T8 troffers, indirects. Shops utilize T5 bay fixtures, vapor tights, standard T8 industrials, strips, vapor tights, MH bay fixtures. Parking garages employ T5 bay fixtures, T12 strips. Storage areas have standard T8 strips, industrials, wraps, T5 bay fixtures, and indirects. Baths use standard T8 wraps, troffers, vanities, vapor tights, compact fluorescent drums. Classrooms employ T5 indirects. Gyms utilize T12 strips. Halls have standard T8 troffers. Cafeterias utilize standard T8 troffers. Kitchens have T5 indirects. Parking lots use LED parking/roadway fixtures. Perimeters employ MH parking/roadway fixtures.

## Department of Public Works Offices

### Building Characteristics

This building, located at 110 Western Avenue directly next to the DPW Headquarters building, is a small, one story building. It has metal siding above a block foundation and a slightly sloped roof. It houses office space for DPW staff and is occupied during normal business hours. Windows are aluminum framed and double paned.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

This building is heated and cooled by four gas-fired; DX cooled Roof Top Units (RTU).

### Energy Management Systems

The four RTUs are controlled by four programmable thermostats. The thermostats are programmed for both cooling and heating setpoints to roughly the occupied hours.

### Domestic Hot Water Systems

This is no domestic hot water at this building.

## Lighting Systems

Offices have standard T8 troffers, indirects. Halls employ standard T8 troffers. Storage areas utilize standard T8 troffers. Baths use standard T8 troffers. Perimeters have compact fluorescent exterior fixtures.

## Henry Street Garage

### Building Characteristics

This mechanic garage is a two story tall cement block building. It has a flat roof and windows are double pane. Two overhead doors lead to the mechanic's garage, with loft bays above. Some windows and doors have been replaced.

## Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by two gas-fired furnaces, one heating the first floor and one heating the second. Two gas-fired unit heaters heat the maintenance garage and big garage, respectively

## Energy Management Systems

Heat is controlled by simple non-programmable thermostats. They are set for a comfortable temperature and must be turned down at night to get any nighttime setback savings.

## Domestic Hot Water Systems

Domestic Hot Water is generated and stored in a small 15 gallon 1.5kW electric hot water heater. No circulation pump is needed as this is not a large building.

## Lighting Systems

Storage areas employ standard T8 wraps, strips, MH bay fixtures. Shops use standard T8 industrials. Offices employ standard T8 troffers, wraps. Halls have standard T8 troffers, wraps. Parking lots employ MH floods. Baths utilize standard T8 troffers. Perimeters use HPS exterior fixtures, floods, MH floods. Parking garages have standard T8 wraps.

# Sanitation Department

## Building Characteristics

The Sanitation Facility is spread over two buildings. The first is a multi-story incinerator plant with lockers, showers, and meeting space. The incinerator is no longer used although the building is still occupied occasionally as meeting space. The lower building is a much newer garage. It has a large garage bay with multiple overhead doors and a small office area. It has a metal frame and siding on top of a concrete foundation.

## Heating, Ventilating, and Air Conditioning Systems (HVAC)

The original incinerator building is heated with electric resistance heaters. There is baseboard in the meeting room and unit heaters in the locker and shower area. The actual incinerator space is not heated. The lower garage is heated by a Carrier gas-fired, DX cooled furnace serving the office space and two gas-fired unit heaters serving the garage space.

## Energy Management Systems

Electric heat for the Incinerator building is controlled by local non-programmable thermostats. The gas-fired furnace and garage unit heaters in the lower building are also controlled by non-programmable thermostats. These maintain one temperature, and would need to be manually set back at night in order to get nighttime savings.

## Domestic Hot Water Systems

Domestic hot water for the old shower facilities is provided by an AO Smith gas-fired 38 gallon hot water heater. Hot water for the two bathrooms in the lower building is provided by a small electric hot water heater.

## Lighting Systems

Mechanical areas have MH bay fixtures, incandescent surface fixtures, T12 strips. Halls have T12 old surface fixtures, wraps, standard T8 wraps, troffers. Storage areas have incandescent surface fixtures, standard T8 wraps, T12 old surface fixtures. Baths utilize incandescent old wall mounted fixtures, old drums, T12 old surface fixtures, standard T8 wraps. Parking garages utilize 150W Induction Lighting bay fixtures. Offices have standard T8 troffers, wraps.

Parking garages employ standard T8 strips. Offices utilize standard T8 troffers. Baths employ standard T8 troffers. Mechanical areas utilize standard T8 strips. Perimeters have HPS exterior fixtures, parking/roadway fixtures, floods. Parking lots have HPS parking/roadway fixtures. Driveways use HPS parking/roadway fixtures.

## Barbieri Elementary School

### Building Characteristics

The Barbieri Elementary School was built in 1974 as a Middle School. It is approximately 112,000 square feet spread over multiple levels with a very open layout. It is standard block construction with a brick exterior and flat rubber membrane roof. It has a large unconditioned storage warehouse that originally housed an indoor pool.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building was originally heated entirely by electric baseboard heaters around the perimeter. Two Weil-McLain 88 gas-fired hot water boilers were installed to provide heating to eight (8) Roof Top Units (RTU). The RTUs provide DX cooling and ventilation air to the occupied spaces. The electric baseboard heat remains and is used only to provide auxiliary heating.

### Energy Management Systems

The school has a new DDC Tridium EMS that can be accessed via the internet. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School. The Tridium system was installed on top of and integrated to existing Trane controllers on the RTUs.

## Domestic Hot Water Systems

Domestic hot water is provided by an AO Smith hot water heater and storage tank in the boiler room.

## Lighting Systems

Classrooms use efficient 4' T8 30w troffers, boxes, industrials, standard T8 troffers. Halls use efficient 4' T8 30w troffers, wraps, strips, incandescent cans. Offices use efficient 4' T8 30w troffers, strips, standard T8 troffers, and T5 "biax" indirects. Storage areas use efficient 4' T8 30w troffers, industrials, strips, T5 bay fixtures. Cafeterias use efficient 4' T8 30w troffers, wraps, standard T8 troffers. Libraries have efficient 4' T8 30w troffers. Auditoriums use LED cans, standard T8 boxes, efficient 4' T8 30w boxes. Baths have efficient 4' T8 30w troffers, strips, compact fluorescent squares, standard T8 troffers, vanities. Gyms use T5 bay fixtures, efficient 4' T8 30w troffers. Mechanical areas utilize efficient 4' T8 30w strips. Kitchens have efficient 4' T8 30w troffers. Perimeters utilize MH exterior fixtures, incandescent cans. Parking lots use MH parking/roadway fixtures, floods.

## Brophy Elementary School

### Building Characteristics

The Brophy Elementary School was built in 1968. It is approximately 68,000 square feet including two levels plus a modular building. It is standard block construction with a brick exterior and flat rubber membrane roof.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

In the main school, two Weil-McLain 88 gas-fired hot water boilers were installed to provide heating to five (5) Air Handling Units (AHU) serving the Cafetorium, Gymnasium and Locker Rooms, twenty-six (26) Unit Ventilators (UV) in the classrooms, and numerous fin tubes throughout the building. The modular classrooms are heated and cooled by two (2) Rheem Roof Top Units.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on dampers and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Burnham hot water heater in the boiler room along with three (3) storage tanks. Two of the tanks are valved off and no longer used.

## Lighting Systems

Classrooms use standard T8 wraps, LED cans. Halls utilize LED cans, standard T8 indirects, wraps, troffers, compact fluorescent decorative fixtures. Offices have standard T8 wraps, indirects, incandescent surface

fixtures, compact fluorescent squares. Baths have compact fluorescent drums, squares, standard T8 vanities. Gyms use T5 bay fixtures. Libraries employ standard T8 wraps. Storage areas utilize compact fluorescent surface fixtures, squares, standard T8 wraps. Kitchens employ standard T8 wraps, LED cans. Auditoriums have standard T8 strips, incandescent surface fixtures. Cafeterias employ standard T8 wraps. Mechanical areas utilize standard T8 strips, compact fluorescent surface fixtures. Parking lots use HPS floods, parking/roadway fixtures. Perimeters utilize MH exterior fixtures, incandescent squares.

## Cameron Middle School

### Building Characteristics

Cameron Middle School was built in 1973. It is approximately 114,000 square feet and two stories. It has one main building section with classroom and Gym space and an Auditorium at the far end. It is brick construction with a flat roof. It has newer double pane, metal framed windows that are operable in the classrooms.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by two Smith 28A gas-fired hot water boilers and cooled by a Trane RTHB 300-ton chiller. Hot and chilled water is fed to seven (7) Air Handling Units (AHU) which provide heating, cooling, and ventilation air to the occupied spaces of the North and South Classrooms, Auditorium, Cafeteria, Gymnasium and Music Room. There are also fin tubes throughout the building that provide additional heating on the perimeter.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by two Raypak hot water heaters and two storage tanks in two separate boiler rooms.

### Lighting Systems

Classrooms utilize efficient 4' T8 28w indirects, wallwash, coves, valances, troffers, boxes, standard T8 indirects, wallwash, coves, valances, troffers, compact fluorescent cans. Halls utilize compact fluorescent cans, sconces, drums, standard T8 coves, wallwash, troffers, boxes, efficient 4' T8 28w coves, troffers, T5 "biax" decorative fixtures. Offices use standard T8 indirects, troffers, wallwash, wraps, strips, compact fluorescent cans, efficient 4' T8 28w indirects, T5 "biax" decorative fixtures. Libraries use compact fluorescent cans, wall

mounted fixtures, T5 "biax" decorative fixtures, standard T8 wallwash. Auditoriums use LED cans, compact fluorescent sconces, incandescent cans. Cafeterias utilize compact fluorescent decorative fixtures, sconces, LED cans, standard T8 troffers. Baths utilize efficient 4' T8 28w troffers, standard T8 troffers. Kitchens use standard T8 troffers, boxes, compact fluorescent cans. Storage areas have standard T8 boxes, troffers, indirects, wraps. Labs have standard T8 indirects, wallwash, coves, and valances. Gyms have T5 bay fixtures. Mechanical areas have standard T8 wraps. Walkways use MH surface fixtures, incandescent cans. Parking lots utilize MH parking/roadway fixtures. Perimeters have compact fluorescent wall mounted fixtures, exterior fixtures, MH exterior fixtures.

## Dunning Elementary School

### Building Characteristics

Dunning Elementary School was built in 1965. It is approximately 61,500 square feet on one level. It is brick construction with a flat rubber membrane roof with gravel ballast. The windows are original single plane type with small operable sections.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

Two Weil-McLain 88 gas-fired hot water boilers were installed to provide heating to two (2) Heating and Ventilation Units (HV) that serve the Gym, thirty-three (33) Unit Ventilators (UV) in the classrooms, and numerous fin tubes throughout the perimeter of the building.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Burnham hot water heater and a storage tank in the boiler room.

### Lighting Systems

Classrooms use efficient 4' T8 30w wraps, compact fluorescent drums. Halls utilize T5 "biax" indirects, compact fluorescent drums, decorative fixtures, efficient 4' T8 30w indirects. Offices utilize efficient 4' T8 30w old surface fixtures, wraps. Baths use T5 "biax" indirects, compact fluorescent drums, and efficient 4' T8 30w old surface fixtures. Auditoriums have efficient 4' T8 30w strips, incandescent cans. Cafeterias employ efficient 4' T8 30w wraps. Storage areas utilize efficient 4' T8 30w wraps, industrials, old surface fixtures, strips, LED surface fixtures, compact fluorescent squares. Gyms use T5 bay fixtures. Mechanical areas employ compact fluorescent surface fixtures, efficient 4' T8 30w strips. Labs have efficient 4' T8 30w

indirects, wraps. Kitchens employ efficient 4' T8 30w old surface fixtures. Driveways utilize MH parking/roadway fixtures. Perimeters use LED floods, squares, HPS exterior fixtures, incandescent exterior fixtures.

## Framingham High School

### Building Characteristics

Framingham High School was built in 1961 but has undergone major renovations throughout the years. It is approximately 396,000 square feet spread over two levels. It has classroom Wings A through K as well as two Gymnasiums, a library, a cafeteria, and a Wellness Center. It is block construction with a brick façade and has a flat rubber membrane roof with stone ballast.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The two boiler rooms at Framingham High School house five Weil-McLain 88 gas-fired hot water boilers that provide heat to four (4) AHUs serving the Gyms, twelve (12) Heat Recovery Units (HRU) serving the classroom wings, three (3) RTUs serving the Wellness Center, two (2) Heating and Ventilation Units and numerous fan coil units, VAV boxes and fin tubes located throughout the building. The VAV boxes modulated heating and cooling air provided by nine (9) gas-fired, DX cooled RTUs.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Lochinvar AWN, a PVI 20N, and a Ruud G91 hot water heater and two storage tanks located in two separate boiler rooms.

### Lighting Systems

Classrooms have standard T8 indirects, troffers, and T5 "biax" indirects. Offices utilize T5 "biax" indirects, standard T8 indirects, troffers, and T12 indirects. Halls utilize compact fluorescent cans, standard T8 troffers. Labs use standard T8 troffers, indirects. Baths utilize standard T8 wraps, troffers, compact fluorescent cans. Storage areas employ standard T8 wraps, indirects, and troffers. Gyms use standard T8 bay fixtures. Auditoriums employ LED cans, compact fluorescent cans, standard T8 wraps, incandescent cans. Cafeterias employ standard T8 wraps, T5 "biax" indirects. Libraries have compact fluorescent cans, decorative fixtures,

and standard T8 coves. Kitchens utilize standard T8 troffers, coves, compact fluorescent cans. Mechanical areas employ standard T8 wraps.

## Hemenway Elementary School

### Building Characteristics

Hemenway Elementary School was built in 1961 and is virtually identical to Dunning Elementary School. It is approximately 66,500 square feet including modular classrooms and is one story. It is brick construction with a flat rubber membrane roof. The existing windows are metal frame and single pane.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

Two Weil-McLain 88 gas-fired hot water boilers were installed to provide heating to two (2) RTUs that serve the Gym, thirty-three (33) Unit Ventilators (UV) in the classrooms, and numerous fin tubes throughout the building.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Burnham hot water heater and one storage tank in the boiler room.

### Lighting Systems

Classrooms utilize standard T8 wraps, troffers, boxes. Halls employ T5 "biax" indirects, standard T8 indirects, troffers, compact fluorescent drums. Offices employ standard T8 old surface fixtures, wraps, indirects, industrials, compact fluorescent drums. Baths have standard T8 troffers, wraps, compact fluorescent drums. Libraries have standard T8 troffers, wraps. Gyms employ T5 bay fixtures. Mechanical areas utilize LED surface fixtures. Cafeterias have standard T8 wraps. Storage areas use standard T8 old surface fixtures, wraps, LED surface fixtures, compact fluorescent drums. Kitchens use standard T8 old surface fixtures. Auditoriums employ incandescent cans. Perimeters utilize LED exterior fixtures.

## Juniper Hill Elementary School

### Building Characteristics

Juniper Hill Elementary School was built in 1959. The building has gone through several different uses over the years, including recently as a Jewish Day School. It is a two story building and approximately 44,300 square feet. It is brick construction with a flat rubber membrane roof. It has original single plane windows that have become very drafty in sections.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

Two Weil-McLain 88 gas-fired hot water boilers were installed to provide heating to one (1) RTU, one (1) Heating & Ventilation Unit in the Gym, twenty-four (24) Unit Ventilators (UV) in the classrooms, and numerous fin tubes throughout the building.

### Energy Management Systems

The school has a new DDC Tridium EMS that can be accessed via the internet. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Burnham hot water heater and one storage tank in the boiler room.

### Lighting Systems

Classrooms utilize standard T8 wraps, troffers. Halls employ compact fluorescent drums, LED cans, standard T8 troffers. Offices use standard T8 old surface fixtures, wraps, troffers. Baths utilize compact fluorescent drums, standard T8 wraps. Cafeterias use standard T8 wraps. Gyms employ T5 bay fixtures. Mechanical areas utilize LED surface fixtures. Storage areas have standard T8 old surface fixtures, wraps, troffers, LED surface fixtures. Kitchens have standard T8 old surface fixtures, wraps. Auditoriums utilize standard T8 wraps. Perimeters have HPS exterior fixtures, squares, standard T8 coves.

## King Administration Building

### Building Characteristics

The King Administration Building was built in 1957 as the Brook Water School. It has been converted to house school administration services, with classrooms converted to offices and meeting space. It is approximately 50,000 square feet spread over two levels. It is block construction with a flat rubber membrane roof. Windows are operable and single pane.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building has Two Weil-McLain 88 gas-fired hot water boilers that provide heating to six (6) RTUs, one (1) AHU, two (2) Heating & Ventilation Units that serve the Cafetorium and All-Purpose Room and twenty-five (25) Unit Ventilators (UV) in the former classrooms. The RTUs provide ventilation air to occupied spaces as well as DX cooled air.

### Energy Management Systems

The school has a new DDC Tridium EMS that can be accessed via the internet. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Ruud storage hot water heater.

### Lighting Systems

Offices have efficient 4' T8 30w troffers, wraps, indirects, standard T8 troffers, incandescent surface fixtures. Halls use standard T8 wraps, indirects, compact fluorescent squares, exits, efficient 4' T8 30w wraps. Auditoriums employ standard T8 indirects. Baths utilize efficient 4' T8 30w wraps, standard T8 indirects, wraps, compact fluorescent squares, LED surface fixtures, incandescent drums. Storage areas employ efficient 4' T8 30w old surface fixtures, troffers, wraps, strips, compact fluorescent squares, surface fixtures, incandescent drums. Gyms use T5 bay fixtures. Mechanical areas employ compact fluorescent surface fixtures. Parking lots utilize MH parking/roadway fixtures, HPS floods. Perimeters utilize HPS exterior fixtures, incandescent squares, MH exterior fixtures, LED floods.

## McCarthy Elementary School

### Building Characteristics

McCarthy Elementary School was built in 1952 but was largely reconstructed in 1994. It is approximately 94,936 square feet on two levels. It is block construction with a brick façade and a flat rubber membrane roof with gravel ballast. Windows are metal framed and double-paned.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

Two Weil-McLain 88 gas-fired hot water boilers provide heating to air handlers serving the Cafeteria, Administration Area, Gym, Library, Kitchen, and hallway along with forty (40) UVs, and six (6) Variable Air Volume (VAV) boxes. The VAVs modulate heating and cooling air delivered to individual spaces.



### Energy Management Systems

The school has a new DDC Tridium EMS that can be accessed via the internet. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Weil-McLain PFG hot water heater and one storage tank in the boiler room.

### Lighting Systems

Classrooms use standard T8 valances, indirects, strips, compact fluorescent cans, MH decorative fixtures, T5 "biax" decorative fixtures. Halls have compact fluorescent exterior fixtures, decorative fixtures, cans, exits, sconces, standard T8 coves, boxes, T5 "biax" decorative fixtures. Offices have standard T8 valances, boxes, coves, wraps, compact fluorescent cans, decorative fixtures, exits, drums. Libraries have standard T8 coves, strips, compact fluorescent cans. Cafeterias have LED cans, standard T8 indirects, wallwash, compact fluorescent cans. Baths have standard T8 strips, coves, valances, wraps, compact fluorescent cans. Storage areas employ standard T8 wraps, valances, strips, compact fluorescent drums. Gyms utilize T5 bay fixtures, compact fluorescent exits. Kitchens use standard T8 troffers, coves, wraps. Auditoriums have LED surface fixtures, standard T8 strips. Bedrooms employ standard T8 valances. Walkways utilize HPS parking/roadway fixtures. Perimeters use incandescent squares, HPS exterior fixtures, floods, compact fluorescent exterior fixtures. Parking lots use HPS parking/roadway fixtures.

## Potter Road Elementary School

### Building Characteristics

The Potter Road Elementary School was built in 1966 and is virtually identical to the Brophy Elementary School. It is two stories and approximately 63,600 square feet. It is standard block construction with a brick exterior and flat rubber membrane roof.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

In the main school, two Weil-McLain 88 gas-fired hot water boilers provide heating to five (5) Air Handling Units (AHU) that serve the Gym, Cafetorium, and Locker Rooms, and twenty-six (26) Unit Ventilators (UV) in the classrooms as well as perimeter heating. Heating hot water is circulated by two ten-horsepower pumps.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Burnham hot water heater in the boiler room along with three (3) storage tanks (two are valved off).

### Lighting Systems

Classrooms have standard T8 wraps, LED cans. Halls employ LED cans, standard T8 indirects, wraps, troffers, compact fluorescent decorative fixtures. Offices utilize standard T8 wraps, indirects, incandescent surface fixtures, compact fluorescent squares. Baths have compact fluorescent drums, squares, standard T8 vanities. Gyms use T5 bay fixtures. Libraries employ standard T8 wraps. Storage areas utilize compact fluorescent surface fixtures, squares, standard T8 wraps. Kitchens employ standard T8 wraps, LED cans. Auditoriums have standard T8 strips, incandescent surface fixtures. Cafeterias employ standard T8 wraps. Mechanical areas utilize standard T8 strips, compact fluorescent surface fixtures. Parking lots employ HPS floods, parking/roadway fixtures. Perimeters utilize MH exterior fixtures, incandescent squares.

## Stapleton Elementary School

### Building Characteristics

Stapleton Elementary School was built in 1922. Additions were built in 1956 and 1972. It is three stories and approximately 59,600 square feet. It is brick construction with most likely little to no insulation in the original section.

## Heating, Ventilating, and Air Conditioning Systems (HVAC)

Two Weil-McLain 88 gas-fired steam boilers were installed to provide heating to an AHU that serves the GYM, twenty-four (24) Unit Ventilators in the classrooms, and numerous fin tubes throughout the building.

## Energy Management Systems

The school has an older, very limited EMS system that is in the process of getting upgraded. Existing pneumatic actuators are currently controlled by the EMS but that are being replaced by DDC actuators to eliminate the need for a pneumatic compressor.

## Domestic Hot Water Systems

Domestic hot water is provided by a Burnham hot water heater in the boiler room and storage tank.

## Lighting Systems

Classrooms have standard T8 wraps. Halls use standard T8 old surface fixtures, wraps. Offices utilize standard T8 troffers, old surface fixtures, wraps, strips. Libraries utilize standard T8 wraps, old surface fixtures. Cafeterias use standard T8 boxes, wraps. Storage areas utilize standard T8 wraps, strips, troffers, old surface fixtures, LED surface fixtures, compact fluorescent squares. Baths employ standard T8 wraps, old surface fixtures, compact fluorescent old drums, squares, LED squares. Gyms have T5 bay fixtures. Kitchens use standard T8 wraps. Auditoriums utilize standard T8 strips. Parking lots employ HPS floods. Perimeters utilize HPS exterior fixtures.

## Thayer Campus of FHS

### Building Characteristics

The Thayer Building was built in 1905. It is approximately 10,800 square feet, with two stories plus a basement. It is brick construction and a shingled roof over the attic. It has previously been used as school and office space and currently houses the alternative high school. Windows are wood framed and have been replaced.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

One Weil-McLain 78 gas-fired steam boiler provides heating to floor mounted cast iron radiators throughout the building. All accessible piping is well insulated.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

## Domestic Hot Water Systems

Domestic hot water is provided by a Ruud storage hot water heater in the basement.

## Lighting Systems

Classrooms have T12 wraps. Offices use T12 wraps, troffers, and standard T8 wraps. Halls have compact fluorescent drums, T12 wraps. Baths have incandescent squares, drums, T12 wraps, compact fluorescent decorative fixtures. Kitchens use T12 wraps. Perimeters employ HPS old exterior fixtures, old surface fixtures.

## Walsh Middle School

### Building Characteristics

Walsh Middle School was built in 1969. It is approximately 201,000 square feet and two stories. The building features classroom space, administration offices, an auditorium, a gymnasium and a cafeteria. It is standard block construction with a brick façade and has a flat rubber membrane roof.

### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building has a hot water heating system with three Weil-McLain 88 gas-fired hot water boilers. These boilers provide hot water Heating & Ventilation units that serve the Cafeteria, Kitchen, Gyms & Locker Rooms, and offices. The classrooms are heated and ventilated by unit ventilators.

### Energy Management Systems

The school has a new DDC Tridium EMS that can be accessed via the internet. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

## Domestic Hot Water Systems

Domestic hot water is provided by a Weil-McLain PFG hot water heater and three storage tanks in the boiler room. A Ruud electric storage tank water heater serves the kitchen.

## Lighting Systems

Classrooms employ efficient 4' T8 28w wraps, strips, standard T8 troffers. Halls use efficient 4' T8 28w wraps, compact fluorescent exits. Gyms utilize T5 bay fixtures, efficient 4' T8 28w wraps. Libraries use LED cans, efficient 4' T8 28w wraps. Cafeterias utilize efficient 4' T8 28w wraps, incandescent cans, compact fluorescent exits. Baths employ efficient 4' T8 28w wraps, old surface fixtures. Offices have efficient 4' T8 28w wraps. Storage areas employ LED surface fixtures.

## Wilson Elementary School

### Building Characteristics

Wilson Elementary School was built in 1998. It is approximately 100,695 square feet and two stories. It is block construction with brick façade and has a flat rubber membrane roof. Windows are double pane with metal frames and operable sections in the classrooms. This building is one of the newest of the Town and School buildings.



### Heating, Ventilating, and Air Conditioning Systems (HVAC)

The building is heated by two Smith 28A gas-fired hot water boilers and cooled by a Trane RTHB 255-ton chiller. Hot and chilled water is fed to seven (7) Air Handling Units (AHU) that serve Library, Kitchen, Gym, and Classroom space and numerous Variable Air Volume (VAV) Boxes which provide heating, cooling, and ventilation air to the occupied spaces. There are also fin tubes throughout the building.

### Energy Management Systems

The school has an older DDC Tridium EMS that can be accessed via VPN. All relevant equipment has been added to the system. All actuators on damper and valves are digital, and adjustments to temperature setpoints and schedules can be made remotely. The system is monitored by staff via a PC at the school facility offices at the Fuller Middle School.

### Domestic Hot Water Systems

Domestic hot water is provided by a Patterson-Kelly hot water heater in the boiler room along with one storage tank.

### Lighting Systems

Classrooms utilize standard T8 indirects, coves, troffers, compact fluorescent cans, and drums. Halls have compact fluorescent sconces, cans, drums, exterior fixtures, standard T8 boxes, troffers, coves, T5 "biax" decorative fixtures. Offices have standard T8 troffers, indirects, valances, coves, compact fluorescent cans, sconces, T5 "biax" decorative fixtures. Libraries have compact fluorescent cans, standard T8 indirects, valances, T5 "biax" decorative fixtures. Baths have compact fluorescent cans, drums, exterior fixtures, sconces, standard T8 strips, troffers. Storage areas employ standard T8 troffers, valances, compact fluorescent cans, and incandescent cans. Cafeterias employ MH cans, incandescent cans, and compact fluorescent sconces. Kitchens employ standard T8 troffers, boxes, compact fluorescent cans. Mechanical areas have standard T8 industrials, strips. Gyms employ T5 bay fixtures, compact fluorescent exterior fixtures. Auditoriums have MH cans. Driveways use MH decorative fixtures. Parking lots employ MH decorative fixtures, floods. Walkways have MH decorative fixtures. Perimeters use MH exterior fixtures, cans, floods.

## Appendix C2: Peregrine Building Assessment -

Priority (1, 2, 3)	Bldg	ECM No.	ECM No. and Description	Technology Group	Approximate Implementation Cost	Utility Incentive Available¹	Potential Utility Savings				Annual Cost Avoidance	Reduces O&M Liability	Addresses End Of Life Equipment	Visual and/or Comfort Improvement	Simple Payback Yr
							Demand kW	Electric kWh/yr	Gas Therm/yr	Water MCF					
1	Barbieri ES	5	Replace CRT Computer Screens	O&M	\$6,100	\$0	24	4,000	(70)	-	\$900	-	X	X	6.8
1	Barbieri ES	7	Lighting Update	LIGHTING	\$84,300	\$23,600	196	64,000	(560)	-	\$11,500	-	-	-	5.3
2	Barbieri ES	9	Lighting Controls	LIGHTING	\$40,000	\$6,000	-	9,000	(100)	-	\$1,000	-	-	-	34.0
2	Barbieri ES	10	Recommission / Adjust Control Systems	CONTROLS	\$24,500	\$0	-	12,000	1,000	-	\$2,600	-	-	-	9.4
1	Barbieri ES	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	300	-	\$400	-	-	-	7.5
2	Barbieri ES	18	Install Fan VFD	CONTROLS	\$3,000	\$8,000	-	3,600	-	-	\$1,200	-	-	-	18.3
2	Barbieri ES	22	Walk-in Evaporator Control & ECM Motors	CONTROLS	\$6,000	\$0	4	3,000	-	-	\$500	-	-	-	12.0
1	Barbieri ES	25	Reduce Airflow (Resheave and/or New Motor)	HVAC	\$5,000	\$0	-	900	600	-	\$800	-	-	-	6.3
1	Barbieri ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$9,000	\$0	-	-	900	-	\$1,000	-	-	X	9.0
1	Brophy ES	5	Replace CRT Computer Screens	O&M	\$900	\$0	-	600	(10)	-	\$100	-	-	-	9.0
1	Brophy ES	6	Replace Refrigerator(s)	O&M	\$1,000	\$0	1	800	-	-	\$100	-	X	-	10.0
2	Brophy ES	8	Exterior Lighting Update	LIGHTING	\$32,000	\$3,200	-	22,000	-	-	\$2,700	-	-	-	10.7
2	Brophy ES	9	Lighting Controls	LIGHTING	\$30,000	\$4,500	-	7,000	(100)	-	\$800	-	-	-	31.9
2	Brophy ES	10	Recommission / Adjust Control Systems	CONTROLS	\$25,000	\$0	-	3,000	900	-	\$1,400	-	-	-	17.9
2	Brophy ES	12	Expand Central DDC Controls	CONTROLS	\$55,000	\$0	-	1,000	300	-	\$500	X	X	X	110.0
2	Brophy ES	13	Add Demand Control Ventilation	CONTROLS	\$12,000	\$700	-	2,000	600	-	\$900	-	-	-	12.6
1	Brophy ES	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	200	-	\$300	-	-	-	10.0
2	Brophy ES	20	Interlock Dishwasher EF	CONTROLS	\$5,000	\$0	-	300	400	-	\$500	-	-	-	10.0
2	Brophy ES	23	Update Pipe Insulation	HVAC	\$5,000	\$0	-	-	300	-	\$300	-	-	X	16.7
2	Brophy ES	24	Replace Motor	HVAC	\$750	\$0	1	400	-	-	\$70	-	-	-	10.7
2	Brophy ES	26	Install 2-Way Valves	HVAC	\$8,000	\$0	-	2,700	-	-	\$300	-	-	-	26.7
3	Brophy ES	29	Convert Electric Heating to Gas	HVAC	\$150,000	\$0	40	24,000	(1,000)	-	\$2,700	-	-	-	55.6
1	Brophy ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$22,000	\$0	-	-	1,700	-	\$1,900	-	-	X	11.6
3	Brophy ES	40	Replace Windows	ENVELOPE	\$800,000	\$0	-	2,000	1,400	-	\$1,800	X	X	X	444.4
1	Cameron MS	5	Replace CRT Computer Screens	O&M	\$3,500	\$0	8	2,000	(30)	-	\$400	-	X	X	8.8
1	Cameron MS	7	Lighting Update	LIGHTING	\$124,500	\$10,300	144	44,000	(350)	-	\$8,100	-	-	-	14.1
2	Cameron MS	9	Lighting Controls	LIGHTING	\$40,000	\$6,000	-	11,000	(200)	-	\$1,100	-	-	-	30.9
2	Cameron MS	10	Recommission / Adjust Control Systems	CONTROLS	\$25,000	\$0	-	2,000	140	-	\$400	X	-	-	62.5
2	Cameron MS	11	Integrate Controls to Web-Based Front End	CONTROLS	\$121,600	\$0	-	1,000	100	-	\$200	X	-	-	608.0
1	Cameron MS	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	300	-	\$400	-	-	-	7.5
2	Cameron MS	19	Install Pump VFD	CONTROLS	\$42,400	\$16,200	-	22,000	-	-	\$2,700	-	-	-	9.7
2	Cameron MS	22	Walk-in Evaporator Control & ECM Motors	CONTROLS	\$6,000	\$0	4	3,000	-	-	\$500	-	-	-	12.0
1	Cameron MS	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$3,300	\$0	-	-	320	-	\$400	-	-	X	8.3
2	Dunning ES	8	Exterior Lighting Update	LIGHTING	\$0	\$0	-	-	-	-	\$0	-	-	-	#DIV/0!
2	Dunning ES	9	Lighting Controls	LIGHTING	\$40,000	\$6,000	-	7,000	(100)	-	\$800	-	-	-	42.5
2	Dunning ES	10	Recommission / Adjust Control Systems	CONTROLS	\$20,000	\$0	-	1,000	2,000	-	\$2,300	X	-	-	8.7
2	Dunning ES	11	Integrate Controls to Web-Based Front End	CONTROLS	\$55,200	\$0	-	500	400	-	\$500	X	-	-	None
2	Dunning ES	13	Add Demand Control Ventilation	CONTROLS	\$8,200	\$450	-	500	300	-	\$400	-	-	-	19.4
1	Dunning ES	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	300	-	\$400	-	-	-	7.5
2	Dunning ES	23	Update Pipe Insulation	HVAC	\$2,500	\$0	-	-	150	-	\$170	-	-	X	14.7
3	Dunning ES	29	Convert Electric Heating to Gas	HVAC	\$150,000	\$0	36	22,000	(900)	-	\$2,500	-	-	X	60.0
1	Dunning ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$7,800	\$0	-	-	1,300	-	\$1,400	-	-	X	5.6
3	Dunning ES	40	Replace Windows	ENVELOPE	\$1,000,000	\$0	-	2,000	2,400	-	\$2,900	X	X	X	344.8
1	Framingham HS	1	Change Operating Policy for Fume Hoods	O&M	\$0	\$0	29	15,000	3,200	-	\$6,000	-	-	-	-
1	Framingham HS	2	Close Doors to Conditioned Space	O&M	\$0	\$0	31	4,000	-	-	\$1,200	-	-	-	-
1	Framingham HS	5	Replace CRT Computer Screens	O&M	\$4,500	\$0	18	2,000	-	-	\$600	-	X	X	7.5
1	Framingham HS	7	Lighting Update	LIGHTING	\$194,000	\$50,000	578	109,000	(1,200)	-	\$24,600	-	-	-	5.9
2	Framingham HS	9	Lighting Controls	LIGHTING	\$100,000	\$15,000	-	24,000	(400)	-	\$2,500	-	-	-	34.0
2	Framingham HS	10	Recommission / Adjust Control Systems	CONTROLS	\$75,000	\$0	72	18,000	3,500	-	\$7,600	-	-	-	9.9
2	Framingham HS	11	Integrate Controls to Web-Based Front End	CONTROLS	\$329,000	\$0	-	5,000	500	-	\$1,200	X	-	-	None
2	Framingham HS	13	Add Demand Control Ventilation	CONTROLS	\$16,500	\$900	-	-	1,500	-	\$1,700	-	-	-	9.2
1	Framingham HS	15	Add HHW Reset	CONTROLS	\$15,000	\$0	-	-	1,100	-	\$1,200	-	-	-	12.5
2	Framingham HS	16	Add Kitchen Exhaust Fan Control	CONTROLS	\$20,000	\$0	1	300	1,100	-	\$1,300	-	-	-	15.4
1	Framingham HS	17	Schedule Domestic Hot Water	CONTROLS	\$5,000	\$0	-	300	400	-	\$500	-	-	-	10.0
2	Framingham HS	18	Install Fan VFD	CONTROLS	\$30,000	\$2,000	48	11,000	-	-	\$2,400	-	-	-	11.7
1	Framingham HS	21	Vending Machine Controller	CONTROLS	\$2,000	\$0	6	2,800	-	-	\$500	-	-	-	4.0
2	Framingham HS	22	Walk-in Evaporator Control & ECM Motors	CONTROLS	\$6,000	\$0	4	3,000	-	-	\$500	-	-	-	12.0
1	Framingham HS	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$63,000	\$0	-	-	3,000	-	\$3,300	-	-	X	19.1
1	Hemenway ES	4	PC Load Management	O&M	\$4,500	\$0	-	3,000	(30)	-	\$300	-	-	-	15.0
2	Hemenway ES	7	Lighting Update	LIGHTING	\$36,700	\$7,100	88	20,000	(200)	-	\$4,100	-	-	-	7.2
2	Hemenway ES	9	Lighting Controls	LIGHTING	\$40,000	\$6,000	-	6,000	(100)	-	\$600	-	-	-	56.7
2	Hemenway ES	10	Recommission / Adjust Control Systems	CONTROLS	\$21,100	\$0	-	4,000	1,600	-	\$2,300	X	-	-	9.2
1	Hemenway ES	13	Add Demand Control Ventilation	CONTROLS	\$8,200	\$450	-	900	440	-	\$600	-	-	-	12.9
1	Hemenway ES	17	Schedule Domestic Hot Water	CONTROLS	\$5,000	\$0	-	300	300	-	\$400	-	-	-	7.5
2	Hemenway ES	23	Update Pipe Insulation	HVAC	\$2,500	\$0	-	-	150	-	\$200	-	-	-	12.5
2	Hemenway ES	29	Convert Electric Heating to Gas	HVAC	\$150,000	\$0	36	22,000	(900)	-	\$2,500	-	-	-	60.0
1	Hemenway ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$9,200	\$0	-	-	1,300	-	\$1,400	-	-	-	6.6
3	Hemenway ES	40	Replace Windows	ENVELOPE	\$1,000,000	\$0	-	2,500	2,400	-	\$2,900	-	-	-	344.8
1	Juniper ES	6	Replace Refrigerator(s)	O&M	\$3,000	\$0	3	2,400	-	-	\$360	-	X	-	8.3
1	Juniper ES	7	Lighting Update	LIGHTING	\$50,700	\$6,100	58	32,000	(200)	-	\$5,000	-	-	-	8.9
2	Juniper ES	9	Lighting Controls	LIGHTING	\$35,000	\$5,300	-	6,000	(100)	-	\$600	-	-	-	49.5
2	Juniper ES	10	Recommission / Adjust Control Systems	CONTROLS	\$21,100	\$0	-	500	2,400	-	\$2,700	X	-	-	7.8
2	Juniper ES	13	Add Demand Control Ventilation	CONTROLS	\$4,100	\$200	-	700	200	-	\$300	-	-	-	13.0
1	Juniper ES	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	400	-	\$500	-	-	-	6.0
2	Juniper ES	23	Update Pipe Insulation	HVAC	\$5,000	\$0	-	-	300	-	\$300	-	-	-	16.7
1	Juniper ES	27	Install Boiler Isolation Valves	HVAC	\$5,000	\$0	-	-	400	-	\$400	X	-	-	12.5
3	Juniper ES	29	Convert Electric Heating to Gas	HVAC	\$80,000	\$0	16	11,000	(500)	-	\$1,200	-	-	-	66.7
1	Juniper ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$2,500	\$0	-	-	400	-	\$400	-	-	X	6.3
3	Juniper ES	40	Replace Windows	ENVELOPE	\$750,000	\$0	-	1,000	1,200	-	\$1,400	X	X	X	535.7

1	King Administration	6	Replace Refrigerator(s)	O&M	\$1,000	\$0	1	800	-	-	\$100	-	X	-	10.0
2	King Administration	8	Exterior Lighting Update	LIGHTING	\$22,500	\$700	-	9,000	-	-	\$1,100	-	X	-	19.8
2	King Administration	9	Lighting Controls	LIGHTING	\$35,000	\$5,300	-	6,000	(100)	-	\$600	-	-	-	49.5
2	King Administration	10	Recommission / Adjust Control Systems	CONTROLS	\$21,200	\$0	-	11,000	1,200	-	\$2,700	X	-	-	7.9
2	King Administration	13	Add Demand Control Ventilation	CONTROLS	\$8,200	\$450	-	1,200	600	-	\$800	-	-	-	9.7
1	King Administration	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	300	-	\$400	-	-	-	7.5
2	King Administration	23	Update Pipe Insulation	HVAC	\$500	\$0	-	-	30	-	\$30	-	-	X	16.7
1	King Administration	27	Install Boiler Isolation Valves	HVAC	\$5,000	\$0	-	-	400	-	\$440	X	-	-	11.4
1	King Administration	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$1,900	\$0	-	-	200	-	\$200	-	-	-	9.5
3	King Administration	40	Replace Windows	ENVELOPE	\$900,000	\$0	6	3,000	1,500	-	\$2,100	X	X	X	428.6
1	McCarthy ES	7	Lighting Update	LIGHTING	\$81,100	\$1,200	175	55,000	(500)	-	\$10,000	-	-	-	8.0
2	McCarthy ES	8	Exterior Lighting Update	LIGHTING	\$0	\$0	-	-	-	-	\$0	X	-	-	#DIV/0!
2	McCarthy ES	9	Lighting Controls	LIGHTING	\$60,000	\$9,000	-	10,000	(200)	-	\$1,000	-	-	-	51.0
2	McCarthy ES	10	Recommission / Adjust Control Systems	CONTROLS	\$40,900	\$0	-	32,000	(40)	-	\$3,900	-	-	-	10.5
2	McCarthy ES	13	Add Demand Control Ventilation	CONTROLS	\$8,100	\$450	-	1,300	1,300	-	\$1,600	-	-	-	4.8
1	McCarthy ES	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	300	-	\$400	-	-	-	7.5
2	McCarthy ES	19	Install Pump VFD	CONTROLS	\$17,900	\$6,300	-	11,400	-	-	\$1,400	-	-	-	8.3
1	McCarthy ES	23	Update Pipe Insulation	HVAC	\$5,000	\$0	-	-	300	-	\$300	-	-	-	16.7
2	McCarthy ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$18,700	\$0	-	300	2,900	-	\$3,200	-	X	-	5.8
1	Walsh MS	3	Shutdown Boiler Plant at Night	O&M	\$0	\$0	-	-	1,300	-	\$1,400	-	-	-	15.5
2	Walsh MS	8	Exterior Lighting Update	LIGHTING	\$43,500	\$0	-	22,300	-	-	\$2,800	X	-	-	56.1
2	Walsh MS	9	Lighting Controls	LIGHTING	\$39,300	\$0	-	7,000	(120)	-	\$700	-	-	-	15.5
2	Walsh MS	10	Recommission / Adjust Control Systems	CONTROLS	\$51,000	\$0	-	6,000	2,300	-	\$3,300	-	-	-	11.2
2	Walsh MS	13	Add Demand Control Ventilation	CONTROLS	\$29,000	\$900	-	5,600	1,600	-	\$2,500	-	-	-	22.2
2	Walsh MS	16	Add Kitchen Exhaust Fan Control	CONTROLS	\$20,000	\$0	1	200	800	-	\$900	-	-	-	7.5
1	Walsh MS	17	Schedule Domestic Hot Water	CONTROLS	\$3,000	\$0	-	300	300	-	\$400	-	-	-	6.3
2	Walsh MS	23	Update Pipe Insulation	HVAC	\$500	\$0	-	-	75	-	\$80	-	-	-	12.5
2	Walsh MS	24	Replace Motor	HVAC	\$2,500	\$0	-	1,600	-	-	\$200	-	-	-	#DIV/0!
2	Walsh MS	28	Add Heating Capacity Where Limited	HVAC	\$15,000	\$0	-	-	-	-	\$0	X	-	X	50.0
2	Walsh MS	33	Replace Domestic Hot Water System	HVAC	\$35,000	\$0	-	-	600	-	\$700	X	-	-	#DIV/0!
1	Walsh MS	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$0	\$0	-	-	-	-	\$0	-	-	X	16.7
2	Walsh MS	36	Seal Windows	ENVELOPE	\$10,000	\$0	-	-	500	-	\$600	X	-	X	790.0
3	Walsh MS	40	Replace Windows	ENVELOPE	\$69,000.0	\$0	-	-	1,000.0	-	\$1,100.0	X	X	X	6.0
1	Wilson ES	7	Lighting Update	LIGHTING	\$99,000	\$16,100	267	72,000	(700)	-	\$13,900	-	-	-	42.9
2	Wilson ES	9	Lighting Controls	LIGHTING	\$35,000	\$5,000	-	7,000	(120)	-	\$700	-	-	-	27.8
2	Wilson ES	10	Recommission / Adjust Control Systems	CONTROLS	\$25,000	\$0	-	3,700	400	-	\$900	X	-	-	None
2	Wilson ES	11	Integrate Controls to Web-Based Front End	CONTROLS	\$121,600	\$0	-	1,000	200	-	\$300	X	-	-	16.6
2	Wilson ES	13	Add Demand Control Ventilation	CONTROLS	\$12,300	\$700	-	1,200	500	-	\$700	-	-	-	10.0
1	Wilson ES	17	Schedule Domestic Hot Water	CONTROLS	\$5,000	\$0	-	300	400	-	\$500	-	-	-	42.8
2	Wilson ES	19	Install Pump VFD	CONTROLS	\$40,700	\$15,000	-	4,800	-	-	\$600	-	-	-	17.4
1	Wilson ES	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$15,700.0	\$0	-	200.0	800.0	-	\$900.0	-	X	-	3.0
1	Fire Headquarters	4	PC Load Management	O&M	\$300	\$0	-	1,000	(20)	-	\$100	-	-	-	8.7
1	Fire Headquarters	7	Lighting Update	LIGHTING	\$54,000	\$8,800	64	32,000	(160)	-	\$5,200	-	-	-	26.0
2	Fire Headquarters	9	Lighting Controls	LIGHTING	\$15,000	\$2,000	-	4,700	(60)	-	\$500	-	-	-	9.6
2	Fire Headquarters	11	Integrate Controls to Web-Based Front End	CONTROLS	\$71,100	\$2,700	-	27,000	3,400	-	\$7,100	-	-	-	51.3
2	Fire Headquarters	19	Install Pump VFD	CONTROLS	\$16,600	\$1,200	-	2,700	-	-	\$300	-	-	-	2.5
1	Fire Headquarters	21	Vending Machine Controller	CONTROLS	\$500	\$0	-	2,000	(40)	-	\$200	-	-	-	666.7
3	Fire Headquarters	31	Redesign/Replace HVAC System	HVAC	\$1,000,000	\$0	-	7,000	600	-	\$1,500	X	-	X	12.3
1	Fire Headquarters	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$8,600	\$0	-	200	600	-	\$700	-	-	X	13.6
1	Fire Headquarters	36	Attention to Overhead Door Seals	ENVELOPE	\$3,000.0	\$0	-	-	200.0	-	\$220.0	-	X	-	4.8
1	Library	4	PC Load Management	O&M	\$2,400	\$0	-	4,800	(100)	-	\$500	-	-	-	7.8
1	Library	7	Lighting Update	LIGHTING	\$26,800	\$400	52	19,900	(180)	-	\$3,400	-	-	-	26.0
2	Library	9	Lighting Controls	LIGHTING	\$15,000	\$2,000	-	4,600	(80)	-	\$500	-	-	-	29.0
2	Library	11	Integrate Controls to Web-Based Front End	CONTROLS	\$353,200	\$13,500	-	67,000	3,100	-	\$11,700	-	-	-	10.0
1	Library	17	Schedule Domestic Hot Water	CONTROLS	\$5,000	\$0	-	300	400	-	\$500	-	-	-	26.8
2	Library	19	Install Pump VFD	CONTROLS	\$23,000	\$6,900	-	5,000	-	-	\$600	-	-	-	8.3
2	Library	23	Update Pipe Insulation	HVAC	\$500	\$0	-	-	50	-	\$60	-	-	X	34.6
2	Library	24	Replace Motor	HVAC	\$4,500	\$0	2	700	-	-	\$130	-	X	-	103.6
3	Library	32	Replace Boiler Plant	HVAC	\$253,300.0	\$15,000.0	-	-	2,100.0	-	\$2,300.0	X	X	-	9.7
1	Library	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$2,900.0	\$0	-	100.0	300.0	-	\$300.0	-	-	X	4.5
1	Memorial Hall	4	PC Load Management	O&M	\$3,600	\$0	-	7,700	(160)	-	\$800	-	-	-	#DIV/0!
1	Memorial Hall	7	Lighting Update	LIGHTING	\$0	\$0	-	-	-	-	\$0	-	-	-	9.6
2	Memorial Hall	11	Integrate Controls to Web-Based Front End	CONTROLS	\$53,000	\$2,250	-	6,000	4,100	-	\$5,300	-	-	-	10.0
1	Memorial Hall	17	Schedule Domestic Hot Water	CONTROLS	\$5,000	\$0	-	300	400	-	\$500	-	-	-	1.1
1	Memorial Hall	21	Vending Machine Controller	CONTROLS	\$1,300	\$390	-	7,800	(170)	-	\$800	-	-	-	29.4
2	Memorial Hall	23	Update Pipe Insulation	HVAC	\$5,000	\$0	-	-	150	-	\$170	X	-	-	416.7
7	Memorial Hall	34	Convert to Hot Water Heating System	HVAC	\$750,000	\$0	-	(5,000)	2,200	-	\$1,800	X	-	X	9.2
1	Memorial Hall	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$1,200	\$0	-	-	120	-	\$130	-	-	-	8.3
2	Memorial Hall	41	Seal Shaft / Fireplace	ENVELOPE	\$500	\$0	-	-	50	-	\$60	-	-	-	33.3
2	Memorial Hall	42	Attention to Airseal Details	ENVELOPE	\$10,000	\$0	-	-	250	-	\$300	-	-	-	66.7
3	Memorial Hall	43	Insulate Attic, Misc	ENVELOPE	\$20,000	\$0	-	-	300	-	\$300	-	-	-	4.0
1	Police Station	4	PC Load Management	O&M	\$1,600	\$0	-	4,200	(90)	-	\$400	-	-	-	5.4
1	Police Station	7	Lighting Update	LIGHTING	\$71,000	\$8,000	160	72,200	(700)	-	\$11,600	-	-	-	18.6
2	Police Station	9	Lighting Controls	LIGHTING	\$15,000	\$2,000	-	6,500	(110)	-	\$700	-	-	-	21.2
2	Police Station	11	Integrate Controls to Web-Based Front End	CONTROLS	\$196,900	\$0	-	59,000	1,800	-	\$9,300	-	-	-	8.3
2	Police Station	14	Add Occupancy Based HVAC Control	CONTROLS	\$10,000	\$0	-	5,000	500	-	\$1,200	-	-	-	2.0
2	Police Station	18	Install Fan VFD	CONTROLS	\$10,000	\$0	-	40,000	-	-	\$4,900	-	-	-	35.2
2	Police Station	19	Install Pump VFD	CONTROLS	\$48,000	\$9,300	-	9,000	-	-	\$1,100	-	-	-	7.5
1	Police Station	21	Vending Machine Controller	CONTROLS	\$450	\$0	-	600	(10)	-	\$60	-	-	-	20.8
2	Police Station	24	Replace Motor	HVAC	\$2,500	\$0	1	800	-	-	\$120	-	-	-	350.0
3	Police Station	30	New HVAC Systems	HVAC	\$49,000	\$0	-	700	50	-	\$140	-	-	-	12.5
1	Police Station	35	Add / Replace Door Seals & Align Doors	ENVELOPE	\$1,500	\$0	-	50	100	-	\$120	-	-	-	4.5
1	Police Station	36	Attention to Overhead Door Seals	ENVELOPE	\$500	\$0	-	-	100	-	\$110	-	-	-	26.7
3	Police Station	43	Insulate Attic, Misc	ENVELOPE	\$8,000	\$0	-	170	260	-	\$300	-	-	-	

**Priority 1 - Building Summary**

Building	Approximate Implementation Cost	Utility Incentive Available	Potential Utility Savings				Annual Cost Avoidance	2013 EUI kBtu/sf	Projected EUI kBtu/sf	Overall Savings	Simple Payback Yr
			Demand kW	Electric kWh/yr	Gas Therm/yr	Water MCF/yr					
Barbieri ES	\$107,400	\$23,600	220	69,200	1,170	-	\$14,600	54	51	5.9%	5.7
Brophy ES	\$26,900	\$0	1	1,700	1,890	-	\$2,400	50	48	5.7%	11.2
Cameron MS	\$134,300	\$10,300	152	46,300	240	-	\$9,300	49	47	3.3%	13.3
Dunning ES	\$10,800	\$0	-	300	1,600	-	\$1,800	57	55	4.6%	6.0
Framingham HS	\$283,500	\$50,000	663	133,100	6,500	-	\$37,900	48	45	5.8%	6.2
Hemenway ES	\$53,400	\$7,100	88	23,300	1,370	-	\$6,200	62	59	5.7%	7.5
Juniper ES	\$64,200	\$6,100	61	34,700	1,000	-	\$6,660	62	57	7.9%	8.7
King Administration	\$10,900	\$0	1	1,100	900	-	\$1,140	73	71	2.6%	9.6
McCarthy ES	\$102,800	\$1,200	175	55,600	2,700	-	\$13,600	55	50	8.7%	7.5
Walsh MS	\$3,000	\$0	-	300	1,600	-	\$1,800	45	44	1.8%	1.7
Wilson ES	\$119,700	\$16,100	267	72,500	500	-	\$15,300	36	34	5.9%	6.8
Fire Headquarters	\$66,400	\$8,800	64	35,200	580	-	\$6,420	97	90	7.4%	9.0
Library	\$37,100	\$400	52	25,100	420	-	\$4,700	72	70	3.3%	7.8
Memorial Hall	\$11,100	\$390	-	15,800	190	-	\$2,230	58	57	1.6%	4.8
Police Station	\$75,050	\$8,000	160	77,050	(600)	-	\$12,290	92	87	5.2%	5.5
<b>Total</b>	<b>\$1,106,550</b>	<b>\$131,990</b>	<b>1,904</b>	<b>591,250</b>	<b>20,060</b>	<b>-</b>	<b>\$136,340</b>	<b>53</b>	<b>50</b>	<b>4.9%</b>	<b>7.1</b>

**Priority 2 - Building Summary**

Building	Approximate Implementation Cost	Utility Incentive Available	Potential Utility Savings				Annual Cost Avoidance	2013 EUI kBtu/sf	Projected EUI kBtu/sf	Overall Savings	Simple Payback Yr
			Demand kW	Electric kWh/yr	Gas Therm/yr	Water MCF/yr					
Barbieri ES	\$100,500	\$14,000	4	33,600	900	-	\$5,300	51	49	3.6%	16.3
Brophy ES	\$172,750	\$8,400	1	38,400	2,400	-	\$7,470	48	42	11.5%	22.0
Cameron MS	\$235,000	\$22,200	4	39,000	40	-	\$4,900	47	46	2.6%	43.4
Dunning ES	\$125,900	\$6,450	-	9,000	2,750	-	\$4,170	55	50	9.1%	28.6
Framingham HS	\$576,500	\$17,900	125	61,300	6,200	-	\$17,200	45	43	4.7%	32.5
Hemenway ES	\$221,800	\$6,450	36	32,900	1,190	-	\$6,200	59	55	6.4%	34.7
Juniper ES	\$65,200	\$5,500	-	7,200	2,800	-	\$3,900	57	50	12.0%	15.3
King Administration	\$87,400	\$6,450	-	27,200	1,730	-	\$5,230	71	66	7.5%	15.5
McCarthy ES	\$131,900	\$15,750	-	54,700	1,360	-	\$8,200	50	47	6.7%	14.2
Walsh MS	\$245,800	\$900	1	42,700	5,755	-	\$11,780	44	41	8.1%	20.8
Wilson ES	\$234,600	\$20,700	-	17,700	980	-	\$3,200	34	32	3.4%	66.8
Fire Headquarters	\$102,700	\$5,900	-	34,400	3,340	-	\$7,900	90	71	20.3%	12.3
Library	\$396,200	\$22,400	2	77,300	3,070	-	\$12,990	70	59	15.4%	28.8
Memorial Hall	\$68,500	\$2,250	-	6,000	4,550	-	\$5,830	57	51	10.9%	11.4
Police Station	\$282,400	\$11,300	1	120,300	2,190	-	\$17,320	87	72	NA	15.7
<b>Total</b>	<b>\$3,047,150</b>	<b>\$166,550</b>	<b>174</b>	<b>601,700</b>	<b>39,255</b>	<b>-</b>	<b>\$121,590</b>	<b>50</b>	<b>46</b>	<b>7.3%</b>	<b>23.7</b>

**Priority 3 - Building Summary**

Building	Approximate Implementation Cost	Utility Incentive Available	Potential Utility Savings				Annual Cost Avoidance	2013 EUI kBtu/sf	Projected EUI kBtu/sf	Overall Savings	Simple Payback Yr
			Demand kW	Electric kWh/yr	Gas Therm/yr	Water MCF/yr					
Barbieri ES	\$0	\$0	-	-	-	-	\$0	49	49	0.0%	NA
Brophy ES	\$950,000	\$0	40	26,000	400	-	\$4,500	42	40	4.5%	211.1
Cameron MS	\$0	\$0	-	-	-	-	\$0	46	46	0.0%	NA
Dunning ES	\$1,150,000	\$0	36	24,000	1,500	-	\$5,400	50	46	7.6%	213.0
Framingham HS	\$0	\$0	-	-	-	-	\$0	43	43	0.0%	NA
Hemenway ES	\$1,000,000	\$0	-	2,500	2,400	-	\$2,900	55	51	7.4%	344.8
Juniper ES	\$830,000	\$0	16	12,000	700	-	\$2,600	50	48	5.0%	319.2
King Administration	\$900,000	\$0	6	3,000	1,500	-	\$2,100	66	63	4.9%	428.6
McCarthy ES	\$0	\$0	-	-	-	-	\$0	47	47	0.0%	NA
Walsh MS	\$869,000	\$0	-	-	1,000	-	\$1,100	41	40	1.2%	790.0
Wilson ES	\$0	\$0	-	-	-	-	\$0	32	32	0.0%	NA
Fire Headquarters	\$1,000,000	\$0	-	7,000	600	-	\$1,500	71	68	4.7%	666.7
Library	\$253,300	\$15,000	-	-	2,100	-	\$2,300	59	55	6.7%	103.6
Memorial Hall	\$20,000	\$0	-	-	300	-	\$300	51	51	0.8%	66.7
Police Station	\$57,000	\$0	-	870	310	-	\$440	72	71	1.1%	129.5
<b>Total</b>	<b>\$7,029,300</b>	<b>\$15,000</b>	<b>98</b>	<b>75,370</b>	<b>10,810</b>	<b>-</b>	<b>\$23,140</b>	<b>46</b>	<b>46</b>	<b>1.6%</b>	<b>303.1</b>

**Priority 1, 2 and 3 - Building Summary**

Building	Approximate Implementation Cost	Utility Incentive Available	Potential Utility Savings				Annual Cost Avoidance	2013 EUI kBtu/sf	Projected EUI kBtu/sf	Overall Savings	Simple Payback Yr
			Demand kW	Electric kWh/yr	Gas Therm/yr	Water MCF/yr					
Barbieri ES	\$207,900	\$37,600	224	102,800	2,070	-	\$19,900	54	49	9.2%	8.6
Brophy ES	\$1,149,650	\$8,400	42	66,100	4,690	-	\$14,370	50	40	20.3%	79.4
Cameron MS	\$369,300	\$32,500	156	85,300	280	-	\$14,200	49	46	5.7%	23.7
Dunning ES	\$1,286,700	\$6,450	36	33,300	5,850	-	\$11,370	57	46	19.8%	112.6
Framingham HS	\$860,000	\$67,900	788	194,400	12,700	-	\$55,100	48	43	10.2%	14.4
Hemenway ES	\$1,275,200	\$13,550	124	58,700	4,960	-	\$15,300	62	51	18.2%	82.5
Juniper ES	\$959,400	\$11,600	77	53,900	4,500	-	\$13,160	62	48	23.0%	72.0
King Administration	\$998,300	\$6,450	7	31,300	4,130	-	\$8,470	73	63	14.2%	117.1
McCarthy ES	\$234,700	\$16,950	175	110,300	4,060	-	\$21,800	55	47	14.8%	10.0
Walsh MS	\$1,117,800	\$900	1	43,000	8,355	-	\$14,680	45	40	10.9%	76.1
Wilson ES	\$354,300	\$36,800	267	90,200	1,480	-	\$18,500	36	32	9.1%	17.2
Fire Headquarters	\$1,169,100	\$14,700	64	76,600	4,520	-	\$15,820	97	68	29.7%	73.0
Library	\$686,600	\$37,800	54	102,400	5,590	-	\$19,990	72	55	23.6%	32.5
Memorial Hall	\$99,600	\$2,640	-	21,800	5,040	-	\$8,360	58	51	13.0%	11.6
Police Station	\$414,450	\$19,300	161	198,220	1,900	-	\$30,050	92	71	22.4%	13.1
<b>Total</b>	<b>\$11,183,000</b>	<b>\$313,540</b>	<b>2,176</b>	<b>1,268,320</b>	<b>70,125</b>	<b>-</b>	<b>\$281,070</b>	<b>53</b>	<b>46</b>	<b>13.9%</b>	<b>38.7</b>

## Appendix C3: Siemens Streetlight Analysis -

# Framingham's Streetlights in 2013

- 4,871 “cobra head” type lights
  - 100% are high pressure sodium lamps (orange color) and
  - 86% are  $\leq 50$  watts (4,171 fixtures) 14% are  $\geq 100$  watts (700 fixtures)
- Existing Cost and Energy Use
  - Annual cost of electricity= \$265,000
  - Annual kilowatt hours of electricity= 1,680,000
- Conversion to LED would...
  - Reduce annual energy use by 55-65%
  - Save the Town approximately \$151,000 per year
  - Pay for itself in ~10 years and could be funded from existing budget
  - Make the Town eligible for ~\$240,000 in grant money from NSTAR

# Streetlight comparison

	High Pressure Sodium (existing)	Light Emitting Diode (LED)
Color	Orange	White
Life expectancy	24,000 hours (~6 years)	100,000 hours (~20 years)
Energy use	-	50-75% less
Payback	-	4-12 years
NSTAR accepts?	Yes	Yes



# Existing vs. Proposed Lights

Streetlight Type	Watts per Fixture	Number of Lights	LED Watts per Fixture	LED Watts Assumed
35 watt HPS	41	7	15-26	26
50 watt HPS	58	4,164	15-26	26
100 watt HPS	117	73	43-53	51
150 watt HPS	175	387	55-67	67
250 watt HPS*	295	180	123-140	140
400 watt HPS*	464	60	123-213	140
<b>TOTAL</b>		<b>4,871</b>		

\* May be more light than necessary, depending on area & spacing of lights.

# Conversion to LED Streetlights: Opportunities for Savings

**SIEMENS**

	Annual operating cost	Net Project Cost	Annual Savings	Payback (years)
Existing HPS	\$265,000	n/a	n/a	n/a
Proposed LED Conversion (Town-wide)	\$114,000	\$1,600,000	\$151,000	10.6
Proposed LED Conversion (High Wattage Fixtures Only- 14%)	\$202,000	\$220,000	\$63,000	3.5

# Status of LED Streetlight Conversions in Massachusetts



- Communities with 1,000+ LED streetlights installed by end of 2012:
  - Arlington
  - Boston
  - Watertown
  
- Communities installing 1,000+ LED streetlights in early 2013:
  - Arlington
  - Chelsea
  - Natick
  - Woburn
  
- Nearly all NSTAR communities are considering installing LED streetlights on a community-wide basis or as a pilot project in the next 6-12 months

## Benefits of Performance Contracting Programs

1

- ***Guaranteed Project Performance***

2

- ***No Change Orders or Added Cost***

3

- ***Design Build Accountability***

4

- ***Improved Facilities and Infrastructure***

5

- ***Single Source Solution***

6

- ***Local Support, Services and Training***

# Framingham's Streetlights in 2013

- 4,871 “cobra head” type lights
  - 100% are high pressure sodium lamps (orange color) and
  - 86% are  $\leq 50$  watts (4,171 fixtures) 14% are  $\geq 100$  watts (700 fixtures)
- Existing Cost and Energy Use
  - Annual cost of electricity= \$265,000
  - Annual kilowatt hours of electricity= 1,680,000
- Conversion to LED would...
  - Reduce annual energy use by 55-65%
  - Save the Town approximately \$151,000 per year
  - Pay for itself in ~10 years and could be funded from existing budget
  - Make the Town eligible for ~\$240,000 in grant money from NSTAR