



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
180 Beaman Street, West Boylston, MA 01583
Phone: 508-792-7880 Fax: 508-792-7706
TTY: 508-835-9796

CHARLES D. BAKER
Governor

KARYN E. POLITO
Lieutenant Governor

MARYLOU SUDDERS
Secretary

MONICA BHAREL, MD, MPH
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

September 21, 2018

Kevin F. Coppinger, Sheriff
Essex County Women in Transition
20 Manning Avenue
Middleton, MA 01949

Re: Facility Inspection – Essex County Women in Transition, Salisbury

Dear Sheriff Coppinger:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Essex County Women in Transition on September 20, 2018 accompanied by Kerri Patterson, Assistant Deputy Superintendent. Violations noted during the inspection are listed below including 4 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(indicates conditions documented on previous inspection reports)*

Hallway

No Violations Noted

Office (# 2)

No Violations Noted

Program Coordinator's Office (# 3)

No Violations Noted

Deputy Superintendent's Office (# 4)

No Violations Noted

Laundry Room (# 5)

No Violations Noted

Staff Bathroom (# 6)

No Violations Noted

Copy Room (# 7)

No Violations Noted

Hot Water Heater Room (# 8)

No Violations Noted

HSU (# 9)

No Violations Noted

Communication Closet (# 10)

No Violations Noted

Visitor's Bathroom (# 12)

No Violations Noted

Dorm Rooms

105 CMR 451.322*

Cell Size: Inadequate floor space in all dorm rooms

Dorm Room (# 11)

105 CMR 451.123*

Maintenance: Ceiling tiles water stained in bathroom

Dorm Room (# 13)

No Violations Noted

Dorm Room (# 14)

105 CMR 451.123

Maintenance: Ceiling vent blocked in bathroom

Dorm Room (# 15)

105 CMR 451.123

Maintenance: Ceiling vent blocked in bathroom

Dorm Room (# 16)

105 CMR 451.123*

Maintenance: Ceiling vent blocked in bathroom

Dorm Room (# 17)

105 CMR 451.123*

Maintenance: Ceiling vent blocked in bathroom

Shower Room (# 18)

No Violations Noted

Kitchen (# 19)

No Violations Noted

Meeting and Dining Room (# 20)

No Violations Noted

Observations and Recommendations

1. The inmate population was 23 at the time of inspection.
2. The handicapped shower was not in use at the time of the inspection.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/des and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Amy Medeiros, MPH
Environmental Health Inspector, CSP, BEH

cc: Monica Bharel, MD, MPH, Commissioner, DPH
Jana Ferguson, Director, BEH
Steven Hughes, Director, CSP, BEH
Marylou Sudders, Secretary, Executive Office of Health and Human Services
Thomas Turco, Commissioner, DOC
Aaron Eastman, Superintendent
Kerri Patterson, Assistant Deputy Superintendent
Elizabeth Gilmartin, EHSO
John Morris, CHO, Director, Salisbury Health Department
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Daniel Bennett, Secretary, EOPSS
Nelson Alves, Director, Policy Development and Compliance Unit