



# MassDEP

Commonwealth of Massachusetts  
Department of Environmental Protection

## Underground Storage Tank Program Fact Sheet

---

### **Installs, Removals, and Closure in Place --- Notification Requirements**

Massachusetts' UST regulations, [310 CMR 80.00](#), establish a number of notification requirements for installations, removals, and closures in place. The following information provides a brief summary of those requirements.

- ✓ **Installations.** Within 30 days of putting regulated substance (e.g., motor vehicle fuel) in a tank, owners/operators must notify MassDEP and submit installation documentation. Please notify MassDEP by registering or updating your tank information at [MassDEP's online tank registration system](#). Installation documents may be sent via email to [DEP.UST@mass.gov](mailto:DEP.UST@mass.gov). More detailed information can be found at [MassDEP's tank installation fact sheet](#).
- ✓ **Removals.** Within 90 days of the tank or equipment removal date, owners/operators must notify MassDEP of the removal and must submit a removal assessment report. Please notify MassDEP by updating your tank information at [MassDEP's online tank registration system](#). Removal assessments may be sent via email to [DEP.UST@mass.gov](mailto:DEP.UST@mass.gov).
- ✓ **Closure in Place.** MassDEP's UST Program reviews the applicability of all closure in place requests. If you are considering closure in place of a tank, please contact the UST Program via email at [DEP.UST@mass.gov](mailto:DEP.UST@mass.gov) or via phone at [617-556-1036](tel:617-556-1036) before developing or submitting a determination/request.