

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 101	03-01-21	Candidate Number	
Skill Title: DON PERSONAL PROTECTIVE CLOTHING				
NFPA Objective:	3.3.9, 4.1.2	Minimum to pass	10	
PERFORMANCE:				P F

■	1.	Dons trouser/boot combination.				
	2.	Assures suspenders are attached to trousers.				
	3.	Trousers are pulled on and fastened at waist.				
	4.	Suspenders are adjusted over shoulders.				
■	5.	Dons protective hood, pulling down around neck and shoulders.				
	6.	Dons turnout coat.				
	7.	Assures all closures are fastened.				
	8.	Assures collar is turned up and secured around neck.				
■	9.	Dons helmet with ear flaps down.				
	10.	Fastens and adjusts chin strap under chin.				
	11.	Dons PASS device, if not integrated into SCBA.				
■	12.	Dons gloves and assures no skin is exposed between cuff of coat and glove.				
	13.	Completes within one minute.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I-102	03-01-21	Candidate Number	
Skill Title: DAILY IN-SERVICE INSPECTION OF SCBA				
NFPA Objective:	4.3.1, 4.5.1	Minimum to pass	12	
PERFORMANCE:			P	F

1.	Candidate appropriately wears full protective clothing				
2.	Candidate ensures all components of SCBA are present and checked for integrity: harness assembly, cylinder, facepiece, hoses, end of service indicators, regulators, and accessories (e.g., PASS device).				
3.	Candidate removes cylinder from harness and inspect all components of SCBA for cleanliness and damage.				
4.	Immediately cleans dirty components. If damage is found, candidate should verbalize that he/she would remove a damaged unit from service.				
5.	Checks integrity of facepiece for cracking and that straps are fully extended.				
6.	Checks facepiece lens for excessive scratches, cracks or separation from mask.				
7.	Checks hydrostatic test date.				
8.	Checks position of mainline, by-pass, don/doffing switch and positive pressure valves. (manufacturer dependent)				
9.	Checks cylinder pressure and determine if full. (90% or above-2216 psi = 1994psi/4500 psi = 4050/5500 psi = 4950 psi)				
10.	Opens cylinder valve fully, checking for low air audible alarm. (Note: on some SCBA, the audible alarm does not sound when the cylinder valve is opened.)				
11.	Integrated PASS device turns on and sounds, if equipped.				
12.	Compares cylinder gauge to remote pressure gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi. 5500 psi systems not to exceed 250 psi.)				
13.	Checks operation of by-pass, purge, and mainline valves. (manufacturer dependent)				
14.	Checks operation of PASS.				
15.	Connects facepiece to regulator and inhales to inspect operation of the regulator.				

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

**Massachusetts Fire Training Council
Firefighter Practical Certification Examination**

16.	Closes cylinder valve and continues inhaling to check the activation of the low air alarm.				
17.	Deactivates PASS device, if integrated.				
18.	Detaches the facepiece and returns SCBA to original area ready for donning.				

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Examiner Name: _____ Signature: _____ Date: __/__/__

Please circle:	PASS	FAIL	RETAKE
----------------	------	------	--------

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 103	03-01-21	Candidate Number	
Skill Title: DON SCBA – OVER THE HEAD METHOD				
NFPA Objective:	4.3.1	Minimum to pass	15	
PERFORMANCE:			P	F

■	1. Candidate appropriately wears full protective clothing			
■	2. Crouches or kneels at end of SCBA opposite cylinder valve.			
■	3. Checks cylinder gauge and determines if full. (90% or above-2216 psi = 1994/4500 psi = 4050/5500 psi = 4950)			
■	4. Opens cylinder valve to its maximum. Low air alarm must sound and PASS device must turn on.			
■	5. Compares cylinder gauge to remote pressure gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi. 5500 psi systems not to exceed 250 psi.)			
■	6. Grasps backplate/harness assembly with both hands.			
■	7. Raises backplate/harness assembly over head.			
■	8. Places and balances backplate/cylinder assembly on upper back.			
■	9. Connects necessary buckles and adjusts underarm straps until snug.			
■	10. Connects waist strap and adjusts until snug.			
■	11. Dons facepiece.			
■	12. Performs facepiece fit test. Adjusts straps if needed.			
■	13. Properly dons protective hood, completely covering head and shoulders.			
■	14. Dons helmet with ear covers down.			
■	15. Connects and adjusts chinstrap under chin and not facepiece.			
■	16. Turns on PASS device, if not integrated.			
■	17. Dons gloves.			
■	18. Connects facepiece to regulator. (activate positive pressure)			
■	19. Declares colors present on heads up display, if equipped. (ex. 2 green, no red)			
■	20. All Personal Protective Equipment is properly worn.			
■	21. Completes within one minute and fifteen seconds.			
	*NOTE: Timing of this skill will begin when the examiner states "please begin" and will stop when the candidate takes his/her first positive pressure breath from a properly sealed facepiece.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 104	03-01-21	Candidate Number	
Skill Title:	DON SCBA-OVER COAT METHOD			
NFPA Objective:	4.3.1	Minimum to pass		15
PERFORMANCE:				P F

1.	Candidate appropriately wears full protective clothing			
2.	Crouches or kneels at end of SCBA with cylinder valve.			
3.	Checks cylinder gauge and determine if full. (90% or above- 2216 psi = 1994/4500 psi = 4050/5500 psi = 4950)			
4.	Opens cylinder valve to its maximum. Low air alarm must sound and PASS device must turn on.			
5.	Compares cylinder gauge to remote pressure gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi. 5500 psi systems not to exceed 250 psi.)			
6.	Grasps right (left) shoulder strap with right (left) hand.			
7.	Raises SCBA and rest right (left) strap on right (left) shoulder.			
8.	Inserts opposite arm through other strap having entire unit rest on both shoulders.			
9.	Connects necessary buckles and adjusts underarm straps until snug.			
10.	Connects waist strap and adjusts until snug.			
11.	Dons facepiece.			
12.	Performs facepiece fit test. Adjust straps if needed.			
13.	Properly dons protective hood, completely covering head and shoulders.			
14.	Dons helmet with ear covers down.			
15.	Connects and adjusts chinstrap under chin and not facepiece.			
16.	Turns on PASS device, if not integrated.			
17.	Dons gloves.			
18.	Connects facepiece to regulator. (Activate positive pressure)			
19.	Declares colors present on heads up display, if equipped. (ex. 2 green, no red)			
20.	All Personal Protective Equipment is properly worn.			
21.	Completes within one minute and fifteen seconds.			
	*NOTE: Timing of this skill will begin when the examiner states "please begin" and will stop when the candidate takes his/her first positive pressure breath from a properly sealed facepiece.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____ / ____ / ____

Please circle: ☐ PASS ☐ FAIL ☐ RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 105	03-01-21	Candidate Number	
Skill Title: SCBA CYLINDER REPLACEMENT-ONE FIREFIGHTER METHOD				
NFPA Objective:	4.3.1	Minimum to pass		14
PERFORMANCE:				P F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Obtain a full air cylinder and position for easy access. (90% or above - 2216 psi = 1944 psi/4500 psi = 4050psi/5500 psi = 4950 psi)				
	3.	Disconnect facepiece from the regulator.				
	4.	Fully close the cylinder valve on the used bottle.				
	5.	Release pressure from high-pressure hoseline through regulator system and not by disconnecting high pressure hoseline from empty cylinder.				
	6.	Reset PASS device.				
	7.	Once all pressure is released, disconnect high-pressure hoseline from empty cylinder.				
	8.	Release cylinder clamps.				
	9.	Remove used cylinder from the harness assembly.				
	10.	Check replacement cylinder opening for debris. Open cylinder valve to clear debris if necessary.				
	11.	Check high-pressure hoseline connection for debris and O-ring for integrity.				
	12.	Install replacement cylinder into the harness assembly.				
	13.	Securely connect high-pressure hoseline connection (hand tight).				
	14.	Adjust cylinder in harness and secure clamps.				
	15.	Slowly and fully open cylinder valve (verbalize that the audible alarm has sounded, and no leaks occur as the system pressurizes).				
	16.	Check regulator gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi. 5500 psi systems not to exceed 250 psi.)				
	17.	Close cylinder valve.				
	18.	Release all pressure through regulator system.				
	19.	Reset PASS device.				
	20.	Place unit back in service.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 106	03-01-21	Candidate Number	
Skill Title: DOFF SCBA				
NFPA Objective:	4.1.2	Minimum to pass	13	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.			
■	2.	Deactivate positive pressure if so equipped and disconnect facepiece from regulator.			
	3.	Release chin strap and remove helmet.			
	4.	Slide protective hood, if utilized, off head and down around neck.			
■	5.	Release facepiece straps and remove facepiece.			
	6.	Extend facepiece straps fully.			
	7.	Disconnect and fully extend waist strap.			
■	8.	Crouch or kneel to the ground.			
	9.	Lean forward and release shoulder strap buckles and fully extend straps.			
	10.	Grasp shoulder strap, which has regulator attached, with the same side hand. (manufacturer dependent)			
	11.	Remove arm from opposite side shoulder strap.			
	12.	Grasp regulator and lock it into in waist regulator cup if so equipped, if a regulator cup is not provided the candidate should protect the regulator with a free hand.			
■	13.	Remove remaining shoulder strap while still protecting regulator.			
	14.	Lower unit to ground or place in case.			
■	15.	Close cylinder valve.			
	16.	Release all pressure through regulator system.			
	17.	Turns off PASS device.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 107	03-01-21	Candidate Number	
Skill Title: DOFF PERSONAL PROTECTIVE CLOTHING				
NFPA Objective:	4.1.2	Minimum to pass	12	
PERFORMANCE:			P	F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	2.	Removes PASS device if separate from SCBA.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	3.	Loosen chinstrap of helmet.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	4.	Doff helmet.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	5.	Doff protective hood, if utilized.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	6.	Unfasten collar.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	7.	Unfasten remaining coat closures.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	8.	Doff gloves.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	9.	Doff coat.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	10.	Remove suspenders from shoulders.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	11.	Unfasten waist closure.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	12.	Roll trousers down to each ankle with suspenders draping from each side.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	13.	Doff trouser/boot combination.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	14.	Inspect PPE for damage. Remove damaged equipment from service.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	15.	Candidate should verbalize that they would clean (decon) and dry equipment as needed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	16.	Place PPE in a ready state.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 201	03-01-21	Candidate Number	
Skill Title: CONDUCT A PRIMARY SEARCH				
NFPA Objective:	4.3.9, 5.3.2	Minimum to pass	12	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn including SCBA and PASS device.			
2.	Carries a forcible entry tool.			
3.	Candidate verbalizes an intended search pattern.			
4.	Initiate accountability system by confirming his/her accountability tag has been placed on the board.			
5.	Searches on hands and knees in low visibility.			
6.	Starts and maintains "left" or "right" search pattern, updates IC on progress as significant benchmarks are achieved.			
7.	Control all doors as search is conducted to prevent flow path development.			
8.	Searches behind and under all objects.			
9.	Searches all areas such as closets, showers, etc.			
10.	Searches one room before moving onto the next.			
11.	Marks rooms that have been searched.			
12.	Pauses occasionally to listen for cries for help, other rescuers, etc.			
13.	Moves up and down stairs, head always up.			
14.	Finds victim.			
15.	Notifies Command or Supervisor of Location, Identification, and Problem (victim rescue).			
16.	Exits structure, reports assignment completion to IC.			

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 202	03-01-21	Candidate Number	
Skill Title: SCBA USE WHILE DISORIENTED/EMERGENCY PROCEDURES				
NFPA Objective:	4.2.4, 4.3.5	Minimum to pass	10	
PERFORMANCE:			P	F

1.	Candidate appropriately wears full protective clothing, utilizes positive pressure SCBA, and PASS device is activated.				
2.	Candidate remains calm.				
3.	Candidate stops movement and breathes normally.				
4.	If radio equipped, candidate communicates "Mayday, Mayday, Mayday".				
5.	Candidate notifies Command or Supervisor of Location, Identification, and Problem. (disoriented)				
6.	Activates PASS device manually to alarm mode.				
7.	Candidate activates flashlight to increase visibility, uses a tool or other object to attract attention.				
8.	Candidate finds hoseline.				
9.	Uses hoseline coupling configuration to determine exit path. (Long lug out)				
10.	Remains low.				
11.	Ascends or descends stairs head toward upper floor.				
12.	Exits building or area using hoseline as a guide.				
13.	Notifies Command or Supervisor of status.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-II-203	03-01-21	Candidate Number	
Skill Title: DISPLACE A VEHICLE DOOR USING HYDRAULIC TOOLS				
NFPA Objective:	5.4.1	Minimum to pass	10	
PERFORMANCE:			P	F

1.	Wears full protective clothing with eye protection in position.			
2.	Assures vehicle is stable and battery disconnected.			
3.	Assesses passive restraint system for deployment.			
4.	Assures patient is properly covered/protected.			
5.	Assures door is not locked and cannot be opened as designed.			
6.	Assures unnecessary personnel are clear of door area.			
7.	Assures all glass in door is safely removed.			
8.	Provides access for hydraulic spreader at either the hinge or latch side of door.			
9.	Displaces first attachment side. (hinge or latch)			
10.	Displaces second attachment side. (hinge or latch)			
11.	Does not jeopardize the patient throughout the evolution.			
12.	Uses leg, not back muscles when lifting equipment.			
13.	Displaces the vehicle door.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 203	03-01-21	Candidate Number	
Skill Title:	INCLINE DRAG RESCUE			
NFPA Objective:	4.3.9	Minimum to pass	6	
PERFORMANCE:				P F

1.	Candidate appropriately wears full protective clothing, utilizes positive pressure SCBA, and PASS device is activated.				
2.	Candidate positions victim for rescue by rolling victim onto the back, if necessary.				
3.	Candidate kneels at the victims head facing the feet.				
4.	Support the victim's head and neck. NOTE: If head or neck injury is suspected, provide appropriate support for head during movement.				
5.	Candidate lifts the victim's upper body into a sitting position.				
6.	Candidate uses right arm, reach under the victim's right arm, across his or her chest, and grasps the wrist of his or her left arm. Repeat for the victim's other arm.				
7.	Candidate stands.				
8.	Drags victim to safety using the incline drag.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 204	03-01-21	Candidate Number	
Skill Title: EXTREMITIES CARRY RESCUE-RESCUER ONE				
NFPA Objective:	4.3.9	Minimum to pass	5	
PERFORMANCE:			P	F

1.	Candidate appropriately wears full protective clothing, utilizes positive pressure SCBA, and PASS device is activated.				
2.	Candidate stands at the victim's head facing the feet.				
3.	Candidate supports the victim's head and neck. NOTE: If a head or neck injury is suspected, provide appropriate support for head during movement.				
4.	With assistance from rescuer two, positions victim into a sitting position				
5.	Candidate uses right arm, reaches under the victim's right arm, across his or her chest, and grasps the wrist of his or her left arm. Repeat for the victim's other arm.				
6.	Stands using leg, not back muscles.				
7.	Carries the victim to safety using the extremities carry.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 205	03-01-21	Candidate Number	
Skill Title: EXTREMITIES CARRY RESCUE-RESCUER TWO				
NFPA Objective:	4.3.9	Minimum to pass	5	
PERFORMANCE:			P	F

1.	Candidate appropriately wears full protective clothing, utilizes positive pressure SCBA, and PASS device is activated.				
2.	Candidate stands at the victim's feet.				
3.	Grasps victims arms and assists rescuer one in moving victim to a sitting position.				
4.	Facing away from the victim, kneels with feet together between the victim's legs and grasps the victim under the knees.				
5.	Stands using leg, not back muscles.				
6.	Carries the victim to safety using the extremities carry.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 206	03-01-21	Candidate Number	
Skill Title: THROUGH THE LOCK ENTRY PROCEDURES WITH THE K-TOOL				
NFPA Objective:	4.3.4	Minimum to pass	8	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.			
	2.	Tries to open the door to determine if actually locked. (try before you pry)			
	3.	Identifies lock type.			
	4.	Selects the correct tool(s) for through the lock entry.			
	5.	Assures eye protection is lowered into position.			
	6.	Places K-tool into position behind the ring and face of the cylinder.			
	7.	Inserts Halligan Bar onto the K tool and forces the K tool onto the cylinder.			
	8.	Pries the cylinder from the door.			
	9.	Inserts key tool(s) into the cylinder hole.			
	10.	Moves locking bolt to open position.			
	11.	Opens the door to access the structure.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 301	03-01-21	Candidate Number	?
Skill Title:	FIGURE EIGHT			
NFPA Objective:	4.3.20, 4.1.2	Minimum to pass	6	
PERFORMANCE:				P F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Makes a bight in the working end of the rope.				
3.	Passes the working end completely around the standing part.				
4.	Inserts the working end back through the bight.				
5.	Dresses the knot by pulling the working end and the standing part at the same time.				
6.	Secures with an overhand safety as needed.				
7.	Completes the correct figure eight (stopper knot) and displays to the examiner.				
8.	Completes within 1 minute.				
	Note: Gloves are not required while tying knots.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 302	03-01-21	Candidate Number	
Skill Title: FIGURE EIGHT ON A BIGHT				
NFPA Objective:	4.3.2, 4.1.2	Minimum to pass	7	
PERFORMANCE:				P F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Forms a bight in the working end of the rope.				
3.	Passes it over the standing part to form a loop.				
4.	Passes the bight under the standing part and then over the loop and down through it; this forms the figure eight.				
5.	Extends the bight through the knot to whatever size working loop is needed.				
6.	Dresses the knot.				
7.	Uses an overhand safety knot on the working end to secure the knot.				
8.	Completes the correct figure eight on a bight and displays to the examiner.				
9.	Completes within one minute.				
	Note: Gloves are not required while tying knots.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 303	03-01-21	Candidate Number	
Skill Title:	WATER KNOT			
NFPA Objective:	4.3.20, 4.1.2	Minimum to pass	5	
PERFORMANCE:				P F

■	1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	
	2.	Ties an overhand knot loosely in the end of the webbing.			
	3.	Take the opposite end of the webbing and retrace the overhand knot.			
	4.	Tightens by pulling both working ends while holding the ends with your thumbs.			
	5.	Dresses the knot by pulling the appropriate ends at the same time.			
■	6.	Completes the correct Water Knot and displays to the examiner.	■	■	
	7.	Completes within one minute.			
		Note: Gloves are not required while tying knots.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 304	03-01-21	Candidate Number	
Skill Title: OVERHAND SAFETY KNOT				
NFPA Objective:	4.3.2, 4.1.2	Minimum to pass	5	
PERFORMANCE:				P F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Brings the working end by the standing part, forming a loop.				
3.	Continues working end back around the standing part, then directs the working end through the loop.				
4.	Dresses the knot by pulling the appropriate ends at the same time.				
5.	Completes the correct overhand safety knot and displays to the examiner.				
6.	Completes within 1 minute.				
	Note: Gloves are not required while tying knots.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 305	03-01-21	Candidate Number	
Skill Title: HOIST A LADDER USING A FIGURE EIGHT ON A BIGHT				
NFPA Objective:	4.3.2, 4.1.2	Minimum to pass	12	
PERFORMANCE:				P F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	2.	Candidate measures sufficient rope to form the size of the knot as required by the ladder to hoist.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	3.	Make a large loop in the end of the rope using a figure-eight on a bight.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	4.	Ties an overhand safety knot in the working end of the rope.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	5.	Displays correctly completed Figure Eight on a Bight and safety knot to the examiner.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	6.	Candidate places the closed loop under the ladder and brings it up between the rung about one-third the distance from the hoisting end.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	7.	Candidate opens the loop and place it over the tip of the ladder.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	8.	Candidate arranges the standing part under the ladder rungs.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	9.	Candidate tightens the loop around the beams, pulling the standing part of the rope up behind rungs toward ladder tip.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	10.	Candidate ties a tag/guide line to the ladder.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	11.	Completes to this point within 2 minutes.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	12.	Dons gloves if removed to tie knot.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	13.	Hoists the ladder at least fifteen (15) feet.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	14.	Lowers the ladder to the ground.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	15.	The knots maintain integrity throughout the evolution.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	16.	Unties the knot and returns the rope and ladder to its original area.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>		Note: Gloves are not required while tying knots.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 306	03-01-21	Candidate Number	
Skill Title: HOIST A PIKE POLE				
NFPA Objective:	4.3.2, 4.1.2	Minimum to pass	9	
PERFORMANCE:				P F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Approximately twelve (12) inches from the end of the pike pole handle applies a clove hitch.				
	3.	Candidate leaves enough excess running end so that it becomes the tag/guide line.				
	4.	Ties an overhand safety knot.				
	5.	Ties two additional half hitches around the pike pole with one in the middle of the handle and one on the head around the pike hook.				
■	6.	Completes the correct knots and displays to the examiner.				
	7.	Completes to this point within 2 minutes.				
■	8.	Dons gloves if removed to tie knot.				
	9.	Hoists the pike pole, pike up, at least fifteen (15) feet.				
	10.	Lowers the pike pole to the ground.				
■	11.	The knots maintain integrity throughout the evolution.				
	12.	Unties the knots and returns the rope and the pike pole to its original area.				
		Note: Gloves are not required while tying knots.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 309	03-01-21	Candidate Number	
Skill Title: SECURE THE TIP OF A LADDER				
NFPA Objective:	4.3.20, 4.1.2	Minimum to pass	4	
PERFORMANCE:			P	F

	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	From the inside of the building, ties a clove hitch with an overhand safety knot on a ladder rung which is on the same plane as the window sill.				
	3.	Places a pike pole across the base of the window sill.				
	4.	Ties another clove hitch with an overhand safety knot to the pike pole making the rope tight between the ladder and the pike pole.				
	5.	Displays correctly completed clove hitch and safety knot to the examiner.				
	6.	Completes within 2 minutes.				
		Note: Gloves are not required while tying knots.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 310	03-01-21	Candidate Number	
Skill Title: TIE A CLOVE HITCH AROUND AN OBJECT				
NFPA Objective:	4.3.20, 4.1.2	Minimum to pass	5	
PERFORMANCE:				P F

■	1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■
	2.	Makes one complete loop around the object, crossing the working end over the standing part.			
	3.	Completes the round turn immediately to the side of the first loop.			
	4.	Passes working end under the wrap just above the cross and pulls the knot tight.			
■	5.	Ties a safety knot by forming a loop around the standing part, passing the running part through the center of the loop and pulling the knot tight.	■	■	■
	6.	Completes the correct clove hitch and displays to the examiner.			
	7.	Completes within one minute.			
		Note: Gloves are not required while tying knots.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-II- 401	03-01-21	Candidate Number	
Skill Title: SERVICE TESTING FIRE HOSE				
NFPA Objective:	5.5.5	Minimum to pass	13	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.			
	2.	Checks gaskets and connects hose lengths together. (no more than 300') hose should be laid out straight.			
■	3.	Connects and tightens an open test gate valve to the discharge port.			
	4.	Utilizes a rope, rope tool, or hose strap to anchor hose to pumper at test gate valve connection.			
	5.	Attaches a shutoff nozzle to the open end of test length.			
	6.	Fills hoseline with water and increases pressure to 50 PSI.			
	7.	Permits air to discharge fully from the line by opening the nozzle.			
	8.	Makes a chalk or pencil mark on hose jacket against each coupling.			
■	9.	Checks that no couplings are leaking. Tightens any couplings, if necessary.			
	10.	Closes test valve and increases pump pressure to the required test pressure as detailed in NFPA 1962.			
	11.	Maintains pressure for three minutes.			
	12.	While at the test pressure the candidate shall walk along the test hose inspecting it for leaks. At no time shall the candidate be any closer than 15 feet to the hose, and he/she shall be on the left side of the hose while looking toward the nozzle end from the pump end.			
	13.	Slowly reduces pump pressure after three minutes, closes discharge valve, assures the pump is disengaged.			
	14.	Opens nozzles to bleed off pressure.			
	15.	Breaks connections and drains water away from the test area.			
	16.	Observes marks placed on hose at the couplings.			
■	17.	Determines whether each length can remain in service or be tagged and placed out of service.			
	18.	Completes evolution safely			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 401	03-01-21	Candidate Number	
Skill Title: STRAIGHT ROLL				
NFPA Objective:	4.5.2	Minimum to pass	7	
PERFORMANCE:			P	F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	2.	Lays out hose on a flat clean surface.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	3.	Removes twists and lays hose flat in a straight line.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	4.	If hose contains water, female coupling shall be on the downhill side.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	5.	Positions self at male coupling.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	6.	Male coupling is rolled onto hose toward female end.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	7.	Upon reaching female end the roll is laid on ground.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	8.	Any protruding coils are gently tamped with foot.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	9.	Completes the straight roll.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 402	03-01-21	Candidate Number	
Skill Title: TWIN DONUT ROLL				
NFPA Objective:	4.5.2	Minimum to pass	6	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■	■
2.	Lays out hose on a flat clean surface.	■	■	■	■
3.	If hose contains water, couplings shall be on the downhill side.	■	■	■	■
4.	Lays hose halves parallel to each other, flat and untwisted.	■	■	■	■
5.	Folds the loop onto both hose sections.	■	■	■	■
6.	Rolls both lines simultaneously toward coupling ends.	■	■	■	■
7.	Upon completion of the roll secures the roll with a rope or strap.	■	■	■	■
8.	Completes twin donut roll.	■	■	■	■

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 407	03-01-21	Candidate Number	
Skill Title: HOSELINE EXTENSION USING A HOSE CLAMP				
NFPA Objective:	4.3.10	Minimum to pass	8	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.			
■	2.	Carries hose sections to the nozzle end of the hoseline.			
■	3.	Candidate restricts the flow of water using a hose clamp positioned approximately 5 feet (1.5 m) behind the nozzle.			
■	4.	Opens nozzle to relieve pressure.			
■	5.	Removes the nozzle utilizing either the foot-tilt or the over-hip method.			
■	6.	Connects the additional sections of hose hand tight.			
■	7.	Reconnects the nozzle to the extended hoseline hand tight.			
■	8.	Checks that the nozzle is closed.			
■	9.	Candidate recharges the hoseline by slowly releasing the hose clamp.			
■	10.	Straightens the hoseline to remove kinks.			
■	11.	Candidate checks the nozzle pattern and bleed the air from the hoseline.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 408	03-01-21	Candidate Number	
Skill Title: REPLACE A SECTION IN A CHARGED LINE				
NFPA Objective:	4.3.10	Minimum to pass	6	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Candidate applies a hose clamp on the supply side approximately 5 feet from the coupling of the hose to be replaced.			
3.	Carries two new sections of hose to the site of replacement.			
4.	Uncouples the damaged section of hose utilizing either the foot-tilt or the over-hip method.			
5.	Removes damaged sections.			
6.	Replaces damaged section with both replacement hoses until hand-tight.			
7.	Candidate slowly releases the hose clamp.			
8.	Straightens the hoseline to remove kinks.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 409	03-01-21	Candidate Number	
Skill Title: NOZZLE OPERATION AND STREAM ADJUSTMENT				
NFPA Objective:	4.3.7, 4.3.10	Minimum to pass	8	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■
■	2.	Holds the nozzle with one hand and grasps the hose with the other hand.			
	3.	Straightens the hoseline behind the nozzle a distance of at least ten (10) feet.			
	4.	Faces the direction of stream projection.			
	5.	Anchors the hose to the ground with a foot and cradles it against the front of the body or hip.			
■	6.	Upon direction from the examiner, the candidate slowly opens the nozzle until it is fully open.	■	■	■
	7.	Sets the nozzle pattern on straight stream upon direction from the examiner.			
	8.	Sets the nozzle pattern for a narrow angle fog (long-reach) pattern upon direction from the examiner.			
	9.	Sets the nozzle pattern for a wide angle for (short-reach) pattern upon direction from the examiner.			
■	10.	Slowly closes the nozzle to avoid creating a water hammer until fully closed upon direction from the examiner.	■	■	■
	11.	Completes nozzle operation without losing control of nozzle.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination
--

Skill Sheet No.	FF-I- 410	03-01-21	Candidate Number.	
Skill Title: UNCHARGED HOSELINE ADVANCEMENT UP A LADDER-NOZZLE				
NFPA Objective:	4.3.10	Minimum to pass	4	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Carries the nozzle on the back with the hose going over the shoulder towards the front then under the arm to the rear.				
3.	Advances the hoseline by climbing the ladder keeping the hanging loop of hose outside the ladder beam.				
4.	Advances to the first fly section and awaits the backup firefighter				
5.	Advances the hoseline to a point as directed by the examiner.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: __/__/__

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 411	03-01-21	Candidate Number	
Skill Title: UNCHARGED HOSELINE ADVANCEMENT UP A LADDER-BACKUP				
NFPA Objective:	4.3.10	Minimum to pass	5	
PERFORMANCE:			P	F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	2.	Candidate grips the hose approximately 20-25 feet behind the nozzle.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	3.	Places a loop of hose over the shoulder keeping the hose on the same side as the nozzle fighter.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	4.	Moves up to approximately ten (10) feet behind the nozzle firefighter.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	5.	Advances the hoseline by climbing the ladder keeping the hanging loop of hose outside the ladder beam.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	6.	Lock in with leg lock or Class I safety harness, leaving hands free to control and advance the hose.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	7.	Advances hose to the nozzle firefighter until signaled to stop as directed by the examiner.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 412	03-01-21	Candidate Number	
Skill Title: OPERATE A CHARGED LINE FROM A LADDER				
NFPA Objective:	4.3.10	Minimum to pass		4
PERFORMANCE:				P F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Places the nozzle between two of the ladder rungs.				
3.	Lock in with leg lock or Class I safety harness, leaving hands free to control and advance the hose.				
4.	Secures the hoseline to the ladder rung using a hose strap, rope etc.				
5.	Safely opens the nozzle, operates as directed, properly shuts down the stream as directed by the examiner.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 413	03-01-21	Candidate Number
Skill Title: CONNECT AND ADVANCE A HOSE LINE FROM A STANDPIPE – NOZZLE POSITION/CREW LEADER			
NFPA Objective:	4.3.10	Minimum to pass	10
PERFORMANCE:			P F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Carries hose into the structure to the standpipe, via the stairwell, to one (1) level below the fire floor.				
3.	Lays hose in stairwell on landing.				
4.	Advances the fire department hoseline from the standpipe to the landing of the fire floor.				
5.	Candidate lays excess hose UP stairwell towards floor above.				
6.	Assures nozzle is closed.				
7.	Orders backup firefighter to charge hoseline.				
8.	Removes kinks from charged hoseline in vicinity of the nozzle.				
9.	Slowly opens the nozzle, bleeds air and flows water to assure proper flow.				
10.	Slowly closes the nozzle.				
11.	Assures backup firefighter is on same side of the hoseline and ready to enter.				
12.	Checks door for heat by applying water from the hose stream to the door.				
13.	Opens door slowly and enters fire floor.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 414	03-01-21	Candidate Number	
Skill Title: CONNECT AND ADVANCE A HOSE LINE FROM A STANDPIPE – BACKUP POSITION				
NFPA Objective:	4.3.10	Minimum to pass	8	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Assists carrying hose into the structure to the standpipe, via the stairwell, to one (1) level below the fire floor.			
3.	Lays hose in stairwell.			
4.	Detaches building hoseline or removes protective cap (screw cap or breakaway) from standpipe (if so equipped or provided).			
5.	Inspects standpipe outlet for debris, damaged threads, etc.			
6.	Connects necessary adapters to allow fire department hoseline attachment.			
7.	Connects fire department hoseline to standpipe hand-tight.			
8.	Upon orders from the nozzle operator, slowly charges the fire department hoseline with the standpipe valve.			
9.	Advances to fire floor, removing kinks from charged hoseline.			
10.	Backs up nozzle operator on same side of the hoseline.			
11.	Assists the nozzle operator with advancing hoseline onto fire floor.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-1- 415	03-01-21	Candidate Number	
Skill Title: OPERATION OF FOG AND SOLID MASTER STREAM NOZZLES				
NFPA Objective:	4.3.8	Minimum to pass	10	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■
■	2.	Carries master stream device to set-up area.			
■	3.	Positions device on solid, level surface.			
■	4.	Secure the monitor.	■	■	■
■	5.	Adjust the nozzle to the proper elevation.	■	■	■
■	6.	Aims female swivels opposite stream direction (determined by examiner) and utilizes the swivel locking device, if present.	■	■	■
■	7.	Extends hoselines around the front of the device from opposite sides forming two large loops to reduce nozzle reaction (10 foot diameter minimum.)	■	■	■
■	8.	Attaches hoseline to device.			
■	9.	Attaches tip to deliver appropriate stream as directed by examiner (solid, fog, straight)			
■	10.	Signals for water; flows stream and adjust direction of water flow as necessary.			
■	11.	Removes kinks in hoselines as necessary.			
■	12.	Upon direction from examiner, signals to shut down monitor.	■	■	■
■	13.	Changes tip to deliver appropriate stream as directed by examiner (solid, fog, straight)			
■	14.	Signals for water. Flows stream.			
■	13.	Upon direction from examiner, signals to stop water.	■	■	■
■	14.	Breaks down and returns all equipment to original location	■	■	■

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 416	03-01-21	Candidate Number	
Skill Title: CONNECT HOSE LINES TO A FIRE DEPARTMENT CONNECTION				
NFPA Objective:	4.3.10	Minimum to pass		6
PERFORMANCE:				P F

■	1.	All Personal Protective Equipment (PPE) is properly worn.			
	2.	Selects proper supply hose, stretches hose lines to fire department sprinkler connection.			
	3.	Assures LDH or threaded male couplings are toward connections.			
	4.	Removes protective caps (screw plug or breakaway) from connection.			
	5.	Inspects connection for debris, damaged threads, or missing gaskets. Replace gaskets, if necessary.			
■	6.	Connects hoselines to fire department connection.			
	7.	Removes kinks from charged hoseline.			
	8.	Communicates to pump operator that connections are complete and the hoselines are ready to be charged.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 501	03-01-21	Candidate Number	
Skill Title:	HYDRANT TO PUMPER CONNECTION-ONE SOFT SLEEVE			
NFPA Objective:	4.3.15	Minimum to pass	9	
PERFORMANCE:				P F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	2.	Directs apparatus at the hydrant for the connection.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	3.	Removes the intake cap.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	4.	Removes the appropriate hydrant discharge cap and places the hydrant wrench on the hydrant operating nut.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	5.	Inspects hydrant threads for damage and integrity. Inspects inside outlet for debris.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	6.	Flush the hydrant to ensure that it is free of debris.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	7.	Attaches the appropriate female end of the soft suction hose to the hydrant.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	8.	Attaches the appropriate female end of the soft suction hose to the intake. (pumper may be repositioned)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	9.	Opens intake valve before opening hydrant.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	10.	Slowly opens the hydrant fully.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	11.	Reduces any leakage by tightening connections and assures soft suction hose has no kinks.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	11.	Adds a chafing block at the point where hose touches the ground, if necessary.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	12.	Completes the connection as directed by the examiner.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-II- 501	03-01-21	Candidate Number	
Skill Title: PRESENTATION OF PUBLIC FIRE EDUCATION MESSAGE				
NFPA Objective:	5.5.2	Minimum to pass	5	
PERFORMANCE:			P	F

1.	Explains the purpose of Stop, Drop, and Roll.	1	1	1	1
2.	Instructs student to STOP and stay in place				
3.	Instructs student to DROP to the ground/floor and cover face with hands.				
4.	Instructs student to ROLL to extinguish flames by tucking in elbows and keeping legs together.				
5.	Demonstrates STOP, DROP, AND ROLL procedure to student.	1	1	1	1
6.	Instructs student to demonstrate.				
7.	Evaluate student's performance.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 502	03-01-21	Candidate Number	
Skill Title: HYDRANT TO PUMPER CONNECTION - FORWARD LAY (1 or 2 LINES)				
NFPA Objective:	4.3.15	Minimum to pass	8	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Pull enough supply hose from the apparatus to reach and wrap around the hydrant.			
3.	Secure a loop of hose around the hydrant. Wrap the hose around the hydrant in a manner that restrains it when the pumper moves away from the hydrant.			
4.	Signal the driver/operator to proceed and deploy the hose to the incident.			
5.	Removes the hydrant caps and places the hydrant wrench on the hydrant operating nut.			
6.	Inspects hydrant threads for damage and integrity. Inspects inside outlets for debris.			
7.	Attaches two closed gates to the hydrant discharge ports.			
8.	Connects the hoseline to the appropriate port.			
9.	Fully opens hydrant, then the hydrant gate(s) slowly to charge the line(s) when signaled to do so by the pump operator.			
10.	Reduces any leakage by tightening connections and assures hoseline(s) have no kinks.			
11.	Completes the assembly as directed by the examiner.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 503	03-01-21	Candidate Number	
Skill Title: HYDRANT TO PUMPER CONNECTION - REVERSE LAY (1 or 2 LINES)				
NFPA Objective:	4.3.15	Minimum to pass	9	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Pull sufficient hose from the supply pumper to reach the intake valve on the attack pumper.			
3.	Anchor the hose before the supply pumper proceeds to the water source.			
4.	Signal the driver/operator to proceed and deploy the hose to the attack pumper.			
5.	Pull the remaining length of the last section of hose from the hose bed.			
6.	Disconnect the couplings and return the unused coupling to the hose bed and provide the hose to the Pump operator.			
7.	Removes the hydrant caps and places the hydrant wrench on the hydrant operating nut.			
8.	Inspects hydrant threads for damage and integrity. Inspects inside outlets for debris.			
9.	Attaches two closed gates to the hydrant discharge ports.			
10.	Connects the hoseline to the appropriate port.			
11.	Proceed along the hose to the fire scene, removing kinks and checking for leaks.			
12.	Completes the assembly as directed by the examiner.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 504	03-01-21	Candidate Number	
Skill Title: HAND LAY HOSE FROM PUMPER TO WATER SOURCE- FIREFIGHTER ONE				
NFPA Objective:	4.3.15	Minimum to pass	8	
PERFORMANCE:			P	F

	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Removes hydrant wrench from pumper.				
	3.	Removes the gates and appropriate amount of supply hose from the hose bed. Transfers to a flat shoulder load.				
	4.	Waits for second firefighter to remove additional hose from bed.				
	5.	Advances with second firefighter toward water source.				
	6.	Once the second firefighter has unloaded his shoulder load, first firefighter starts allowing his hose to lay out on ground.				
	7.	Continues to advance toward water source.				
	8.	If source is not reached after both firefighters have laid their shoulder loads, they must return to pumper and pull off sufficient hose to reach source.				
	9.	Places hydrant wrench on hydrant operating stem.				
	10.	Attaches a hydrant gate to each 2½ port. Attaches hose into one gate.				
	11.	Completes evolution as directed by the examiner.				
		Candidate cannot return to apparatus solely to retrieve hydrant wrench				

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination
--

Skill Sheet No.	FF-I- 505	03-01-21	Candidate Number	
Skill Title: HAND HOSE LAY FROM PUMPER TO WATER SOURCE – FIREFIGHTER TWO				
NFPA Objective:	4.3.15	Minimum to pass	5	
PERFORMANCE:				P F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Waits for first firefighter remove hose, gates, and hydrant wrench from hose bed.				
	3.	Removes appropriate amount of supply hose and transfers to a flat shoulder carry.				
	3.	Advances with first firefighter toward water source.				
	4.	Allows hose to lay out on ground as advancement continues.				
	5.	If source is not reached after both firefighters have laid their shoulder loads, they must return to pumper and pull off sufficient hose to reach source.				
	6.	Assists first firefighter in attaching hydrant gates and/or hose as needed.				
■	7.	Completes evolution as directed by the examiner.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 506	03-01-21	Candidate Number	
Skill Title: ASSEMBLE DRAFTING EQUIPMENT				
NFPA Objective:	4.3.15	Minimum to pass	9	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Removes pumper intake cap.				
3.	Check the hard-suction couplings.				
	a. Remove any dirt or debris.				
	b. Replace worn gaskets.				
4.	Attaches two sections of hard suction together, taking care not to get dirt in the couplings.				
5.	Attaches strainer to hard suction hose male coupling.				
6.	Utilizes rubber mallet, as necessary, to provide an airtight connection.				
7.	Attaches rope to strainer.				
8.	Lowers hose and strainer into static source (portable tank.)				
9.	Attaches female coupling of hard suction hose to pumper intake.				
10.	Secures strainer rope to pumper or another stationary object.				
11.	Assures strainer and strainer-to-hose coupling is under water.				
12.	Completes the assembly as directed by the examiner.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 601	03-01-21	Candidate Number
Skill Title: ONE FIREFIGHTER SHOULDER LADDER CARRY FROM THE GROUND			
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	9
PERFORMANCE:			P F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Visually inspects the work area.			
	a. Inspects terrain for solid, level footing.			
	b. Inspects overhead for electrical wires and obstructions.			
3.	Faces the tip of the ladder near the center of ladder.			
4.	Crouches/kneels beside the ladder on knee closest to ladder.			
5.	Grasps rung nearest the ladder's balance point, with the hand closest to the ladder and places the ladder on its beam.			
6.	Stands and pivots into the ladder inserting the other arm through the rungs.			
7.	Faces ladder butt and places the upper beam onto the shoulder.			
8.	Steadies ladder with both hands.			
9.	Tilts butt end so it is lowered slightly toward the ground as it is carried.			
10.	Uses leg, not back muscles, throughout the entire skill.			
11.	Carries the ladder to the destination as directed by the examiner and places the ladder flat on the ground (both beams touching the ground).			
12.	Carries the ladder using the low shoulder carry as directed.			

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 602	03-01-21	Candidate Number	
Skill Title: ONE FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	11	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Visually inspects the work area.			
	a. Inspects terrain for solid, level footing.			
	b. Inspects and verbalizes that the overhead is clear of electrical wires and obstructions.			
3.	Positions the ladder butt for the raise with the butt spurs against the wall of the building.			
4.	Raises the ladder, hand over hand, toward the ladder butt until ladder is vertical against the building.			
5.	Rolls the ladder to position the fly section of the ladder toward the building, if necessary.			
6.	Positions the tip of the ladder away from the building to a proper location for extending the fly.			
7.	Steadies the ladder with the instep, knee, and leg.			
8.	Grasps the halyard and extends the fly hand over hand to a height as directed by the examiner.			
9.	Locks the fly into place with the pawls.			
10.	Places ladder against the building and rolls ladder over so fly section is out.			
11.	Grasps a lower rung to carefully move the butt away from the building to the desired position.			
12.	Checks for proper placement, climbing angle, and makes necessary adjustments.			
13.	Secures the halyard.			
14.	Uses leg, not back, muscles throughout the entire skill.			
15.	Performs the flat raise as directed.			

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 603	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER SHOULDER CARRY FROM THE GROUND-BUTT				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	12	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Visually inspects the work area.				
	a. Inspects terrain for solid, level footing.				
	b. Inspects overhead for electrical wires and obstructions.				
3.	Position is on the same side of the ladder relative to the tip firefighter.				
4.	Crouches/kneels next to the ladder facing the tip on the knee closest to ladder.				
5.	Grasps a rung with the hand nearest to the ladder, palms facing forward.				
6.	Stands ladder on the beam.				
7.	Verbalizes commands to lift ladder to the shoulder.				
8.	Stands and pivots into the ladder toward the butt.				
9.	Places the free arm between the rungs.				
10.	Lowers the upper beam onto the shoulder.				
11.	Is so positioned as to be able to reach beyond the butt of the ladder.				
12.	Provides commands to advance to destination.				
13.	Controls the ladder with the inside hand.				
14.	Uses leg, not back, muscles throughout the entire skill.				
15.	Carries the ladder to the destination as directed by the examiner and places onto the ground on the bed section.				
16.	Carries the ladder using the low shoulder carry as directed.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 604	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER SHOULDER CARRY FROM THE GROUND-TIP				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	11	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Visually inspects the work area.				
		a. Inspects terrain for solid, level footing.				
		b. Inspects overhead for electrical wires and obstructions.				
	3.	Position is on the same side of the ladder relative to the butt firefighter.				
	4.	Crouches/kneels next to the ladder facing the tip while on the knee closest to ladder.				
	5.	Grasps a rung with the hand nearest to the ladder, palms facing forward.				
	6.	Stands ladder on beam.				
	7.	Obeys commands to lift ladder to the shoulder.				
	8.	Stands and pivots into the ladder toward the butt.				
	9.	Places the free arm through the rungs.				
	10.	Lowers the upper beam onto the shoulder.				
	11.	Obeys commands to advance to destination.				
	12.	Controls the ladder with the free hand.				
	13.	Uses leg, not back muscles, throughout the entire skill.				
	14.	Carries the ladder to the destination as directed by the examiner and places onto the ground on the bed section.				
	15.	Carries the ladder using the low shoulder carry as directed.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 605	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-BUTT				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	10	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Visually inspects the work area.			
	a. Inspects terrain for solid, level footing.			
	b. Inspects and verbalizes that the overhead is clear of electrical wires and obstructions.			
3.	Positions the ladder butt for the raise with the fly section against the ground. (perpendicular to the structure, approximately ¼ of the usable height from the building).			
4.	Braces the ladder butt by standing on the bottom rung, grasping an upper rung and leaning back.			
5.	Grasps successively higher rungs as ladder comes to the vertical.			
6.	Steadies ladder in preparation for extending the fly section.			
7.	Grasps the halyard and extends the fly, hand over hand, to a height as directed by the tip firefighter.			
8.	Locks the fly in place with the pawls.			
9.	Slowly lowers the ladder into the building.			
10.	Secures the halyard <u>after</u> properly positioning the ladder resting on the structure and climbing angle adjustments are made.			
11.	Provides commands throughout the evolution to allow for fluid motion.			
12.	Uses leg, not back, muscles throughout the entire skill.			
13.	Performs the flat raise of an extension ladder as directed.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 606	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-TIP				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	10	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Visually inspects the work area.				
		a. Inspects terrain for solid, level footing.				
		b. Inspects overhead for electrical wires and obstructions.				
	3.	Raises ladder by advancing hand over hand along the rungs toward the butt end until ladder is in a vertical position.				
	4.	Heels the ladder at the assigned beam.				
	5.	Braces the ladder, with both hands on the beams, as the fly is extended.				
	6.	Inform the butt firefighter when the desired height has been reached.				
■	7.	Assures the fly is locked with the pawls.				
	8.	Slowly lowers the ladder into the building, bracing with foot on rung.				
	9.	Checks for proper placement, climbing angle, and makes the necessary adjustments.				
	10.	Obeys commands to allow for fluid motion.				
■	11.	Uses leg, not back, muscles throughout the entire skill.				
■	12.	Performs the flat raise of an extension ladder as directed.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 607	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER <u>BEAM</u> RAISE OF AN EXTENSION LADDER FROM THE GROUND-BUTT				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	10	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Visually inspects the work area.				
	a. Inspects terrain for solid, level footing.				
	b. Inspects and verbalizes that the overhead is clear of electrical wires and obstructions.				
3.	Positions the ladder beam butt on the ground for the raise. (approximately 1/4 the usable height from the building).				
4.	Places foot on the beam at a spur.				
5.	Grasps the upper beam and counterbalances the weight of the ladder.				
6.	Pivots the ladder to position the fly section of the ladder away from the building, if necessary.				
7.	Faces the tip firefighter and braces the ladder.				
8.	Grasps the halyard and extends the fly, hand over hand, to a height as directed by the tip firefighter.				
9.	Locks the fly in place with the pawls.				
10.	Slowly lowers the ladder into the building.				
11.	Secures the halyard <u>after</u> properly positioning the ladder resting on the structure and climbing angle adjustments are made.				
12.	Provides commands to allow for fluid motion.				
13.	Uses leg, not back, muscles throughout the entire skill.				
14.	Performs the beam raise as directed.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 608	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER <u>BEAM</u> RAISE OF AN EXTENSION LADDER FROM THE GROUND-TIP				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	10	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Visually inspects the work area.				
	a. Inspects terrain for solid, level footing.				
	b. Inspects overhead for electrical wires and obstructions.				
3.	Lifts and rests the beam of the ladder onto the shoulder.				
4.	Advances, hand over hand, along beam toward the butt end until ladder is in a vertical position.				
5.	Pivots the ladder to position the fly section of the ladder away from the building, if necessary.				
6.	Faces the butt firefighter and braces the ladder.				
7.	Informs butt firefighter when the fly has reached the desired height as directed.				
8.	Assures the fly is locked with the pawls.				
9.	Slowly lowers the ladder into the building while bracing with foot on rung.				
10.	Checks for proper placement, climbing angle, and makes the necessary adjustments.				
11.	Obeys commands to allow for fluid motion.				
12.	Uses leg, not back, muscles throughout the entire skill.				
13.	Performs and completes the beam raise as directed.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 609	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-BUTT				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	9	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Visually inspects the work area.			
	a. Inspects terrain for solid, level footing.			
	b. Inspects and verbalizes that the overhead is clear of electrical wires and obstructions.			
3.	Unties the halyard and prepares to remove ladder from building.			
4.	Slowly removes the ladder from the building.			
5.	Extends the fly enough to unlock the pawls.			
6.	Slowly lowers the fly section using the halyard, hand over hand, to its lowered position.			
7.	Locks the pawls at the appropriate rung, if possible, and secures the halyard, if necessary.			
8.	Braces the ladder butt by standing on the bottom rung, grasping an upper rung and leaning back.			
9.	Braces the ladder as it is lowered to the ground.			
10.	Provides commands to allow for fluid motion throughout evolution.			
11.	Uses leg, not back, muscles throughout the entire skill.			
12.	Performs the flat lowering of an extension ladder as directed.			

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 610	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-TIP				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	10	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Visually inspects the work area.				
		a. Inspects terrain for solid, level footing.				
		b. Inspects overhead for electrical wires and obstructions.				
	3.	Braces the ladder with one foot on the rung.				
	4.	Slowly raises the ladder away from the building.				
	5.	Braces the ladder.				
	6.	Inform the butt candidate when fly section is unlocked.				
	7.	Steadies the ladder with both hands on the beams as the fly is lowered.				
	8.	Repositions for lowering the ladder to the ground.				
	9.	Lowers the ladder hand over hand along the rungs toward the tip until the ladder is in the horizontal position, swinging out on command.				
	10.	Lowers ladder to the ground, kneeling down on inside knee.				
	11.	Obeys commands to allow for fluid motion.				
■	12.	Uses leg, not back, muscles throughout the entire skill.				
	13.	Performs the flat lowering of an extension ladder as directed.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 611	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER BEAM LOWERING OF AN EXTENSION LADDER TO THE GROUND-BUTT				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	10	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Visually inspects the work area.			
	a. Inspects terrain for solid, level footing.			
	b. Inspects and verbalizes that the overhead is clear of electrical wires and obstructions.			
3.	Unties the halyard and prepares to remove ladder from building.			
4.	Slowly removes the ladder from the building.			
5.	Extends the fly enough to unlock the pawls.			
6.	Slowly lowers the fly section using the halyard, hand over hand, to its lowered position.			
7.	Locks the pawls at the appropriate rung, if possible, and secures the halyard. (if necessary)			
8.	Repositions for lowering.			
9.	Places foot on the beam the ladder will be lowered on, at the spur.			
10.	Grasps the upper beam and counterbalances the weight of the ladder.			
11.	Steadies the ladder as it is lowered to the ground.			
12.	Provides commands to allow for fluid motion throughout the evolution.			
13.	Uses leg, not back, muscles throughout the entire skill.			
14.	Performs the beam lowering of an extension ladder as directed.			

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 612	03-01-21	Candidate Number	
Skill Title: TWO FIREFIGHTER <u>BEAM</u> LOWERING OF AN EXTENSION LADDER TO THE GROUND-TIP				
NFPA Objective:	4.3.6, 4.3.11, 4.3.12	Minimum to pass	9	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Visually inspects the work area.				
	a. Inspects terrain for solid, level footing.				
	b. Inspects overhead for electrical wires and obstructions.				
3.	Faces the butt firefighter and braces the ladder with one foot on the rung.				
4.	Steadies and slowly raises the ladder from the building.				
5.	Informs the butt candidate when fly section is unlocked.				
6.	Braces the ladder.				
7.	Steadies the ladder as the fly section is lowered.				
8.	Repositions for lowering to the ground.				
9.	Lowers ladder, hand over hand, along the beam toward tip until the ladder is lowered fully to the ground.				
10.	Obeys commands to allow for fluid motion.				
11.	Uses leg, not back, muscles throughout the entire skill.				
12.	Performs the beam lowering of an extension ladder as directed.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 622	03-01-21	Candidate Number	
Skill Title: DEPLOYMENT OF A ROOF LADDER-RAISED TO A LADDER				
NFPA Objective:	4.3.6, 4.3.12	Minimum to pass	9	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.			
	2.	Carries the roof ladder to the ground ladder to be ascended.			
	3.	Places the roof ladder on the ground and opens the hooks.			
	4.	Raises the roof ladder, resting it against the ground ladder, hooks facing outward.			
	5.	Climbs the ground ladder positioning the shoulder about two (2) rungs above the midpoint of the roof ladder.			
	6.	Reaches through the rungs of the roof ladder and places it onto the shoulder.			
	7.	Climbs to the top of the ground ladder with the roof ladder on shoulder.			
■	8.	Secures with a leg lock as directed by the examiner.			
	9.	Lowers the roof ladder from the shoulder onto the roof and, using the hand-over-hand method, pushes the roof ladder, hooks down, toward the ridge line.			
■	10.	When the hooks of the roof ladders fall over the ridge line, tugs roof ladder and ascertains that the hooks are firmly secured over the peak.			
	11.	Uses leg, not back, muscles throughout the entire evolution.			
	12.	Deploys the roof ladder properly and safely as directed.			

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 623	03-01-21	Candidate Number	
Skill Title: CLIMB A LADDER WITH A TOOL AND TAKE A SECURE POSITION				
NFPA Objective:	4.3.9, 4.3.6, 4.3.10, 4.3.11, 4.3.12	Minimum to pass	12	
PERFORMANCE:			P	F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	2.	Checks for correct climbing angle.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	3.	Checks that ladder pawls are locked and verbalizes their status.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	4.	Climbs the ladder to the desired height while carrying a forcible entry/ventilation tool.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	5.	Keeps eyes forward with an occasional glance at the tip of the ladder.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	6.	Slides the tool along the side of the ladder beam and the free hand under the other ladder beam maintaining constant contact.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	7.	After reaching the desired height the firefighter descends the number of rungs as directed by the examiner.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	8.	Climbs one rung higher than working height.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	9.	Extends leg opposite the working side through rung. Bend knee. Bring foot through ladder just below rung supporting the knee.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	10.	Hooks foot over either a rung or top of beam.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	11.	Rests on thigh and steps down one rung.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	12.	Secures a leg lock as directed by the examiner.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	13.	Simulates performing work off the side of the ladder.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	14.	Releases the leg lock.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	15.	Descends the ladder to the ground.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	16.	Holds onto the tool at all times.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	17.	Completes the evolution as directed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 624	03-01-21	Candidate Number	
Skill Title: ASSIST A CONSCIOUS VICTIM DOWN A LADDER				
NFPA Objective:	4.3.6, 4.3.9	Minimum to pass	5	
PERFORMANCE:				P F

1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■	■
2.	Receives the victim, feet first, from the building opening.	■	■	■	■
3.	Positions the victim to descend the ladder.	■	■	■	■
4.	Descends first keeping both arms around the victim under the armpits with hands on the rungs in front of the victim for support.	■	■	■	■
5.	Keeps at least one hand on the ladder at all times.	■	■	■	■
6.	Supports and reassures the victim during descent.	■	■	■	■
7.	Fully descends the ladder with the victim to the ground.	■	■	■	■

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 625	03-01-21	Candidate Number	
Skill Title: ASSIST AN UNCONSCIOUS VICTIM DOWN A LADDER				
NFPA Objective:	4.3.6, 4.3.9	Minimum to pass	7	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Victim is secured by a safety harness.				
3.	Receives the victim from the building opening, positioned facing the rescuer.				
4.	Places the victim's legs and arms outside the beams of the ladder.				
5.	Fully supports the victim's body.				
6.	Keeps both arms around the victim.				
7.	Maintains control of the victim.				
8.	Keeps hands on the rungs in front (back) of the victim.				
9.	Lowers victim one rung at a time.				
10.	Fully descends the ladder with the victim to the ground.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 701	03-01-21	Candidate Number	
Skill Title: SALVAGE COVER ROLL FOR A ONE-FIREFIGHTER SPREAD				
NFPA Objective:	4.3.14	Minimum to pass	12	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Lays salvage cover flat on a clean surface with finished side up.				
3.	Takes a position at the end of the length of the cover, kneeling, and facing other firefighter.				
4.	Grasps the edge of the cover with the outside hand midway between the center of the cover and the edge to be folded.				
5.	Places free hand on cover midway between outside hand and center.				
6.	Folds cover by bringing fold over pivot hand to center of cover to create an inside and an outside fold.				
7.	Positions for next fold by placing outside hand at corner of cover and free hand as a pivot over outside fold.				
8.	Grasps the outside corner with outside hand and using inside hand as a pivot, brings outside corner to the center.				
9.	Moves to other half of cover and completes steps 3 through 8 to fold.				
10.	Straightens folds, if necessary.				
11.	Folds both ends of cover approximately 12 inches toward the center.				
12.	Repositions at one end with other firefighter.				
13.	Rolls cover toward opposite end.				
14.	Compresses cover tightly tucking wrinkles forming ahead of cover and keeping edges aligned.				
15.	Secures roll with supplied equipment.				
16.	Completes the salvage cover roll.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 702	03-01-21	Candidate Number	
Skill Title: SALVAGE COVER FOLD FOR A ONE-FIREFIGHTER SPREAD				
NFPA Objective:	4.3.14	Minimum to pass	12	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Lays salvage cover flat on a clean surface with finished side up.				
3.	Takes a position at the end of the length of the cover, kneeling, and facing other firefighter.				
4.	Grasps the edge of the cover with the outside hand midway between the center of cover and edge to be folded.				
5.	Places free hand on cover midway between outside hand and center.				
6.	Folds cover by bringing fold over pivot hand to center of cover to create an inside and an outside fold.				
7.	Positions for next fold by placing outside hand at corner of cover and free hand as a pivot over outside fold.				
8.	Grasps the outside corner with outside hand and using inside hand as a pivot, brings outside corner to the center.				
9.	Moves to other half of cover and completes steps 3 through 8.				
10.	Repositions, standing alongside other firefighter at the same end, facing the cover.				
11.	Picks up cover with one hand on the outside fold and one hand on the inside fold.				
12.	Folds cover to a point just short of the center (approximately 4 inches).				
13.	Using one hand as a pivot, brings the folded end over the top of the first fold.				
14.	Folds cover again using techniques from steps 10 and 13.				
15.	Aligns one set of folds on top of the other set using space between the two stacks as a hinge.				
16.	Completes the salvage cover fold.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 703	03-01-21	Candidate Number	
Skill Title: ONE FIREFIGHTER SPREAD OF A ROLLED SALVAGE COVER				
NFPA Objective:	4.3.14	Minimum to pass	9	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Starts unrolling cover just enough to cover end of objects while keeping remainder of roll tight.				
3.	Positions cover on the top near edge of the objects to be covered.				
4.	Unrolls cover across objects toward opposite end.				
5.	Allows cover to fall into place covering opposite end of objects.				
6.	Repositions at one end and faces unrolled cover.				
7.	Grasps the cover with each hand at the open edges.				
8.	Opens cover by snapping both hands up and out covering objects.				
9.	Repositions at opposite end.				
10.	Grasps cover and covers objects using same technique.				
11.	Tucks edges under and in to keep water out.				
12.	Completes the rolled salvage cover spread.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 704	03-01-21	Candidate Number	
Skill Title: ONE FIREFIGHTER SPREAD OF A FOLDED SALVAGE COVER				
NFPA Objective:	4.3.14	Minimum to pass	10	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■	■
2.	Takes a position at one side of the objects to be covered.				
3.	Places cover on objects near the center.				
4.	Separates the stacked folds by unfolding the top folds at the hinge and laying folds flat.				
5.	Unfolds one-half of the cover toward one end, covering objects.				
6.	Repositions, and unfolds remaining half toward opposite end.				
7.	Allows cover to fall into place covering both ends fully.				
8.	Repositions at one end and faces unrolled cover.				
9.	Grasps the cover with each hand at the open edges.				
10.	Opens cover by snapping both hands up and out, covering objects.	■	■	■	■
11.	Repositions at opposite end.				
12.	Grasps cover and covers objects using same technique.	■	■	■	■
13.	Tucks edges under and in to keep water out.				
14.	Completes the folded salvage cover spread.	■	■	■	■

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 705	03-01-21	Candidate Number	
Skill Title: CONSTRUCTION OF A WATER CHUTE				
NFPA Objective:	4.3.14	Minimum to pass	6	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Positions salvage cover at desired location, finished side down, flat and open				
3.	Places pike poles on opposite edges with pikes extending off end of cover.				
4.	Rolls both edges equally over pike poles until there is a three foot width between the rolls.				
5.	Flips cover over keeping folds in place.				
6.	Elevates one end by hooking pike poles over ladder or object.				
7.	Extends chute out a door or window.				
8.	Completes and indicates that the water chute is complete.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: __/__/__

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 706	03-01- 21	Candidate Number	
Skill Title: CONSTRUCTION OF A WATER CATCH-ALL				
NFPA Objective:	4.3.14	Minimum to pass	8	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Positions salvage cover at desired location, flat and open				
3.	Takes a position on one side of cover and rolls inward approximately 3 feet.				
4.	Repositions to opposite side and rolls inward approximately 3 feet.				
5.	Forms four corners by folding about 3 feet of the rolled edge toward center of cover forming a 90° angle.				
6.	Repositions at an unrolled end.				
7.	Tightly rolls cover up to and over right-angle edge roll.				
8.	Locks corners formed by lifting edge roll with outside hand and tucking end roll under edge roll.				
9.	Repositions at opposite unrolled end.				
10.	Tightly rolls cover up to and over right-angle edge roll.				
11.	Locks corners formed by lifting edge roll with outside hand and tucking end roll under edge roll.				
12.	Completes construction of water catch-all.				

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 707	03-01-21	Candidate Number	
Skill Title: SHUTTING OFF ELECTRICAL SERVICE TO A BUILDING				
NFPA Objective:	4.3.18	Minimum to pass	4	
PERFORMANCE:			P	F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	2.	Searches area/building for electrical service box or panel.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	3.	Shuts off main breakers or pulls knife switch arm to shut off power using a concentrated motion for a clean break.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	4.	Looks away while manipulating breakers/switches.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	5.	Applies lock out/tag out equipment (if available).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	6.	Confirms to examiner that electrical service has been shut off.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 708	03-01-21	Candidate Number	
Skill Title: SHUTTING OFF NATURAL GAS SERVICE				
NFPA Objective:	4.3.18	Minimum to pass	4	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.	■	■	■	■
■	2.	Searches area/building for natural gas meter.	■	■	■	■
■	3.	Using a proper wrench, turns petcock to the "CLOSED" position.	■	■	■	■
■	4.	Turns any remaining visible valves to the "CLOSED" position.	■	■	■	■
■	5.	Applies lock out/tag out equipment (if available).	■	■	■	■
■	6.	Confirms to examiner that natural gas has been shut off.	■	■	■	■

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 709	03-01-21	Candidate Number	
Skill Title: SHUTTING OFF LPG OR CNG SERVICE				
NFPA Objective:	4.3.18	Minimum to pass	4	
PERFORMANCE:			P	F

<input checked="" type="checkbox"/>	1.	All Personal Protective Equipment (PPE) is properly worn.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	2.	Searches area/building for LPG or CNG cylinder or tank.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	3.	Locates shut-off on cylinder or tank.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	4.	Closes shut-off valve clockwise fully or in the direction of the arrow on the valve.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	5.	Confirms to examiner the LPG or CNG service has been shut off.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

☒ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: __/__/__

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 710	03-01-21	Candidate Number	
Skill Title: SHUTTING OFF WATER SERVICE				
NFPA Objective:	4.3.18	Minimum to pass	3	
PERFORMANCE:			P	F

1.	All Personal Protective Equipment (PPE) is properly worn.			
2.	Searches area/building for main water feeder.			
3.	Closes feeder-main valve fully.			
4.	Confirms to examiner that water service has been shut off.			

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 711	03-01-21	Candidate Number	
Skill Title: USE OF A SPRINKLER WEDGE OR STOPPER				
NFPA Objective:	4.3.18, 4.3.14	Minimum to pass	4	
PERFORMANCE:			P	F

■	1.	All Personal Protective Equipment (PPE) is properly worn.				
■	2.	Places ladder and safely climbs ladder to within reach of sprinkler head.				
■	3.	Inserts a wedge (flat sides up & down) or inserts sprinkler tongs between head arms.				
■	4.	Drives wedge into sprinkler or opens and locks tongs.				
■	5.	Stops flow of water from head.				

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-1- 712	03-01-21	Candidate Number	
Skill Title: OPEN AND CLOSE A SPRINKLER SYSTEM MAIN DRAIN				
NFPA Objective:	4.3.18, 4.3.14	Minimum to pass	4	
PERFORMANCE:				P F

1.	All Personal Protective Equipment (PPE) is properly worn.				
2.	Assures water supply valves are closed.				
3.	Opens main drain valve by slowly turning counter clockwise.				
4.	Opens main drain valve fully.				
5.	Once flow has stopped, close main drain valve by turning clockwise until fully closed.				

☐ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ____/____/____

Please circle: PASS FAIL RETAKE