



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|------------------------------|---|-----------------------|
| Skill Sheet No. FFII C 021 B | Presentation of Public Education Message | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.5.2 | Date: 01-01-25 |

| MINIMUM TO PASS: 10 FFII 10 of 14 (all worth 1 point) | | 1 st Test | | Retest | |
|--|---|----------------------|---|--------|---|
| | | P | F | P | F |
| 1* | Gathers and prepares needed presentation materials. | | | | |
| | 2 Ensures environment is conducive to learning. | | | | |
| | 3 Addresses any hazards present such as extension cords on floor, etc. | | | | |
| | 4 Introduces self. | | | | |
| | 5 Orients audience to location of exits and restrooms. | | | | |
| | 6 Correctly display and advance through PowerPoint presentation. | | | | |
| | 7 Presents fire safety message to audience in 4 – 6 minutes. | | | | |
| | 8 Speaks loudly enough to be heard by all members of the audience. | | | | |
| 9* | Ensures all information is presented. | | | | |
| | 10* Ensures accuracy of presented materials. | | | | |
| | 11 Asks a question to assess audience understanding | | | | |
| 12* | Answers all questions or refers to appropriate authority. | | | | |
| | 13* Completes and submits appropriate documentation of presentation. | | | | |
| | 14 Indicates to examiner when they have completed their presentation. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL

01012025



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|---|-----------------------|
| Skill Sheet No. FFII C 021 | Presentation of Public Education Message | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.5.2 | Date: 01-01-25 |

| MINIMUM TO PASS: 6 FFII 6 of 8 (all worth 1 point) | | 1 st Test | | Retest | |
|---|--|----------------------|---|--------|---|
| | | P | F | P | F |
| 1* | Explains the purpose of Stop, Drop, and Roll. | | | | |
| 2 | Instructs student to STOP and stay in place. | | | | |
| 3 | Instructs student to DROP to the ground/floor and cover face with hands. | | | | |
| 4 | Instructs student to ROLL to extinguish flames by tucking in elbows and keeping legs together. | | | | |
| 5* | Demonstrates STOP, DROP, and ROLL procedure to student. | | | | |
| 6 | Instructs students to demonstrate. | | | | |
| 7 | Evaluate student's performance. | | | | |
| 8* | Complete and submit appropriate documentation of presentation. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL

01012025



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|---|--------------------|
| Skill Sheet No. FFII C 022 | Perform a Life Safety Inspection | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.5.1 | Date: 01-01-25 |

| MINIMUM TO PASS: 6 FFII 6 of 8 (all worth 1 point) | | 1 st Test | | Retest | |
|---|--|---|---|--------|---|
| | | P | F | P | F |
| 1* | Candidate selects proper form to conduct a life safety inspection. | | | | |
| | 2* | Performs inspection of the occupancy to identify life safety hazards. | | | |
| 3 | Identify immediate hazards on form and indicate necessary corrections. | | | | |
| 4 | Submits copy of Life Safety Inspection form to building owner/representative (examiner) to communicate all findings and any further actions to be taken. | | | | |
| 5 | Correctly identifies and documents all hazards. | | | | |
| 6 | All unresolved issues reported to proper authority. | | | | |
| 7* | All documentation fully completed. | | | | |
| 8 | Project submitted within the given timeframe. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL

01012025



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|-----------------------------|--------------------------------------|--------------------|
| Skill Sheet No. FFII C 023B | Perform a Pre-Incident Survey | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.5.3 | Date: 01-01-25 |

| MINIMUM TO PASS: 8 FFII 8 of 11 (all worth 1 point) | | 1 st Test | | Retest | |
|--|--|----------------------|---|--------|---|
| | | P | F | P | F |
| 1* | Candidate selects proper form to conduct a Pre-Incident Survey. | | | | |
| 2 | Properly conducts Pre-Incident Survey based on assignment. | | | | |
| 3* | Candidate selects proper tools to conduct a Pre-Incident Survey. | | | | |
| 4 | Performs an inspection noting pertinent information. | | | | |
| 5 | Identifies and document's locations of fire detection systems. | | | | |
| 6 | Identifies and document's locations of fire suppression systems. | | | | |
| 7 | Identifies and document's locations of any special hazards. | | | | |
| 8 | Identifies and document's locations of any special features. | | | | |
| 9* | Accurately sketches or diagrams the site. | | | | |
| 10* | All required occupancy information is recorded. | | | | |
| 11 | Project submitted within the given timeframe. | | | | |
| TOTAL | | | | | |
| TOTAL: <i>ONLY if Retesting</i> | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL

01012025



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|-----------------------------------|--------------------------------------|--------------------|
| Skill Sheet No. FFII C 023 | Perform a Pre-Incident Survey | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.5.3 | Date: 01-01-25 |

| MINIMUM TO PASS: 7 FFII 7 of 10 (all worth 1 point) | | 1 st Test | | Retest | |
|--|--|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate appears in proper uniform and is readily identifiable as a fire department representative. | | | | |
| 2* | Candidate selects proper form to conduct a Pre-Incident Survey. | | | | |
| 3 | Candidate selects proper tools to conduct a Pre-Incident Survey. | | | | |
| 4 | Candidate introduces themselves to building owner/representative. | | | | |
| 5 | Candidate explains the purpose for the survey and how it will be conducted. | | | | |
| 6* | Performs a walkthrough inspection noting pertinent information. | | | | |
| 7 | Identifies and documents locations of fire detection and suppression systems. | | | | |
| 8 | Identifies and documents locations of any special hazards. | | | | |
| 9* | Accurately sketches / diagrams the site with appropriate labeling for clarification | | | | |
| 10* | All required occupancy information is recorded. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL

01012025



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|------------------------------------|---|--------------------|
| Skill Sheet No. FFII C 024B | Complete a Basic Incident Report | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.2.1 | Date: 01-01-25 |

| MINIMUM TO PASS: 5 FFII 5 of 8 (all worth 1 point) | | | 1 st Test | | Retest | |
|---|---|--|----------------------|---|--------|---|
| | | | P | F | P | F |
| 1* | Determine the necessary data management/NFIRS codes used to complete the report. | | | | | |
| 2 | Operate computer equipment normally used by local agency for completing incident reports. | | | | | |
| 3* | Complete all applicable alarm information sections. | | | | | |
| 4* | Record all pertinent information within the report. | | | | | |
| 5 | Complete all applicable narrative sections. | | | | | |
| 6 | Proofread report to ensure accuracy and completeness. | | | | | |
| 7 | Route, file, and/or forward report in accordance with local agency criteria. | | | | | |
| 8 | Project submitted within the given timeframe. | | | | | |
| TOTAL | | | | | | |
| TOTAL: ONLY if Retesting | | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL

01012025



MASSACHUSETTS FIRE TRAINING COUNCIL CERTIFICATION EXAMINATION SKILL SHEET

Candidate number

| | | |
|------------------------------|----------------------------------|--------------------|
| Skill Sheet No. FFII – C 421 | Service Testing Fire Hose | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.5.5, (NFPA 1962) | Date: 01-01-25 |

| MINIMUM TO PASS: 12 FFII 12 of 16 (all worth 1 point) | | 1 st Test | | Retest | |
|---|---|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| 2 | Verbalizes then checks gaskets and connects hose lengths together (no more than 300'). Hose is laid out straight. | | | | |
| 3* | Connects and tightens an open test gate valve to the discharge port. | | | | |
| 4 | Attaches a shutoff nozzle to the open end of the test length. | | | | |
| 5 | Makes chalk or pencil mark on hose jacket against each coupling. | | | | |
| 6 | Fills hoseline with water and increases pressure to 50 PSI. | | | | |
| 7 | Discharges all air from the line by opening the nozzle. | | | | |
| 8* | Verbalizes then checks that no couplings are leaking. Tightens any couplings, as necessary. | | | | |
| 9* | Closes test valve and increase pump pressure to 300psi (NFPA 1962). | | | | |
| 10 | Maintains pressure for three minutes. | | | | |
| 11 | While at test pressure the candidate shall walk along the test hose inspecting it for leaks. At no time shall the candidate be any closer than 15 feet to the hose. | | | | |
| 12 | Reduces pump pressure after three minutes, closes discharge valve, open nozzle to bleed off pressure. | | | | |
| 13 | Breaks connections and drains water away from the test area. | | | | |
| 14 | Observes marks placed on hose at the coupling. Verbalizes if coupling has slipped. | | | | |
| 15* | Determines and verbalizes whether each length can remain in service or be tagged and placed out of service. | | | | |
| 16 | Completes evolution safely. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*

FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET

*

Examiner name: (Printed) _____

Date: ____/____/____

Examiner Signature: _____

Circle one: PASS FAIL

Coordinator review: Date: ____/____/____

Initials: _____

PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|--|--------------------|
| Skill Sheet No. FFII C 921 | Extinguish an Exterior Flammable Liquid Fire with Foam – Single Firefighter | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.1 | Date: 04-21-25 |

| MINIMUM TO PASS: 12 FFII 12 of 16 (all worth 1 point) | | 1 st Test | | Retest | |
|--|-----|--|---|--------|---|
| | | P | F | P | F |
| | 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | |
| ■ | 2* | Ensures the foam nozzle, the in-line eductor, and the foam concentrate are both GPM and percentage of concentrate compatible. | | | |
| | 3 | Connects the proper foam nozzle to a sufficient length of hoseline to reach the intended target from the eduction point. | | | |
| | 4 | Connects the in-line eductor to the hoseline. | | | |
| | 5 | Connects sufficient hose from the engine discharge to the point of the foam eduction operation. | | | |
| | 6 | Places the supply of foam concentrate near the in-line eductor. | | | |
| | 7 | Places the in-line eductor pick-up tube into the foam concentrate container. | | | |
| | 8 | Indicates to the pump operator to charge hoseline. | | | |
| ■ | 9* | Dons SCBA mask and goes on air. | | | |
| | 10 | Removes kinks in hoseline during advancement. | | | |
| ■ | 11* | Turns the foam nozzle away from the fire, slowly opens the foam nozzle and ensures proper foam stream is being generated. | | | |
| ■ | 12* | Applies foam in either a finished foam spray or indirectly by directing the stream against a stationary object allowing the foam to spread over the burning fuel with as little agitation as possible. | | | |
| | 13 | If foam stops while in the process of application, the firefighter redirects the stream away from the existing foam blanket. | | | |
| ■ | 14* | Extinguishes the fire using foam. | | | |
| | 15* | Back away from the fuel source after the fire is extinguished. | | | |
| ■ | 16* | The candidate completed all tasks safely and efficiently per instructions. | | | |
| | | TOTAL | | | |
| | | TOTAL: ONLY if Retesting | | | |

■* FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ■*

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|--|--------------------|
| Skill Sheet No. FFII C 922 | Extinguish Exterior Flammable Gas Fire From a 20 LB Cylinder with a Hoseline Using SCBA Nozzle Position | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.3 | Date: 01-01-25 |

| MINIMUM TO PASS: 12 FFII 12 of 16 (all worth 1 point) | | 1 st Test | | Retest | |
|--|---|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| 2* | Identifies and verbalizes fuel type. | | | | |
| 3 | Continuously observes and verbalizes noted fire behavior and smoke conditions, vessel integrity and wind direction. | | | | |
| 4 | Sets nozzle for a 30-degree fog pattern. | | | | |
| 5 | Slowly opens the nozzle fully maintaining control of the hoseline, to expel air and test the fog pattern. | | | | |
| 6 | Confirms then verbalizes hoseline selected is of sufficient length to encircle the fire area if wind direction changes. | | | | |
| 7 | Ensures that the other two firefighters are ready to enter the fire area. | | | | |
| 8 | Advances hoseline to fire approaching from the upwind side. | | | | |
| 9* | Keeps nozzle <i>open fully</i> while advancing on fire, widening the fog pattern as needed for protection. | | | | |
| 10* | Upon reaching the fire, positions the fog-stream to push vapors/fire away from cylinder and valve so the valve can be closed without reaching through the fog stream. | | | | |
| 11* | Calls for a second backup firefighter to stabilize cylinder with rake or hook. | | | | |
| 12* | Calls for first backup firefighter to close the cylinder valve. | | | | |
| 13* | Ensures fire is extinguished after stopping the flow of gas. | | | | |
| 14* | Maintains appropriate fog-stream while backing away from the fuel source while avoiding kinks. | | | | |
| 15* | Remains standing, not kneeling, throughout evolution. | | | | |
| 16* | Completes evolution using safe fire suppression skills. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|--|--------------------|
| Skill Sheet No. FFII C 923 | Extinguish Exterior Flammable Gas Fire From a 20 LB Cylinder with a Hoseline Using SCBA - First Back-Up | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.3 | Date: 01-01-25 |

| MINIMUM TO PASS: 11 FFII 11 of 16 (all worth 1 point) | | 1 st Test | | Retest | |
|--|---|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| 2* | Continuously observes and verbalizes noted fire behavior and smoke conditions, vessel integrity and wind direction. | | | | |
| 3 | Takes position on the same side of the hoseline as the nozzle firefighter. | | | | |
| 4 | Removes kinks in the hoseline prior to advancing the line. | | | | |
| 5 | Checks, then verbalizes obstacles in the area during fire attack to maintain the safety of the fog pattern. | | | | |
| 6 | Ensures the line is of sufficient length to encircle the fire area if wind direction changes. | | | | |
| 7 | Keeps the hoseline straight while approaching from the upwind side when possible. | | | | |
| 8 | The candidate ensures the line is without kinks while advancing on the fire. | | | | |
| 9* | Works with the nozzle person to avoid reaching through hose stream to shut the valve. | | | | |
| 10* | Upon reaching the fire, the candidate closes the cylinder valve to stop gas flow. | | | | |
| 11 | Advises nozzle firefighter status of cylinder valve and returns to hoseline to assist with retreat. | | | | |
| 12* | Ensure that the fire crew does not trip over the retreating hoseline while backing out. | | | | |
| 13 | Stabilizes the hose line while backing away from the fuel source, avoiding kinks. | | | | |
| 14* | Remains standing, not kneeling, throughout the evolution. | | | | |
| 15* | Completes evolution using safe fire suppression skills. | | | | |
| 16 | Continuously observes and verbalizes noted fire behavior and smoke conditions, vessel integrity and wind direction. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|---|--------------------|
| Skill Sheet No. FFII C 924 | Extinguish Exterior Flammable Gas Fire From a 20 LB Cylinder with a Hoseline Using SCBA - Second Back-Up | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.3 | Date: 01-01-25 |

| MINIMUM TO PASS: 7 FFII 7 of 9 (all worth 1 point) | | 1 st Test | | Retest | |
|---|---|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| 2 | Continuously observes and verbalizes noted fire behavior and smoke conditions, vessel integrity and wind direction. | | | | |
| 3 | Takes a position on the same side of the hoseline relative to nozzle firefighter with a rake or hook. | | | | |
| 4 | Removes kinks in the hoseline prior to advancing the line. | | | | |
| 5 | Advances hoseline based on the need of the first back-up firefighter. | | | | |
| 6* | Once the nozzle is in position to protect the cylinder valve, comes off hoseline to stabilize cylinder with rake or hook. | | | | |
| 7 | Returns to hoseline to assist with retreat. | | | | |
| 8* | Remains standing, not kneeling, throughout evolution. | | | | |
| 9* | Completes evolution using safe fire suppression skills. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|--|--------------------|
| Skill Sheet No. FFII C 925 | Extinguish an Exterior Flammable Liquid Fire with Foam - Nozzle | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.1 | Date: 04-21-25 |

| MINIMUM TO PASS: 9 FFII 9 of 12 (all worth 1 point) | | 1 st Test | | Retest | |
|--|--|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| 2* | Ensures the foam nozzle, the in-line eductor, and the foam concentrate are both GPM and percentage of concentrate compatible. | | | | |
| 3 | Connects the proper foam nozzle to a sufficient length of hoseline to reach the intended target from the education point. | | | | |
| 4 | Connects the in-line eductor to the hoseline. | | | | |
| 5 | Indicates to pump operator to charge the hoseline once all connections have been made. | | | | |
| 6* | Dons SCBA mask and goes on air. | | | | |
| 7 | Turns the nozzle away from the fire, slowly opens the foam nozzle and assures proper foam stream is being generated. | | | | |
| 8* | Applies foam in either a finished foam spray or indirectly by directing the stream against a stationary object allowing the foam to spread over the burning fuel with as little agitation as possible. | | | | |
| 9 | If foam stops while in the process of application, the firefighter redirects the stream away from the existing foam blanket. | | | | |
| 10* | Extinguishes the fire using foam. | | | | |
| 11* | Back away from the fuel source after the fire is extinguished. | | | | |
| 12* | The candidate completed all tasks safely and efficiently per instructions. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|---|--------------------|
| Skill Sheet No. FFII C 926 | Extinguish an Exterior Flammable Liquid Fire with Foam – First Back up | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.1 | Date: 04-21-25 |

| MINIMUM TO PASS: 6 FFII 6 of 8 (all worth 1 point) | | 1 st Test | | Retest | |
|---|--|----------------------|---|--------|---|
| | | P | F | P | F |
| 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| 2 | Connects sufficient hose from the engine discharge to the point of the foam education operation. | | | | |
| 3* | Connects the in-line eductor to the supply side hoseline. | | | | |
| 4 | Verbalizes then coordinates with nozzle firefighter to don SCBA mask and go on air. | | | | |
| 5 | Takes up position on same side of hoseline as nozzle firefighter. | | | | |
| 6 | Removes kinks in hoseline during advancement. | | | | |
| 7* | Back away from the fuel source after the fire is extinguished. | | | | |
| 8* | The candidate completed all tasks safely and efficiently per instructions. | | | | |
| TOTAL | | | | | |
| TOTAL: ONLY if Retesting | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL



MASSACHUSETTS FIRE TRAINING COUNCIL
FIRE FIGHTER II CERTIFICATION EXAMINATION

CANDIDATE #

| | | |
|----------------------------|--|--------------------|
| Skill Sheet No. FFII C 927 | Extinguish an Exterior Flammable Liquid Fire with Foam – Second Back up | Passing Score: 70% |
| NFPA 1001-2019 edition | Objective: 5.3.1 | Date: 04-21-25 |

| MINIMUM TO PASS: 5 FFII 5 of 7 (all worth 1 point) | | | 1 st Test | | Retest | |
|---|----|---|----------------------|---|--------|---|
| | | | P | F | P | F |
| | 1 | Candidate arrives at test station wearing full complete Firefighting gear, with SCBA. | | | | |
| | 2* | Ensures foam concentrate and foam eductor are percentage of concentrate compatible. | | | | |
| | 3 | Places adequate supply of foam concentrate near the in-line eductor. | | | | |
| | 4 | Places the in-line eductor pick-up tube into the foam concentrate container. | | | | |
| | 5* | Monitors foam concentrate usage and ensures that foam concentrate does not run out. | | | | |
| | 6 | Assists with hose management while crew backs away from the fuel source after fire is extinguished. | | | | |
| | 7* | The candidate completed all tasks safely and efficiently per instructions. | | | | |
| TOTAL | | | | | | |
| TOTAL: ONLY if Retesting | | | | | | |

*** FAILURE OF THIS CRITICAL PORTION IS CAUSE FOR FAILURE OF THE ENTIRE SKILL SHEET ***

Examiner name: (Printed) _____ Date: ____/____/____

Examiner Signature: _____ Circle one: PASS FAIL

Coordinator review: Date: ____/____/____ Initials: _____ PASS FAIL