



FP-044B

The Commonwealth of Massachusetts
City of Town of _____



TRANSFER TANK INSPECTION
(Transportation of Combustible Liquids)

REG #: _____ **VIN #:** _____

NAME OF OWNER: _____

527 CMR 1.00: CHAPTER 42 REQUIREMENTS	YES	NO
Tank is securely mounted to the vehicle body or truck bed - 527 CMR 1.00: Chapter 42, Section 42.16.2(1)		
Tank does not exceed 119 gallons - 527 CMR 1.00: Chapter 42, Section 42.16.2(1)		
Tank not less than 14 USS gauge standard open hearth steel tank plate or 1/8 inch aluminum – 527 CMR 1.00: Chapter 42, Section 42.16.2(2)		
Liquid is drawn only from the top of the tank by means of a suitable pump to which is attached a durable hose equipped with a self-closing nozzle – 527 CMR 1.00: Chapter 42, Section 42.16.2(3)		
All openings are securely plugged or capped - Chapter 42, Section 42.16.2(4)		
Vehicle is equipped with a fire extinguisher with a minimum rating of 1-A: 10-B,C – 527 CMR 1.00: Chapter 13, Section 13.6 and 42.16.2(5)		
Tank not mounted in bed or body of any vehicle which contains a hoist to raise such bed or body		

NOTES: _____

INSPECTED BY: _____

FIRE DEPARTMENT: _____

DATE: _____