

BOARD POLICY

ALTERNATIVE METHOD TO MEETING THE REQUIREMENTS OF 248 CMR 10.09 (enacted 05-29-2013)

CRITERIA

May Only be Used for a Maximum of 2 Vehicles/Bays

Size Double Wall Tank Using Minimum of 60 Gallons per Vehicle

Properly Filed Variance Must be Approved by the Board Prior to Installation

No Engineer Stamp Required

Pump and Tank Do Not Require Product Acceptance

Allowable for New or Retrofit Installations

