

Massachusetts Department of Environmental Protection Source Water Assessment and Protection (SWAP) Report for

Green Meadow School

What is SWAP?

The Source Water Assessment Program (SWAP), established under the federal Safe Drinking Water Act, requires every state to:

- I nventory land uses within the recharge areas of all public water supply sources;
- Assess the susceptibility of drinking water sources to contamination from these land uses; and
- Publicize the results to provide support for improved protection.

SWAP and Water Quality

Susceptibility of a drinking water source does *not* imply poor water quality. Actual water quality is best reflected by the results of regular water tests.

Water suppliers protect drinking water by monitoring for more than 100 chemicals, treating water supplies, and using source protection measures to ensure that safe water is delivered to the tap.

Prepared by the
Massachusetts Department of
Environmental Protection,
Bureau of Resource Protection,
Drinking Water Program

Date Prepared October 28, 2003

Table 1: Public Water System (PWS) Information

PWS Name	Green Meadow School				
PWS Address	North Road				
City/Town	Hampden, Massachusetts				
PWS ID Number	1120011				
Local Contact	Mr. Michael Framarin				
Phone Number	413-525-4879				

Well Name	Source ID#	Zone I (in feet)	IWPA (in feet)	Source Susceptibility
Well #1	1120011-01G	100	418	Moderate
Well #2 (Proposed)	1120011-02A			

Introduction

We are all concerned about the quality of the water we drink. Drinking water wells may be threatened by many potential contaminant sources, including septic systems, road salting, and improper disposal of hazardous materials. Citizens and local officials can work together to better protect these drinking water sources.

Purpose of this report:

This report is a planning tool to support local and state efforts to improve water supply protection. By identifying land uses within water supply protection areas that may be potential contaminant sources, the assessment helps focus protection efforts on appropriate best management practices (BMPs) and drinking water source protection measures. Department of Environmental Protection (DEP) staff are available to provide information about funding and other resources that may be available to your community.

This report includes:

- 1. Description of the Water System
- 2. Discussion of Land Uses within Protection Areas
- 3. Recommendations for Protection
- 4. Attachments, including a Map of the Protection Areas

1. Description of the Water System

The Green Meadow School (the school) is located in central Hampden. The school student and staff population is approximately 400 people per day and is served by a single potable supply well (Well #1). Currently the school is undergoing a renovation and expansion. As part of that project, a new well, (Well #2) is being developed. The well is being permitted through the New Source Approval process. Once that well is approved and added to the system, this report will be updated to include Well #2.

What is a Protection Area?

A well's water supply protection area is the land around the well where protection activities should be focused. Each well has a Zone I protective radius and an Interim Wellhead Protection Area (I WPA).

- The Zone I is the area that should be owned or controlled by the water supplier and limited to water supply activities.
- The IWPA is the larger area that is likely to contribute water to the well.

In many instances the I WPA does not include the entire land area that could contribute water to the well. Therefore, the well may be susceptible to contamination from activities outside of the I WPA that are not identified in this report.

What is Susceptibility?

Susceptibility is a measure of a well's potential to become contaminated due to land uses and activities within the Zone I and Interim Wellhead Protection Area (I WPA).

Well #1was installed at the time of the original construction of the school and is located in a pit, immediately adjacent to (east of) the school. There is no municipal wastewater sewer system in Hampden; therefore, the school and surrounding facilities are served by on-site septic disposal. Well #1 is a bedrock well with a 6-inch diameter casing and is approximately 95 feet deep. The school is located east of the valley border fault that separates the Jurassic sedimentary beds of the Connecticut River valley from the metamorphic (schist) rocks of the eastern highlands. The geologic map for the area identifies the bedrock at the school site as the Ammonoosac Volcanics, an amphibolite – gneiss.

The Zone I is the area immediately around the wellhead where only activities associated with supplying water or non-threatening activities are allowed to occur. The Interim Wellhead Protection Area (IWPA) is a larger area that potentially contributes water to the well. The IWPA is only an interim protection area until an actual Zone II contribution area is delineated; the actual area of contribution to the wellhead may be larger or smaller then the IWPA. The well has a Zone I protective radius of 100 feet and an IWPA radius of 418 feet. These protective radii were calculated based on the metered water use from the two highest months of water use. Please refer to the attached map that shows the Zone I and IWPA. The Zone I area for Well #1 is not conforming to current DEP requirements. The Zone I area for 01-G includes the school, the boiler room and fuel oil, a storm drain, the dumpster and some school parking. The IWPA includes the entire school including the septic system and leachfield, the ball fields and parking.

The school is located in an area of faulted and folded bedrock uplands. The surficial maps indicate thin till deposits overlying the upland bedrock. There is no evidence of a continuous, protective confining clay layer in the vicinity of the wells. Wells drilled in these conditions are considered highly vulnerable to potential contamination from the ground surface because there is no significant hydrogeologic barrier, such as clay, to prevent surface contamination from migrating into the aquifer. The water does not require and is, at the time this report was prepared, not treated. You may request additional information regarding the quality of the water, from the local contact listed in Table 1.

Please refer to the following section, attached maps of the Zone Is and IWPAs and Table 2 for additional assessment information.

Table 2: Table of Activities within the Water Supply Protection Areas

Potential Sources of Contaminants	Zone I	IWPA	Threat	Comments
Fuel Oil Storage	Yes	Yes	Moderate	AST w/containment at school
Floor Drains in Boiler Rooms	Yes	Yes	Moderate	Consult with UIC program regarding compliance. Ensure that the new boiler room has a tight tank.
Athletic fields	Yes	Yes	Moderate	Continue current practice of prohibiting the use of pesticides/fertilizers on fields
School facilities and parking	Yes	Yes	Moderate	Limit road deicing usage, use BMPs for household hazardous materials and monitor parking areas and control stormwater
Septic systems components	Yes	Yes	Moderate	School leachfield in the IWPA

⁻For more information on Contaminants of Concern associated with individual facility types and land uses please see the SWAP Draft Land Use / Associated Contaminants Matrix on DEP's website - www.state.ma.us/dep/brp/dws/.

Glossary

Zone I: The area closest to a well; a 100 to 400 foot radius proportional to the well's pumping rate. To determine your Zone I radius, refer to the attached map.

IWPA: A 400-foot to ½ mile radius around a public water supply well proportional to its pumping rate; the area DEP recommends for protection in the absence of a defined Zone II. To determine I WPA radius, refer to the attached map.

Zone 11: The primary recharge area defined by a hydrogeologic study.

Aquifer: An underground water-bearing layer of permeable material that will yield water in a usable quantity to a well.

Hydrogeologic Barrier: An underground layer of impermeable material that resists penetration by water.

Recharge Area: The surface area that contributes water to a well

2. Discussion of Land Uses in the Protection Areas

During the assessment, several land uses and activities were identified within the drinking water supply protection areas that are potential sources of contamination.

Key issues include:

- 1. Non-conforming Zone I;
- 2. Aboveground fuel oil tank;
- 3. Floor drains in boiler room;
- 4. School facilities and athletic fields; and
- 5. Residential housing

There are several activities within the Zone I and IWPA that pose a significant threat to the water supply. The overall ranking of susceptibility to contamination for the well is moderate. Please refer to Table 2. The school is commended for its proactive approach to source protection by applying for and being awarded a Wellhead Protection Grant to address source protection issues for Well #1. Additional source protection measures will be undertaken as part of the school renovations including the development of a new well.

1. Non-conforming Zone I – The water supplier owns the entire Zone I area. However, there are numerous activities in the Zone I that are not allowed. DEP requires that only water supply related activities or non-threatening activities occur within Zone I. Systems not meeting DEP Zone I requirements, must get DEP approval and address Zone I issues prior to increasing water use or modifying systems. The school is in the process of developing a new well as part of a school expansion.

Zone I Recommendations:

- V Prohibit any additional activities within Zone I and, where feasible, remove nonconforming activities within the Zone I areas.
- V Use Best Management Practices for handling treatment chemicals and vehicles used to access the area.
- V Monitor all fuel oil deliveries.
- V Do not use or store pesticides, fertilizers or road salt within the Zone I.




Figure 1: Example of how a well could become contaminated by different land uses and activities.

2. Aboveground fuel oil storage tank – A fuel oil AST is located within the Zone I. It is in the building and within containment. The school uses propane and has kept the oil tank as an emergency backup. If managed improperly, fuel oil tanks can be a potential source of contamination due to leaks or spills of the materials they store.

Recommendation:

- V Any modifications to the tank must be accomplished in a manner consistent with Massachusetts's plumbing, building, and fire code requirements. Consult with the local fire department for any additional local code requirements regarding ASTs.
- V Monitor all activities associated with the fuel oil especially delivery.
- **3. Floor Drains in Boiler Room** There are floor drains in the boiler room, that discharge to the stormdrain system. Title 5 prohibits disposal of any wastewater other than sanitary waste to a septic system and the UIC regulations prohibit dry wells in areas where hazardous materials (boiler blow down) or petroleum may enter the floor drain. The floor drain must be

For More Information:

Contact Catherine V. Skiba in DEP's Springfield Regional Office at (413) 755-2119 for more information and for assistance in improving current protection measures.

More information relating to drinking water and source protection is available on the Drinking Water Program web site at:

www.state.ma.us/dep/brp/dws/

Additional Documents:

To help with source protection efforts, more information is available by request or online at www.state.ma.us/dep/brp/dws, including:

- Water Supply Protection Guidance Materials such as model regulations, Best Management Practice information, and general water supply protection information.
- 2. MA DEP SWAP Strategy
- 3. Land Use Pollution Potential Matrix
- 4. Draft Land/Associated Contaminants Matrix

Copies of this assessment have been provided to the public water supplier, town boards, the town library and the local media. protected to prevent boiler blow down, oil or other prohibited discharges through the floor drain. The floor drains for the new boiler will be directed to a tight tank.

Recommendations:

- V Be sure that the floor drains are in compliance with Department Regulations (refer to Industrial Floor Drain Brochure attached). Ensure that that the renovation designs are in compliance.
 - Contact the UIC coordinator for the Western Region Office of the Department (Rick Larson 413-755-2207 or Tony Zaharias 413-755-2122).
- V Seal all cracks in the floor and the floor drain if it cannot be adequately protected to prevent a prohibited discharge.
- **4. School facilities and athletic fields** Elementary schools generally use only household hazardous materials for cleaning. There are state and federal regulations controlling some if the activities and products used at schools to promote "healthy schools". All of the school's facilities are located within the Zone I or IWPA of the well. Potential exists for contamination of the well by onsite use of fertilizers or pesticides. Stormdrains in the parking areas at the school drain directly into the ground.

Recommendations:

- V Continue the use of Best Management Practices for all activities at the school and at the athletic fields across the street. Consider drought resistant grasses and/or low release nutrient fertilizers in the IWPA, as required.
- V Investigate Integrated Pest Management and Best Management Practices within the IWPA, as necessary.
- V Use secondary containment for any petroleum products kept for maintenance and lawn care equipment.
- V Use Best Management Practices for handling treatment chemicals and vehicles used to access the area. Do not use or store pesticides, fertilizers or deicing materials within Zone I.
- V Review your emergency response plan regarding accidental releases within the area. Ensure that emergency responders in town are aware of the locations of your resource areas
- V Refer to the Massachusetts Public Health Associations Healthy Schools website online at http://www.mphaweb.org/pol_schools.html for additional information.
- **5. Residential Land Use** There are a few residences on the edge of the IWPA protection area. If managed improperly, activities associated with residential areas can contribute to drinking water contamination. Common potential sources of contamination include:
- **Septic Systems** Improper disposal of household hazardous chemicals to septic systems is a potential source of contamination to the groundwater because septic systems leach to the ground. If septic systems fail or are not properly maintained they could be a potential source of microbial contamination.
- Household Hazardous Materials Hazardous materials may include automotive
 wastes, paints, solvents, pesticides, fertilizers, and other substances. Improper use,
 storage, and disposal of chemical products used in homes are potential sources of
 contamination.
- **Heating Oil Storage** If managed improperly, Underground and Aboveground Storage Tanks (USTs and ASTs) can be potential sources of contamination due to leaks or spills of the fuel oil they store.
- Stormwater Catchbasins transport stormwater from roadways and adjacent properties to the ground and streams. As flowing stormwater travels, it picks up debris and contaminants from streets and lawns. Common potential contaminants

include lawn chemicals, pet waste, and contaminants from automobile leaks, maintenance, washing, or accidents. Visit the Nonpoint Source pollution web site for information at http://www.state.ma.us/dep/brp/wm/nonpoint.htm.

Residential Land Use Recommendations:

V Educate residents on best management practices (BMPs) for protecting water supplies. Distribute the fact sheet "Residents Protect Drinking Water" available in Appendix A and on www.mass.gov/dep/brp/dws/protect.htm, which provides BMPs for common residential issues.

3. Protection Recommendations

Implementing protection measures and best management practices (BMPs) will further reduce the well's susceptibility to contamination. The DEP commends the practice of not using pesticides and fertilizers in the Zone I and having a propane backup generator. The school district should comment to the various town boards regarding developments that may impact the well.

Please review and adopt the key recommendations listed above and as follows:

Priority Recommendations:

- V Communication with the Town boards regarding the location of the well and the protection areas.
- V Contact the UIC coordinator to evaluate compliance for the floor drains in the boiler room and ensure that the school renovation designs include a tight tank for the boiler room.

Zone I and IWPA:

- V Prohibit any new non-water supply activities from Zone I.
- V Conduct regular inspections of the Zone I and IWPA.
- V Monitor activities and if there is evidence of increased activity or access, consider relocating the well.
- V Post drinking water supply signs in key location such as along the access road and in the parking areas but away from the well.
- V Provide information to staff and pertinent school organizations about the potential hazards of household chemicals, lawn care chemicals and fertilizers.
- V Use Best Management Practices (BMPs) for the use of petroleum products, lawn care products, pesticides and household hazardous waste.

Training/Education and Facilities Management:

- V Incorporate groundwater education into the school curriculum (K-6 curricula available; contact DEP for copies).
- V Staff should be instructed on the proper disposal of spent household chemicals. Include custodial staff, groundskeepers, and certified operator. In order to participate in a Community Hazardous Waste Pick-up day, the school must be registered as a Very Small Quantity Generator. The school is currently not registered as a generator of hazardous waste or waste oil. Review the enclosed document "A SUMMARY OF REQUIREMENTS FOR SMALL QUANTITY GENERATORS OF HAZARDOUS WASTE" and register to participate, if necessary.

Planning:

- V Work with local officials to develop an Aquifer Protection District Bylaw that includes the school well's IWPA and to assist you in continued protection of the water supply.
- V Have a plan to address short-term water shortages and long-term water demands. Keep the phone number of a bottled water company readily available.
- V Supplement the SWAP assessment with additional local information and incorporate it into water supply educational efforts.
- V Use a potential contaminant threat inventory to assist in setting priorities, focusing inspections, and creating educational activities.

Funding:

The Department's Wellhead Grant Protection Program provides funds to assist public water suppliers in addressing Wellhead protection through local projects. Protection recommendations discussed in this document may be eligible for funding under the "Wellhead Protection Grant Program". If funds area available, the Department posts a new Request for Response (RFR), grant application form. Other funding opportunities are described in "Grant and Loan Programs: Opportunities for Watershed Protection, Planning and Implementation" on the MA DEP website at http://www.state.ma.us/dep/brp/mf/files/glprgm.pdf.

These recommendations are only part of your ongoing local drinking water source protection. Citizens and community officials should use this SWAP report to encourage discussion of local drinking water protection measures.

4. Attachments

- Map of the Public Water Supply (PWS) Protection Area
- Recommended Source Protection Measures Fact Sheet
- UIC/Industrial Floor Drain