

Quarterly Leak Summary (Re

QUARTER - 1Q 2024

Name of Operator: Holyoke Gas &

Operator Name	A	B				C			
	Leaks Carried Forward from Previous Year	New Leaks Identified				Leaks Repaired			
		Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4
Grade 1	0	5				4			
Grade 2	0	1				1			
Grade 3SEI ¹	0	1				1			
Grade 3 nonSEI	0	1				1			
Totals	0	8	0	0	0	7	0	0	0

¹ Grade 3SEI ("G3SEI") refers to Grade 3 leaks of significant environmental impact.

v. 4/2024)

& Electric

D				E	Leaks Classified Up	Leaks Classified Down	Notes
Leaks Eliminated by Replacement or Otherwise				Leaks Pending at End of Quarter			
Q1	Q2	Q3	Q4				
0				0	0	1	
0				0	0	0	
0				0	0	0	
1				0	1	0	
1	0	0	0	0	1	1	

Detailed Quarterly Information

Rev: 4/2024

QUARTER Q1- 2024
Name of Operator: Holyoke Gas & Electric

Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Designation Date	Leak Extent or Barhole Reading	Method Used (Leak Extent/ Barhole)	
2024H-001	5 HARRISON AVE	Holyoke	1	1/17/24	1/17/24	Newly Identified	Repaired					Replace
2024H-002	COMMERCIAL ST	Holyoke	2	1/22/24	2/1/24	Newly Identified	Repaired					Encapsulate bell joint
2024H-003	4 LEXINGTON AVE	Holyoke	1	2/8/24	2/8/24	Newly Identified	Repaired					Replace
2024H-005	WHITNEY AVE	Holyoke	3/5	2/15/24	2/27/24	Newly Identified	Repaired		2/15/24	84	Barhole	Apply LLFA tape
2024H-006	2239 NORTHAMPTON ST	Holyoke	1	2/25/24	2/25/24	Newly Identified	Repaired					Tighten
2024H-007	1597 NORTHAMPTON ST	Holyoke	3	3/18/24	3/19/24	Newly Identified	Repaired	1				Encapsulate bell joint
2024H-008	23 SPRING ST	Holyoke	1	3/8/24	3/8/24	Newly Identified	Repaired					Encapsulate bell joint
2024H-004	37 EDWARD DR	Holyoke	3	2/8/24	2/18/24	Newly Identified	Eliminated					Insert service