

Quarterly Leak Summary (Rev. 10/2025)

QUARTER - 3Q 2025

Name of Operator: Holyoke Gas & Electric

Operator Name	A	B				C				D				E	Leaks Classified Up	Leaks Classified Down	Notes
	Leaks Carried Forward from Previous Year	New Leaks Identified				Leaks Repaired				Leaks Eliminated by Replacement or Otherwise				Leaks Pending at End of Quarter			
		Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4				
Grade 1	0	12	5	3		12	4	3		0	0	0		0	0	1	
Grade 2	0	6	2	1		6	2	3		0	1	0		0	3	0	
Grade 3SEI ¹	0	0	0	1		0	0	2		0	0	0		0	1	0	
Grade 3 nonSEI	0	0	0	5		0	0	2		0	0	0		0	0	3	
Totals	0	18	7	10	0	18	6	10	0	0	1	0	0	0	1	1	

¹ Grade 3SEI ("G3SEI") refers to Grade 3 leaks of significant environmental impact.

Detailed Quarterly Information (Rev. 10/2025)

QUARTER Q3-2025

Name of Operator: Holyoke Gas & Electric

Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Designation Date	Leak Extent or Barhole Reading	Method Used (Leak Extent/ Barhole)	
2025H-019	35 NORWOOD TER	Holyoke	1	9/21/2025	9/21/2025	Newly Identified	Repaired					Replace
2025H-018	69 HITCHCOCK ST	Holyoke	1	9/11/2025	9/11/2025	Newly Identified	Repaired					Replace
2025H-017	169 MICHIGAN AVE	Holyoke	1	7/27/2025	7/27/2025	Newly Identified	Repaired					Tighten
2025-017	60 LONGFELLOW RD	Holyoke	3	9/4/2025	9/16/2025	Newly Identified	Repaired					Install full seal clamp
2025-016	93 SHEEHAN DR	Holyoke	2	9/3/2025	9/16/2025	Newly Identified	Repaired	3				Tighten
2025-015	12 HILLVIEW RD	Holyoke	2	8/26/2025	8/26/2025	Newly Identified	Repaired					Tighten
2025-013	18 WAYNE CT	Holyoke	3SEI	8/19/2025	9/12/2025	Newly Identified	Repaired	3	9/12/2025	50	Barhole	Install full seal clamp
2025-012	LEARY DR	Holyoke	2	8/18/2025	8/29/2025	Newly Identified	Repaired	3				Replace
2025-011	3 HUMESTON SLOPE	Holyoke	3	8/13/2025	9/12/2025	Newly Identified	Repaired					Replace
2025-010	375 WHITNEY AVE	Holyoke	3SEI	7/1/2025	7/14/2025	Newly Identified	Repaired		7/1/2025	94	Barhole	Install full seal clamp