

DEPARTMENT OF DEVELOPMENTAL SERVICES

LICENSURE AND CERTIFICATION

DDS FOLLOW-UP REPORT

Provider Hopewell Inc. Provider Address 3 Allied Drive 308, Dedham
 Survey Team Bullard, David; Hutchison, Melanie; Date(s) of Review 10-JUN-24 to 11-JUN-24

Follow-up Scope and results :						
Service Grouping	Licensure level and duration	# Critical Indicators std. met/ std. rated at follow-up	# Indicators std. met/ std. rated at follow-up	Sanction status prior to Follow-up	Combined Results post-Follow-up; for Deferred, License level	Sanction status post Follow-up
Residential and Individual Home Supports 5 Locations 5 Audits	Defer Licensure	1/1	1/1	<input type="checkbox"/> Eligible for new business (Two Year License) <input checked="" type="checkbox"/> Ineligible for new business. (Deferred Status: Two year mid-cycle review License)	2 Year License with Mid-Cycle Review	<input checked="" type="checkbox"/> Eligible for New Business (80% or more std. met; no critical std. not met) <input type="checkbox"/> Ineligible for New Business (<=80% std met and/or more critical std. not met)

DEPARTMENT OF DEVELOPMENTAL SERVICES

LICENSURE AND CERTIFICATION

DDS FOLLOW-UP REPORT

Summary of Ratings

Residential and Individual Home Supports Areas Needing Improvement on Standard not met - Identified by DDS

Indicator #	L12
Indicator	Smoke detectors
Area Need Improvement	At two locations, carbon monoxide detectors were not located within 10 feet of bedroom doors. At one location, a smoke detector was not present outside the individual's sleeping area. The agency needs to ensure that smoke and carbon monoxide detectors are located where required.
Status at follow-up	The agency updated its home requirement checklist for placement service providers to include the proper type and location of smoke detectors based on the year that a home was built or the year that a home was renovated. It also added requirements for where carbon monoxide detectors must be in homes which use a fossil fuel for heating the home and/or hot water. The agency trained staff on the updated home requirement checklist. At five locations, all had smoke and carbon monoxide detectors located where required. All detectors functioned correctly when tested.
#met /# rated at followup	5/5
Rating	Met