

**Finlayson, Ian (ENE)**

---

**From:** Charles Hornig (Town) <hornig.lex@charleshornig.org>  
**Sent:** Tuesday, 9 August 2022 8:42 AM  
**To:** STRETCHCODE (ENE)  
**Subject:** BUILDING CODE COMMENTS

**CAUTION:** This email originated from a sender outside of the Commonwealth of Massachusetts mail system. Do not click on links or open attachments unless you recognize the sender and know the content is safe.

Thank you for the opportunity to comment on the draft Stretch Energy Code.

The proposed 225 CMR 22 section R404.4 Exception 1 should be changed to limit the number of EV Ready Spaces to the number of parking spaces actually provided, not the number required by local ordinance. Without this change, no EV Ready Spaces will be required where local zoning requires no parking or less than 1 space per dwelling unit.

Thank you for your consideration.

Charles Hornig  
18 Bacon Street  
Lexington, MA 02421