

COMPLIANCE CHECKLIST**IP10 Pediatric & Adolescent Patient Care Unit**

The following checklist is intended to be used in the plan review applications for health care facilities submitted to the Massachusetts Department of Public Health. This checklist summarizes and references the applicable requirements from the Licensure Regulations and the 2022 Edition of the FGI Guidelines for Design and Construction of Hospitals. Applicants must verify compliance of the plans submitted to the Department with all referenced requirements from the Licensure Regulations and FGI Guidelines when completing this Checklist. A separate Checklist must be completed for each nursing unit, hospital or clinic department, or clinical suite.

Other jurisdictions, regulations and codes may have additional requirements which are not included in this checklist, such as:

- NFPA 101 Life Safety Code (2012) and applicable related standards contained in the appendices of the Code
- State Building Code (780 CMR)
- Accreditation requirements of The Joint Commission
- CDC Guidelines for Preventing the Transmission of Mycobacterium Tuberculosis in Health Care Facilities
- USP 797 & Regulations of the Massachusetts Board of Registration in Pharmacy
- Occupational Safety & Health Standards (OSHA)
- Accessibility Guidelines of the Americans with Disabilities Act (ADA)
- Architectural Access Board Regulations (521 CMR)
- Local Authorities having jurisdiction.

Instructions:

1. All requirement lines must be completed according to the following instructions and included in the plan submissions for Self-Certification Process or Abbreviated Review Process.
2. This checklist must be completed by the project architect or engineer based on the design actually reflected in the plans at the time of completion of the checklist.
3. Each requirement line (____) of this Checklist must be completed exclusively with one of the following marks, unless otherwise directed in the checklist. If a functional space is not affected by a renovation project, the mark "E" may be indicated on the requirement line (____) before the name of the functional space (associated requirements on indented lines below that name, or associated MEP requirements do not have to be completed in this case). If more than one functional space serves a given required function (e.g. patient room or exam room), that clarification should be provided in the Project Narrative, and the requirement lines are understood to only address the functional spaces that are involved in the project.

X = Requirement is met, for new space, for renovated space, or for existing direct support space for an expanded service.

☒ = Check box under section titles or individual requirements lines for optional services or functions that are not included in the project area.

E = Requirement relative to an existing suite or area that has been *licensed* for its designated function, is *not affected* by the construction project and *does not pertain to a required direct support space* for the specific service affected by the project. "E" must not be used for an existing required support space associated with a new patient care room or area.

W = Waiver requested for specific section of the Regulations or FGI Guidelines, where hardship in meeting requirement can be demonstrated (a Physical Plant Waiver Form must be completed for each waiver request). An explicit floor plan or plan detail must be attached to each waiver request.

4. All room functions marked with "X" must be shown on the plans with the same name labels as in this checklist.
5. Mechanical, electrical & plumbing requirements are only partially mentioned in this checklist. The relevant section of the FGI Guidelines must be used for project compliance with all MEP requirements and for waiver references.
6. Oxygen, vacuum, medical air, waste anesthesia gas disposal and instrument air outlets (if required) are identified respectively by the abbreviations "OX", "VAC", "MA", "WAGD" & "IA".
7. Requirements referenced with "FI" result from formal interpretations from the FGI Interpretations Task Group.
8. The location requirements including asterisks (*) refer to the definitions of the Glossary in the beginning section of the FGI Guidelines and reproduced in this checklist.

Facility Name:

DoN Project Number: (if applicable)

Facility Address:

Patient Care Unit Bed Complements:

Current = Proposed =

Satellite Name: (if applicable)

Building/Floor Location:

Satellite Address: (if applicable)

Submission Dates:

Initial Date:

Revision Date:

Project Description:

Architectural Requirements**Building Systems Requirements**

2.2-2.12

**DISCRETE PEDIATRIC & ADOLESCENT
PATIENT CARE UNIT**☐ check if not included in project

2.1-1.2.3

Shared Services:

☐ No combined functions unless specifically allowed in this checklist

2.2-2.12.2

PATIENT ROOM

2.2-2.12.2.1

Capacity:

(1)

☐ maximum number of beds per room is one bed

(2)

or
☐ renovation work is undertaken
☐ present capacity is more than one patient in each room
☐ proposed room capacity is no more than present capacity
☐ maximum 2 patients in each room

2.2-2.12.2.2

Space Requirements:

(1)(a)

☐ single-patient rooms☐ check if not included in project☐ min. clear floor area 120 sf

2.2-2.2.2.2

(2)(a)

☐ min. clearance 3'-0" between sides of bed & any wall or any other fixed obstruction

☐ min. clearance 3'-0" between foot of bed & any wall or any other fixed obstruction

(1)(b)

☐ multiple-patient rooms☐ check if not included in project☐ min. clear floor area 100 sf per bed

2.2-2.2.2.2

(2)(a)

☐ min. clearance 3'-0" between sides of bed & any wall or any other fixed obstruction

(2)(b)

☐ min. clearance 4'-0" at foot of each bed to permit passage of equipment & beds

2.2-2.12.2.3

Windows in Patient Rooms:

2.1-7.2.2.5(1)

☐ each patient room provided with natural light by means of window to outside

Ventilation:

☐ Min. 4 air changes per hour Table 7-1

Lighting: 2.1-8.3.4.3(1)

☐ General lighting
☐ Reading light for each patient bed (a)

☐ controls accessible to patients in bed

☐ Night-light located in each patient room (b)

☐ no central control of night-lights outside room

☐ night-light illuminates path from room entrance to bedside

☐ night-light illuminates path between bed & toilet room

Power:

☐ Min. 12 receptacles in total☐ Min. 2 receptacles at each side of the head of the bed
☐ Min. 2 receptacles on all other walls (not including any TV receptacle)

Table 2.1-1

Nurse Call System:

☐ Patient station☐ Staff assistance station☐ Emergency call station

Table 2.1-2

Medical Gases:

☐ 1 OX, 1 VAC per bed

Table 2.1-3

Architectural Requirements**Building Systems Requirements**

- 2.1-7.2.2.5(2) ☐ operable windows in patient rooms
☐ check if not included in project
☐ window operation is limited with either stop limit/restrictor hardware or open guard/screen
☐ prevents passage of 4-inch diameter sphere through opening
☐ insect screens
- 2.1-7.2.2.6
 2.1-7.2.2.5(3)
 (a) ☐ min. net glazed area be no less than 8% of required min. clear floor area
 (b) ☐ max. 36" windowsill height above finished floor

- 2.1-2.1.2 Patient Privacy:
☐ Provisions are made to address patient visual & speech privacy
- 2.1-2.2.5 Handwashing Station in Patient Room:
 2.1-2.2.5.1 ☐ provided in patient room in addition to that in toilet room
 (1) ☐ adjacent to entrance to patient room for use by health care personnel & others
 Multi-Patient Rooms:
☐ check if not included in project
 (2) ☐ handwashing station located outside patients cubicle curtains
- 2.1-2.2.6 ☐ Patient toilet room
 2.1-2.2.6.2 ☐ in patient care units patient toilet room serve no more than one patient room
- 2.1-2.2.6.3
 (1) ☐ toilet
 (2) ☐ handwashing station
 (3) ☐ bedpan washer

- Ventilation:
☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

- 2.1-2.2.7 Patient Bathing Facilities:
 2.1-2.2.7.1(1) ☐ located in toilet room directly accessible from each patient room

- or**
 2.1-2.2.7.1(2) ☐ located in central bathing facility

- 2.1-2.2.7.2 Central Bathing Facilities:
☐ check if not included in project
 (1) ☐ each bathtub or shower in individual room or enclosure that provides privacy for bathing drying & dressing
 (2) ☐ at least one shower or bathtub provided for each patient care unit

- Ventilation:
☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

- Nurse Call System:
☐ Bath station Table 2.1-2

Architectural Requirements

- (3)(a) ☐ toilet in or directly accessible to each central bathing facility
- ☐ in separate enclosure
or
☐ located in private bathing room

- (3)(b) ☐ handwashing sink in or directly accessible to each central bathing facility

- (3)(c) ☐ storage for soap & towels in or directly accessible to each central bathing facility

2.1-2.2.7.3

Mobile Lifts, Shower Gurney Devices & Wheelchair Access:

- (1) ☐ doorways designed to allow entry of portable/mobile mechanical lifts & shower gurney devices
- (2) ☐ thresholds designed to facilitate use & prevent tipping of wheelchairs & other portable wheeled equipment
- (3) ☐ patient shower rooms designed to allow entry of portable/mobile mechanical lifts & shower gurney devices
- (4) ☐ floor drain grates designed to facilitate use & prevent tipping of wheelchairs & other portable wheeled equipment

- (3) **Mobile Lifts, Shower Gurney Devices & Wheelchair Access:**

- (a) ☐ doorways designed to allow entry of portable/mobile mechanical lifts & shower gurney devices
- (b) ☐ thresholds designed to facilitate use & prevent tipping of wheelchairs & other portable wheeled equipment
- (c) ☐ patient shower rooms designed to allow entry of portable/mobile mechanical lifts & shower gurney devices
- (d) ☐ floor drain grates be designed to facilitate use & prevent tipping of wheelchairs & other portable wheeled equipment

2.2-2.2.2.8

Patient Storage:

- 2.1-2.2.8 ☐ separate wardrobe, locker, or closet suitable for garments & for storing personal effects

Building Systems Requirements**Ventilation:**

- ☐ Min. 10 air changes per hour Table 7-1
- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

Nurse Call System:

- ☐ Bath station Table 2.1-2

Architectural Requirements**Building Systems Requirements****2.2-2.12.3 FAMILY SUPPORT REQUIREMENTS**

- 2.2-2.7.2.2(2)(a) ☐ Space at each bedside for families & visitors
 ☐ provided in addition to space provided for staff
 ☐ space provided for parental accommodations & for movable furniture does not encroach on minimum clearance requirements
- 2.2-2.7.2.2(2)(b) ☐ Space for recumbent sleep of parent/visitor
 ☐ communication system
 ☐ check if not included in project (only if sleeping area is adjoining patient area)
- 2.2-2.11.2.2 Space Requirements:
 ☐ enough space provided for parents to stay 24 hours

2.2-2.12.4 SPECIAL PATIENT CARE ROOMS

- 2.2-2.12.4.2 ☐ Airborne infection isolation (AII) room
 (1) ☐ at least one AII room be provided in each pediatric unit
- 2.1-2.4.2.2 ☐ complies with requirements applicable to patient rooms
 (1) ☐ capacity one bed
 (2) ☐ personal protective equipment (PPE) storage at entrance to room
 ☐ provisions for PPE disposal at entrance to room
 (3) ☐ handwashing station
 (4) ☐ patient toilet room
 ☐ serves only one AII room
 (5) ☐ bathtub or shower
- 2.1-2.4.2.3 ☐ Anteroom
 ☐ check if not included in project
- (2)(a) ☐ provides space for persons to don personal protective equipment (PPE) before entering patient room
 ☐ provides space for persons to doff PPE after leaving patient room
- (2)(b) ☐ all doors to anteroom have self-closing devices
 or
 ☐ audible alarm activated when AII room is in use as isolation room
- (3)(a) ☐ handwashing station
 (3)(b) ☐ storage for unused PPE
 (3)(c) ☐ disposal/holding container for used PPE

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ No recirculating room units

Architectural Requirements**Building Systems Requirements**

- 2.1-2.4.2.4 Architectural Details & Furnishings:
- (1)(a) ☐ perimeter walls ceiling & floor including penetrations constructed to prevent air exfiltration
- (1)(b) ☐ self-closing devices on all room exit doors
- or**
- ☐ activation of audible alarm when AII room is in use as isolation room
- ☐ edge seals provided along sides & top of doorframe for any door into AII room
- (2) (a) ☐ window treatments do not include fabric drapes & curtains
- 2.1-2.4.2.5 ☐ room pressure visual or audible alarm

2.2-2.12.8 **SUPPORT AREAS FOR PEDIATRIC & ADOLESCENT UNITS**

- 2.1-2.8.1 ☐ Support areas provided on each patient care unit floor (permitted to be arranged & located to serve more than one patient care unit)

- 2.2-2.2.8.2 ☐ Administrative center or nurse station

Nurse Call System:

☐ Nurse master station

Table 2.1-2

- 2.1-2.8.2.1(1) ☐ space for counters
- 2.1-2.8.2.1(2) ☐ handwashing station next to or directly accessible*
- or**
- ☐ hand sanitation dispenser next to or directly accessible*

- 2.1-2.8.2.2 ☐ Center for reception & communication
- ☐ self-contained
- or**
- ☐ combined with administrative center or nurse station

- 2.2-2.2.8.3 ☐ Documentation area
- 2.1-2.8.3.1 ☐ work surface to support documentation process
- 2.2-2.2.8.4 ☐ Nurse or supervisor office

- 2.2-2.2.8.5 ☐ Multipurpose room
- 2.1-2.8.5 ☐ at least one multipurpose room for each facility for patient conferences, reports, education, training sessions & consultation (may serve several patient care units & departments)

- 2.2-2.2.8.7 ☐ Handwashing station
- 2.1-2.8.7.1 ☐ located in each room where hands-on patient care is provided

Architectural Requirements**Building Systems Requirements**

- 2.2-2.2.8.8 _____ Medication safety zones
- 2.1-2.8.8.1(2) _____ Design Promoting Safe Medication Use:
- (a) _____ medication safety zones located out of circulation paths
 - (b) _____ work space designed so that staff can access information & perform required tasks
 - (c) _____ work counters provide space to perform required tasks
 - (e) _____ sharps containers placed at height that allows users to see top of container
 - (f) _____ max. 45 dBA noise level caused by building systems
- 2.1-2.8.8.2(1) _____ medication preparation room
- (a) _____ under visual control of nursing staff
 - (b) _____ work counter
 - _____ handwashing station
 - _____ lockable refrigerator
 - _____ locked storage for controlled drugs
 - _____ sharps containers
 - _____ ☐ check if not included in project
 - (c) _____ self-contained medication-dispensing unit
 - _____ ☐ check if not included in project
 - _____ room designed with space to prepare medications
- or**
- 2.1-2.8.8.2(2) _____ automated medication-dispensing unit
- (a) _____ located at nurse station, in clean workroom or in alcove
 - (c) _____ handwashing station or hand sanitation dispenser located next to stationary medication-dispensing units or stations
- 2.2-2.2.8.9 _____ Nourishment area or room
- 2.1-2.8.9.2 _____
- (1) _____ handwashing station
 - (2) _____ work counter
 - (3) _____ refrigerator
 - (4) _____ microwave
 - (5) _____ storage cabinets
 - (6) _____ space for temporary storage of food service implements
- 2.1-2.8.9.3 _____ provisions & space for separate temporary storage of unused meal trays
- 2.1-2.8.9.4 _____ provisions & space for soiled meal trays
- Lighting:
_____ Task lighting 2.1-2.8.8.1(2)(d)
- Ventilation:
_____ Min. 4 air changes per hour Table 7-1
- Ventilation:
_____ Min. 2 air changes per hour Table 7-1

Architectural Requirements**Building Systems Requirements**

- 2.2-2.2.8.10 ☐ Ice-making equipment
 ☐ located in each patient care unit
 ☐ equipment to provide ice for treatments & for nourishment
- 2.2-2.2.8.11 ☐ Clean workroom or clean supply room
 2.1-2.8.11.2 ☐ clean workroom
 ☐ used for preparing patient care items
 (1) ☐ work counter
 (2) ☐ handwashing station
 (3) ☐ storage facilities for clean & sterile supplies
- or**
- 2.1-2.8.11.3 ☐ clean supply room
 ☐ used only for storage & holding as part of system for distribution of clean & sterile supplies
- 2.2-2.2.8.12 ☐ Soiled workroom or soiled holding room
 2.1-2.8.12.2 ☐ soiled workroom
 (1)(a) ☐ handwashing station
 (1)(b) ☐ flushing-rim clinical service sink with bedpan-rinsing device or equivalent flushing-rim fixture
 (1)(c) ☐ work counter
 (1)(d) ☐ space for separate covered containers for waste & soiled linen
 (2) ☐ fluid waste management system is used
 ☐ check if not included in project
 (a) ☐ electrical & plumbing connections that meet manufacturer requirements
 (b) ☐ space for docking station
- or**
- 2.1-2.8.12.3 ☐ soiled holding room
 (1) ☐ handwashing station or hand sanitation station
 (2) ☐ space for separate covered containers for waste & soiled linen
- 2.1-2.8.13.1 ☐ Clean linen storage
 (1) ☐ stored in clean workroom or clean supply room
- or**
- ☐ separate closet
- or**
- ☐ covered cart distribution system on each floor

Ventilation:
☐ Min. 4 air changes per hour Table 7-1

☐ Positive pressure

Ventilation:
☐ Min. 4 air changes per hour Table 7-1
☐ Positive pressure

Ventilation:
☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

Ventilation:
☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

Architectural Requirements**Building Systems Requirements**

- (2) ☐ storage of clean linen carts in designated corridor alcoves, clean workroom or closets
- 2.1-2.8.13.2 ☐ Equipment & supply storage room or alcoves
☐ sized to provide min. 10 sf per patient bed
- 2.1-2.8.13.3 ☐ Storage space for gurneys, stretchers & wheelchairs
- 2.1-2.8.13.4 ☐ Emergency equipment storage
- (1) ☐ each patient care unit has at least one emergency equipment storage location
- (2) ☐ provided under visual observation of staff
- (3) ☐ storage locations in corridors do not encroach on minimum required corridor width
- 2.2-2.2.8.14 ☐ Environmental services room
- 2.1-2.8.14.1 ☐ readily accessible* to unit or floor it serves (permitted to serve more than one patient care unit on floor)
- 2.1-2.8.14.2 ☐ service sink or floor-mounted mop sink
- (1) ☐ provisions for storage of supplies & housekeeping equipment
- (2) ☐ handwashing station
- (3) ☐ **or**
☐ hand sanitation station
- 2.2-2.12.8.15 ☐ Examination room
- 2.2-2.2.8.15 ☐ ☐ check if not included in project
 (1) (only if all patient rooms in patient care unit are single-patient rooms)
☐ designed for single patient
- (2) ☐ serves only one patient care unit
or
☐ serves more than one patient care unit on same floor
☐ centrally located
- 2.1-2.1.2 Patient privacy:
☐ provisions are made to address patient visual & speech privacy
- 2.1-3.2.2.1 ☐ Space Requirements:
- (1) ☐ min. clear floor area 120 sf
☐ min. clear dimension 10'-0"
- (2)(a) ☐ room size permits room arrangement with min. clearance 3'-0" at each side & at foot of exam table, recliner or chair
- Ventilation:
☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units
- Ventilation:
☐ Min. 6 air changes per hour Table 7-1
- Lighting:
☐ Portable or fixed exam light 2.1-8.3.4.3(3)

Architectural Requirements**Building Systems Requirements**

- (2)(b) ☐ room arrangement (layout #1) shown in the plans
- ☐ exam table, recliner or chair is placed at angle closer to one wall than another or against wall to accommodate type of patient being served
- ☐ check if not included in project
- ☐ room arrangement (layout #2) shown in the plans

- Power:
- ☐ Min. 8 receptacles in total Table 2.1-1
- ☐ Min. 4 receptacles convenient to head of gurney or bed
- Nurse Call System:
- ☐ Staff assistance station Table 2.1-2
- ☐ Emergency call station

- 2.2-2.12.8.5 ☐ Multipurpose activity room
- ☐ multipurpose activity room for dining education & developmentally appropriate play & recreation
- ☐ provided in or adjacent* to areas serving pediatric & adolescent patients
- (1) ☐ provides access & accommodates equipment for patients with physical restrictions
- (2) ☐ insulation & structural provisions to minimize transmission of impact noise through floor, walls or ceiling of multipurpose room

- 2.2-2.12.8.9 ☐ Infant feeding facilities
- ☐ storage for human milk & formula be provided

- 2.2-2.12.8.13 ☐ Equipment & supply storage
- (1) ☐ storage closets or cabinets for toys & educational & recreational equipment
- (2) ☐ storage space provided in facility to permit exchange of cribs & adult beds
- (3) ☐ provisions for storage of equipment & supplies for parents who stay with patient overnight

2.2-2.12.9 **SUPPORT AREAS FOR STAFF**

- 2.1-2.9.1 ☐ Staff lounge
- ☐ min.100 sf
- 2.1-2.9.2 ☐ Staff toilet room (permitted to be unisex)
- 2.1-2.9.2.1 ☐ readily accessible* to each patient care unit
- 2.1-2.9.2.2 ☐ toilet & handwashing station
- 2.1-2.9.3 ☐ Staff storage facilities
- 2.1-2.9.3.1 ☐ securable closets or cabinet compartments for personal articles of staff
- ☐ located in or near nurse station

- Ventilation:
- ☐ Min. 10 air changes per hour Table 7-1
- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

Architectural Requirements**Building Systems Requirements****2.2-2.2.10 SUPPORT AREAS FOR PATIENTS FAMILIES & VISITORS**

- 2.2-2.2.10.1 ☐ Family & visitor lounge
☐ each patient care unit provides access to lounge for family & visitors
- 2.1-2.10.1.1(1) ☐ accommodates at minimum 3 chairs & 1 wheelchair space
 (2) ☐ accommodates at least 1 person for every 4 beds in unit
- 2.1-2.10.1.2 ☐ immediately accessible* to patient care units served (permitted to serve more than one patient care unit)
- 2.1-2.10.1.4 ☐ designed to minimize impact of noise & activity on patient rooms & staff functions
- 2.2-2.2.10.2 (1) ☐ Toilet room
☐ handwashing station
☐ readily accessible* to multipurpose room
- 2.2-2.2.10.4 ☐ Place for meditation & prayer
☐ dedicated space accessible to the public provided to support meditation, bereavement & prayer
- 2.2-2.12.10.2 ☐ Patient toilet rooms (in addition to toilet rooms serving bed areas)
☐ handwashing stations
☐ immediately accessible* to multipurpose room
☐ immediately accessible* to each central bathing facility

Communications:

- ☐ Public communication services provided in each family & visitor lounge

2.1-2.10.1.6

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

Architectural Requirements**Building Systems Requirements**

2.2-2.12

PEDIATRIC SUB-UNIT☐ check if not included in project

130.740(A)(2)

Location:

- ☐ discrete sub-unit is located within an adult care unit
- ☐ discrete sub-unit contains beds permanently designated as pediatric beds

130.740(A)(2)(a)

- ☐ such pediatric beds are located in a specific room, or contiguous specific rooms

130.740(A)(2)(d)

- ☐ pediatric sub-unit is situated in such a way that the flow of adult patients through it is discouraged

2.2-2.12.2

PATIENT ROOM

2.2-2.12.2.1

Capacity:

(1)

- ☐ maximum number of beds per room is one bed

(2)

or

- ☐ renovation work is undertaken
- ☐ present capacity is more than one patient in each room
- ☐ proposed room capacity is no more than present capacity
- ☐ maximum 2 patients in each room

2.2-2.12.2.2

Space Requirements:

(1)(a)

- ☐ single-patient rooms
- ☐ check if not included in project
- ☐ min. clear floor area 120 sf

2.2-2.2.2.2

(2)(a)

- ☐ min. clearance 3'-0" between sides of bed & any wall or any other fixed obstruction
- ☐ min. clearance 3'-0" between foot of bed & any wall or any other fixed obstruction

(1)(b)

- ☐ multiple-patient rooms
- ☐ check if not included in project
- ☐ min. clear floor area 100 sf per bed

(2)(a)

- ☐ min. clearance 3'-0" between sides of bed & any wall or any other fixed obstruction

Ventilation:

- ☐ Min. 4 air changes per hour Table 7-1
- Lighting: 2.1-8.3.4.3(1)

- ☐ General lighting
- ☐ Reading light for each patient bed (a)

- ☐ controls accessible to patients in bed

- ☐ Night-light located in each patient room (b)

- ☐ no central control of night-lights outside room

- ☐ night-light illuminates path from room entrance to bedside

- ☐ night-light illuminates path between bed & toilet room

Power:

- ☐ Min. 12 receptacles in total
- ☐ Min. 2 receptacles at each side of the head of the bed

Table 2.1-1

Architectural Requirements

- (2)(b) ☐ min. clearance 4'-0" at foot of each bed to permit passage of equipment & beds
- 2.2-2.12.2.3 Windows in Patient Rooms:
2.1-7.2.2.5(1) ☐ each patient room provided with natural light by means of window to outside
- 2.1-7.2.2.5(2) ☐ operable windows in patient rooms
☐ check if not included in project
☐ window operation is limited with either stop limit/restrictor hardware or open guard/screen
☐ prevents passage of 4-inch diameter sphere through opening
☐ insect screens
- 2.1-7.2.2.6
2.1-7.2.2.5(3) (a) ☐ min. net glazed area be no less than 8% of required min. clear floor area
- (b) ☐ max. 36" windowsill height above finished floor
- 2.1-2.1.2 Patient Privacy:
☐ Provisions are made to address patient visual & speech privacy
- 2.1-2.2.5 Handwashing Station in Patient Room:
2.1-2.2.5.1 ☐ provided in patient room in addition to that in toilet room
- (1) ☐ adjacent to entrance to patient room for use by health care personnel & others
- Multi-Patient Rooms:
☐ check if not included in project
- (2) ☐ handwashing station located outside patients cubicle curtains
- 2.1-2.2.6 ☐ Patient toilet room
2.1-2.2.6.2 ☐ in patient care units patient toilet room serve no more than one patient room
- 2.1-2.2.6.3 (1) ☐ toilet
 (2) ☐ handwashing station
 (3) ☐ bedpan washer
- 2.2-2.2.2.7 Patient Bathing Facilities:
2.1-2.2.7.1(1) ☐ located in toilet room
☐ directly accessible from each patient room
- or**
- 2.1-2.2.7.1(2) ☐ located in central bathing facility

Building Systems Requirements

- ☐ Min. 2 receptacles on all other walls (not including any TV receptacle)
- Nurse Call System:
☐ Patient station
☐ Staff assistance station
☐ Emergency call station
- Medical Gases:
☐ 1 OX, 1 VAC per bed
- Table 2.1-2
Table 2.1-3

- Ventilation:
☐ Min. 10 air changes per hour
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units
- Table 7-1

Architectural Requirements**Building Systems Requirements**

2.1-2.2.7.2

Central Bathing Facilities:

☐ check if not included in project

- (1) ☐ each bathtub or shower in individual room or enclosure that provides privacy for bathing drying & dressing
- (2) ☐ at least one shower or bathtub provided for each patient care unit
- ☐ at least one bathing facility with space for attendant to accommodate patients on gurneys, carts & wheelchairs (may be shared with multiple patient care units located on separate floors)
- (3)(a) ☐ toilet in or directly accessible to each central bathing facility
- ☐ in separate enclosure
- or**
- ☐ located in private bathing room
- ☐ handwashing sink in or directly accessible to each central bathing facility
- ☐ storage for soap & towels in or directly accessible to each central bathing facility

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

Nurse Call System:

- ☐ Bath station Table 2.1-2

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

Nurse Call System:

- ☐ Bath station Table 2.1-2

2.1-2.2.7.3

Mobile Lifts, Shower Gurney Devices & Wheelchair Access:

- (1) ☐ doorways designed to allow entry of portable/mobile mechanical lifts & shower gurney devices
- (2) ☐ thresholds designed to facilitate use & prevent tipping of wheelchairs & other portable wheeled equipment
- (3) ☐ patient shower rooms designed to allow entry of portable/mobile mechanical lifts & shower gurney devices
- (4) ☐ floor drain grates be designed to facilitate use & prevent tipping of wheelchairs & other portable wheeled equipment

2.2-2.2.2.8

Patient Storage:

2.1-2.2.8

- ☐ separate wardrobe, locker, or closet suitable for garments & for storing personal effects

Architectural Requirements**Building Systems Requirements**

2.2-2.12.3

FAMILY SUPPORT REQUIREMENTS

- 2.2-2.7.2.2(2)(a) ☐ Space at each bedside for families & visitors
☐ provided in addition to space provided for staff
☐ space provided for parental accommodations & for movable furniture does not encroach on minimum clearance requirements
- 2.2-2.7.2.2(2)(b) ☐ Space for recumbent sleep of parent/visitor
☐ communication system
☐ check if not included in project (only if sleeping area is adjoining patient area)

- 2.2-2.11.2.2 ☐ Space Requirements:
☐ enough space provided for parents to stay 24 hours

- 2.2-2.12.4.2 (1) ☐ Airborne infection isolation room
☐ at least one AII room be provided in pediatric sub-unit

- (2) 2.1-2.4.2.2 ☐ complies with requirements applicable to patient rooms

- (1) ☐ capacity one bed
 (2) ☐ personal protective equipment (PPE) storage at entrance to room
☐ provisions for PPE disposal at entrance to room

- (3) ☐ handwashing station

- (4) ☐ patient toilet room
☐ serves only one AII room

- (5) ☐ bathtub or shower

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ Negative pressure
☐ No recirculating room units

- 2.1-2.4.2.3 ☐ Anteroom
☐ check if not included in project

- (2)(a) ☐ provides space for persons to don personal protective equipment (PPE) before entering patient room

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
☐ Exhaust
☐ No recirculating room units

- ☐ provides space for persons to doff PPE after leaving patient room
 (2)(b) ☐ all doors to anteroom have self-closing devices

or

- ☐ audible alarm activated when AII room is in use as isolation room

- (3)(a) ☐ handwashing station

- (3)(b) ☐ storage for unused PPE

- (3)(c) ☐ disposal/holding container for used PPE

Architectural Requirements**Building Systems Requirements**

- 2.1-2.4.2.4
(1)(a) ☐ Architectural Details & Furnishings:
 ☐ perimeter walls ceiling & floor
 including penetrations constructed to
 prevent air exfiltration
- (1)(b) ☐ self-closing devices on all room exit
 doors
- or**
- ☐ activation of audible alarm when AII
 room is in use as isolation room
- ☐ edge seals provided along sides & top
 of doorframe for any door into AII room
- (2) (a) ☐ window treatments do not include
 fabric drapes & curtains
- 2.1-2.4.2.5 ☐ room pressure visual or audible alarm

130.740(A)(2)(b) **NURSE STATION OR SUB-STATION**

- ☐ Nurse station or sub-station
 ☐ serves pediatric patients
 ☐ adjacent* to the room(s) containing
 beds designated for pediatric patients
 ☐ observation of these rooms is possible
 from the nurse station or sub-station

Nurse Call System:

- ☐ Nurse master station

Table 2.1-2

- 2.1-2.8.2.1(1) ☐ space for counters
- 2.1-2.8.2.1(2) ☐ handwashing station next to or directly
 accessible*
- or**
- ☐ hand sanitation dispenser next to or
 directly accessible*

2.2-2.12.8.5 130.740(A)(3) **MULTIPURPOSE ACTIVITY ROOM**

- ☐ Pediatric sub-unit has an area or areas that
 are used primarily for recreation or play and
 equipped with items appropriate for the
 pediatric patients of the age using the areas

- 2.2-2.12.8.5 ☐ Multipurpose activity room
 ☐ multipurpose activity room for dining
 education & developmentally
 appropriate play & recreation
 ☐ provided in or adjacent* to areas
 serving pediatric & adolescent patients
- (1) ☐ provides access & accommodates
 equipment for patients with physical
 restrictions
- (2) ☐ insulation & structural provisions to
 minimize transmission of impact noise
 through floor, walls or ceiling of
 multipurpose room

2.2-2.12.8 **OTHER SUPPORT AREAS FOR PEDIATRIC
SUB-UNIT**

(may be shared with adjacent* med/surg adult unit)

- 2.1-2.8.2.2 ☐ Center for reception & communication

Architectural Requirements**Building Systems Requirements**

- | | | |
|----------------|--|---|
| | <input type="checkbox"/> self-contained
or
<input type="checkbox"/> combined with administrative center or nurse station | |
| 2.2-2.2.8.3 | <input type="checkbox"/> Documentation area | |
| 2.1-2.8.3.1 | <input type="checkbox"/> work surface to support documentation process | |
| 2.2-2.2.8.4 | <input type="checkbox"/> Nurse or supervisor office | |
| 2.2-2.2.8.5 | <input type="checkbox"/> Multipurpose room | |
| 2.1-2.8.5 | <input type="checkbox"/> at least one multipurpose room for each facility for patient conferences, reports, education, training sessions & consultation (may serve several patient care units & departments) | |
| 2.2-2.2.8.7 | <input type="checkbox"/> Handwashing station | |
| 2.1-2.8.7.1 | <input type="checkbox"/> located in each room where hands-on patient care is provided | |
| 2.2-2.2.8.8 | <input type="checkbox"/> Medication safety zones | |
| 2.1-2.8.8.1(2) | Design Promoting Safe Medication Use: | |
| (a) | <input type="checkbox"/> medication safety zones located out of circulation paths | |
| (b) | <input type="checkbox"/> work space designed so that staff can access information & perform required tasks | |
| (c) | <input type="checkbox"/> work counters provide space to perform required tasks | |
| (e) | <input type="checkbox"/> sharps containers placed at height that allows users to see top of container | |
| (f) | <input type="checkbox"/> max. 45 dBA noise level caused by building systems | |
| 2.1-2.8.8.2(1) | <input type="checkbox"/> medication preparation room | |
| (a) | <input type="checkbox"/> under visual control of nursing staff | |
| (b) | <input type="checkbox"/> work counter
<input type="checkbox"/> handwashing station
<input type="checkbox"/> lockable refrigerator
<input type="checkbox"/> locked storage for controlled drugs
<input type="checkbox"/> sharps containers
<input type="checkbox"/> <input type="checkbox"/> check if <u>not</u> included in project | Lighting:
<input type="checkbox"/> Task lighting
Ventilation:
<input type="checkbox"/> Min. 4 air changes per hour |
| (c) | <input type="checkbox"/> self-contained medication-dispensing unit
<input type="checkbox"/> <input type="checkbox"/> check if <u>not</u> included in project
<input type="checkbox"/> room designed with space to prepare medications | 2.1-2.8.8.1(2)(d)
Table 7-1 |
| | or | |

Architectural Requirements**Building Systems Requirements**

- 2.1-2.8.8.2(2) ☐ automated medication-dispensing unit
- (a) ☐ located at nurse station, in clean workroom or in alcove
- (c) ☐ handwashing station or hand sanitation dispenser located next to stationary medication-dispensing units or stations

2.2-2.2.8.9 ☐ Nourishment area or room

2.1-2.8.9.2

- (1) ☐ handwashing station
- (2) ☐ work counter
- (3) ☐ refrigerator
- (4) ☐ microwave
- (5) ☐ storage cabinets
- (6) ☐ space for temporary storage of food service implements
- 2.1-2.8.9.3 ☐ provisions & space for separate temporary storage of unused meal trays
- 2.1-2.8.9.4 ☐ provisions & space for soiled meal trays

2.2-2.2.8.10

- ☐ Ice-making equipment
- ☐ located in each patient care unit
- ☐ equipment to provide ice for treatments & for nourishment

2.2-2.2.8.11

2.1-2.8.11.2

- ☐ Clean workroom or clean supply room
- ☐ clean workroom
- ☐ used for preparing patient care items
- (1) ☐ work counter
- (2) ☐ handwashing station
- (3) ☐ storage facilities for clean & sterile supplies

or

2.1-2.8.11.3

- ☐ clean supply room
- ☐ used only for storage & holding as part of system for distribution of clean & sterile supplies

2.2-2.2.8.12

2.1-2.8.12.2

- (1)(a) ☐ soiled workroom
- (1)(b) ☐ handwashing station
- (1)(b) ☐ flushing-rim clinical service sink with bedpan-rinsing device or equivalent flushing-rim fixture
- (1)(c) ☐ work counter
- (1)(d) ☐ space for separate covered containers for waste & soiled linen
- (2) ☐ fluid waste management system is used
- ☐ check if not included in project

Ventilation:

☐ Min. 2 air changes per hour Table 7-1

Ventilation:

☐ Min. 4 air changes per hour Table 7-1

☐ Positive pressure

Ventilation:

☐ Min. 4 air changes per hour Table 7-1

☐ Positive pressure

Ventilation:

☐ Min. 10 air changes per hour Table 7-1

☐ Exhaust

☐ Negative pressure

☐ No recirculating room units

	Architectural Requirements	Building Systems Requirements
(a)	_____ electrical & plumbing connections that meet manufacturer requirements	
(b)	_____ space for docking station	
2.1-2.8.12.3	or _____ soiled holding room	Ventilation: _____ Min. 10 air changes per hour Table 7-1 _____ Exhaust _____ Negative pressure _____ No recirculating room units
(1)	_____ handwashing station or hand sanitation station	
(2)	_____ space for separate covered containers for waste & soiled linen	
2.1-2.8.13.1	_____ Clean linen storage	
(1)	_____ stored in clean workroom or clean supply room	
	or _____ separate closet	
	or _____ covered cart distribution system on each floor	
(2)	_____ storage of clean linen carts in designated corridor alcoves, clean workroom or closets	
2.1-2.8.13.2	_____ Equipment & supply storage room or alcoves _____ sized to provide min. 10 sf per patient bed	
2.1-2.8.13.3	_____ Storage space for gurneys, stretchers & wheelchairs	
2.1-2.8.13.4	_____ Emergency equipment storage	
(1)	_____ each patient care unit has at least one emergency equipment storage location	
(2)	_____ provided under visual observation of staff	
(3)	_____ storage locations in corridors do not encroach on minimum required corridor width	
2.2-2.2.8.14 2.1-2.8.14.1	_____ Environmental services room _____ readily accessible* to unit or floor it serves (permitted to serve more than one patient care unit on floor)	Ventilation: _____ Min. 10 air changes per hour Table 7-1 _____ Exhaust _____ Negative pressure _____ No recirculating room units
2.1-2.8.14.2	_____ service sink or floor-mounted mop sink	
(1)	_____ provisions for storage of supplies & housekeeping equipment	
(2)	_____ handwashing station	
(3)	or _____ hand sanitation station	

Architectural Requirements**Building Systems Requirements**

- 2.2-2.12.8.15
2.2-2.2.8.15
(1) ☐ Examination room
☐ check if not included in project
(only if all patient rooms in patient care unit are single-patient rooms)
- (2) ☐ designed for single patient
☐ serves only one patient care unit
or
☐ serves more than one patient care unit on same floor
☐ centrally located
- 2.1-2.1.2 Patient privacy:
☐ provisions are made to address patient visual & speech privacy
- 2.1-3.2.2.1
(1) Space Requirements:
☐ min. clear floor area 120 sf
☐ min. clear dimension 10'-0"
- (2)(a) ☐ room size permits room arrangement with min. clearance 3'-0" at each side & at foot of exam table, recliner or chair
☐ room arrangement (layout #1) shown in the plans
- (2)(b) ☐ exam table, recliner or chair is placed at angle closer to one wall than another or against wall to accommodate type of patient being served
☐ check if not included in project
☐ room arrangement (layout #2) shown in the plans
- 2.2-2.12.8.9 ☐ Infant feeding facilities
☐ storage for human milk & formula
- 2.2-2.12.8.13
(1) ☐ Equipment & supply storage
☐ storage closets or cabinets for toys & educational & recreational equipment
- (2) ☐ storage space provided in facility to permit exchange of cribs & adult beds
- (3) ☐ provisions for storage of equipment & supplies for parents who stay with patient overnight
- 2.2-2.12.9 **SUPPORT AREAS FOR STAFF**
(may be shared with adjacent* med/surg adult unit)
- 2.1-2.9.1 ☐ Staff lounge
☐ min.100 sf
- 2.1-2.9.2 ☐ Staff toilet room (permitted to be unisex)
- 2.1-2.9.2.1 ☐ readily accessible* to each patient care unit
- Ventilation:
☐ Min. 6 air changes per hour Table 7-1
- Lighting:
☐ Portable or fixed exam light 2.1-8.3.4.3(3)
- Power:
☐ Min. 8 receptacles in total Table 2.1-1
☐ Min. 4 receptacles convenient to head of gurney or bed
- Nurse Call System:
☐ Staff assistance station Table 2.1-2
☐ Emergency call station
- Ventilation:
☐ Min. 10 air changes per hour Table 7-1

Architectural Requirements**Building Systems Requirements**

- 2.1-2.9.2.2 ☐ toilet & handwashing station
- 2.1-2.9.3 ☐ Staff storage facilities
- 2.1-2.9.3.1 ☐ securable closets or cabinet
☐ compartments for personal articles of staff
☐ located in or near nurse station

- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

2.2-2.2.10 **SUPPORT AREAS FOR PATIENTS FAMILIES & VISITORS**

(may be shared with adjacent* med/surg adult unit)

- 2.2-2.2.10.1 ☐ Family & visitor lounge
☐ each patient care unit provides access to lounge for family & visitors
- 2.1-2.10.1.1(1) ☐ accommodates at minimum 3 chairs & 1 wheelchair space
- 2.1-2.10.1.1(2) ☐ accommodates at least 1 person for every 4 beds in unit
- 2.1-2.10.1.2 ☐ immediately accessible* to patient care units served (permitted to serve more than one patient care unit)
- 2.1-2.10.1.4 ☐ designed to minimize impact of noise & activity on patient rooms & staff functions

Communications:

- ☐ Public communication services provided in each family & visitor lounge 2.1-2.10.1.6

- 2.2-2.2.10.2 (1) ☐ Toilet room
☐ handwashing station
☐ readily accessible* to multipurpose room

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

- 2.2-2.2.10.4 ☐ Place for meditation & prayer
☐ dedicated space accessible to the public provided to support meditation, bereavement & prayer

- 2.2-2.12.10.2 ☐ Patient toilet rooms (in addition to toilet rooms serving bed areas)
☐ handwashing stations
☐ immediately accessible* to multipurpose room
☐ immediately accessible* to each central bathing

Ventilation:

- ☐ Min. 10 air changes per hour Table 7-1
- ☐ Exhaust
- ☐ Negative pressure
- ☐ No recirculating room units

***LOCATION TERMINOLOGY:**

Directly accessible: Connected to the identified area or room through a doorway, pass-through, or other opening without going through an intervening room or public space

Adjacent: Located next to but not necessarily connected to the identified area or room

Immediately accessible: Available either in or adjacent to the identified area or room

Readily accessible: Available on the same floor or in the same clinic as the identified area or room

Architectural Details & MEP Requirements

2.1-7.2.2	ARCHITECTURAL DETAILS	(4)	___ Lever hardware or push/pull latch hardware
2.1-7.2.2.1	CORRIDOR WIDTH:	(5)	Doors for Patient Bathing/Toilet Facilities:
NFPA 101, 18.2.3.3	___ Aisles, corridors & ramps required for exit access in a hospital not less than 8'-0" in clear & unobstructed width	(a)	___ two separate doors
	or		or
	___ Detailed code review incorporated in Project Narrative		___ door that swings outward
			or
	___ Aisles, corridors & ramps in adjunct areas not intended for the housing, treatment, or use of inpatients not less than 44" in clear & unobstructed width		___ door equipped with emergency rescue hardware (permits quick access from outside the room to prevent blockage of the door)
			or
			___ sliding door other than pocket door
2.1-7.2.2.2	CEILING HEIGHT:	(b)	___ bathing area or toilet room opens onto public area or corridor
(1)	___ Min. ceiling height 7'-6" in corridors & in normally unoccupied spaces		<input type="checkbox"/> check if <u>not</u> included in project
(2)	___ Min. ceiling height 9'-0" in seclusion rooms & secure holding rooms		___ visual privacy is maintained
(3)	___ Min height 7'-6" above floor of suspended tracks rails & pipes located in traffic path for patients in beds & on stretchers		
	___ Min ceiling height 7'-10" in other areas	2.1-7.2.2.5	WINDOWS IN PATIENT ROOMS:
2.1-7.2.2.3	DOORS & DOOR HARDWARE:	2.1-7.2.2.5(1)	___ Each patient room provided with natural light by means of window to outside
(1)	Door Type:	2.1-7.2.2.5(2)	___ Operable windows in patient rooms or suites
(a)	___ doors between corridors rooms or spaces subject to occupancy swing type or sliding doors		<input type="checkbox"/> check if <u>not</u> included in project
			___ window operation is limited with either stop limit/restrictor hardware or open guard/screen
(b)	___ sliding doors		___ prevents passage of 4-inch diameter sphere through opening
	<input type="checkbox"/> check if <u>not</u> included in project	2.1-7.2.2.6	___ insect screens
	___ manual or automatic sliding doors comply with NFPA 101	2.1-7.2.2.5(3)	Window Size In Patient Rooms:
	___ detailed code review incorporated in Project Narrative	(a)	___ minimum net glazed area be no less than 8% of required min.
	___ no floor tracks		clear floor area of room served
(2)	Door Opening to Patient Rooms:	(b)	___ maximum 36 inches windowsill height above finished floor
(a)	___ min 45.5" clear door width		
	___ min 83.5" clear door height	2.1-7.2.2.7	GLAZING MATERIALS:
(b)	___ swinging doors for personnel use in addition to sliding doors		___ Glazing within 1 foot 6 inches of floor
	<input type="checkbox"/> check if <u>not</u> included in project		<input type="checkbox"/> check if <u>not</u> included in project
	___ min clear width 34.5"		___ must be safety glass wire glass or plastic break-resistant material
(3)	Door Swing:	2.1-7.2.2.8	HANDWASHING STATIONS:
(a)	___ doors do not swing into corridors except doors in behavioral health units & doors to non-occupiable spaces (e.g. environmental services rooms & electrical closets) & doors with emergency breakaway hardware	(1)(c)	___ Handwashing stations in patient care areas located so they are visible & unobstructed

(3)(a)	___ Handwashing station countertops made of porcelain stainless steel solid-surface materials or impervious plastic laminate assembly	(2)	___ Noise reduction criteria in Table 1.2-6 applicable to partitions floors & ceiling construction are met in patient areas
(3)(b)	___ Countertops substrate ___ <input type="checkbox"/> check if <u>not</u> included in project ___ marine-grade plywood (or equivalent <u>material</u>) with impervious seal	2.1-7.2.2.14	DECORATIVE WATER FEATURES:
(4)	___ Handwashing station casework ___ <input type="checkbox"/> check if <u>not</u> included in project ___ designed to prevent storage beneath sink	(1)	___ No indoor unsealed water features
(5)	___ Provisions for drying hands	(2)	___ Covered fish tanks ___ <input type="checkbox"/> check if <u>not</u> included in project ___ restricted to public areas
(a)	___ hand-drying device does not require hands to contact dispenser	2.1-7.2.3	SURFACES
(b)	___ hand-drying device is enclosed to protect against dust or soil & to ensure single-unit dispensing	2.1-7.2.3.1	FLOORING & WALL BASES:
(6)	___ liquid or foam soap dispensers	(1)	___ Flooring surfaces cleanable & wear-resistant for location
2.1-7.2.2.9	GRAB BARS:	(3)	___ Smooth transitions provided between different flooring materials
(1)	___ Grab bars anchored to sustain concentrated load 250 pounds	(4)	___ Flooring surfaces including those on stairways are stable firm & slip-resistant
(2)	___ Grab bars in toilet rooms used by patients of size anchored to sustain concentrated load 800 pounds	(5)	___ Floors & wall bases of soiled workrooms, toilet rooms & other areas subject to frequent wet cleaning are constructed of materials that are not physically affected by cleaning solutions
(3)	___ Ends of grab bars constructed to prevent snagging clothes of patients staff & visitors	(7)(a)	Floors are monolithic & integral coved wall bases are at least 6" high & tightly sealed to wall in rooms listed below: ___ airborne infection isolation (All) room ___ protective environment (PE) room ___ <input type="checkbox"/> check if <u>not</u> included in project ___ combination All/PE room ___ <input type="checkbox"/> check if <u>not</u> included in project ___ anteroom to All & PE rooms ___ <input type="checkbox"/> check if <u>not</u> included in project ___ soiled workroom & soiled holding room
2.1-7.2.2.10	HANDRAILS:		
(1)(a)	___ Installed on both sides of patient use corridors	2.1-7.2.3.2	WALLS & WALL PROTECTION:
(1)(b)	(may be omitted at nurse stations, doors, alcoves & fire extinguisher cabinets)	(1)(a)	___ Wall finishes are washable
(2)	___ Rail ends return to wall or floor	(1)(b)	___ Wall finishes near plumbing fixtures are smooth, scrubable & water-resistant
(3)	___ Handrail gripping surfaces & fasteners are smooth (free of sharp or abrasive elements)	(2)	___ Wall surfaces in areas routinely subjected to wet spray or splatter (e.g environmental services rooms) are monolithic or have sealed seams that are tight & smooth
(4)	___ Handrails have eased edges & corners	(5)	___ Wall protection devices & corner guards durable & scrubable
(5)	___ Handrails have surface light reflectance value that contrasts with that of wall surface by min. 30%		
(6)	___ Handrail finishes are cleanable & able to withstand disinfection	2.1-7.2.3.3	CEILINGS:
2.1-7.2.2.12	NOISE CONTROL:	(1)	___ Ceilings provided in all areas except mechanical, electrical & communications equipment rooms
(1)	___ Recreation rooms exercise rooms equipment rooms & similar spaces where impact noises may be generated are not located directly over patient bed areas	(a)	___ Ceilings cleanable with routine housekeeping equipment
	or	(b)	___ Acoustic & lay-in ceilings where used do not create ledges or crevices
	___ Special provisions are made to minimize impact noise		

2.1-7.2.4.1	<p>Built-In Furnishings:</p> <p><input type="checkbox"/> check if <u>not</u> included in project</p> <p>___ upholstered with impervious materials in patient treatment areas</p>	Part 3/6.2	AIR-HANDLING UNIT (AHU) DESIGN:
		Part 3/6.2.1	___ AHU casing is designed to prevent water intrusion resist corrosion & permit access
2.1-7.2.4.2	Window Treatments in Patient Rooms & Other Patient Care Areas:	Part 3/6.3	OUTDOOR AIR INTAKES & EXHAUST DISCHARGES:
(1)	___ blinds sheers or other patient-controlled window treatments provided to allow for patient privacy & to control light levels & glare	Part 3/6.3.1	Outdoor Air Intakes:
(2)	___ window treatments do not compromise patient safety	Part 3/6.3.1.1	___ located such that shortest distance from intake to any specific potential outdoor contaminant source be equal to or greater than separation distance listed in Table 6-1
(3)	___ window treatments selected for ease of cleaning disinfection or sanitization		___ located min of 25 ft from cooling towers & all exhaust & vent discharges
2.1-7.2.4.3	___ Privacy curtains in patient rooms & other patient care areas are washable		___ air intakes located away from public access
	<input type="checkbox"/> check if <u>not</u> included in project		___ all intakes designed to prevent entrainment of wind-driven rain
2.1-8.2	HEATING VENTILATION & AIR-CONDITIONING (HVAC) SYSTEMS UTILITIES:	Part 3/6.3.1.4	___ contain features for draining away precipitation
Part 3/6.1	Ventilation Upon Loss of Electrical Power:		___ equipped with birdscreen of mesh no smaller than 0.5 inches
Part 3/6.1.1	___ space ventilation & pressure relationship requirements of Tables 7.1 are maintained for All Rooms & PE Rooms in event of loss of normal electrical power		___ intake in areaway
			<input type="checkbox"/> check if <u>not</u> included in project
Part 3/6.1.2	Heating & Cooling Sources:	Part 3/6.3.2	___ bottom of areaway air intake opening is at least 6'-0" above grade
Part 3/6.1.2.1	___ heat sources & essential accessories are provided in number & arrangement sufficient to accommodate facility needs (reserve capacity) even when any one of heat sources is not operating	Part 3/6.3.2.1	___ bottom of air intake opening from areaway into building is at least 3'-0" above bottom of areaway
	___ capacity of remaining source or sources is sufficient to provide for domestic hot water & to provide heating for intensive care nursery & inpatient rooms		Exhaust Discharges:
Part 3/6.1.2.2	Central cooling systems greater than 400 tons (1407 kW) peak cooling load		___ ductwork within building is under negative pressure for exhaust of contaminated air (i.e air from All rooms)
	<input type="checkbox"/> check if <u>not</u> included in project		___ exhaust discharge outlets with contaminated air located such that they reduce potential for recirculation of exhausted air back into building
	___ number & arrangement of cooling sources & essential accessories is sufficient to support owner's facility operation plan upon breakdown or routine maintenance of any one of cooling sources	Part 3/6.3.2.2	___ exhaust discharge outlets with contaminated air is arranged to discharge to atmosphere in vertical direction at least 10'-0" above adjoining roof level
			___ exhaust discharge outlets from All rooms is located not less than 25'-0" horizontally from outdoor air intakes, openable windows/doors & areas that are normally accessible to public

Part 3/6.4	FILTRATION:	Part 3/7	SPACE VENTILATION - HOSPITAL SPACES:
a.	<input type="checkbox"/> Particulate matter filters, min. MERV-8 provided upstream of first heat exchanger surface of any air-conditioning system that combines return air from multiple rooms or introduces outdoor air	Part 3/7.1.a	<input type="checkbox"/> Spaces ventilated according to Table 7-1
b.	<input type="checkbox"/> Outdoor air filtered in accordance with Table 7-1	Part 3/7.1.a.1	<input type="checkbox"/> Air movement is from clean to less-clean areas
c.	<input type="checkbox"/> Air supplied from equipment serving multiple or different spaces is filtered in accordance with Table 7-1	Part 3/7.1.a.3	<input type="checkbox"/> Min number of total air changes required for positive pressure rooms is provided by total supply airflow
d.	<input type="checkbox"/> Air recirculated within room is filtered in accordance with Table 7-1 or Section 7.1(a)(5)		<input type="checkbox"/> Min number of total air changes required for negative pressure rooms is provided by total exhaust airflow
h.	<input type="checkbox"/> For spaces that do not permit air recirculated by means of room units & have minimum filter efficiency of MERV-14, MERV-16 or HEPA in accordance with Table 7-1, the min. filter requirement listed in Table 7-1 is installed downstream of all wet-air cooling coils & supply fan	Part 3/7.1a.5	<input type="checkbox"/> Air recirculation through room unit <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> complies with Table 7-1 <input type="checkbox"/> room unit receive filtered & conditioned outdoor air <input type="checkbox"/> serve only single space <input type="checkbox"/> provides min MERV 8 filter located upstream of any cold surface so that all of air passing over cold surface is filtered
Part 3/6.5	HEATING & COOLING SYSTEMS:	Part 3/7.2	ADDITIONAL ROOM-SPECIFIC REQUIREMENTS:
Part 3/6.5.3	<input type="checkbox"/> Radiant heating systems <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> ceiling or wall panels with exposed cleanable surfaces or radiant floor heating are provided in All room PE room & burn unit	Part 3/7.2.1	Airborne Infection Isolation (All) Rooms <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> All rooms have permanently installed device and/or mechanism to constantly monitor differential air pressure between room & corridor <input type="checkbox"/> Local visual means is provided to indicate whenever negative differential pressure is not maintained <input type="checkbox"/> Air from All room is exhausted directly to outdoors
Part 3/6.7	AIR DISTRIBUTION SYSTEMS:		Exhaust air from All rooms, associated anterooms & toilet rooms:
Part 3/6.7.1	<input type="checkbox"/> pressure relationships required in tables 7.1 maintained in all modes of HVAC system operation <input type="checkbox"/> Spaces that have required pressure relationships are served by fully ducted return systems or fully ducted exhaust systems <input type="checkbox"/> Inpatient facilities are served by fully ducted return or exhaust systems		<input type="checkbox"/> is discharged directly to outdoors without mixing with exhaust air from any other non-All room or exhaust system
Part 3/6.7.2	Air Distribution Devices: <input type="checkbox"/> supply air outlets comply with Table 6-2		or
Part 3/6.7.3	Smoke Barriers: <input type="checkbox"/> HVAC zones coordinated with compartmentation to minimize ductwork penetrations of fire & smoke barriers.		<input type="checkbox"/> is discharged into the general exhaust stream, provided the All exhaust air first passes through a HEPA filter (all exhaust ductwork kept under negative pressure)
Part 3/6.8	ENERGY RECOVERY SYSTEMS:	Part 3/7.2.1	<input type="checkbox"/> Exhaust air grille or register in patient room is located directly above patient bed on ceiling or on wall near head of bed
	<input type="checkbox"/> check if <u>not</u> included in project		
Part 3/6.8.1	<input type="checkbox"/> Located upstream of filters required by Part 3/6.8.4		
Part 3/6.8.2	<input type="checkbox"/> All room exhaust systems or combination All/PE rooms are not used for energy recovery		

	Anteroom <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> All room is at negative pressure with respect to anteroom <input type="checkbox"/> Anteroom is at negative pressure with respect to corridor	2.1-8.3.3 2.1-8.3.3.1 (1) (2)	POWER-GENERATING & -STORING EQUIPMENT <input type="checkbox"/> Essential electrical system or emergency electrical power <input type="checkbox"/> essential electrical system complies with NFPA 99 <input type="checkbox"/> emergency electrical power complies with NFPA 99
Part 3/7.2.2	Protective Environment (PE) Rooms <input type="checkbox"/> check if <u>not</u> included in project	2.1-8.3.4	LIGHTING:
Part 3/7.2.2	<input type="checkbox"/> Supply air diffusers are located above patient bed <input type="checkbox"/> Exhaust grilles or registers are located near patient room door <input type="checkbox"/> PE rooms have permanently installed device to constantly monitor differential air pressure between room & corridor <input type="checkbox"/> Visual means is provided to indicate whenever positive differential pressure is not maintained	2.1-8.3.4.1 (1) (2)	<input type="checkbox"/> Luminaires in patient areas shall have smooth, cleanable, impact-resistant lenses concealing light source <input type="checkbox"/> Luminaires dissipate heat such that touchable surfaces will not burn occupants or ignite materials.
Part 3/7.2.3	Combination Airborne Infectious Isolation/Protective Environment Room (AII/PE) <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> Supply air diffusers are located above patient bed <input type="checkbox"/> Exhaust grilles or registers are located near patient room door. <input type="checkbox"/> Anteroom <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> anteroom is at positive pressure with respect to both AII/PE room & corridor or common space or <input type="checkbox"/> anteroom is at negative pressure with respect to both AII/PE room & corridor or common space <input type="checkbox"/> First device monitors pressure differential between AII/PE room & anteroom <input type="checkbox"/> Second device monitors pressure differential between anteroom & corridor or common space <input type="checkbox"/> Local visual means are provided to indicate whenever differential pressures are not maintained	2.1-8.3.4.2 (1) (a) (b) (c) (d) (e) (f)	Patient rooms: <input type="checkbox"/> provide general level of illumination <input type="checkbox"/> provide exam level of illumination (may be dimmable & limited to patient care station) <input type="checkbox"/> illumination for reading provided for each patient bed <input type="checkbox"/> patients must be able to adjust illumination without having to get out of bed <input type="checkbox"/> no incandescent & halogen light sources <input type="checkbox"/> light sources are either encapsulated or covered by diffuser or lens or use fixtures designed to contain fragments Night-lighting: <input type="checkbox"/> at least one night-light fixture located in each patient room <input type="checkbox"/> night-lights used by staff that illuminate path from entry to bedside are switched at room entrance <input type="checkbox"/> night-light fixture located no more than 18 inches from finished floor illuminates pathway from bed to toilet room <input type="checkbox"/> night-light color temperature 2,700K or warmer
2.1-8.3 2.1-8.3.2.2 (1)	ELECTRICAL SYSTEMS Panelboards: <input type="checkbox"/> panelboards serving life safety branch circuits serve floors on which they are located & floors immediately above & below	(2)(a)	<input type="checkbox"/> Corridors in patient care units have general illumination with provisions for reducing light levels at night
(2)	<input type="checkbox"/> panelboard critical branch circuits serve floors on which they are located	(3)	Exam/treatment rooms:
(3)	<input type="checkbox"/> panelboards not located in exit enclosures or exit passageways		<input type="checkbox"/> portable or fixed exam light

(6)	Food & nutrition areas: ___ light sources in kitchen & serving areas are either encapsulated or covered by diffuser or lens or use fixtures designed to contain fragments	(1)(a)	___ drainage system independent from tap water drainage
(7)	___ Uplight fixtures installed in patient care areas are covered	(4)	___ liquid waste & disposal system for hemodialysis treatment area are designed to minimize odor & prevent backflow
2.1-8.3.5	ELECTRICAL EQUIPMENT:	(5)	___ hemodialysis distribution piping is readily accessible* for inspection & maintenance
2.1-8.3.5.1	___ Handwashing sinks that depend on building electrical service for operation are connected to essential electrical system	2.1-8.4.2.5	Heated potable water distribution systems: ___ heated potable water distribution systems serving patient care areas are under constant recirculation to provide continuous hot water at each hot water outlet
2.1-8.3.6	ELECTRICAL RECEPTACLES:	(2)	___ non-recirculated fixture branch piping does not exceed 10 feet in length
2.1-8.3.6.1	Receptacles In Corridors:	(3)(a)	___ no installation of dead-end piping (installation of empty risers mains & branches for future use is permitted)
(1)	___ duplex-grounded receptacles for general use installed 50'-0" apart or less in all corridors	(3)(c)	Renovations: <input type="checkbox"/> check if <u>not</u> included in project
	___ duplex-grounded receptacles for general use installed within 25'-0" of corridor ends	(3)(b)	___ dead-end piping is removed
(2)	___ receptacles in pediatric & psychiatric unit corridors are of tamper-resistant type		
2.1-8.3.6.3	Essential Electrical System Receptacles:	2.1-8.4.2.6	Drainage Systems:
(1)	___ cover plates for electrical receptacles supplied from essential electrical system are distinctively colored or marked for identification	(1)(a)	___ drainage piping above ceiling of or exposed in rooms listed below piping have special provisions to protect space below from leakage & condensation
(2)	___ same color is used throughout facility		<ul style="list-style-type: none"> • operating rooms • delivery rooms • procedure rooms • trauma rooms • nurseries • central kitchens • one-room sterile processing facilities • clean workroom of two-room sterile processing facilities • pharmacies • Class 2 & 3 imaging rooms • electronic mainframe rooms (EFs & TERs) • main switchgear • electrical rooms • electronic data processing areas • electric closets
2.1-8.4	PLUMBING SYSTEMS		
2.1-8.4.2	Plumbing & Other Piping Systems:		
2.1-8.4.2.1(3)	___ no plumbing piping exposed overhead or on walls where possible accumulation of dust or soil may create cleaning problem		
2.1-8.4.2.2	Hemodialysis/Hemoperfusion Water Distribution:		
	<input type="checkbox"/> check if <u>not</u> included in project		
(1)(a)	___ separate treated water distribution system		
(2)(b)	___ outlet at each individual hemodialysis treatment bay		
	___ outlet at hemodialysis equipment repair area		
	___ outlet at dialysate preparation area		
	or		
(1)(b)	___ dialysis equipment includes sufficient water treatment provisions for use of domestic cold water		

(1)(b)	<input type="checkbox"/> drip pan for drainage piping above ceiling of sensitive area <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> accessible <input type="checkbox"/> overflow drain with outlet located in normally occupied area that is not open to restricted area	2.1-8.4.3.4	Ice-Making Equipment: <input type="checkbox"/> copper tubing provided for supply connections to ice-making equipment
2.1-8.4.3	PLUMBING FIXTURES:	2.1-8.4.3.5	Clinical Sinks: <input type="checkbox"/> check if <u>not</u> included in project
2.1-8.4.3.1(1)	<input type="checkbox"/> Materials used for plumbing fixtures are non-absorptive & acid-resistant	(1)	<input type="checkbox"/> trimmed with valves that can be operated without hands (may be single-lever or wrist blade devices)
2.1-8.4.3.2	Handwashing Station Sinks:	(a)	<input type="checkbox"/> handles are at least 6 in long
(1)	<input type="checkbox"/> designed with basins & faucets that reduce risk of splashing to areas where direct patient care is provided, sterile procedures are performed or food is prepared	(2)	<input type="checkbox"/> integral trap wherein upper portion of water trap provides visible seal
(2)	<input type="checkbox"/> sink basins have nominal size of no less than 144 square inches <input type="checkbox"/> sink basins have min dimension 9 inches in width or length	2.1-8.4.3.7	Human waste disposal systems:
(3)	<input type="checkbox"/> sink basins are made of porcelain stainless steel or solid-surface materials	(1)	<input type="checkbox"/> bedpan-rinsing device
(5)	<input type="checkbox"/> water discharge point of faucets is min. 10" above bottom of basin	(a)	<input type="checkbox"/> provided in each inpatient toilet room <input type="checkbox"/> use cold water only
(7)	<input type="checkbox"/> anchored so that allowable stresses are not exceeded where vertical or horizontal force of 250 lbs. is applied	(b)	or
(8)	<input type="checkbox"/> sinks used by staff, patients & public have fittings that can be operated without using hands (e.g. single-lever or wrist blade devices)	(2)	<input type="checkbox"/> bedpan washer-disinfector system
(a)	<input type="checkbox"/> blade handles <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> at least 4 inches in length <input type="checkbox"/> provide clearance required for operation	(a)	<input type="checkbox"/> located in patient toilet room or soiled workroom
(b)	<input type="checkbox"/> sensor-regulated water fixtures <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> meet user need for temperature & length of time water flows <input type="checkbox"/> designed to function at all times & during loss of normal power	(b)	<input type="checkbox"/> electrical & plumbing connections that meet manufacturer requirements are provided
2.1-8.4.3.3	Showers & Tubs:	(3)	or
(1)	<input type="checkbox"/> nonslip surfaces	(a)	<input type="checkbox"/> disposable bedpan macerator system
(2)	<input type="checkbox"/> Surfaces for personal effects (e.g., shampoo, soap): <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> surfaces for personal effects are recessed	(b)	<input type="checkbox"/> installed in soiled workroom <input type="checkbox"/> electrical & plumbing connections per manufacturer requirements are provided
		2.1-8.4.4	MEDICAL GAS & VACUUM SYSTEMS
			<input type="checkbox"/> Station outlets provided as indicated in Table 2.1-3
		2.1-8.5.1	CALL SYSTEMS
		2.1-8.5.1.1(1)	<input type="checkbox"/> Nurse call stations provided as required in Table 2.1-2
		2.1-8.5.1.1(2)	<input type="checkbox"/> Nurse call systems report to attended location with electronically supervised visual & audible annunciation as indicated in Table 2.1-2
		2.1-8.5.1.1(4)	<input type="checkbox"/> Call system complies with UL 1069 "Standard for Hospital Signaling & Nurse Call Equipment"
		2.1-8.5.1.1(5)	<input type="checkbox"/> Wireless nurse call system <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> complies with UL 1069

2.1-8.5.1.2 (1)	<input type="checkbox"/> Patient Call Stations: each patient sleeping bed except nursery beds provided with patient call station equipped for two-way voice communication	(2)	<input type="checkbox"/> shower/tub bath stations locat- ed 3'-0" to 4'-0" above floor within view of user & within reach of staff without need to step into shower or tub
(2)(a)	<input type="checkbox"/> indicator light that remains lighted as long as voice circuit is operating	(3)	<input type="checkbox"/> toilet bath stations located on the side of toilets within 12" of front of toilet bowl & 3'-0" to 4'-0" above floor
(2)(b)	<input type="checkbox"/> reset switch for canceling call		
(3)(a)	<input type="checkbox"/> visible signal in corridor at patient's door Multi-Corridor Patient Areas: <input type="checkbox"/> check if <u>not</u> included in project <input type="checkbox"/> additional visible signals at corridor intersections	2.1-8.5.1.5	<input type="checkbox"/> Emergency call stations are equipped with continuous audible or visual confirmation to person who initiated the code call
		2.1-8.6.2	ELECTRONIC SURVEILLANCE SYSTEMS <input type="checkbox"/> check if <u>not</u> included in project
(3)(b)	<input type="checkbox"/> visible & audible signal at the nurse master station of patient care units or patient care areas	2.1-8.6.2.1	<input type="checkbox"/> Display screens in patient areas are mounted in tamper-resistant enclosure that is unobtrusive
2.1-8.5.1.2(4)	<input type="checkbox"/> Nurse call system provided in each patient care area as required in Table 2.1-2	2.1-8.6.2.2	<input type="checkbox"/> Display screens are located so they are not readily observable by general public or patients
2.1-8.5.1.3	Bath Stations: <input type="checkbox"/> bath station that can be acti- vated by patient lying on floor provided at each patient toilet bathtub sitz bath or shower stall	2.1-8.6.2.3	<input type="checkbox"/> Electronic surveillance systems receive power from essential electrical system
(1)	<input type="checkbox"/> alarm in these areas can only be turned off at bath station where it was initiated		