
From: Carley, Stephen (DPS)
Sent: Tuesday, June 14, 2016 8:43 AM
To:
Cc: Zemel, Felix (DPS)
Subject: FW: 9th edition mechanical ventilation

Good morning. Below please find a comment on the ninth edition of the building code. This is another that pertains to a portion of the ninth edition not concerning the energy provisions and therefore not under consideration at today's public hearing. Thank you.

From: Zemel, Felix (DPS)
Sent: Monday, June 13, 2016 10:17 PM
To: Carley, Stephen (DPS)
Cc: Zemel, Felix (DPS)
Subject: FW: 9th edition mechanical ventilation

FYI

Felix J. Zemel
Department of Public Safety
Technical Director / Acting Chief of Inspections -- Building

From: Mark Barbadoro [mailto:mark.barbadoro@state.ma.gov]
Sent: Monday, May 02, 2016 8:08 AM
To: Zemel, Felix (DPS)
Subject: 9th edition mechanical ventilation

hi Felix,

I was looking over the ventilation requirements of the MA amendment N1103.6 Mechanical Ventilation. the model code directs us to M1507 but the amendment replaces this with a formula for ventilation. the problem is that there is no amendment for section M1507 so there will be two different mechanical ventilation requirements in the 9th edition.

I recommend that you add an amendment that says the following:

M1507.3.3

Replace the first paragraph of section M1507.3.3 as follows:

"1507.3.3 the whole house mechanical ventilation system shall provide outdoor air at a continuous rate of not less than that determined in accordance with section N1103.6"

I think that will close the loop.

let me know if I'm off track.

thanks

Mark Barbadoro
Building Inspector for Oak Bluffs and Aquinnah