



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
5 Randolph Street, Canton, MA 02021
Phone: 781-828-7700 Fax: 781-828-7703

CHARLES D. BAKER
Governor

KARYN E. POLITO
Lieutenant Governor

MARYLOU SUDDERS
Secretary

MONICA BHAREL, MD, MPH
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

January 19, 2016

Allison Hallett, Superintendent
Massachusetts Alcohol and Substance Abuse Center
2 Administration Road
Bridgewater, MA 02324

Re: Facility Inspection – Massachusetts Alcohol and Substance Abuse Center, Bridgewater

Dear Superintendent Hallett:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Massachusetts Alcohol and Substance Abuse Center on January 8, 2016 accompanied by Sergeant Robert Hierholcer, Tool Control. Violations noted during the inspection are listed below including 19 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

Control Center

Lobby

No Violations Noted

Bathroom

No Violations Noted

Slop Sink

No Violations Noted

Kitchenette

FC 4-903.11(A)(2)*

Protection of Clean Items, Storing: Single-service items not protected from contamination, utensils left uncovered

Administration Building # 5

Lobby

No Violations Noted

Female Bathroom # 102

No Violations Noted

Male Bathroom # 143

No Violations Noted

Male Officer's Locker Room # 114

No Violations Noted

Female Officer's Locker Room # 115

No Violations Noted

Roll Call Room # 117

No Violations Noted

Slop Sink # 121

No Violations Noted

Classrooms

No Violations Noted

Room # 128

No Violations Noted

Room # 108

No Violations Noted

Food Service Area # 6

Kitchen

FC 6-501.111(B)

Maintenance and Operations; Pest Control: Cockroaches observed around dishwasher

Food Storage # 150

FC 6-501.11

Maintenance and Operation; Repairing: Facility not in good repair, exterior door paint damaged

FC 4-601.11(C)

Cleaning of Equipment and Utensils, Objective: Non-food contact surface dirty, cooler gaskets dirty

FC 3-305.11(A)(3)

Preventing Contamination from Premises: Food stored in an inappropriate location, food stored less than 6 inches from the floor, apples and oranges stored on floor in cooler

Dining Area

No Violations Noted

Administrative Assistant Office

No Violations Noted

Intake # 6

Toxic/Caustic Cabinet

No Violations Noted

Inmate Bathroom # 151

105 CMR 451.123 Maintenance: Light shield not secure

Slop Sink Room # 152

105 CMR 451.353 Interior Maintenance: Debris in light shield

Urinalysis Room # 153

No Violations Noted

Staff Bathroom # 154

105 CMR 451.123 Maintenance: Wall vent dusty

Biohazard Storage Room # 155

FC 6-501.12(A) Maintenance and Operation; Cleaning: Facility not cleaned properly, ice build-up in freezer

Laundry Cage

105 CMR 451.353 Interior Maintenance: Return vent dusty

Medication Room # 161

No Violations Noted

X-Ray Room # 165

No Violations Noted

Dentist Office # 162 and 164

No Violations Noted

Shower Room # 167

105 CMR 451.123* Maintenance: Ceiling vent dusty in shower

Shake Room # 168

105 CMR 451.353* Interior Maintenance: Ceiling vent dusty

Room # 169

No Violations Noted

Property Room # 170

FC 4-501.11(B)* Maintenance and Operation, Equipment: Equipment components not maintained in a state of good repair, refrigerator gaskets damaged

Property Room # 171

No Violations Noted

Doctor's Office # 172

No Violations Noted

A Barracks

A1 Barracks

105 CMR 451.322* Cell Size: Inadequate floor space in dorm room

Officer's Station # 186

No Violations Noted

Officer's Bathroom # 185

105 CMR 451.123 Maintenance: Ceiling vent dusty

Counselor's Office # 188

No Violations Noted

Sleeping Area

No Violations Noted

Laundry

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)* Privacy: No privacy partition between showers
105 CMR 451.123 Maintenance: Toilets dirty
105 CMR 451.123 Maintenance: Wall damaged in shower area
105 CMR 451.123 Maintenance: Caulking dirty, possible mold or mildew, in shower area
105 CMR 451.123 Maintenance: Light out in shower area

A2 Barracks

105 CMR 451.322* Cell Size: Inadequate floor space in dorm room

Janitor's Closet

No Violations Noted

Sleeping Area

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)* Privacy: No privacy partition between showers
105 CMR 451.123 Maintenance: One urinal not working
105 CMR 451.123 Maintenance: Showerhead leaking

B Barracks

B1 Barracks

105 CMR 451.322* Cell Size: Inadequate floor space in dorm room

Officer's Station # 201

No Violations Noted

Officer's Bathroom # 201A

No Violations Noted

Toxic and Caustic Storage Room # 203

No Violations Noted

Sleeping Area

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)* Privacy: No privacy partition between showers
105 CMR 451.123 Maintenance: Caulking dirty, possible mold or mildew in shower area
105 CMR 451.123 Maintenance: Floor damaged near toilet # 1

B2 Barracks

105 CMR 451.322* Cell Size: Inadequate floor space in dorm room

Sleeping Area

No Violations Noted

Slop Sink Room # 200

105 CMR 451.353 Interior Maintenance: Wall damaged
105 CMR 451.353 Interior Maintenance: Wall dirty, possible mold or mildew

Inmate Bathroom

105 CMR 451.121(A)* Privacy: No privacy partition between showers

C Barracks**C Recreational Area**

No Violations Noted

Officer's Station # 218

No Violations Noted

Officer's Bathroom # 218A

No Violations Noted

Recreational Office # 216

No Violations Noted

Workout Area

105 CMR 451.353 Interior Maintenance: Workout equipment padding damaged

Laundry

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)* Privacy: No privacy partition between showers

C1 Barracks

105 CMR 451.322* Cell Size: Inadequate floor space in dorm room

Janitor's Closet Room # 215

No Violations Noted

Sleeping Area

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)* Privacy: No privacy partition between showers
105 CMR 451.123 Maintenance: Wall epoxy damaged in shower area
105 CMR 451.123 Maintenance: Soap scum on shower curtain

D1 Barracks

105 CMR 451.322* Cell Size: Inadequate floor space in dorm room

Officer's Station

No Violations Noted

Storage Closet

No Violations Noted

Sleeping Area

No Violations Noted

Medical Cells

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)*

Privacy: No privacy partition between showers

105 CMR 451.123

Maintenance: Soap scum on shower curtain

105 CMR 451.123

Maintenance: Countertop damaged in front of sinks

Nurse's Station # 231

No Violations Noted

Nurse's Bathroom

No Violations Noted

Exam Room # 233

No Violations Noted

D2 Barracks

105 CMR 451.322*

Cell Size: Inadequate floor space in dorm room

Doctor's Office

No Violations Noted

Sleeping Area

No Violations Noted

Slop Sink Room # 230

No Violations Noted

Inmate Bathroom

105 CMR 451.121(A)*

Privacy: No privacy partition between showers

105 CMR 451.123

Maintenance: Wall left unfinished

105 CMR 451.123

Maintenance: Soap scum on shower curtain

Observations and Recommendations

1. The inmate population was 168 at the time of inspection.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "[1999 Food Code](#)".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Marian Robertson
Environmental Health Inspector, CSP, BEH

cc: Jan Sullivan, Acting Director, BEH
Steven Hughes, Director, CSP, BEH
Jay Youmans, Director of Government Affairs
Marylou Sudders, Secretary, Executive Office of Health and Human Services
Carol Higgins O'Brien, Commissioner, DOC
Michael DeCosta, EHSO/FSO
Eric J. Badger, CHO, Health Agent, Bridgewater Board of Health
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Daniel Bennett, Secretary, EOPSS
Jennifer Gaffney, Director, Policy Development and Compliance Unit