

request for supporting documentation

Cushing, Thomas (DEP)

Wed 8/5/2020 5:35 PM

To: Barry Goodrich <Barry.Goodrich@enbridge.com>; Kate Brown <Kate.Brown@enbridge.com>;

Based on my review, I am requesting the following information:

1. A copy of the June 2020 communication from National Grid, which is referenced in the prefiled direct testimony of Mr. John Heintz . During conversations on or about July 29 and again on August 5, you indicated this document, which supports the necessity to upgrade the Edgar substation is considered confidential by National Grid and consequently, Algonquin may not be able to provide the requested document. Should you be unable to provide either the requested document or sufficient alternative documentation regarding the necessity for upgrades to the Edgar substation, MassDEP may consider excluding the costs associated the Edgar substation from the BACT analysis.
2. Please provide a discussion of using 115 kV transmission line power as opposed to 13.8 kV distribution line power for the electric motor drive under consideration.
3. Please provide a map, which identifies the proposed route of the underground cable that was used for costing purposes.
4. Please identify to what extent National Grid would be responsible for costs referenced in the EMD BACT.