



The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Environmental Health

Community Sanitation Program

5 Randolph Street

Canton, MA 02021

Telephone: (781) 828-8046

Facsimile: (781) 828-7703

mikel.beacham@state.ma.us

DEVAL L. PATRICK
GOVERNOR

TIMOTHY P. MURRAY
LIEUTENANT GOVERNOR

JUDYANN BIGBY, MD
SECRETARY

JOHN AUERBACH
COMMISSIONER

February 24, 2011

Steven J. O'Brien, Superintendent
M.C.I. Plymouth
Myles Standish State Forest
P.O. Box 207
South Carver, MA 02366

Re: Facility Inspection

Dear Superintendent O'Brien:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, and Department of Public Health Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the M.C.I. Plymouth on February 16, 2011 accompanied by Jason Badger, Environmental Health and Safety Officer. Violations noted are listed below (* indicates conditions documented on previous inspection reports).

Central Control

Lobby

No Violations Noted

Staff Bathroom

105 CMR 451.121(B)*

Privacy: Bathroom is unisex

Medical Office

No Violations Noted

A Dorm

Bathroom

105 CMR 451.123*

Maintenance: Tiles need re-grouting

105 CMR 451.123

Maintenance: Tiles damaged

105 CMR 451.123

Maintenance: 3 light shields missing

105 CMR 451.123

Maintenance: Fan dirty

Hallway

105 CMR 451.350
105 CMR 450.340

Structural Maintenance: Light shield damaged
Illumination: Light out

B Dorm

Bathroom

105 CMR 451.123
105 CMR 451.123

Maintenance: Tiles damaged
Maintenance: Fan dirty

Hallway

105 CMR 450.340
FC 4-601.11(A)

Illumination: Light out
Equipment: Microwave dirty

C Dorm (Offices and Dog Area)

Staff Male Bathroom

No Violations Noted

Staff Female Bathroom

105 CMR 451.123

Maintenance: Light shield damaged

Inmate Bathroom

105 CMR 451.123*

Maintenance: Tile damaged

Inmate Break Room

FC 4-601.11(A)

Equipment: Microwave dirty

Food Service

Inmate Bathroom

No Violations Noted

Kitchen

FC 6-501.16
FC 5-205.15(B)
FC 4-903.11(A)(2)

Maintenance and Operation; Cleaning: Wet mop stored in bucket
Plumbing System, Operations and Maintenance: Handwash sink in dish area leaks
Protection of Clean Items, Storing: Single-service items not protected from contamination, utensils not stored with handles up
Plumbing System, Design: Handwashing sinks water temperature recorded at 145°F
Cleaning of Equipment and Utensils, Objective: Chute inside ice machine dirty

FC 5-202.12(A)

FC 4-601.11(A)

Walk In Refrigerator

No Violations Noted

Dry Storage

No Violations Noted

Toxic/Caustic Room

No Violations Noted

Morton Building

Freezer

No Violations Noted

Program Center No Violations Noted

Storage One No Violations Noted

Bunk House No Violations Noted

Weight Building No Violations Noted

Property Room No Violations Noted

Maintenance Building No Violations Noted

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please indicate next to each entry on the inspection report a plan of correction. Said plan of correction must be submitted within ten working days of receiving this report and should detail the specific steps that will be taken and the date of expected compliance. The plan of correction should be submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Community Sanitation Regulations" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

Mikel Beacham
Environmental Health Inspector, CSP, BEH

cc: Suzanne K. Condon, Associate Commissioner, Director, BEH
Steven Hughes, Director, CSP, BEH
JudyAnn Bigby, MD, Secretary, Executive Office of Health and Human Services
Luis S. Spencer, Acting Commissioner, DOC
Jason Badger, Environmental Health and Safety Officer
Carver Board of Health
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Mary Elizabeth Heffernan, EOPS