



**CHARLES D. BAKER**  
GOVERNOR

**KARYN E. POLITO**  
LIEUTENANT GOVERNOR

**MIKE KENNEALY**  
SECRETARY OF HOUSING AND  
ECONOMIC DEVELOPMENT

**Commonwealth of Massachusetts**  
**Division of Professional Licensure**  
**Office of Public Safety and Inspections**  
1000 Washington Street, Suite 710  
Boston, Massachusetts 02118

**EDWARD A. PALLESCHI**  
UNDERSECRETARY OF CONSUMER  
AFFAIRS AND BUSINESS  
REGULATION

**DIANE M. SYMONDS**  
COMMISSIONER, DIVISION OF  
PROFESSIONAL LICENSURE

**NOTICE OF MEETING**

In accordance with the provisions of M.G.L.c. 30A, §20 notice is hereby given that a meeting of the Board of Elevator Regulations will be held on **Tuesday, April 2, 2019 at 1:00 p.m.**, at **1000 Washington Street, Boston, MA 02118** on the **1<sup>st</sup> Floor – Room 1C**. It is anticipated that the following will be discussed at the aforementioned meeting:

1. Roll Call
2. 5 High Street – Monson, MA  
Relief from Inspector's Report  
524 CMR Section 17.03 – Hoistway vent not code compliant.
3. 1 Charles Street – Boston, MA  
ASME A18.1-2014
  - (a) Section 2.1.1.4 – Interlock requirement.
  - (b) Section 2.1.1.3 – Doors cannot be more than 1" wider than the platform.
  - (c) Section 2.1.1.3 – Doors must present a smooth surface not closer than  $\frac{3}{8}$ " and not more than  $\frac{3}{4}$ " from the platform floor.
  - (d) Glass must be laminated safety glass as required by applicable elevator codes.
4. 250 Franklin Street – Boston, MA  
Variance request for a 1' deep pit and installation of "Gillespie Elevator" shallow pit elevator safety system due to the existing conditions of a loading dock located beneath the location of the elevator.  
Section 3.4 – Bottom and top clearances and run bys for cars and counterweight.  
Section 3.4.1 – Bottom car clearance
5. Approval of meeting minutes from March 26, 2019



6. Discussion of outside hoists.
7. Old business (The Board may or may not discuss):
  - 55 South Street – Hingham, MA  
Placed on hold: Deadline April 18, 2019
  - Discussion regarding the adoption of the 2016 elevator code.
8. Matters not reasonably anticipated 48 hours in advance of meeting.

