
From: Benjamin Reynolds <B.Reynolds@holtec.com>
Sent: Tuesday, December 19, 2023 2:21 PM
To: Langley, Lealdon (DEP); Jean Fleming
Subject: RE: Second request for Historic PNPS Permits
Attachments: PNPS_DEP RFI#2_12192023.pdf

CAUTION: This email originated from a sender outside of the Commonwealth of Massachusetts mail system. Do not click on links or open attachments unless you recognize the sender and know the content is safe.

Director Langley,

Based on MassDEP's December 8, 2023 request, Holtec is providing additional information to supplement the April 5, 2023 application to modify the Massachusetts surface water discharge permit (Permit No. MA0003557) for Pilgrim Nuclear Power Station.

Please let Jean Fleming or myself know if Holtec can further support the evaluation of the modification request.

Thank you and I hope you enjoy the holidays.

Ben

From: Langley, Lealdon (DEP) <lealdon.langley@mass.gov>
Sent: Friday, December 8, 2023 3:47 PM
To: Jean Fleming <J.Fleming@holtec.com>; Benjamin Reynolds <B.Reynolds@holtec.com>
Subject: Second request for Historic PNPS Permits

Some people who received this message don't often get email from lealdon.langley@mass.gov. [Learn why this is important](#)

CAUTION: This email came from a source OUTSIDE of Holtec!!
Do not click any links or open any attachments unless you trust the sender and know the contents to be safe.
Clicking links or opening attachments could lead to infecting your computer or Holtec's servers with malicious viruses.

Ms. Fleming

Please find attached MassDEP's letter providing additional opportunity for Holtec to provide historic permit documents. Thank you. L2

Lealdon Langley, Director
Division of Watershed Management
Massachusetts Department of Environmental Protection (MassDEP)
100 Cambridge Street, Suite 900
Boston, MA 02114
Cell: (617) 259-0537

Note: MassDEP's office has moved. My prior office phone # has been deactivated.
For phone contact, please call the cell number above. Please remove my office phone # from your contact list.

The information contained herein is intended only for the person or entity to which it is addressed and may contain confidential and/or privileged material from Holtec International. If you are not the intended recipient, you must not keep, use, disclose, copy or distribute this email without the author's prior permission. Further, review, retransmission, dissemination, or other use of this information in whole or part for any other purpose by persons outside the recipient's organization is strictly prohibited unless explicit authorization to such effect has been issued by the sender of this message. Holtec International policies expressly prohibit employees from making defamatory or offensive statements and infringing any copyright or any other legal right by Email communication. Holtec International will not accept any liability in respect of such communications. Holtec International has taken precautions to minimize the risk of transmitting software viruses, but we advise you to carry out your own virus checks on any attachment to this message. Holtec International cannot accept liability for any loss or damage caused by software viruses. If you are the intended recipient and you do not wish to receive similar electronic messages from us in the future then please respond to the sender to this effect.

December 19, 2023

Mr. Lealdon Langley
Director of Watershed Management
Massachusetts Department of Environmental Protection
100 Cambridge Street Suite 900
Boston, MA 02114

Re: Pilgrim Nuclear Power Station – Application to Modify a Massachusetts Permit to Discharge Pollutants to Surface Waters (Permit No. MA0003557, January 30, 2020)

Dear Director Langley:

On December 8, 2023 Holtec Decommissioning International, LLC (HDI) received Massachusetts Department of Environmental Protection's (MassDEP) second request for additional information to supplement the April 5, 2023 application to modify the Massachusetts surface water discharge permit (Permit No. MA0003557). Specifically, MassDEP requested the "Pilgrim Station No. 600 Boston Edison Company, Salt Water Use and Waterfront Development for Pilgrim Nuclear Power Station [Salt Water Use Report] and operating records pertaining to treatment of liquid wastes" as well as "any applications and associated materials related to the three Water Quality Certifications (July 31, 1970, April 15, 1971 and April 23, 1971)."

HDI is providing the following records (Enclosure 1 and 2):

- United States of America Atomic Energy Commission Summary of Application for an Operating License for Pilgrim Nuclear Power Station, Docket No. 50-293, August 6, 1971 (OL Application)
- Department of the Army, Corps of Engineers Application for Permit to Discharge or Work in Navigable Waters and Their Tributaries, September 30, 1971 (ACOE Application)

Please note, the OL Application contains the Salt Water Use Report as well as information regarding the treatment of liquid wastes (at the time of submittal) and the April 23, 1971 Water Quality Certification is a required approval of the ACOE Application. No additional materials were identified to support the request at this time.

Should MassDEP have any additional concerns or wish to discuss this matter further, please feel free to contact Mr. Ben Reynolds, HDI Director of Environmental Affairs, or myself at (856) 797-0900, ext. 3578.

Respectfully,

Jean A. Fleming
Vice President, Licensing, Regulatory Affairs, & PSA
Holtec International



KPS Technology Campus, 1 Holtec Blvd., Camden, NJ 08104

Telephone (856) 797-0900 – Fax (856) 797-0900

www.holtecinternational.com

Enclosures:

1. United States of America Atomic Energy Commission Summary of Application for an Operating License for Pilgrim Nuclear Power Station, Docket No. 50-293, August 6, 1971
2. Department of the Army, Corps of Engineers Application for Permit to Discharge or Work in Navigable Waters and Their Tributaries, September 30, 1971

Enclosure 1

United States of America Atomic Energy Commission

Summary of Application for an Operating License for Pilgrim Nuclear Power Station

Docket No. 50-293

August 6, 1971

File 1.8.9

UNITED STATES OF AMERICA
ATOMIC ENERGY COMMISSION

SUMMARY OF APPLICATION
FOR AN OPERATING LICENSE
FOR
PILGRIM NUCLEAR POWER STATION

Docket No. 50-293

August 6, 1971

BOSTON  **Edison** COMPANY

November 29, 1971

ERRATA IN "SUMMARY OF APPLICATION
FOR AN OPERATING LICENSE FOR
PILGRIM NUCLEAR POWER STATION"

(A) Errata incorporated in second printing

Page

- iv Bottom line should read: "9.2 Pre-Operational and Startup Testing"
- vi In titles of Figures 4-4 and 4-5, change "1968" to "1965".
- In title of Figure 4-5 insert "and" after "Resident".
- 1-1 Line 16, third word is "water".
- 2-9 Line 2, change "Section 12.0" to "Section 10.0".
- 5-3 Line 4, add the word "principally" after "consist".
- 7-2 In the footnote, change "Section 7.5" to "Section 8.5".

(B) Errata not incorporated in any copies

- 8-3 Add the following at bottom of page: "vessel in the shape of a light bulb, and the pressure suppression chamber is a torus-shaped steel pressure".
- 8-22 Line 1, change "amendable " to "amenable".
- 9-4 Line 5, change "clerical" to "electrical".
- 10-5 Line 16, change "dispatching" to "dissipating".

0 6 9 4

0 2 3 3 9

(C) Suggested editorial changes (not incorporated in any copies)

Page

- 7-1 Lines 3 and 4, change "minimize radiation. . . site" to "maintain radiation exposures well below the applicable regulatory limits".
- 8-3 Line 19, after the word "containment", remove the word "is" and insert "consists of the drywell".
- 8-13 Lines 10 and 11, change "coolant system piping, pumps, valve supports, and hangers" to read "emergency coolant system piping welds."
- 8-16 Line 11, change "involving the gross release" to "which could potentially involve the release."

0 2 3 3 9
0 6 9 5

November 29, 1971

ERRATA IN "SUMMARY OF APPLICATION
FOR AN OPERATING LICENSE FOR
PILGRIM NUCLEAR POWER STATION"

Page

- iv Bottom line should read: "9.2 Pre-Operational and Startup Testing"
- vi In titles of Figures 4-4 and 4-5, change "1968" to "1965".
- In title of Figure 4-5 insert "and" after "Resident".
- 1-1 Line 16, third word is "water".
- 2-9 Line 2, change "Section 12.0" to "Section 10.0".
- 5-3 Line 4, add the word "principally" after "consist".
- 7-2 In the footnote, change "Section 7.5" to "Section 8.5".
- 8-3 Add the following at bottom of page: "vessel in the shape of a light bulb, and the pressure suppression chamber is a torus-shaped steel pressure".
- 8-22 Line 1, change "amendable " to "amenable".
- 9-4 Line 5, change "clerical" to "electrical".
- 10-5 Line 16, change "dispatching" to "dissipating".

06960

02339

0 6 9 7
0 2 3 3 9
1 station structural design criteria differentiates between
2 two types of station structures, Class I structures and
3 Class II structures, and applies detailed design require-
4 ments to each classification. Class I includes those
5 structures, equipment and components whose failure or mal-
6 function might cause or increase the severity of an accident
7 which might endanger the public health and safety. This
8 category includes those structures, required for safe shut-
9 down and isolation of the reactor. Class II includes those
10 structures, equipment, and components which are important
11 to reactor operation, but are not essential for preventing
12 an accident which would endanger the public health and
13 safety and are not essential for the mitigation of the con-
14 sequences of these accidents. ⁽¹⁾

15 8.2.2 Primary Containment System⁽²⁾

16 The primary containment system houses the reactor
17 vessel, the reactor coolant recirculation system and other
18 branch connections of the reactor coolant system. The pri-
19 mary containment is a pressure suppression chamber which
20 stores a large volume of water, a connecting vent system
21 between the drywell and water pool, isolation valves,
22 vacuum relief system, containment cooling systems, and
23 other service equipment. The drywell is a steel pressure
24 vessel in the shape of a light bulb, and the pressure sup-
25 pression chamber is a torus-shaped steel pressure

1 a time when the core geometry is amenable to cooling.

2 4. The core temperature is reduced and decay heat
3 can be removed for an extended period of time.

4 The systems' power supplies have been chosen to
5 allow initiation and operation regardless of the avail-
6 ability of offsite a-c power. The design of the systems
7 allows testing to verify the operability of all active
8 components during normal operation of the nuclear system.

9 The core standby cooling systems provided on
10 Pilgrim Nuclear Power Station are functionally equivalent
11 to those included in other operating BWR's. A short
12 description of the systems is included in the following
13 paragraphs.

14 8.5.2 Core Spray System⁽¹⁴⁾

15 Two independent loops are provided as a part of
16 the core spray system to circulate water from the pressure
17 suppression chamber pool to the reactor primary vessel.
18 Each loop consists of a core spray pump, a sparger ring,
19 a spray nozzle, and the necessary piping, valves, and
20 instrumentation. The core spray system provides protection
21 of the core for the postulated case of a large break in
22 the nuclear system when the feedwater system, control
23 rod drive water pumps, reactor core isolation cooling

1 subsection 12.2.1.2 of the FSAR. A summary of the
2 Class I protection instrument and control systems is
3 included in subsection 7.1.1 of the FSAR. The "essen-
4 tial items" are identified on the Q(Quality)-List.
5 Within the Class I mechanical and electrical systems,
6 every item or component is not Q-listed. Rather, each
7 component is reviewed to determine which of the follow-
8 ing categories it falls into:

9 Category A

10 Its function is essential for the operation
11 of a Class I component or system to meet the
12 Class I criteria (e.g., pumps and switches that
13 must operate to accomplish their safety objective).
14 If so, it is included on the Q-List.

15 Category B

16 Its pressure boundary integrity is essential
17 for the operation of a Class I component to meet
18 the Class I criteria. If so, it is included on
19 the Q-List and, if required for clarity, it is
20 given a note (pressure boundary only) on the Q-List.

21 Category C

22 It is not essential for either functioning
23 or pressure boundary integrity of A or B above

0 7 0 0
0 2 3 3 9
0 2 3 3 9
1 shield itself. Thus the design effectively precludes the
2 possibility of missile generation as a result of pipe or
3 safe-end ruptures within the shield. (2)

4 (4) Fuel Cask Drop

5 "The applicant proposes to assure that accidental
6 dropping of the spent-fuel cask into the fuel stor-
7 age pool will not cause leakage in excess of the
8 make-up capacity, and will make such modifications
9 as may be necessary."

10 Boston Edison Company has conducted studies to determine
11 the effects of a spent-fuel cask dropped into the fuel stor-
12 age pool. In order to assure that any resultant leakage
13 from the pool will be within the pool makeup capability, an
14 energy absorbing/load distributing pad will be installed in
15 the cask loading area which will be capable of absorbing,
16 distributing, and dissipating the kinetic energy associated
17 with a loaded cask drop from the maximum height. (3)

18 (5) Confirmatory Vibration Testing

19 "The applicant said he would make tests adequate to
20 confirm the predicted vibrational characteristics of
21 the vessel internals."

22 A program of confirmatory vibration measurements will
23 be implemented for the Pilgrim reactor. Both cold and hot

UNITED STATES OF AMERICA
ATOMIC ENERGY COMMISSION

In the Matter of)
BOSTON EDISON COMPANY)
(Pilgrim Nuclear Power Station))

Docket No. 50-293

SUMMARY OF APPLICATION

AUGUST 6, 1971

0 2 3 3 9
0 7 0 1

TABLE OF CONTENTS

	<u>Page</u>
1.0 <u>INTRODUCTION</u>	1-1
2.0 <u>BACKGROUND</u>	2-1
2.1 <u>Boston Edison Company</u>	2-1
2.2 <u>Applicant's Participation in the Development of</u> <u>Nuclear Power</u>	2-2
2.3 <u>Need for Pilgrim Station</u>	2-3
2.4 <u>Pilgrim Station Licensing History to Date</u>	2-7
3.0 <u>THE EVOLUTION OF THE PILGRIM STATION DESIGN CONCEPT</u> . .	3-1
4.0 <u>SITE CHARACTERISTICS</u>	4-1
4.1 <u>Location</u>	4-1
4.2 <u>Population</u>	4-2
4.3 <u>Land Use</u>	4-2
4.4 <u>Recreational Use</u>	4-3
4.5 <u>Meteorology</u>	4-5
4.6 <u>Hydrology and Oceanography</u>	4-7
4.7 <u>Geology and Seismology</u>	4-13
5.0 <u>ENVIRONMENTAL QUALITY</u>	5-1
5.1 <u>General</u>	5-1

5.2	<u>Aesthetics and Land Use</u>	5-1
5.3	<u>Thermal and Chemical Discharges</u>	5-2
5.4	<u>Radiological Discharges</u>	5-3
5.5	<u>Environmental Surveillance Program</u>	5-4
5.6	<u>National Environmental Policy Act of 1969</u>	5-5
5.7	<u>Water Quality Improvement Act of 1970</u>	5-7
6.0	<u>ENVIRONMENTAL MONITORING PROGRAMS</u>	6-1
6.1	<u>Aquatic Ecological Surveillance</u>	6-1
6.2	<u>Environs Radiation Surveillance</u>	6-3
7.0	<u>STATION SAFETY ANALYSIS</u>	7-1
8.0	<u>DESCRIPTION OF PILGRIM NUCLEAR POWER STATION</u>	8-1
8.1	<u>Introduction</u>	8-1
8.2	<u>Containment Systems</u>	8-2
8.2.1	General	8-2
8.2.2	Primary Containment System	8-3
8.2.3	Secondary Containment System	8-6
8.3	<u>Reactor Description</u>	8-8
8.4	<u>Station Instrumentation and Control Systems</u>	8-13
8.4.1	Reactor Control	8-13
8.4.2	Protection Systems	8-14
8.4.3	Reactor Nuclear Instrumentation	8-19

0 2 3 3 9 0 7 0 3

8.5	<u>Core Standby Cooling Systems and Related</u>	
	<u>Auxiliary Cooling Water Systems</u>	8-20
8.5.1	General	8-20
8.5.2	Core Spray System	8-22
8.5.3	High Pressure Coolant Injection (HPCI) System	8-23
8.5.4	Pressure Relief System/Automatic Depressurization System	8-24
8.5.5	Reactor Core Residual Heat Removal System	8-25
8.5.6	Reactor Building Closed Cooling Water System	8-27
8.5.7	Salt Service Water System	8-28
8.6	<u>Steam Power Conversion Systems</u>	8-28
8.7	<u>Electrical Power Systems</u>	8-30
8.8	<u>Radiation Monitoring Systems</u>	8-33
8.9	<u>Shielding, Access Control and Radiation Protection</u> <u>Procedures</u>	8-35
8.10	<u>Radioactive Waste Systems</u>	8-37
8.10.1	General	8-37
8.10.2	Liquid Radwaste System	8-38
8.10.3	Gaseous Radwaste System	8-41
8.10.4	Solid Radwaste System	8-43
9.0	<u>QUALITY ASSURANCE AND STATION TESTING PROGRAMS</u> . . .	9-1
9.1	<u>Quality Assurance</u>	9-1
9.2	<u>Pre-Operational and Startup Testing</u>	9-5

0 2 3 3 9 0 7 0 4

Page

10.0	<u>COMMENTS ON ACRS REPORT</u>	10-1
11.0	<u>OTHER GOVERNMENTAL AGENCIES</u>	11-1
12.0	<u>TECHNICAL QUALIFICATIONS</u>	12-1
12.1	<u>Boston Edison Company</u>	12-1
12.2	<u>Bechtel Corporation</u>	12-2
12.3	<u>General Electric Company</u>	12-4
13.0	<u>EMERGENCY PLAN</u>	13-1
14.0	<u>COMMON DEFENSE AND SECURITY</u>	14-1
15.0	<u>FINANCIAL QUALIFICATIONS</u>	15-1
16.0	<u>FINANCIAL PROTECTION</u>	16-1
17.0	<u>CONCLUSION</u>	17-1

0 2 3 3 9
0 7 0 5

FIGURES

	<u>Page</u>
4-1 Site Location Map (0-50 mile radius)	4-15
4-2 Site Location Map (0-4 mile radius)	4-16
4-3 Site Plot Plan	4-17
4-4 Resident Population for Years 1965 & 2015	4-18
4-5 Resident and Seasonal Population for Years 1965 & 2015	4-19
4-6 Annual Wind Rose - 300 ft. MSL	4-20
4-7 Cooling Water Dispersion	4-21
4-8 Cooling Water Dispersion	4-22
8-1 Simplified Station Process Flow Diagram	8-48
8-2 Reactor Vessel Isometric	8-49
9-1 Quality Assurance - Quality Control Responsibility Chart	9-10
9-2 Site Construction - Quality Assurance Organization Chart	9-11
9-3 Pilgrim Nuclear Power Station Organization Chart	9-12

1 1.0 INTRODUCTION

2 This document, prepared and filed by Boston Edison
3 Company, the applicant, is a summary of the application*
4 filed by the Company for a license from the Atomic
5 Energy Commission to operate a nuclear power station loca-
6 ted on a site in the town of Plymouth, Plymouth County,
7 Massachusetts. To assist interested members of the public
8 in understanding the complex technical material dealt with
9 in this report, the applicant has endeavored to use non-
10 technical language whenever possible.

11 The Pilgrim Nuclear Power Station occupies a 517-acre
12 site on the shore of Cape Cod Bay. Construction and pre-
13 operational testing is presently scheduled to be completed
14 and the station ready for fuel loading and low power
15 reactor operation in December, 1971. The unit is a con-
16 ventional boiling water reactor (BWR) designed to generate
17 about 685 megawatts of electricity. It has similar design
18 characteristics to other boiling water reactors which have
19 been licensed and are in operation.

20 This document has been prepared in accordance with
21 the provisions of Title 10 of the Code of Federal
22 Regulations, Part 2, Appendix A, Section II (e).
23 It includes a summary description of the station, an

*The application and other pertinent documents currently in
the record of this proceeding may be examined at the Plymouth
Public Library, North Street, Plymouth, Massachusetts.

0 2 3 3 9 0 7 0 8

1 evaluation of the considerations important to safety,
2 and a comparison of the Pilgrim reactor design with the
3 design of similar reactors previously licensed and in
4 operation. The applicant has included comments on the
5 operating license application rendered by the Advisory
6 Committee on Reactor Safeguards on the application
7 pursuant to Section 29 of the Atomic Energy Act of
8 1954 as amended (42 U.S.C. 2039), and information
9 incorporated in the docket in accordance with the
10 National Environmental Policy Act of 1969, P.L. 91-190.

11 In addition to a summary of the application, this
12 document contains a summary of the applicant's program
13 of consultation with interested federal, state and local
14 government officials in planning for the Pilgrim Nuclear
15 Power Station. This summary also describes the status
16 of the applicant's efforts to obtain the permits and
17 approvals required by federal, state, and local agencies.

18 As set forth more fully in the ensuing sections of
19 this summary, the station has been designed and constructed
20 with preservation of the environment and assurance of
21 nuclear safety as paramount considerations. The station
22 has been designed and will be operated to keep radio-
23 activity in station effluents at small fractions of the

0 7 0 9
0 3 3 3 9
0 2 3 3 9

1 applicable limits specified in 10 CFR 20*, "Standards
2 for Protection Against Radiation." Environmental
3 monitoring programs have been established to determine
4 environmental radiation levels prior to station
5 operation for comparison with similar data obtained
6 after station operation. This will serve as a check
7 on the effectiveness of the various source controls to
8 assure that public exposure to radiation remains at
9 small fractions of applicable 10 CFR 20 limits.

10 No adverse environmental effects are expected to
11 result from the operation of Pilgrim Station. The
12 environmental monitoring programs include aquatic
13 ecological surveillances for detection and evaluation
14 of any environmental effects. If an effect of
15 significance is detected, the applicant will take
16 steps to correct or mitigate any adverse situation.

*10 CFR 20-Code of Federal Regulations, Title 10, Part 20.

1 2.0 BACKGROUND

2 2.1 Boston Edison Company

3 Boston Edison Company is the sole applicant for the
4 facility license, and as owner and applicant, is responsible
5 for the design, construction, and operation of the station.
6 Boston Edison Company is a publicly-held corporation
7 incorporated under the laws of The Commonwealth of Massachu-
8 setts in 1886, with its principal executive office at
9 800 Boylston Street, Boston, Massachusetts.

10 The applicant is an operating public utility engaged in
11 the electric and steam businesses, supplying electricity at
12 retail in the cities of Boston (except the Charlestown dis-
13 trict), Somerville, Newton, Chelsea, Waltham and Woburn, in
14 the towns of Brookline, Arlington, Watertown, Framingham,
15 and in thirty other smaller towns in eastern Massachusetts,
16 covering an area of approximately 590 square miles within
17 30 miles of Boston. It also supplies electricity in bulk
18 at wholesale to other utilities, including the total elec-
19 tric requirements of the Charlestown District of Boston
20 and thirteen other cities and towns in the vicinity of
21 Boston.

22 The applicant's electric generating facilities have an
23 aggregate peak capability of approximately two million

1 kilowatts. The principal steam-electric generating stations
2 operated by the applicant are the Edgar station in North
3 Weymouth, the Mystic station in Everett, and the L Street
4 and New-Boston stations in South Boston. The applicant
5 also supplies steam, chiefly from its three steam gener-
6 ating plants located in Boston to approximately 625 cus-
7 tomers in that city and engages in the business of pur-
8 chasing and selling electrical appliances.

9 2.2 Applicant's Participation in the Development
10 of Nuclear Power

11 Boston Edison's involvement with nuclear power plants
12 began in 1955 and has continued up to the present time.
13 Boston Edison was a contributor and active participant in
14 the Power Reactor Development Corporation (PRDC), an organ-
15 ization which gave financial support and technical assist-
16 ance to the Fermi Reactor Project. It is a sponsor of
17 Yankee Atomic Electric Company and Connecticut Yankee Atomic
18 Power Company, and owns 9-1/2 percent of the stock of each
19 of those companies and receives 9-1/2 percent of the power
20 generated by each of those companies. Boston Edison is
21 currently contributing to the development of fast breeder
22 reactors and, through the Edison Electric Institute, to
23 the nuclear research and development programs of that
24 organization.

1 2.3 Need for Pilgrim Station

2 Pilgrim Nuclear Power Station is presently scheduled
3 for full power operation in April, 1972 and is part of
4 the comprehensive plan to meet the applicant's electric
5 power requirements. The peak load of the applicant for the
6 power year commencing November 1, 1971, is forecast at
7 2,010 megawatts and will occur after the Pilgrim Nuclear
8 Power Station is scheduled for full power operation.

9 Although the Pilgrim Station will add approximately 655 net
10 megawatts of new capacity, 140 megawatts of this capacity
11 is contracted to utilities outside the applicant's service
12 area as unit sales, and an additional 300 MW is contracted
13 to other utilities as system sales based upon Pilgrim's
14 availability.

15 Pilgrim Station was originally scheduled for service
16 in 1971 when the New England region, assuming both the
17 Pilgrim Nuclear Power Station and the Vermont Yankee Unit
18 were in commercial operation, expected to have 15,676 MW
19 of capacity to meet a peak load of 12,820 MW. The reserve
20 margin was expected to be 2,856 MW, which is equal to 22.3%
21 of the estimated peak. With the capacity of Vermont Yankee
22 not available, the area's capacity will be reduced to
23 15,163 MW with 2,343 MW of reserve which is equal to 18.3%

0 7 1 3
1 of the estimated peak. With the capacity of the Pilgrim
2 Nuclear Unit also not available, the area's capacity will
3 be reduced to 14,508 MW with 1,688 MW of reserve which will
4 equal only 13.2% of the estimated peak load.

5 In the most recent report of the New England Planning
6 Committee, of which Boston Edison is a member, the 1972-73
7 winter peak load of the New England area is estimated to
8 be 13,846 MW. Without any capacity additions or retire-
9 ments New England will have 14,405 MW of capacity to meet
10 this load forecast resulting in a 4.0% reserve margin.
11 The addition of Pilgrim Station (655 net MW) will increase
12 the New England reserve margin to 8.8%.

13 Other generating units under construction for service
14 during this period are Vermont Yankee (513 MW), Maine
15 Yankee (792 MW), Northfield Mountain (1000 MW), and two
16 gas turbines (44.7 MW).

17 The Pilgrim unit is a significant part of a comprehen-
18 sive plan for bulk supply and its non-availability would
19 result in lower-than-needed capacity in the area with the
20 resulting decrease in service reliability.

21 As a public utility in Massachusetts, the Company is
22 under a legal mandate to furnish electricity to customers
23 in its service area and to provide sufficient "plants" for

0 2 3 3 9 0 7 1 4
1 that purpose. The operation of the Pilgrim Station is an
2 integral and necessary part of the applicant's plans to
3 provide the required service supported by sufficient reserve
4 to insure reliability of that service.

5 Moreover, the applicant is a participant in a plan for
6 coordinated New England system operations where reliability,
7 together with economy of bulk power supply for the region as
8 a whole, are prime considerations. Among the responsi-
9 bilities of this participation are the necessity to provide
10 its share of the region's capacity as well as its share of
11 the overall reserve requirement. These reserves are necessary
12 to insure the availability of power during times of scheduled
13 maintenance, forced outages and unexpected load growth.

14 Load growth has increased sharply in recent years. In
15 the fifties and early sixties load was growing at compound
16 rate of 6% in New England. Long range load forecasts made
17 at that time were based on the assumption that this rate of
18 growth would continue. However, the rate actually ex-
19 perienced since 1964 has approached 8%. As this changing
20 rate of growth became apparent, steps were taken to meet the
21 additional load requirement. One step taken was the in-
22 stallation of combustion turbines and diesel engines which
23 now total 1,319 megawatts of capacity for service by the

1 summer of 1971.

2 It has been the recent experience of the industry
3 that the forced outage rate of the new larger units has
4 been much greater than was forecast at the time the units
5 were planned. Although capacity planning now recognizes
6 higher forced outages rates, lower rates were in use at
7 the time the commitments were being made for the capacity
8 now nearing construction completion. For example, esti-
9 mated forced outage rates for units in the 400 megawatt
10 class have increased from 4.8% in 1965 to 7.5% in 1969.
11 Planning now utilizes the higher rates which result in an
12 increase of 3 to 4% in New England reserve requirements.

13 The higher than predicted loads and the greater than
14 predicted outage rates both tend to require greater gener-
15 ation reserves. As a consequence, in 1968, the desired
16 reserve for the seventies was increased to the order of
17 20 to 22% as compared to the 14% reserve considered adequate
18 in 1964.

19 The power that the Pilgrim Station will provide is an
20 important step in establishing adequate reserve margins in
21 the New England region as a whole and in permitting the
22 applicant to meet its power generation obligations.

1 2.4 Pilgrim Station Licensing History to Date

2 An application for a provisional construction permit
3 was filed with the United States Atomic Energy Commission
4 (the "Commission") on June 30, 1967. The application was
5 reviewed by the Regulatory Staff of the Commission and the
6 Advisory Committee on Reactor Safeguards ("ACRS"), each
7 concluding that the proposed Pilgrim Station could be
8 constructed and operated without undue risk to the health
9 and safety of the public.

10 On May 6, 1968, the Commission issued a "Notice of
11 Hearing on Application for a Provisional Construction Per-
12 mit" which was published in the Federal Register on May 10,
13 1968. Subsequently, Petitions for Leave to Intervene were
14 filed by the Commonwealth of Massachusetts, and as joint
15 intervenors, the Municipal Electric Association of Massa-
16 chusetts ("MEAM") and the electric light departments of four
17 Massachusetts towns. The Intervention was allowed the
18 Commonwealth and the Towns of Wakefield and Braintree and
19 denied as to MEAM and the other two towns.

20 Pursuant to the Notice of Hearing, hearings were held
21 before the Atomic Safety and Licensing Board (ASLB) on
22 June 18 and 19, 1968 in the Town of Plymouth. At that
23 time, appearances were made by the Plymouth Board of

0 2 3 3 9 0 7 1 7
1 Selectmen, the Plymouth Industrial Development Corporation,
2 the Plymouth Development and Industrial Commission and an
3 abutting land owner.

4 On August 26, 1968, the ASLB handed down a decision
5 directing the Commission's Director of Regulation to issue a
6 provisional construction permit in which it concluded that
7 the proposed Pilgrim Station could be constructed and
8 operated without undue risk to the health and safety
9 of the public. On the same date, the Commission issued
10 the permit (CPPR-49) to the Company. MEAM and four muni-
11 cipals filed exceptions to the ASLB's action with the
12 Commission, which denied them on March 20, 1970.

13 On January 5, 1970, the applicant filed Amendment 12
14 to the application, the Pilgrim Nuclear Power Station Final
15 Safety Analysis Report (FSAR).

16 The FSAR and the subsequent eighteen amendments submitted
17 in conformance with 10 CFR 50.34(b), include information that
18 describes the facility, presents the design bases and the
19 limits on its operation, and presents a safety analysis of
20 the structures, systems and components and of the facility
21 as a whole. The FSAR also contains answers to certain con-
22 cerns raised by the US-AEC Division of Reactor Licensing
23 and by the Advisory Committee on Reactor Safeguards.

1 (The subjects of the ACRS concerns and the resolutions to
2 the concerns are discussed in Section 10.0 of this summary.)

3 Following a meeting with the ACRS on April 2, 1971, a
4 a letter dated April 7, 1971 was sent to the Commission by
5 the ACRS stating, in part, that subject to attention being
6 given by the applicant to certain concerns of the ACRS
7 referred to above and subject to satisfactory completion
8 of construction and pre-operational testing, there was
9 reasonable assurance that the Pilgrim Station could be
10 operated without undue risk to the health and safety of
11 the public.

12 The Commission, on April 23, published in the Federal
13 Register a "Notice of Consideration of Issuance of Facility
14 Operating License." In response to the Notice approximately
15 forty-three generally worded requests for a hearing and
16 three formal petitions to intervene were received.

17 One petition was filed jointly by the Sierra Club and
18 the Union of Concerned Scientists, a second by the Common-
19 wealth of Massachusetts and a third by MEAM and the four
20 towns (on anti-trust grounds) which had sought to intervene
21 on the issuance of a construction permit. On July 12 the
22 Commission issued a Memorandum and Order determining that
23 a hearing should be held and that intervenor party status

1 should be granted to the Sierra Club and the Union of Con-
2 cerned Scientists and the Commonwealth. In denying "without
3 prejudice", MEAM and the four towns' petition to intervene,
4 the Commission noted that they would be afforded the oppor-
5 tunity to intervene in later proceedings on anti-trust
6 issues should the Commission determine on the recommendation
7 of the Attorney General that a hearing be held on such
8 matters.

0 2 3 3 9 0 7 1 9

1 3.0 THE EVOLUTION OF THE PILGRIM STATION DESIGN CONCEPT

2 The Pilgrim Nuclear Power Station utilizes a boiling
3 water reactor (BWR) designed by the General Electric Company
4 to produce steam for direct use in the steam turbine. The
5 Pilgrim BWR design and safety systems have evolved from
6 years of design and operating experience from other BWR's
7 having similar basic design and operating characteristics.

8 The Vallecitos Boiling Water Reactor was started up
9 in 1957 by General Electric to test BWR design concepts
10 and fuel technology. The Dresden 1 BWR which began opera-
11 tion in 1960, was the first large-scale privately-owned
12 nuclear power plant in the United States. Presently,
13 there are twenty-one BWR's designed by General Electric
14 which are in operation, generating electricity, with an
15 aggregate capacity of approximately 6,570,000 kilowatts.

16 Principal design characteristics of the Pilgrim
17 Station are compared in Tables 3.1, 3.2, 3.3 and 3.4 to
18 three operating boiling water reactors; Dresden II,
19 Monticello and Millstone I. The Pilgrim Station design
20 characteristics are most comparable to those of Millstone I
21 which was granted an operating license in October, 1970,
22 and which has now generated over 2 billion kilowatthours
23 of electricity.

Table 3.1
COMPARISON OF NUCLEAR SYSTEM DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
THERMAL AND HYDRAULIC DESIGN				
Core Power, MWt	1998	2527	1670	2011
Steam Flow Rate, lb/hr	7.983×10^6	9.945×10^6	6.77×10^6	7.94×10^6
Core Coolant Flow Rate lb/hr	69×10^6	98×10^6	57.6×10^6	69×10^6
Feedwater Flow Rate, lb/hr	7.983×10^6	9.94×10^6	6.77×10^6	7.94×10^6
Feedwater Temperature, °F	359.4	348	376.3	350.1
System Pressure Nominal in Steam Dome psia	1020	1015	1015	1015
Average Power Density kW/liter	40.5	41.08	40.6	40.8
Maximum Thermal Output kW/ft	17.5	17.5	17.5	17.5
Average Thermal Output kW/ft	5.66	5.7	5.7	5.7
Maximum Heat Flux Btu/hr-ft ²	405,200	405,200	405,200	405,200
Average Heat Flux Btu/hr-ft ²	131,100	131,860	131,350	129,000
Maximum UO ₂ Temperature, °F	4230	4230	4230	4230
Average Volumetric Fuel Temperature, °F	1059	1050	900	1050
Average Fuel Rod Surface Temperature, °F	558	558	558	558
Minimum Critical Heat Flux Ratio (MCHFR)	>1.9	>1.9	>1.9	>1.9
Coolant Enthalpy at Core Inlet, Btu/lb	522.5	520.5	522.9	519.4
Core Maximum Exit, % Voids Within Assemblies	78.2	76	76	79.1
Core Average Exit Quality, % Steam	11.8	10.1	12.1	11.8
Power Peaking Factor				
Maximum Relative Assembly Power	1.66	1.50	1.58	1.57
Local Peaking Factor	1.24	1.30	1.24	1.25
Axial Peaking Factor	1.5	1.57	1.57	1.57
Total Peaking Factor	3.09	3.06	1.09	3.08
NUCLEAR DESIGN (First Core)				
Water/UO ₂ Volume Ratio (Cold)	2.41	2.41	2.42	2.41
Reactivity with Strongest Control Rod Out, K _{eff}	<0.99	<0.99	<0.99	<0.99
Moderator Temperature Coefficient				
At 68°F, Δk/k-°F Water	-8.0×10^{-5}	-8.0×10^{-4}	-8.0×10^{-4}	-8.0×10^{-4}
Hot, no voids, Δk/k-°F Water	-20.0×10^{-5}	-17.0×10^{-4}	-17.0×10^{-4}	-17.0×10^{-4}

Table 3.1
COMPARISON OF NUCLEAR SYSTEM DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
Moderator Void Coefficient				
Hot, no voids, $\Delta k/k$ -% Void	-1.0×10^{-3}	-1.0×10^{-3}	-1.0×10^{-3}	-1.0×10^{-3}
At Rated Output, $\Delta k/k$ -% Void	-1.6×10^{-3}	-1.4×10^{-3}	-1.4×10^{-3}	-1.4×10^{-3}
Fuel Temperature Doppler Coefficient				
At 68°F, $\Delta k/k$ -°F Fuel	-1.3×10^{-5}	-1.2×10^{-5}	-1.2×10^{-5}	-1.2×10^{-5}
Hot, No Void, $\Delta k/k$ -°F Fuel	-1.2×10^{-5}	-1.2×10^{-5}	-1.2×10^{-5}	-1.2×10^{-5}
At Rated Output, $\Delta k/k$ -°F Fuel	$<-1.3 \times 10^{-5}$	$<-1.2 \times 10^{-5}$	$<-1.2 \times 10^{-5}$	$<-1.2 \times 10^{-5}$
Initial Average U-235	2.19%	2.12%	2.25%	2.07%
Enrichment, W/O				
Fuel Average Discharge	19,000	19,000	19,000	15,000
Exposure, MWd/Ton				
CORE MECHANICAL DESIGN				
Fuel Channel				
Overall Dimension	166.875	166.875	166.875	166.875
inches (length)				
Thickness, inch	0.080	0.080	0.080	0.080
Cross Section Dimensions, inches	5.438 X 5.438	5.438 X 5.438	5.438 X 5.438	5.438 X 5.438
Material	Zircaloy-4	Zircaloy-4	Zircaloy-4	Zircaloy-4
Core Assembly				
Total Weight of UO ₂ , pounds	280,325	356,200	238,370	284,500
Core Diameter (equivalent)	163.1	182.2	149	163.1
inches				
Core Height (Active Fuel)	144	144	144	144
inches				
Reactor Control System				
Method of Variation	Movable	Movable	Movable	Movable
of Reactor Power	Control Rods	Control Rods	Control Rods	Control Rods
	and Variable	and Variable	and Variable	and Variable
	Coolant	Coolant	Coolant	Coolant
	Pumping	Pumping	Pumping	Pumping
Number of	145	177	121	145
Movable Control Rods				
Shape of	Cruciform	Cruciform	Cruciform	Cruciform
Movable Control Rods				
Pitch of	12.0	12.0	12.0	12.0
Movable Control Rods				
Control Material	B ₄ C granules	B ₄ C granules	B ₄ C granules	B ₄ C granules
in Movable Rods	Compacted	Compacted	Compacted	Compacted
	in SS Tubes	in SS Tubes	in SS Tubes	in SS Tubes
Type of Control Rod Drives	Bottom entry,	Bottom entry,	Bottom Entry,	Bottom entry,
	Locking	Locking	Locking	Locking
	Piston	Piston	Piston	Piston
Fuel Assembly				
Number of Fuel Assemblies	580	724	484	580
Fuel Rod Array	7 X 7	7 X 7	7 X 7	7 X 7

Table 3.1
COMPARISON OF NUCLEAR SYSTEM DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
Overall Dimensions, inches	175.88	175.88	175.88	175.88
Weight of UO ₂ per Assembly pounds	Undished 490.53 Dished 480.62	492.5	Undished 492.5 Dished 481.7	490.2
Weight of Fuel Assembly pounds	Undished 676.91 Dished 667.00	678.9	Undished 678.9 Dished 668	690.3
Fuel Rods				
Number per Fuel Assembly	49	49	49	49
Outside Diameter, inch	0.563	0.563	0.563	0.570
Clad Thickness, inch	0.032	0.032	0.032	0.036
Gap-Pellet to Clad, inch	0.0055	0.0055	0.005	0.0055
Length of Gas Plenum, inches	11.24	11.24	11.24	11.24
Clad Material	Zircaloy-2	Zircaloy-2	Zircaloy-2 and/or Zr-4	Zircaloy-2
Cladding Process	Free standing loaded tubes	Free standing loaded tubes	Free standing loaded tubes	Free standing loaded tubes
Fuel Pellets				
Material	Uranium Dioxide	Uranium Dioxide	Uranium Dioxide	Uranium Dioxide
Density, % of theoretical	93%	93%	93%	93%
Diameter, inch	0.488	0.488	0.488	0.488
Length, inch	0.5	0.5	0.5	0.5
Number of Temporary Control Curtains	264	340	216	264
Curtain Material	Flat, boron- stainless steel	Flat, boron- stainless steel	Flat, boron- stainless steel	Flat, boron- stainless steel
In-Core Neutron Instrumentation				
Number of In-Core Neutron Detectors (Fixed)	120	164	96	120
Number of In-Core Detector Assemblies	30	41	24	30
Number of Detectors per Assembly	4	4	4	4
Number of Flux Mapping Neutron Detectors	4	4	2	4
Range (and Number) of Detectors				
Source Range Monitor	Source to 0.001% power (4)	Source to 0.001% power (4)	Source to 0.001% power (4)	Source to 0.001% power (4)
Intermediate Range Monitor	0.0001% to 10% Power (8)	0.0003% to 10% power (8)	0.0001% to 10% power (8)	0.0003% to 10% power (8)
Local Power Range Monitor	5% to 125% power (120)	5% to 125% power (164)	5% to 125% power (96)	5% to 125% power (120)
Average Power Range Monitor	5% to 125%	5% to 125%	5% to 125%	5% to 125%
Number and Type of In-Core Neutron Sources	5 Sb-Be	7 Sb-Be	5 Sb-Be	5 Sb-Be

Table 3.1
COMPARISON OF NUCLEAR SYSTEM DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
REACTOR VESSEL DESIGN				
Material	← Carbon Steel/Clad Stainless Steel →			
Design Pressure, psia	1265	1265	1265	1265
Design Temperature, °F	575	575	575	575
Inside Diameter ft-in.	18-8	20-11	17-11	18-8
Inside Height, ft-in	64-8½	64-8	63-2	68-7
Side Thickness (including clad)	5.688	6.125	5.187	5.688
Minimum Clad Thickness, inches	1/8	1/8	1/8	1/8
REACTOR COOLANT RECIRCULATION DESIGN				
Number of Recirculation Loops	2	2	2	2
Design Pressure				
Inlet Leg, psig	1148	1175	1148	1175
Outlet Leg, psig	1241	1325	1248	1325
Design Temperature, °F	562	565	562	564
Pipe Diameter, inches	28	28	28	28
Pipe Material	304/316	304/316	304	304/316
Recirculation Pump	45,200	45,200	45,200	45,200
Flow Rate, gpm				
Number of Jet Pumps in Reactor	20	20	20	20
MAIN STEAM LINES				
Number of Steam Lines	4	4	4	4
Design Pressure, psig	1146	1146	1146	1146
Design Temperature, °F	563	563	563	563
Pipe Diameter, inches	20	20	18	20
Pipe Material	← Carbon Steel (ASTM A155 KC70 or ASTM A106 Grade B) →			
CORE STANDBY COOLING SYSTEMS (These systems are sized on design power)				
Core Spray System				
Number of Loops	2	2	2	2
Flow Rate (gpm)	3600 at 104 psid	4500 at 90 psid	3020 at 307 psid	3600 at 90 psid
High Pressure Coolant Injection System (No.)				
Number of Loops	1	1	1	1
Flow Rate (gpm)	4250	5600	3000	8000 *
Automatic Depressurization System (No.)				
	1	1	1	1

*Utilizes feedwater pumps

3-5

Table 3.1
COMPARISON OF NUCLEAR SYSTEM DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
Low Pressure Coolant Injection (No.)	1	1	1	1
Number of pumps	4	4	4	4
Flow Rate (gpm/pump)	4800 at 20 psid	5350 at 0 psid	4000 at 20 psid	5000 at 0 psid
AUXILIARY SYSTEMS				
Residual Heat Removal System				
Number of pumps	4	3	4	4
Flow Rate (gpm/pump)	4800	5350	4000	5000
Number of heat exchangers	2	3	2	2
Capacity (Btu/hr/heat exchanger) ¹	64×10^6	27×10^6	24.5×10^6	40×10^6
Service Water System				
Number of pumps	5	4	4	4
Flow rate (gpm/pump)	2700	3500	3500	2500
Reactor Core Isolation Cooling System				
Flow Rate (gpm)	400 at 1120 psid	*	400 at 1120 psid	*
Fuel Pool Cooling and Cleanup System				
Capacity (Btu/hr)	6.53×10^6	3.65×10^6	2.87×10^6	7.84×10^6
Reactor Building Closed Cooling Water System				
Number of pumps	6	-	-	-
Flow Rate (gpm)	1700	-	-	-
Number of heat exchangers	2	-	-	-
Capacity (Btu/hr/heat exchanger) ²	65×10^6	-	-	-

¹ Capacity during post-accident cooling mode with 165°F shell side inlet temperature maximum service water temperature, and 1 RHR pump in operation.

² Capacity during post-accident cooling mode at 65°F service water temperature with 2 RBCCW pumps and 1 RBCCW heat exchanger in operation.

*No RCIC, these units utilize isolation condenser in place of RCIC.

Table 3.2
COMPARISON OF POWER CONVERSION SYSTEM DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
TURBINE-GENERATOR				
Design Power, MWe (Net)	655	810	543	652
Generator Speed, rpm	1800	1800	1800	1800
Steam Flow, lb/hr	7.983×10^6	9.945×10^6	6.77×10^6	7.94×10^6
Turbine Inlet Pressure psig	965	950	965	965
TURBINE BYPASS SYSTEM				
Capacity, percent of turbine design steam flow	25	40	15	105
MAIN CONDENSER				
Heat removal capacity, Btu/hr	4433×10^6	-	3750×10^6	-
CIRCULATING WATER SYSTEM				
Number of Pumps	2	3	2	4
Flow Rate, gpm/pump	155,500	-	140,000	105,000
CONDENSATE AND FEEDWATER SYSTEMS				
Flow Rate, lb/hr	7.983×10^6	9.725×10^6	6.77×10^6	7.94×10^6
Number of Condensate Pumps	3	4	2	3
Number of Condensate Booster Pumps	-	4	-	3
Number of Feedwater Pumps	3	3	2	2
Condensate Pump Drive	a-c power	a-c power	a-c power	a-c power
Condensate Booster Pump Drive	-	a-c power	-	a-c power
Feedwater Pump Drive	a-c power	a-c power	a-c power	a-c power

Table 3.3
COMPARISON OF ELECTRICAL POWER SYSTEMS DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
TRANSMISSION SYSTEM				
Outgoing lines (number-rating)	2-345 kV	5-345 kV	2-345 kV	2-345 kV
NORMAL AUXILIARY A-C POWER				
Incoming lines (number-rating)	2-345 kV 1-23 kV	5-345 kV 6-138 kV	1-345 kV 1-115 kV	2-345 kV 1-27.6 kV
Auxiliary transformers	2*	4	2	1
Startup transformers	1	1	1	1
STANDBY A-C POWER SUPPLY				
Number diesel generators	2	3	2	1 plus 1 (Gas)
Number of 4160V standby buses	2	4	4	6
Number of 480V standby buses	3	2	4	4
D-C POWER SUPPLY				
Number of 125V or 250V batteries	2-125V 1-250V	2-125V 1-250V	2-125V 1-250V	1-125V
Number of 125V or 250V buses	3-125V 1-250V	2-125V 2-250V	2-125V 1-250V	2-125V

* 1 unit auxiliary transformer, 1 shutdown transformer

Table 3.4
COMPARISON OF CONTAINMENT DESIGN CHARACTERISTICS

	Pilgrim	Dresden II	Monticello	Millstone I
PRIMARY CONTAINMENT				
Type	Pressure Suppression	Pressure Suppression	Pressure Suppression	Pressure Suppression
Construction				
Drywell	Light bulb shape; steel vessel	Light bulb shape; steel vessel	Light bulb shape; steel vessel	Light bulb shape; steel vessel
Pressure Suppression Chamber—Internal Design	+56	+62	+62	+62
Pressure (psig)				
Pressure Suppression Chamber—External Design	+2	+1	+2	+1
Pressure (psi)				
Drywell—Internal	+56	+62	+56	+62
Design Pressure (psig)				
Drywell—External	+2	+2	+2	+2
Design Pressure (psi)				
Drywell Free Volume (ft ³)	147,000	158,236	134,200	146,900
Pressure Suppression Chamber Free Volume (ft ³)	110,000	117,245	108,250	109,900
Pressure Suppression Pool Water Volume (ft ³)	84,000	112,203	77,970	83,500
Submergence of Vent Pipe Below Pressure Pool Surface (ft)	4	3–5 in.	4	4
Design Temperature of Drywell (°F)	281	281	281	281
Design Temperature of Pressure Suppression Chamber (°F)	281	281	281	281
Downcomer Vent Pressure	6.21	6.21	6.21	6.21
Loss Factor				
Break Area Per Total Vent Area	0.0194	0.0194	0.0194	0.0194
Calculated Maximum Pressure After Blowdown Drywell (psig)	45	47	41	43
Pressure Suppression Chamber (psig)	26	28	26	26
Initial Pressure	35	50	45	35
Suppression Pool Temperature Rise (°F)				
Leakage Rate (% Free Volume/Day)	0.5	0.5	0.5	0.5
SECONDARY CONTAINMENT				
Type	Controlled Leakage, Elevated Release	Controlled Leakage, Elevated Release	Controlled Leakage, Elevated Release	Controlled Leakage, Elevated Release

Construction

Lower Levels and Foundation

Upper Levels

Roof

Internal Design Pressure
(psig)

Design Inleakage Rate (% of
free volume/day at 0.25
inches H₂O)

ELEVATED RELEASE POINT

Type

Construction

Height (above ground)

*Above Mean Sea Level

Reinforced
Concrete
Precast Panels
and Reinforced
Concrete
Steel
Sheeting

0.25

100

Stack
Steel

*400 feet

Reinforced
Concrete
Steel Super-
structure and
Siding
Pre-cast
Concrete

0.25

100

Stack
Reinforced
Concrete

310 feet

Reinforced
Concrete
Steel Super-
structure and
Siding
Built up on
steel decking

0.25

100

Stack
Reinforced
Concrete

238 feet

Reinforced
Concrete
Steel Super-
structure and
Siding
Steel
Sheeting

0.25

100

Stack
Reinforced
Concrete

385½ feet

0 2 3 3 9 0 7 2 9

1 4.0 SITE CHARACTERISTICS

2 4.1 Location⁽¹⁾

3 The Pilgrim Nuclear Power Station is located on the
4 western shore of Cape Cod Bay in the Town of Plymouth,
5 Plymouth County, Massachusetts. Figure 4-1 shows the sta-
6 tion site location with respect to major population centers.
7 The nearest urbanized area is Plymouth located approximately
8 four miles to the west as shown in Figure 4-2. Brockton
9 is the nearest densely populated center having more than
10 25,000 residents, with the nearest boundary about 23 miles
11 from the site.

12 The site contains approximately 517 acres owned in fee
13 by the applicant. The site boundaries are posted and a
14 security fence is erected around the immediate station
15 area. The nearest site boundary is approximately 1,600
16 feet from the reactor to the northwest. The nearest resi-
17 dences are approximately 2,000 feet from the reactor to
18 the northwest and southeast. The site plot plan is included
19 as Figure 4-3. Normal access to the site is by a two-lane
20 paved road which was built across the site to Route 3A,
21 leading to either Plymouth or nearby Route 3. Alternate
22 access from the site to Plymouth and Route 3 via Route 3A
23 is provided by Rocky Hill Road.

(2)

1 4.2 Population

2 The estimated resident population distribution for
3 the years 1965 and 2015 are presented in Figure 4-4. The
4 1965 resident population within a four-mile radius was esti-
5 mated as approximately 3,700 while the corresponding total
6 summer population (resident plus seasonal) was estimated as
7 approximately 8,800. The increase results from the influx
8 of seasonal residents during the summer months which is
9 typical of the coastal region of Massachusetts. Estimates
10 of the total resident and seasonal population distribution
11 for the years of 1965 and 2015 are presented in Figure 4-5.

12 Brockton is the nearest densely populated center hav-
13 ing more than 25,000 residents and is located about 25
14 miles to the west-northwest of the site. Other population
15 centers include New Bedford which is 27 miles to the south-
16 west, Boston which is 36 miles to the northwest, and Provi-
17 dence, Rhode Island, which is 44 miles west of the site.

(3)

18 4.3 Land Use

19 Since the site is located along the coast, approxi-
20 mately 60 percent of the area within a 50-mile radius is
21 open water. The area within 2 miles of the site is spar-
22 sely developed with the exception of the seasonal residences
23 along Priscilla Beach and White Horse Beach.

1 Approximately 85 percent of the land within a 10-mile
2 radius of the site is categorized as open space and vacant.
3 Approximately 7 percent of the land use is agricultural,
4 the major portion of which is cranberry bogs. The remain-
5 ing land is utilized for residential, commercial, or indus-
6 trial purposes. The adjacent waters of Cape Cod Bay are
7 used for commercial fishing and sport fishing. The prin-
8 cipal marine species harvested in the vicinity of the site
9 are lobsters and Irish moss.

10 Although little published data are available for pre-
11 dicting future land use, it appears that the increased land
12 use will be primarily residential as the resort areas and
13 suburbs experience growth.

14 4.4 Recreational Use

15 The applicant has made provisions for public access to
16 two areas on the station site, the station overlook area
17 and the shorefront, breakwater area as shown on Figure 4-3.

18 The station overlook area was opened in January, 1969
19 to permit site visitors to safely observe the generating
20 station area during construction phases and will be retained
21 after station operation commences.

1 The shorefront, breakwater area, will be opened to the
2 public following completion of the breakwater and access
3 facilities. This area will permit observation from the
4 shorefront and fishing from the shorefront and main break-
5 water.

6 The individual public use of the station overlook area
7 is expected to be infrequent and of short duration after
8 construction activities are completed. Parking space has
9 been provided in this area for up to fifty automobiles.
10 The time spent by an individual at the overlook during a
11 visit averages less than one half hour.

12 Public use of the shorefront breakwater area can only
13 be estimated at this time, but public use is expected to
14 be principally for fishing during fair weather conditions.
15 Parking space has been provided for about one hundred
16 automobiles in this area.

17 The applicant maintains control of access to both of
18 these areas by gates provided at the entrances to these
19 access roads from Rocky Hill Road. These gates will be
20 closed, locked and posted during those periods when access
21 is not permitted. The following restrictions on public
22 access are planned:

0 2 3 3 9
0 7 3 4
1 1) Access to the breakwater area will be terminated
2 when weather or ocean conditions make the area
3 hazardous.

4 2) Access to both the breakwater and overlook area
5 will be terminated from about December 1 to
6 March 1 because of the prevalence of hazardous
7 conditions and unpleasant weather.

8 3) Access to the breakwater and overlook areas will
9 be terminated whenever necessary to permit con-
10 tinued station operation within the radiation
11 exposure limitations established by regulatory
12 agencies.

13 4.5 Meteorology

14 The main features of the weather of eastern Massachu-
15 setts are variety and changeability since it lies in a
16 transition zone of westerly air currents which encompass
17 the southward movement of polar air masses and northward
18 movement of tropical air masses. The area is frequently
19 situated in or near the tracks of low pressure systems
20 during the Fall, Winter, and Spring seasons. As a result,
21 the region has no dry season, with Summer precipitation
22 coming in the form of showers or thunderstorms. The
23 coastline location of the site results in seasonal

0 7 3 5
1 temperatures which are less extreme than inland locations
2 due to on-shore winds in the Summer (seabreeze) and the
3 presence of relatively warm water in the Winter. The
4 storm cycle in this area consists generally of northeasters
5 in the Winter and Spring, thunderstorms in late Spring and
6 Summer. Hurricanes sometimes occur in the late Summer and
7 Fall. Tornado activity in eastern Massachusetts is un-
8 common. (4)

9 The station is designed with protection against storm
10 flooding from either Northeasters or hurricanes. Analysis
11 and model studies have shown that flooding due to the com-
12 bined effects of storm surge and wave action from the most
13 severe storms do not subject the reactor building to a
14 flooding condition. (5)

0 2 3 3 9
15 Meteorological data for the Pilgrim site has been
16 collected from the site meteorological tower. The tower
17 instrumentation has made measurements of wind speed, wind
18 direction, directional variability, temperature and the
19 occurrence or non-occurrence of precipitation. The most
20 frequent wind directions observed were from the SSW through
21 NNW which are all offshore directions. The site experienced
22 onshore winds 36% of the time, offshore winds 63.6% of the
23 time, and calm conditions the remaining 0.4% of the time.

1 The annual mean wind speed observed was about 16 mph.
2 Figure 4-6 presents the annual wind rose for the site
3 developed from observations at 300 feet above mean sea
4 level. The meteorological observations have been utilized
5 to evaluate the diffusion climatology at the Pilgrim Sta-
6 tion site and to evaluate atmospheric dispersion of radio-
7 active effluents from the station.

8 4.6 Hydrology ⁽⁶⁾ and Oceanography ⁽⁷⁾

9 The site is located in a small isolated drainage area
10 on the northeast side of the Pine Hills as shown on Figure
11 4-2. All surface drainage in the station site area is into
12 Cape Cod Bay. The ground water table generally follows the
13 site surface topography and as a result, moderately steep
14 ground water gradients are present with flow toward Cape
15 Cod Bay.

16 Ground water usage in the area is limited to a few
17 locations since most of the residents are supplied with
18 water from the Town of Plymouth. The closest Plymouth
19 water supply source is the Manomet Well located two and
20 three-quarters miles southeast of the site.

21 The site is located on Cape Cod Bay and water from
22 the Bay is utilized as cooling water within the station.
23 Within Cape Cod Bay the general ocean circulation pattern

1 is counterclockwise. A portion of a coastal current that
2 flows southward along the coasts of Maine and Massachusetts
3 enters Cape Cod Bay along the western shore of the bay,
4 circulates in a counterclockwise direction, leaves the bay
5 on the eastern side, swings eastward around the Cape and
6 then continues southward again. This general circulation
7 pattern coupled with tidal exchange and wind induced motion
8 of the waters within the bay are the principal natural
9 mechanisms which contribute to renewal and effective flush-
10 ing waters of Cape Cod Bay.

11 The dispersion of liquid effluents (that is, the move-
12 ment and mixing of the station discharge in and with the
13 receiving waters of Cape Cod Bay) occurs in three stages.
14 First, the excess momentum associated with the condenser
15 cooling water as it is discharged into the waters of Cape
16 Cod Bay will produce an entraining jet which will be
17 diluted by the mechanical entrainment required to reduce
18 the velocity of the jet to that of the surrounding waters.
19 Secondly, natural turbulent diffusion will further mix the
20 waters of the diluted condenser water plume as it moves
21 downcurrent with the natural flow. Finally, the large
22 scale circulation pattern coupled with tidal flushing,
23 will carry any conserved component out of the Bay.

1 In the case of the rejected heat, surface cooling will have
2 returned the temperatures to ambient long before the large-
3 scale circulation pattern will have carried the condenser
4 cooling water out of the bay.

5 The most important mechanism for the rapid dispersion
6 of the heat rejected from the station is the mechanical
7 entrainment required to reduce the initial momentum of the
8 discharge to that of the receiving waters of the Bay. This
9 phenomenon, momentum mixing, causes rapid reduction of the
10 temperature rise above ambient of the discharge and signi-
11 ficantly reduces the areas of the discharge isotherms.

12 Table 4-1 summarizes the area inside several surface tem-
13 perature isotherms. To indicate the importance of momentum
14 mixing, the last column of Table 4-1 gives the area inside
15 the surface isotherms which would be required if the heated
16 discharge were spread over the surface without mixing and
17 heat loss by surface cooling only.

18 Both theoretical and empirical studies of momentum
19 mixing in a jet discharge provide the basis for computing
20 the isotherms (temperature rise above ambient) in the vici-
21 nity of the site. Model studies of the thermal discharge
22 were conducted which showed three significant features:

TABLE 4-1
SURFACE TEMPERATURE ISOTHERMS
DIMENSIONS AND AREA

Temperature Rise Above Ambient (°F)	Length of Area (ft)	Width of Area (ft)	Predicted Area (Acres)	Comparable Area* Surface Cooling Only (Acres)
20°	430	110	1.1	248
10°	1100	250	6.3	725
5°	3400	900	70.3	1203
3°	5900	1300	176	1557
2°	8400	2200	425	1834

* This column is shown for purposes of comparison only, and represents the area within the designated isotherms which would be required if the temperature reduction resulted only from surface cooling.

0 2 3 3 9 0 7 4 0

- 1 1. Even when a current flow near the maximum observed
2 at the site is simulated in the model, and directed
3 downcoast, thus bending the plume of heated water
4 toward the intake structure, very effective two-
5 sided entrainment of cool diluting water occurs.
6 The circulation pattern set up by the entraining
7 jet actually brings new water at near ambient tem-
8 perature to the intake.
- 9 2. There is little significant difference in the
10 effectiveness of the jet entrainment between
11 low tide and high tide conditions. In both cases,
12 the heated plume appears confined primarily to the
13 upper 5 feet of the water column, and the areas
14 within given isotherms appear to be essentially
15 independent of tidal height.
- 16 3. There is little difference in the shape and size
17 of the heated plume for ambient current conditions
18 varying from 0.2 knot, which is near the average
19 observed off the plant site, to 0.6 knot, a speed
20 exceeded in the observations to date less than 1%
21 of the time.
- 22 The distributions of the surface temperature rise above
23 ambient resulting from operation of the station have been

0 2 3 3 9 0 7 4 1

1 predicted and are included as Figures 4-7 and 4-8. Two
2 cases were considered, the first with the offshore current
3 directed toward the ESE (Figure 4-7), and the second with
4 the offshore current directed toward the WNW (Figure 4-8).
5 The temperature distributions appear to be relatively
6 independent of tidal stage and of the strength of the
7 current in the range from 0.2 knot to 0.6 knot, at least
8 with respect to the general shape of the temperature iso-
9 therm and the area within a given isotherm. The strength
10 of the current will influence the rate of bending of the
11 plume from the initial offshore-directed jet discharge
12 to a plume extending downcurrent. Thus, for the weaker
13 current speeds, the heated discharge will extend somewhat
14 farther offshore than in the case of a strong current
15 parallel to shore.

16 Introduction of any radioactive effluents into the
17 cooling water discharge will be controlled so that, after
18 mixing, the concentration of radioactive materials in the
19 discharge will be only a fraction of the allowable concen-
20 trations specified in 10 CFR Part 20 for drinking water.
21 Radioactive materials discharged from the station will
22 experience further physical dilution as a result of
23 momentum mixing and natural dispersion in the receiving

1 waters of Cape Cod Bay. Such further dilution serves as
2 an additional safety factor which is not, however, used
3 in computing allowable concentrations for release of radio-
4 active materials.

5 4.7 Geology and Seismology (8)

6 The natural surface stratum in the station area con-
7 sists of approximately 20 feet of silty and clayey fine
8 sands with scattered boulders. The soils underlying the
9 upper stratum are moderately compact to compact with poorly
10 to well graded sands with some gravel and cobbles. Boulders
11 are scattered throughout the overburden soil and a discon-
12 tinuous thin layer of small boulders overlies bedrock.
13 Bedrock is approximately 30 to 90 feet below Mean Sea Level.
14 There are no known faults at or near the station site.

15 It is indicated from geologic and tectonic history
16 that the region is relatively quiescent. Low magnitude
17 seismic events can occur, but should be infrequent. The
18 horizontal ground acceleration at the site due to the
19 maximum expected earthquake is less than 8 percent of
20 gravity. For the design of safety-related structures and
21 equipment, however, a horizontal ground acceleration of
22 8 percent of gravity has been used with no increase in
23 code allowable stresses. Safety-related structures and

1 equipment have also been examined for a horizontal ground
2 acceleration of 15 percent of gravity to ascertain that
3 no failure can occur that would prevent safe shutdown of
4 the station.

References for Section 4.0

1. FSAR, Section 2.2.1
2. Environmental Report, Part C. I. b
3. Environmental Report, Part C. I. c
4. Environmental Report, Part C. I. d
5. FSAR, Section 2.4.4
6. FSAR, Section 2.4.1
7. FSAR, Section 2.4.3
8. FSAR, Section 2.5

0 2 3 3 9 0 7 4 4




FIGURE 4-1
STATION SITE LOCATION MAP
(0 to 50 Miles Radius)

REFERENCE:

THIS MAP WAS PREPARED FROM A PORTION OF USSS.
BOSTON, SECTIONAL AERONAUTICAL CHART, 1965.





FIGURE 4-2
STATION SITE
LOCATION MAP
(0 to 4 Miles Radius)

REFERENCE:
THIS MAP WAS PREPARED FROM THE FOLLOWING
USGS QUADRANGLES: MA0001, MASS., 1962
AND PLYMOUTH, MASS., 1962.


0 2 3 3 9 0 7 4 9



4-20

<p>PILGRIM NUCLEAR POWER STATION</p>
<p>Elevation 300 ft MSL—Wind Rose Annual Pilgrim Site FIGURE 4-6</p>


0 2 3 3 9 0 7 5 0



SURFACE CURRENT
0.2 TO 0.6 KNOTS

PILGRIM NUCLEAR POWER STATION
Cooling Water Dispersion FIGURE 4-7

0 2 3 3 9 0 7 5 1



PREDICTED TEMPERATURE RISE DISTRIBUTION
IN °F FOR CONDENSER COOLING WATER FLOW AT
720 GFS. TEMPERATURE RISE AT CONDENSER
OUTLET 28.7 °F. OFF-SHORE CURRENT TOWARDS
WNW. AT 0.2 TO 0.6 KNOTS BASED ON COMBINED
MODEL STUDIES AND ANALYTICAL TREATMENT
AUG. 1968.

PILGRIM NUCLEAR POWER STATION
Cooling Water Dispersion FIGURE 4-8

1 5.0 ENVIRONMENTAL QUALITY

2 5.1 General

3 Pilgrim Nuclear Power Station has been designed
4 and constructed with preservation of the environment
5 as a paramount consideration. Boston Edison Company
6 is making every effort to ensure that environmental
7 quality is not adversely affected due to the design,
8 construction, or operation of Pilgrim Station. These
9 efforts are reflected in the station design and the
10 special environmental studies and environmental moni-
11 toring programs which have been established.

12 5.2 Aesthetics and Land Use

13 In the design of Pilgrim Nuclear Power Station
14 special effort has been devoted to combining pleasing
15 appearance with functional design, recognizing the
16 area's natural aesthetics and integrating the facility's
17 structures into the existing environment. Station
18 structures and developments have been harmoniously
19 grouped within the total station concept of scale,
20 form, materials, and color with the intent of preventing
21 any detrimental effect on the natural beauty of the area.
22 Boston Edison Company has developed recreational facilities
23 on the site with the intent of enhancing the recreational

0 7 5 3
0 2 3 3 9
1 uses of the area. Provision has been made for public
2 access under the control of Boston Edison Company to
3 the station site to permit observation from the station
4 overlook and fishing from the shore front and breakwater.
5 Areas of the station site not utilized for the facility's
6 structures, developed for recreational purposes, or
7 landscaped for aesthetic effect, have been retained in
8 their natural state.⁽¹⁾ Refer to Sections 4.3 and 4.4 of
9 this summary.

10 5.3 Thermal and Chemical Discharges

11 Circulating seawater used to remove rejected heat
12 from the station's main condenser will be discharged through
13 the high velocity discharge canal to the waters of Cape
14 Cod Bay with a temperature increase of about 29°F. The
15 discharge canal has been designed to promote rapid
16 mixing of the heated water effluent with the colder
17 water of the bay. This is accomplished by discharging
18 the heated water on to the surface of the receiving body
19 of water with sufficient velocity to promote momentum
20 mixing, thereby, significantly reducing the total area
21 of thermal effect. (See Section 4.6 of this summary).
22 The station low velocity intake canal and the station
23 intake structure with its trash racks and traveling

0 7 5 4
0 7 3 3 9
0 2 3 3
1 screens, have been designed to prevent fish larger
2 than 3/8 inch from being drawn into the intake. (2)

3 Limited chemical additions from the station found
4 in the circulating water discharge will consist principally
5 of sodium sulfate, which is produced during regen-
6 eration of the condensate and makeup demineralizer
7 resins, and sodium hypochlorite, which is added to
8 the condenser cooling water to control biological
9 fouling in the intake bays, the circulating water
10 system piping, and the main condenser. These
11 chemical additions will be maintained below the
12 allowable concentrations specified in available
13 standards on water quality. No adverse effect on the
14 environment is predicted to occur as a result of the
15 station discharges. (3)

16 5.4 Radiological Discharges

17 The radioactive waste control systems designed
18 to minimize releases of radioactivity in station
19 effluents are described in Section 8.10 of this
20 summary. Boston Edison Company intends to make full
21 utilization of the station process equipment to maintain
22 offsite releases as low as practicable. The release
23 of radioactivity from PNPS* during normal operation will

*Pilgrim Nuclear Power Station.

1 be small fractions of the applicable limits of 10 CFR
2 Part 20, Standards For Protection Against Radiation.
3 Thus, the annual average exposure levels due to station
4 effluents will generally be only a fraction of the
5 exposure resulting from natural background radiation. (4)
6 The orderly, immediate shutdown of the station will be
7 required in any situation in which the radioactive
8 releases approach the maximum levels permitted by the
9 Technical Specifications, which are established to
10 maintain annual average exposure levels due to station
11 effluents at small fractions of the 10 CFR Part 20
12 limits.

13 5.5 Environmental Surveillance Program

14 A comprehensive environmental surveillance program
15 designed to monitor the atmospheric, terrestrial and
16 aquatic environments in the vicinity of the Pilgrim
17 Station has been in effect to establish a base line
18 from which any increase in radiation or temperature
19 in the environs during operation can be detected and
20 evaluated. The program includes the collection and
21 analysis of air, domestic water, seawater, marine life,
22 bottom sediment, milk, and commercially harvested crops.
23 This program is described more fully in Section 6.0

1 of this summary.

2 5.6 National Environmental Policy Act of 1969

3 The National Environmental Policy Act (NEPA)
4 requires, among other things, that all agencies of
5 the federal government include in every recommendation
6 or report on major federal action significantly
7 affecting the quality of the human environment, a
8 detailed statement by the responsible official
9 on the following:

- 10 "(i) the environmental impact of the proposed
11 action;
12 (ii) any adverse environmental effects which
13 cannot be avoided should the proposal be
14 implemented;
15 (iii) alternatives to the proposed action;
16 (iv) the relationship between local short-term
17 uses of man's environment and the main-
18 tenance and enhancement of long-term
19 productivity; and
20 (v) any irreversible and irretrievable commit-
21 ments of resources which would be involved
22 in the proposed action should it be
23 implemented."

0 2 3 3 9 0 7 5 7

1 Prior to making such a detailed statement, the
2 agency is required to consult with and obtain comments
3 of any federal state, or local agency which has
4 jurisdiction by law or special expertise with respect
5 to environmental impact.

6 In compliance with the policy of the Atomic Energy
7 Commission, the applicant has prepared and filed with
8 the Commission (on September 14, 1970), an environmental
9 report providing information on the above five points.
10 The Atomic Energy Commission has circulated it for
11 comments to federal and state agencies having juris-
12 diction or special expertise with respect to environ-
13 mental impact and, by publication of notice in the
14 Federal Register on October 16, 1970, has made the
15 report available to local agencies.

16 Comments on the Environmental Report were subse-
17 quently received by the AEC and transmitted to Boston
18 Edison Company from the following agencies: Department
19 of Defense, Department of Health, Education and Welfare;
20 Department of Agriculture; Federal Power Commission,
21 Department of the Interior; and the Fish and Wildlife
22 Service. Some of the comments indicated that further
23 clarifications and/or more detailed information would be

0 7 5 8
1 useful to the particular agency making the comment.
2 Boston Edison Company has since supplied additional
3 information to the AEC in all cases for which it was
4 requested. Specific recommendations made to the AEC
5 by the Department of Health, Education and Welfare
6 have either already been implemented or have been
7 considered in accordance with the resolution of
8 certain concerns raised by the Advisory Committee on
9 Reactor Safeguards and summarized in Section 10.0 of
10 this summary.

11 5.7 Water Quality Improvement Act of 1970

12 The Federal Water Quality Improvement Act of 1970
13 requires that a certification be obtained from the
14 Commonwealth of Massachusetts as to the reasonable assurance
15 that the Pilgrim Nuclear Power Station can be operated in
16 compliance with applicable water quality standards.

17 The Water Resources Commission, Division of Water
18 Pollution Control, of the Commonwealth of Massachusetts
19 has reviewed Boston Edison Company's application for
20 certification and, on April 23, 1971 did issue the
21 certification, subject to the conditions of the salt water
22 use permit.⁽⁵⁾ The certification⁽⁶⁾ states, in part:

23 "In accordance with the provisions of

1 Section 21 (b) (1) of the Federal Water
2 Quality Improvement Act of 1970 (Public
3 Law 91-224), this Division hereby
4 certifies that, based on information and
5 investigations, there is reasonable
6 assurance that the proposed activity will
7 be conducted in a manner which will not
8 violate applicable water quality standards
9 adopted by this Division under authority of
10 Section 27 (4) of Chapter 21 of the Massa-
11 chusetts General Laws, said water quality
12 standards as filed with the Secretary of
13 State of the Commonwealth on March 6, 1967."

References for Section 5.0

1. Environmental Report, p. B-8
2. Environmental Report, p. C-21
3. Environmental Report, p. C-42
4. FSAR, Amendment 16, Section 9.9 as amended in Amendment 30.
5. Environmental Report, Part D, Attachment 5.
6. The Commonwealth of Massachusetts, Water Resources
Commission, Division of Water Pollution Control,
Letter to Boston Edison Company, April 23, 1971.

0 2 3 3 9
0 7 6 0

1 6.0 ENVIRONMENTAL MONITORING PROGRAMS

2 6.1 Aquatic Ecological Surveillance⁽¹⁾

3 A six-year program of studies on the thermal discharge
4 from Pilgrim Station was begun in early 1967 and is scheduled
5 to be completed in January 1973. The objective of the pro-
6 gram is to assure that every reasonable precaution is taken
7 in the operation of the station relative to the environment.

8 The initial studies were used to establish the design
9 of the breakwaters, intake structure and discharge canal.
10 These studies were guided by consultants that are recognized
11 authorities in the fields of coastal engineering, physical
12 oceanography, cooling water dispersion and marine ecology
13 as well as by comments and suggestions from the Division of
14 Marine Fisheries of the Commonwealth of Massachusetts and the
15 Fish and Wildlife Service of the Department of the Interior.
16 Model studies at the Alden Research Laboratories and the
17 Massachusetts Institute of Technology provided the basis for
18 design of the intake and discharge structures and prediction
19 of thermal patterns.

20 The ongoing work consists of a four-year, before-and-
21 after field and laboratory ecology study of Cape Cod Bay in
22 the vicinity of the station. This work is being conducted
23 by the Massachusetts Division of Marine Fisheries under a

0 2 3 3 9 0 7 6 2
1 grant to the Commonwealth of Massachusetts by Boston Edison
2 Company. These studies will document, through field surveys,
3 any changes in the distribution of important marine species
4 that may be brought about by the operation of the station.
5 An administrative-technical committee coordinates the work,
6 reviews the results, and provides overall supervision of the
7 program. The committee includes representatives from the
8 Commonwealth of Massachusetts (Division of Marine Fisheries
9 and Division of Water Pollution Control), the Federal
10 Government (Bureau of Commercial Fisheries, Bureau of Sport
11 Fisheries and Wildlife, Water Quality Administration of
12 the Environmental Protection Agency, the University of
13 Massachusetts, and Boston Edison Company.

14 These studies are designed to provide quantitative data
15 on the floral and faunal components of the marine ecosystem
16 in the vicinity of the site. The studies being conducted
17 include finfish sampling, lobster investigations, plankton
18 studies, and a benthic inventory. This information, in
19 conjunction with the results of laboratory investigations
20 and hydrographic data collected at the site, will be used
21 as a basis for detecting and evaluating the nature and extent
22 of station influence upon marine resources. Boston Edison
23 Company will take steps to correct or mitigate any adverse

1 situation which comes to light as a result of these
2 studies.

3 6.2 Environs Radiation Surveillance⁽²⁾

4 A study of environmental radiation levels in all media
5 of interest was started during 1969 and 1970 to provide
6 baselines from which any increases in radiation due to
7 operation of the station may be detected and evaluated.
8 This radiation surveillance program will continue to be
9 conducted during start-up and operation of the Pilgrim Station
10 to evaluate the effect of station operation on the surrounding
11 environs and to provide a check on the effectiveness of the
12 various source controls.

13 During operation airborne particulates will be collected
14 on a routine basis at six locations within a 5-mile radius
15 of the station and at a control point approximately 23 miles
16 away. Gaseous iodine will be collected on special filters
17 used in conjunction with the air particulate filters. These
18 sample stations have been in operation since March and
19 September 1970.

20 Background gamma radiation levels have been measured
21 since June 1970 using thermoluminescent dosimeters (TLD) at
22 18 monitoring locations within a 10-mile radius of the
23 station. Background gamma radiation levels have also been

1 measured at a control point approximately 23 miles away.
2 Six of these monitoring points are presently located onsite,
3 and the remainder are distributed throughout Kingston and
4 Plymouth.

5 Samples of domestic water are collected monthly from the
6 Deep Water Pumping Station (Lout Pond Well and Little South
7 Pond) and Warner's Pond Pumping Station (Manomet Well) which
8 control the bulk of the town water supplies for most of the
9 residences in the area. An additional monthly grab sample
10 for control purposes is collected from the Weymouth Great
11 Pond Pumping Station, approximately 24 miles from the station.

12 Grab samples of sea water are being collected monthly
13 during the preoperational phase of the program from various
14 points offshore in the vicinity of the station. This
15 sampling began in August 1969. After the station becomes
16 operational, routine sampling of the intake and discharge
17 canals will be utilized to collect monthly composites from
18 these areas.

19 The Massachusetts Division of Marine Fisheries, as part
20 of its Ecology Study (see Section 6.1), has been supplying the
21 applicant since November 1969 with samples of fish and lobster
22 which are indigenous to the area. Edible marine species are
23 sampled principally during the commercial harvesting seasons

1 when the species are readily available. For example, lobster
2 samples are obtained between the months of May through October
3 and flounder samples are obtained during November or December.
4 Irish Moss samples are collected between the months of May
5 through September. Edible molluscs will be sampled during
6 the summer months if such organisms can be found within a
7 reasonable distance from the station. Samples of bottom
8 sediment are collected semiannually from an area encompassing
9 the discharge canal outfall.

10 There is presently only one dairy herd within the Town
11 of Plymouth. This herd is located approximately 3-1/2 miles
12 west of the station. Grab samples of milk have been collected
13 monthly since August 1969 from this point. Grab samples of
14 milk have also been obtained from a dairy in Hingham, Massa-
15 chusetts, as a control point.

16 Grab samples of cranberries and other crops having
17 commercial significance are collected annually during their
18 principal harvesting seasons from areas within a 5-mile
19 radius of the station. Samples of cranberries have been
20 collected and analyzed starting in the fall of 1968. The
21 collection and analysis of other selected crops was initiated
22 in the fall of 1969.

23 All the samples as well as the thermoluminescent

1 dosimeters (TLD) are being collected by Boston Edison Company
2 but are being analyzed or "read out" by an independent
3 laboratory.

4 References for Section 6.0

- 5 1. Environmental Report, Part C. III. a
6 2. FSAR, Section 2.6.

0 2 3 3 9 0 7 6 6

1 7.0 STATION SAFETY ANALYSIS

2 The safety objective of the design of Pilgrim
3 Nuclear Power Station is to minimize radiation exposures
4 to any persons either on or off the station site.

5 In order to meet this objective, the station design
6 and operation include the following:

7 (a) Positive control of all station processes.

8 (b) Inherent safety features and automatic devices
9 to prevent an accident. Tests are conducted periodically
10 to assure proper functioning of such devices.

11 (c) Multiple barriers to contain the radioactive
12 materials. The reactor core is conservatively designed
13 to operate with thermal parameters significantly below
14 those which could lead to fuel damage.

15 (d) Operating personnel thoroughly knowledgeable
16 in the operating characteristics of the station, and
17 trained to follow written procedures to minimize the
18 occurrence of operating errors.

19 In order to evaluate the ability of the station
20 systems to protect the public, a series of events--abnormal
21 operational transients and hypothetical accidents which
22 are postulated for design basis purposes--have been
23 analyzed to provide a safety evaluation of the Pilgrim

0 2 3 3 9 0 7 6 8

1 Nuclear Power Station. The extreme accidents postulated
2 are highly improbable because of the large degree of
3 quality control, design conservatism, and multiplicity of
4 safeguards which are built into the system. However,
5 for analysis purposes the accidents have been evaluated
6 to include the far end of the spectrum of challenges to
7 station design; thus they are referred to as the "design
8 basis accidents". The results of the analyses of these
9 accidents show that the effects of radioactivity released
10 to the environment in the unlikely event that an accident
11 should occur are well within the guidelines established
12 by the AEC (10 CFR Part 100).

13 Of the numerous malfunctions evaluated, the design
14 basis loss-of-coolant accident would be the most severe.
15 Core standby cooling systems are provided to limit fuel
16 clad damage for the entire spectrum of reactor coolant
17 system failures ranging from the smallest leak to the
18 complete severance of the largest reactor coolant pipe.
19 The core cooling systems* insure that core integrity
20 would be maintained ⁽¹⁾. Either the primary containment
21 sprays or suppression pool cooling system would maintain
22 the integrity of the primary containment which acts in
23 conjunction with the secondary containment to assure that

*The systems referred to here are described in Section 8.5
of this summary.

0 2 3 3 3 9 0 7 6 9

1 the public would be protected against potential
2 radiation hazards from the postulated accidents⁽²⁾.
3 Emergency electrical power is available on-site to
4 insure operation of these systems even if all external
5 sources of electric power to the station are assumed
6 to be unavailable at the time of the accident⁽³⁾.

7 Results of the safety analyses show that, even in
8 the event of a loss-of-coolant accident, no core melting
9 would occur⁽⁴⁾. However, in order to further demonstrate
10 that the operation of a nuclear power station at the
11 proposed site does not present a hazard to the general
12 public, a "maximum hypothetical accident" has been
13 analyzed assuming a release from the fuel of 100 percent
14 of the noble gases, 50 percent of the halogens and 1
15 percent of the solids in the fission product inventory.
16 Fifty percent of the released halogens would then plate
17 out within the containment. To have such a gross release
18 of fission products, one must postulate a multitude of
19 failures in the engineered safeguards systems⁽⁵⁾; therefore,
20 the accident is not regarded as credible. Even given
21 these assumptions, however, the low leakage rate of the
22 primary containment, the existence of the secondary
23 containment and the iodine removal by the standby gas

- 1 treatment system would limit the potential radiation
- 2 doses to below the AEC safety guideline values
- 3 (10 CFR Part 100)⁽⁶⁾.

References for Section 7.0

1. FSAR, Sections 4.5 and 17.6.3
2. FSAR, Sections 11.2, 11.3 and 17.6.3
3. FSAR, Section 7
4. FSAR, Section 4.5
5. FSAR, Section 17.9
6. FSAR, Section 17.9

0 2 3 3 9 0 7 7 0

1 8.0 DESCRIPTION OF PILGRIM NUCLEAR POWER STATION

2 8.1 Introduction

3 The Pilgrim Nuclear Power Station reactor is a single
4 cycle, forced circulation, boiling water reactor, substan-
5 tially similar, except as to the reactor rating and specific
6 engineered safeguard systems to several other stations which
7 have been previously licensed. (see Section 3.0) A simpli-
8 fied station system process flow diagram (Figure 8-1) is
9 attached.

10 The nuclear steam supply system will operate at power
11 levels up to 1998 MW thermal with a gross electrical out-
12 put of approximately 685 MWe and a net electrical output
13 of approximately 655 MWe. The station engineered safeguard
14 systems performance and design and the safety and accident
15 analyses have been examined on the basis of the 1998 MW
16 thermal power level operation.

17 The principal architectural and engineering criteria
18 for the design of this unit, including reactor design, con-
19 tainment systems, reactor auxiliary, station service and
20 plant cooling systems, control and instrumentation systems,
21 electric power systems, shielding and access control, and
22 fuel handling and storage systems are summarized in Section 1
23 of the Final Safety Analysis Report (FSAR). The principal

0 2 3 3 9 0 7 7 2
1 design features of Pilgrim Nuclear Power Station are
2 compared to other boiling water reactors in Section 3
3 of this document. Refer also to Table 8-1 of this Section
4 for a summary of the Station Engineered Safeguards and
5 other safety related systems and components provided for
6 Pilgrim Nuclear Power Station.

7 8.2 Containment Systems

8 8.2.1 General

9 The station employs two independent containment
10 systems. The primary containment system consists of a
11 drywell, a pressure suppression chamber, and inter-connecting
12 vent pipes, and provides the first containment barrier
13 around the reactor primary system. The reactor building,
14 together with the reactor building isolation and control
15 system, standby gas treatment system and the station main
16 stack, provides the second containment barrier. The con-
17 tainment systems for the reactor are basically the same as
18 those being provided for other BWR power stations.

19 These containment systems, as station structures,
20 are designed in accordance with the governing codes and
21 regulations, design criteria, and loading considerations
22 discussed in Section 12 of the Final Safety Analysis Report
23 (FSAR) and amplified in Appendix C of the FSAR. The

0 2 3 3 9
0 7 7 3
1 station structural design criteria differentiates between
2 two types of station structures, Class I structures and
3 Class II structures, and applies detailed design require-
4 ments to each classification. Class I includes those
5 structures, equipment and components whose failure or mal-
6 function might cause or increase the severity of an accident
7 which might endanger the public health and safety. This
8 category includes those structures, required for safe shut-
9 down and isolation of the reactor. Class II includes those
10 structures, equipment, and components which are important
11 to reactor operation, but are not essential for preventing
12 an accident which would endanger the public health and
13 safety and are not essential for the mitigation of the con-
14 sequences of these accidents.⁽¹⁾

15 8.2.2 Primary Containment System⁽²⁾

16 The primary containment system houses the reactor
17 vessel, the reactor coolant recirculation system and other
18 branch connections of the reactor coolant system. The pri-
19 mary containment is a pressure suppression chamber which
20 stores a large volume of water, a connecting vent system
21 between the drywell and water pool, isolation valves,
22 vacuum relief system, containment cooling systems, and
23 other service equipment. The drywell is a steel pressure

1 vessel located below and encircling the drywell and which
2 has approximately 40% of its volume filled with water.

3 The primary containment system is designed to with-
4 stand the forces from any size breach of the nuclear
5 system primary barrier up to and including an instantan-
6 eous circumferential break of the reactor recirculation
7 piping and provides a hold-up time for decay of any radio-
8 active material released. The water stored within the
9 torus of the primary containment system is sufficient to
10 condense the steam released as a result of a breach in the
11 nuclear system primary barrier and to supply water to the
12 core standby cooling systems. The vent system from the
13 drywell terminates below the water level in the pressure
14 suppression chamber, so that in the event of a pipe failure
15 in the drywell, the released steam passes directly to the
16 suppression pool water where it is condensed. This trans-
17 fer of energy to the water pool rapidly reduces the residual
18 pressure in the drywell and substantially reduces the poten-
19 tial for subsequent leakage from the primary containment.

Provisions are made for the removal of heat from within the primary containment to maintain the integrity of the primary containment system following a loss-of-coolant accident. Capability is provided in the primary

1 containment structural design to withstand the forces
2 exerted in the event that it is necessary to flood the
3 primary containment vessel (drywell and suppression
4 chamber) to a level which would flood the reactor core.

5 Isolation valves are provided on lines penetrating
6 the drywell and the suppression chamber to provide integ-
7 rity of the containment when required. These valves are
8 actuated automatically by signals received from the primary
9 containment isolation system. The valves of the reactor
10 auxiliary and station cooling systems are left open or are
11 closed, depending upon the functional requirements of the
12 system, without reducing the integrity of the primary
13 containment system.

14 Provisions are made for initial preoperational and
15 subsequent periodic leak rate testing of the primary con-
16 tainment system. The primary containment system will be
17 tested on a periodic basis to verify that, under design
18 basis accident conditions, the leak rate of the system
19 would not be in excess of the maximum allowable leak rate
20 at the calculated peak accident pressure. The tests will
21 be performed in accordance with the conditions and evaluated
22 against the limits specified in the Technical Specifications
23 for Pilgrim Nuclear Power Station issued by the Commission.

1 Based upon the system design and the specified
2 allowable leak rate, the effectiveness of the primary
3 containment system (in conjunction with other engineered
4 safeguards and nuclear safety systems) has been evaluated
5 in Section 14 of the FSAR; and it has been concluded that
6 the system would be effective in reducing the consequences
7 of a postulated design basis loss-of-coolant accident to
8 below the guideline values of 10 CFR Part 100.

9 8.2.3 Secondary Containment System ⁽³⁾

10 The safety objective of the secondary containment
11 system, in conjunction with other engineered safeguards and
12 nuclear safety systems, is to limit the release to the
13 environs of radioactive materials so that off-site doses
14 from a postulated design basis accident will be below the
15 guideline values of 10 CFR Part 100.

16 The secondary containment system consists of four
17 subsystems. These subsystems are the reactor building,
18 the reactor building isolation and control system, the
19 standby gas treatment system and the main stack. The
20 secondary containment system surrounds the primary contain-
21 ment system and is designed to provide secondary contain-
22 ment for the postulated loss-of-coolant accident. The
23 secondary containment system also surrounds the refueling

0 2 3 3 9 0 7 7 8

1 The reactor building is a massive concrete
2 and steel Class I structure which completely encloses
3 the reactor and its pressure suppression primary
4 containment system. The reactor building houses the
5 refueling and reactor servicing equipment, new and spent
6 fuel storage facilities and other reactor auxiliary and
7 service equipment. Also housed within the reactor building
8 are the core standby cooling systems, reactor clean-up
9 demineralizer system, standby liquid control system,
10 control rod drive system, reactor protection system and
11 electrical equipment components.

12 The effectiveness of the secondary containment
13 system, in conjunction with other engineered safeguards
14 and nuclear safety systems, in reducing the consequences
15 of postulated design basis accidents to below the
16 guideline values in 10 CFR Part 100 has been evaluated
17 in Section 14 of the FSAR.

18 8.3 Reactor Description (4)

19 The reactor is a single-cycle, forced circulation,
20 boiling water reactor producing steam for direct use in
21 the steam turbine. The fuel consists of uranium dioxide
22 pellets contained in sealed Zircaloy-2 clad fuel rods.
23 Water serves as both the moderator and coolant. Figure 8-2

0 2 3 3 9 0 7 7 9

1 is an isometric drawing of the reactor vessel.

2 Water enters the bottom of the reactor core and
3 flows upward through the fuel assemblies where boiling
4 produces steam. The steam-water mixture is separated by
5 steam separators and dryers located within the reactor
6 primary vessel. The separated water mixes with the
7 incoming feedwater and is returned to the reactor core
8 inlet through jet pumps located within the reactor
9 primary vessel. The steam passes through the main steam
10 lines to the turbine.

11 The reactor vessel has an inside diameter
12 of approximately 18 feet-8 inches and an inside height
13 between heads of approximately 64 feet-8 inches. The
14 main connections to the reactor vessel include
15 the main steam lines, the reactor coolant recirculation
16 pump suction lines and jet pump reactor coolant recir-
17 culation system lines, the reactor feedwater system lines,
18 the reactor core spray cooling system lines and the control
19 rod drive housings. Other connections are provided for
20 the standby liquid control system, the control rod drive
21 system supply lines and the instrumentation systems.

22 The bottom-entry cruciform control rods are moved
23 vertically within the reactor core by individual control

0 2 3 3 9 .
0 7 8 0

1 rod drives. The drives are of the hydraulically-operated,
2 locking-piston type. The control rod drive hydraulic
3 system is designed to allow control rod withdrawal or
4 insertion at a limited rate, one control rod at a time,
5 for reactor power level control and neutron flux shaping
6 during reactor operation. Stored energy available from
7 gas-charged accumulators and from reactor pressure
8 provides hydraulic power for rapid insertion of all
9 control rods simultaneously for reactor shutdown.
10 Each drive has its own separate control and scram devices.
11 The control rod drive housings are provided with a support
12 structure designed to prevent significant movement of the
13 control rod drive housing in the unlikely event of drive
14 housing structural failure.
15 In addition, there is provided a standby liquid control
16 system containing a neutron-absorbing boron solution which
17 is capable of shutting down the reactor and maintaining it
18 in a shutdown condition. This system is an independent
19 system that would be used to shut down the reactor in the
20 unlikely event that shutdown cannot be accomplished with
21 the control rod system alone.
22 Two reactor coolant recirculation system loops with
23 a connecting equalizer line are provided, each having a

0 2 3 3 9 0 7 8 1

1 variable speed centrifugal pump with mechanical seals,
2 motor operated gate valves for isolation of the pumps,
3 and instrumentation for recirculation flow measurement.
4 The motive force for the jet pumps is supplied by the
5 water discharged from the two reactor coolant recirculation
6 pumps. Variable frequency motor-generator sets power the
7 recirculation pump motors. Changing the pump speed
8 changes the recirculation flow rate, which changes reactor
9 power level. Two important features included in the
10 design are as follows: (a) the internal reactor core
11 arrangement provides the function of a second vessel
12 around the core formed by the core shroud and the jet pump
13 diffuser system pipes, and (b) the recirculation water
14 provides the motive force for the jet pumps located
15 inside the reactor primary vessel. The features noted in
16 (a) together with internal design features of the vessel
17 and core, enable the core to be reflooded with water in the
18 event of a loss-of-coolant accident.

19 The reactor core includes the fuel assemblies,
20 control rods and temporary control curtains. The mechanical,
21 thermalhydraulic and nuclear design of this reactor is
22 similar to other boiling water reactors as discussed in
23 Section 3.0.

1 chamber pool. Steam to drive the turbine comes from
2 a main steam line and exhausts to the suppression chamber
3 pool.

4 The station has removable insulation in specified
5 areas which permit direct inservice inspection of the
6 exterior of the reactor vessel and other primary system
7 components. This permits inspection of selected
8 nozzle-to-shell welds, inspection of reactor vessel studs,
9 nuts and bushings, selected sampling of high cyclic stress
10 vessel welds, and selected sampling of coolant system
11 piping, pumps, valve supports, and hangers.

12 8.4 Station Instrumentation and Control Systems

13 8.4.1 Reactor Control

14 Reactor power is controlled by movement of
15 control rods and by regulation of the reactor coolant
16 recirculation system flow rate. Control rods are used to
17 bring the reactor through the full range of power (from
18 shutdown to power operation) and to shape the reactor
19 core power distribution. Changing recirculation flow
20 rate provides a second and more convenient operational
21 method for controlling reactor power level. Adjustments
22 in reactor power level, and load following, are accom-
23 plished with recirculation flow control. Procedural

0 7 8 4
0 2 3 3 9
1 controls and protective devices are used so that thermal
2 performance does not exceed established limits.⁽⁵⁾

3 Reactor pressure is automatically controlled by
4 the initial pressure regulator (IPR), which varies
5 steam flow to the turbine to maintain constant pressure
6 in the reactor. As a result, the turbine power output
7 follows the reactor power output.⁽⁶⁾

8 The turbine-bypass system, having a capacity of
9 approximately 25 percent rated turbine steam flow, is
10 supplied with the turbine to regulate steam pressure
11 during startup and shutdown and to restrict overpressure
12 transients resulting from sudden turbine control valve
13 or stop valve closure. The turbine bypass system valves
14 are operated on an over-pressure signal from the IPR.
15 Rapid partial load rejection (approximately 25 percent
16 of rated turbine steam flow) can be accommodated by the
17 turbine bypass system without shutting down the reactor.⁽⁷⁾

18 8.4.2 Protection Systems

19 Protection systems are provided which automatically
20 initiate appropriate action whenever the station conditions
21 monitored by the systems approach pre-established limits.

22 These protection systems act to shut down the reactor,
23 close primary containment isolation valves, and initiate

1 secondary containment isolation, the operation of the
2 standby gas treatment system, the diesel generators and
3 the core standby cooling systems as required.

4 8.4.2.1 Reactor Protection System

5 The reactor protection system automatically
6 initiates reactor scram* upon appropriate inputs from
7 system sensors which monitor station conditions in order
8 to provide timely protection against the onset and
9 consequences of conditions that could threaten the
10 integrity of the fuel barrier and the nuclear system
11 process barrier. The reactor protection system limits
12 the uncontrolled release of radioactive material from the
13 fuel and nuclear system process barrier by terminating
14 excessive temperature and pressure increases through
15 the initiation of an automatic scram. The reactor
16 protection system is designed so that no single failure
17 will prevent it from accomplishing its protective function
18 (scram) or cause spurious tripping of the reactor at
19 power. The reactor protection system is designed to
20 initiate scram on loss of power to the system. Components
21 of the reactor protection system can be removed from
22 service for testing or maintenance without interrupting
23 station operations and without negating the ability of

*Scram - immediate shut-down of the reactor.

1 the reactor protection system to perform its protective
2 function upon receipt of appropriate signals. (8)

3 8.4.2.2 Primary Containment and Reactor Vessel Isolation
4 Control System

5 The primary containment and reactor vessel
6 isolation control system initiates automatic isolation
7 of appropriate pipelines which penetrate the primary
8 containment whenever monitored variables exceed pre-
9 selected operational limits in order to provide timely
10 protection against the onset and consequences of
11 accidents involving the gross release of radioactive
12 materials from the fuel and the nuclear system process
13 barrier. A gross failure of the fuel barrier would allow
14 the escape of fission products from the fuel. A gross
15 failure of the nuclear system process barrier could
16 allow the escape of gross amounts of reactor coolant.
17 The loss of coolant could lead to overheating and failure
18 of the fuel. For a gross failure of the fuel, the primary
19 containment and reactor vessel isolation control system
20 initiates isolation of the reactor vessel to contain
21 released fission products. For a gross breach in the
22 nuclear system process barrier outside the primary con-
23 tainment, the isolation control system acts to interpose

0 7 8 8
0 3 3 9
0 2 3 3
0 2 3 3
1 cooled under abnormal or accident conditions. The
2 cooling provided by the systems restricts the release
3 of radioactive materials from the fuel by limiting
4 the extent of fuel damage following situations in
5 which reactor coolant is lost from the nuclear system.
6 Controls and instrumentation are designed to automatically
7 initiate and control with precision, reliability and time-
8 liness the core standby cooling systems to allow removal
9 of heat from the reactor core in time to limit fuel clad
10 damage, so that fuel deformation would not limit effective
11 cooling of the core.

12 The instrumentation and controls for the core
13 standby cooling systems are designed so that no single
14 failure, maintenance, calibration, or test operation
15 can prevent the integrated operations of the core standby
16 cooling systems from providing adequate core cooling.
17 The power supplies for the controls and instrumentation
18 for the core standby cooling systems have been chosen
19 so that core cooling can be accomplished concurrently
20 with a loss of off-site ac power. (10)

21 8.4.2.4 Reactor Building Isolation and Control System

22 The reactor building isolation and control system
23 automatically initiates secondary containment isolation

0 2 3 3 9 0 7 3 9

1 and standby gas treatment system operation upon receipt
2 of appropriate signals in order to minimize the potential
3 for ground level release of airborne radioactive materials,
4 and to provide for controlled filtered elevated release
5 of the reactor building atmosphere under postulated
6 design basis accident conditions. The system is designed
7 so that no single failure can prevent it from accomplishing
8 its protective functions. The system is designed so that
9 it is fully testable during station power operation. (11)

10 8.4.2.5 Diesel Generator Instrumentation and Control

11 System

12 The diesel generators provide standby ac power
13 to the core standby cooling systems and primary containment
14 isolation system. The diesel generators are initiated by
15 appropriate signals which also initiate the core standby
16 cooling systems or by signals from the ac auxiliary power
17 system. The diesel generator initiation circuitry may
18 be tested independently of the station operation. The
19 diesel generator load carrying capability may be demon-
20 strated during station operation by synchronization with
21 the auxiliary power system. (12)

22 8.4.3 Reactor Nuclear Instrumentation

23 Reactor power (neutron level) is monitored from

0 2 3 3 9
0 7 9 0

1 the source (start-up) range up through the power
2 (operating) range by suitable neutron monitoring channels.
3 All detectors for neutron monitoring are placed inside
4 the reactor vessel. This location has been
5 selected to provide maximum sensitivity to control rod
6 movement during the startup period and to provide
7 accurate monitoring in intermediate and power ranges.

8 The neutron monitoring system provides information
9 for the efficient, expedient operation and control of the
10 reactor. It consists of six major subsystems whose
11 particular functions encompass the range of neutron
12 flux from startup to power operation and include operator
13 aids and calibration information. This system of incore
14 neutron detectors and out-of-core electronics monitoring
15 equipment provides neutron flux measurements that can be
16 correlated to thermal power level for the entire range
17 of flux conditions that may exist in the core.

18 8.5 Core Standby Cooling Systems and Related Auxiliary

19 Cooling Water Systems

20 8.5.1 General

21 Several automatically initiated, reliable,
22 redundant, diverse core standby cooling systems are
23 provided to insure adequate cooling of the reactor core

0 2 3 3 3 9 0 7 9 1

1 under abnormal operational transients and postulated
2 accident conditions. The integrated operation of
3 these systems is designed to provide for continuity
4 of core cooling over the complete range of postulated
5 break sizes in the nuclear system process barrier, removing
6 the residual heat from the reactor core, thereby limiting
7 peak fuel clad temperatures and limiting fission product
8 release from the fuel.

9 The core standby cooling systems for Pilgrim
10 Nuclear Power Station have been recently reevaluated in
11 accordance with the USAEC's INTERIM ACCEPTANCE CRITERIA
12 FOR EMERGENCY CORE COOLING SYSTEMS FOR LIGHT-WATER
13 POWER REACTORS, June 19, 1971. The results of this
14 analysis show that the PNPS core standby cooling systems,
15 when evaluated in strict accordance with Appendix A,
16 Part 2 of the interim policy statement, do meet the
17 criteria of Section IV, A; i.e.,

- 18 1. The calculated maximum fuel element cladding
19 temperature does not exceed 2,300°F.
- 20 2. The amount of fuel element cladding that reacts
21 chemically with water or steam does not exceed 1% of the
22 total amount of cladding in the reactor.
- 23 3. The clad temperature transient is terminated at

1 a time when the core geometry is amenable to cooling.

2 4. The core temperature is reduced and decay heat
3 can be removed for an extended period of time.

4 The systems' power supplies have been chosen to
5 allow initiation and operation regardless of the avail-
6 ability of offsite a-c power. The design of the systems
7 allows testing to verify the operability of all active
8 components during normal operation of the nuclear system.

9 The core standby cooling systems provided on
10 Pilgrim Nuclear Power Station are functionally equivalent
11 to those included in other operating BWR's. A short
12 description of the systems is included in the following
13 paragraphs.

14 8.5.2 Core Spray System⁽¹⁴⁾

15 Two independent loops are provided as a part of
16 the core spray system to circulate water from the pressure
17 suppression chamber pool to the reactor primary vessel.
18 Each loop consists of a core spray pump, a sparger ring,
19 a spray nozzle, and the necessary piping, valves, and
20 instrumentation. The core spray system provides protection
21 of the core for the postulated case of a large break in
22 the nuclear system when the feedwater system, control
23 rod drive water pumps, reactor core isolation cooling

1 (RCIC) system and the high pressure coolant injection
2 (HPCI) system are unable to maintain reactor vessel
3 water level.

4 The protection provided by the core spray system
5 also extends to a small break condition in which the
6 feedwater system, control rod drive water pumps, RCIC,
7 and HPCI are all unable to maintain the reactor vessel
8 water level, and the automatic depressurization system
9 has operated to lower the reactor vessel pressure so
10 that the low pressure coolant injection, (LPCI), system
11 and the core spray system can provide core cooling. The
12 water from this system is distributed directly on the
13 reactor core by spray headers mounted inside the plenum
14 above the reactor core.

15 8.5.3 High Pressure Coolant Injection (HPCI) System

16 The HPCI is provided to assure that the reactor
17 core is adequately cooled to limit fuel clad temperature
18 in the event of a small break in the nuclear system and
19 loss of coolant which does not result in rapid de-
20 pressurization of the reactor vessel. The HPCI permits
21 the reactor to be shut down while maintaining sufficient
22 reactor vessel water inventory until the reactor vessel is
23 depressurized. The HPCI continues to operate until

0 2 3 3 9
0 7 9 4

1 reactor vessel pressure is below the pressure at
2 which LPCI operation or core spray system operation
3 maintain core cooling. The system is designed to
4 perform its function without reliance on electrical
5 power supplies other than the station battery system.
6 The system consists of a steam turbine driven makeup
7 pump which supplies water from either the condensate
8 storage tank or the pressure suppression pool. Steam
9 to drive the turbine comes from a main steam line and
10 exhausts to the suppression chamber pool.

11 8.5.4 Pressure-Relief System/Automatic Depressurization⁽¹⁶⁾

12 System

13 The primary system relief and safety valves
14 open on a reactor vessel overpressure to protect the
15 nuclear system process barrier. In addition, the relief
16 valves will function as an automatic depressurizer in
17 case the capability of the feedwater system, the control
18 rod drive water pumps, RCIC , and HPCI is not sufficient
19 to maintain the reactor water level. The automatic
20 depressurization system functions to reduce the reactor
21 pressure so that flow from LPCI and the core spray
22 system enters the reactor vessel in time to cool the
23 core and limit fuel clad temperature. In order to

0 2 3 3 9 0 7 9 5
1 accomplish this function the valves open, when signalled
2 to do so, following a loss-of-coolant accident, and
3 remain open below a preset closing pressure.

4 8.5.5 Reactor Core Residual Heat Removal System (RHR) (17)

5 The residual heat removal system is made up of
6 the following three sub-systems:

- 7 A. A low pressure coolant injection system (LPCI) is
8 provided as an independent, redundant means of
9 removing stored and decay heat from the reactor core
10 following a loss-of-coolant accident. The system
11 is designed to restore the water level in the
12 reactor vessel and to maintain this water
13 level by making up any leakage from the core
14 shroud.
- 15 B. A Containment Cooling System is provided:
- 16 (1) To limit the suppression chamber pool water temper-
17 ature following the design basis loss-of-coolant
18 accident to 170°F. Removal of this heat load is
19 accomplished by circulating the pool water through
20 the RHR heat exchangers via the containment
21 cooling system operation.
- 22 (2) To increase the containment capability for metal-
23 water reaction by providing the capability to

1 remove energy from the containment by means
2 of spray cooling.

3 C. A reactor shutdown cooling system is provided to
4 remove decay and sensible heat from the reactor
5 core during normal shutdown operation. A head
6 spray cooling system is provided to condense the
7 steam dome in the reactor vessel during normal
8 shutdown operation.

9 The major equipment of the RHR consists of
10 two heat exchangers and four main system pumps. The
11 RHR heat exchangers are cooled by the reactor building
12 closed cooling water system which is, in turn, cooled
13 by the station salt service water system. The main
14 system pumps are sized on the basis of the flow
15 required during the low pressure coolant injection
16 (LPCI) mode of operation, which is the mode requiring
17 maximum system flow rate. The heat exchangers are
18 sized on the basis of their required duty for the
19 shutdown cooling function, which is the mode of RHR
20 operation requiring the maximum heat exchanger surface
21 area.

22 The RHR has the capability of being intertied
23 with the fuel pool cooling system. This capability

0 2 3 3 9 0 7 9 7
1 increases the spent fuel pool cooling capacity in the
2 event that such additional capacity is necessitated by
3 removal from the core of an unusually large number of
4 fuel elements.

5 8.5.6 Reactor Building Closed Cooling Water System⁽¹⁸⁾

6 The reactor building closed cooling water system
7 is designed to provide the required cooling to the
8 equipment located in the reactor building during normal
9 planned operations, to provide cooling to the core
10 standby cooling systems and their related auxiliaries
11 during transient and accident conditions and to provide
12 a heat sink for the RHR heat exchangers. The systems
13 consists of two independent loops with three pumps per
14 loop, either loop with two pumps operating being capable
15 of providing the required heat transfer for the design
16 basis accident conditions. The system power supplies
17 have been chosen to allow initiation and operation
18 regardless of the availability of offsite a-c power.
19 The operability of the major system components and
20 instrumentation can be verified during normal station
21 power operation. The system is designed so that no
22 single failure can prevent it from accomplishing
23 its safety function of providing cooling to the CSCS*

*Core Standby Cooling System

0 2 3 3 9 0 7 9 8
1 components when required.

2 8.5.7 Salt Service Water System⁽¹⁹⁾

3 The salt service water system provides cooling
4 to the reactor building closed cooling water system and
5 the turbine building cooling water system during normal
6 planned operation and under transient and postulated
7 accident conditions. The system consists of two loops,
8 two pumps per loop, with a common spare pump which can
9 be valved into either loop. The system can be initiated
10 and operated regardless of the availability of offsite
11 a-c power.

12 8.6 Steam Power Conversion Systems⁽²⁰⁾

13 The power conversion systems are designed to produce
14 electrical energy through conversion of a portion of
15 the thermal energy contained in the steam supplied from
16 the reactor, condense the turbine exhaust steam into
17 water, and return the water to the reactor as heated
18 feedwater, with a major portion of its gaseous, dissolved
19 and particulate impurities removed.

20 The major components of the power conversion
21 system are: turbine-generator, main condenser,
22 condensate pumps, air ejector, turbine gland seal system,
23 turbine bypass system, condensate demineralizers, reactor

1 feed pumps, feedwater heaters, and condensate storage
2 system. The heat rejected to the main condenser is
3 removed by the circulating water system.

4 The saturated steam produced by the boiling water
5 reactor is passed through the high pressure turbine
6 where the steam is expanded and then exhausted through
7 the moisture separators. Moisture is removed in the
8 moisture separators, and the steam is then passed through
9 the low pressure turbines where the steam is again expanded.

10 From the low pressure turbines the steam is exhausted
11 into the condenser where the steam is condensed and
12 deaerated, and then returned to the cycle as condensate.

13 A small part of the main steam supply is continuously
14 used by the steam jet air ejectors and by the plant
15 heating system. The condensate pumps, taking suction
16 from the condenser hotwell, deliver the condensate through
17 the air ejector condensers, turbine gland seal condenser,
18 condensate demineralizer and three stages of low
19 pressure feedwater heaters to the reactor feed pumps.

20 The reactor feed pumps supply feedwater through two
21 stages of high pressure feedwater heaters to the reactor.

22 Steam for heating the feedwater in the heating cycle
23 is supplied from turbine extractions. The feedwater

0 0 3 0 0 9 0 2 3 0 0
1 heaters also provide the means of handling the moisture
2 separated from the steam in the turbine and in the
3 moisture separators. Normally, the turbine utilizes
4 all the steam being generated by the reactor; however,
5 an automatic pressure-controlled steam bypass system
6 is provided to discharge excess steam up to 25% of the
7 design flow directly to the condenser.

8 8.7 Electrical Power Systems (21)

9 The station electrical power systems provide a
10 diversity of dependable power sources which are physically
11 separated. The station electrical power systems consist
12 of unit and preferred a-c power systems, the secondary
13 a-c power system, auxiliary power distribution system,
14 standby a-c power system, 125/250 volt d-c power system,
15 24 volt d-c power system and the 120 volt a-c power
16 system.

17 The unit a-c power source provides a-c power to
18 all station auxiliaries and is the normal station a-c
19 power source when the main generator is operating. The
20 station preferred (off-site) a-c power source can
21 provide a-c power to all station auxiliaries and is
22 in use when the unit a-c power source is unavailable.

23 The secondary (off-site) a-c power source can

1 provide a-c power to essential station auxiliaries.

2 It is used to supply essential station auxiliary loads
3 only when the reactor is shut down and there is an
4 extended outage of the preferred a-c power source.

5 The station auxiliary power distribution system
6 distributes all a-c power necessary for startup,
7 operation, or shutdown of station loads. All portions
8 of this distribution system receive a-c power from the
9 unit a-c power source or the preferred a-c power source.

10 The emergency service portions of this distribution system
11 also can receive a-c power from the standby a-c power
12 source or the secondary a-c power source.

13 The standby a-c power source provides two independent
14 diesel generators as the on-site sources of a-c power
15 to the emergency service portions of the station auxiliary
16 power distribution system. Each on-site source is
17 automatically initiated upon loss of unit and preferred
18 a-c power sources or upon signals which initiate the
19 core standby cooling systems. Each diesel generator
20 unit is capable of providing a-c power to safely shut
21 down the reactor, maintain the safe shutdown condition,
22 and operate all auxiliaries necessary for station safety.

23 The station 125/250 volt d-c power systems provide

1 independent on-site sources of d-c power for start-up,
2 operation, shutdown and all loads essential to station
3 safety.

4 The station 24 volt d-c power system, provides a
5 reliable on-site source of power to some radiation
6 monitoring instrumentation.

7 The station 120 volt a-c power system provides a
8 versatile distribution system to supply a-c power to
9 the station computer, instruments and control devices
10 requiring uninterruptable power, and conventional in-
11 strumentation and monitoring systems.

12 The electrical output of Pilgrim Station is fed
13 through the station's switchyard via two 345 kV trans-
14 mission lines to New England Gas and Electric Association's
15 Canal Station and Montaup Electric Company's Bridgewater
16 Station. The Canal and Bridgewater Stations are connected
17 to the New England Power Grid and the Boston Edison system
18 by two 345 kV lines. When the station is not operating,
19 off-site auxiliary electrical power is available from
20 the New England Power Grid through either of the two
21 345 kV lines or one 23 kV line which provides a
22 secondary a-c power source to shutdown the station.

1 8.8 Radiation Monitoring Systems (22)

2 The station radiation monitoring systems include
3 process and area radiation monitoring systems. The
4 following are the significant process radiation monitoring
5 systems:

6 1) The main steam line radiation monitoring system
7 monitors for the gross release of fission products from
8 the fuel and, upon indication of such failure, initiates
9 appropriate action to limit fuel damage and contain the
10 released fission products.

11 2) The air ejector offgas radiation monitoring
12 system indicates when limits on the release of airborne
13 radioactive material to the environment are approached
14 and effects appropriate control of the offgas so that
15 short term limits are not exceeded during normal station
16 operation.

17 Abnormally high radiation levels will cause a
18 time delay switch to be activated which, in turn, closes
19 drain valves and an outlet valve on the air ejector offgas
20 line. A time delay of not greater than 15 minutes is
21 provided to allow the operator to reduce power or correct
22 for a spurious trip condition before the outlet valve
23 is closed.

1 3) The main stack radiation monitoring system
2 indicates and records the rate of radioactive material
3 release from the main stack. Two alarms are provided
4 on this system based on the technical specifications
5 on average annual release limit and short term maximum
6 release limit.

7 4) The refueling ventilation exhaust monitoring
8 system provides prompt indication of a gross release of
9 fission products from the spent fuel in the refueling
10 floor area and provides appropriate signals to the
11 reactor building isolation and control system to effect
12 secondary containment isolation and standby gas treatment
13 system operation prior to the transport of fission
14 products from the refueling area to the normal building
15 exhaust location.

16 5) The building exhaust vent radiation monitoring
17 system records the rate of radioactive material release
18 from the building vent to the environs and alarms
19 whenever abnormal amounts of radioactive material exist
20 in the building vent effluent.

21 6) The radwaste liquid discharge radiation moni-
22 toring system records the radioactivity level of material
23 released through the liquid radwaste discharge header

1 during planned operations. Whenever abnormal amounts
2 of radioactive material are detected in the liquid
3 radwaste discharge header, an upscale trip alarms in
4 the main control room, trips the monitor tank pumps,
5 and terminates the discharge.

6 The area radiation monitoring system provides the
7 operating personnel with a record and indication in
8 the main control room of the radiation levels in
9 selected locations within the various station buildings
10 and provides local alarms in areas where it is necessary
11 to warn personnel of substantial immediate changes in
12 radiation levels.

13 Whenever alarms indicating abnormally high station
14 effluent levels are sounded, appropriate operator action
15 will be taken to ensure that the station technical
16 specifications are not violated.

17 8.9 Shielding, Access Control, and Radiation Protection
18 Procedures (23)

19 Control of radiation exposure of station personnel
20 and people external to the station exclusion area is
21 accomplished by a combination of radiation shielding,
22 control of access into certain areas, and administrative
23 procedures. Shielding is used to reduce radiation dose

1 rates in various parts of the station to acceptable
2 limits consistent with operational and maintenance
3 requirements. Access control and administrative
4 procedures are used to limit the integrated dose
5 received by station personnel to less than that set
6 forth in 10 CFR 20. Access control and administrative
7 procedures are also used to limit the potential spread
8 of radioactive contamination from various areas,
9 particularly areas where maintenance occurs. Access
10 control is established in the station arrangement and
11 design so that, in general, most areas and equipment are
12 kept freely accessible, and areas where radiation and/or
13 contamination may be present are entered and exited via
14 access control stations.

15 Procedures have been established for use of survey
16 instruments, protective clothing, film badges, and
17 dosimeters for personnel protection. During operation,
18 periodic surveys will be made to determine radiation
19 levels and to maintain control of potentially contaminated
20 areas. Surveys will also be made prior to maintenance
21 or unusual work to provide exposure control.

1 8.10 Radioactive Waste Control Systems

2 8.10.1 General

3 The radioactive waste control systems, i.e.,
4 the liquid radwaste system, the solid radwaste system
5 and the gaseous radwaste system, are designed to collect
6 radioactive and potentially radioactive station wastes
7 and process and dispose of them in a safe manner.

8 The radioactive waste control systems are
9 designed to minimize the potential for the inadvertent
10 release of radioactivity from the station and to assure
11 that the discharge of radioactive wastes will be within
12 the regulatory limits. The releases of radioactivity
13 from PNPS* during normal operation will be small fractions
14 of the allowable limits of 10 CFR Part 20, "Standards For
15 Protection Against Radiation." Thus annual average
16 exposure levels due to station effluents will generally
17 be small fractions of the average exposure resulting
18 from natural background radiation.

19 Boston Edison Company recognizes its obligation
20 to exert its best efforts to keep levels of radioactive
21 materials in effluents as low as practicable. Boston
22 Edison Company intends to operate PNPS in a manner
23 consistent with that obligation compatible with its

*PNPS - Pilgrim Nuclear Power Station.

1 legal mandate to furnish a dependable source of
2 power. The applicant has initiated a program of
3 selecting, designing, and installing additional
4 equipment* to reduce radioactivity releases from
5 Pilgrim Station to comply with the requirements of
6 10 CFR Part 50 Appendix I, "Numerical Guides For
7 Design Objectives and Limiting Conditions For
8 Operation To Meet the Criterion 'As Low As Practical'
9 For Radioactive Material In Light-Water-Cooled Nuclear
10 Power Reactor Effluents".** The applicant plans to
11 initiate installation of that equipment when approved
12 by the USAEC and to complete installation as soon as
13 practicable.

14 8.10.2 Liquid Radwaste System

15 The liquid radwaste systems collects and
16 processes radioactive and potentially radioactive liquid
17 wastes. The liquid radwaste system is composed of three
18 subsystems, the clean radwaste subsystem, the chemical
19 radwaste subsystem, and the miscellaneous radwaste
20 subsystem; hence, different types of liquid wastes from
21 various sources from within the station can be segregated
22 and processed more efficiently, thus maximizing the
23 recycling of liquid wastes and minimizing the radioactivity

*i.e., beyond the equipment on which the radwaste
system description in this summary is based.

**These guides are not yet part of the regulations but
are proposed to be incorporated into the regulations.

1 in the discharge of liquid effluent. Cross connections
2 between the subsystems have been provided to obtain the
3 availability of additional flexibility for processing
4 liquid wastes.

5 The clean radwaste subsystem processes low
6 conductivity radioactive liquid wastes, viz., equipment
7 leakage collected in equipment drain sumps, condensate
8 demineralizer backwash, and resin transfer water. Water
9 from these sources are transferred to the clean waste
10 receiver tank and are processed on a batch basis through
11 filters and demineralizers before collection in the
12 treated waste holdup tanks. After processing, the water
13 in the treated water holdup tanks normally is no longer
14 classified as liquid radwaste; rather, the water quality
15 is such that it may be recycled for use in the station
16 by transfer to the condensate storage tank. Normally,
17 there is no liquid effluent discharge from the station
18 resulting from the clean radwaste subsystem and, hence,
19 no radioactivity released to the environs as a result
20 of the operation of this subsystem.

21 The chemical radwaste subsystem processes
22 high conductivity, potentially radioactive liquid
23 wastes collected in floor drain sumps and resulting

0 2 3 3 9
0 3 1 0
1 from chemical regeneration of the condensate
2 demineralizer system. These wastes are transferred
3 to the chemical waste receiver for batch processing.
4 After neutralization the wastes are filtered to remove
5 insolubles, and the processed liquid is then transferred
6 to the monitor tanks for holdup and radioactive decay.
7 After decay, the low level liquid wastes are sampled,
8 analyzed, and then released on a controlled basis to
9 the circulating water discharge canal.

10 The miscellaneous radwaste subsystem processes
11 those wastes which have a potentially high detergent level
12 but typically a very low radioactivity concentration.
13 These wastes are collected, sampled and analyzed for
14 radioactivity concentration. If within allowable limits
15 the wastes are filtered and discharged on a controlled
16 basis to the circulating water discharge canal. Miscellaneous
17 wastes of high radioactivity concentrations
18 are transferred to the chemical waste receiver tanks for
19 processing in the chemical radwaste subsystem.

20 Records will be maintained of the discharge
21 rates, concentrations and quantities of liquid radwaste
22 released to the environs. Analyses of the effluent
23 batch samples will be used to assure that the limits

1 of the applicable regulations are not exceeded.

2 8.10.3 Gaseous Radwaste System⁽²⁵⁾

3 The gaseous radwaste system collects radio-
4 active gaseous wastes from the main condenser air
5 ejectors, the startup mechanical vacuum pump, and
6 the turbine gland seal condenser and monitors their
7 release to the atmosphere. The waste gases are
8 routed via hold-up pipes to the main stack for dilution,
9 and elevated release to the atmosphere. The discharge
10 of radioactive effluents to the environment through the
11 main stack are continuously monitored and recorded.

12 The main condenser air ejector subsystem
13 consists of a thirty minute hold-up line, high efficiency
14 filters, isolation valves, dilution fans and the main
15 stack. During power operation, the main condenser
16 off-gas is the major contributor to the activity in
17 the station off-gas release. The gases entering this
18 subsystem are the non-condensibles from the main
19 condenser, consisting of hydrogen and oxygen formed
20 in the reactor by radiolytic decomposition of water,
21 air in-leakage to the turbine-condenser, water vapor,
22 and trace quantities of fission gases resulting from
23 leakage through defects in the fuel cladding and

0 2 3 3 9 0 8 1 2

1 carried over in the steam to the turbine-condenser.
2 The hold-up time in this system for radioactive decay
3 of the fission gases carried over with the steam
4 effects an approximate reduction of 50 or greater
5 in radioactivity. This hold-up time allows the
6 radioactive Xenon and Krypton isotopes with short
7 half-lives to decay to their solid particulate
8 daughter isotopes which are retained on the High
9 Efficiency Particulate Absorber (HEPA) filters at the
10 end of the hold-up pipe. Approximately 98% of the
11 noble gas activity present in the steam at the reactor
12 vessel nozzle experiences decay to stable or radio-
13 active solid daughters prior to reaching the end of
14 the hold-up pipe, and essentially all the solid
15 particulates are retained on the HEPA filters.

16 The turbine gland seal off-gas subsystem
17 collects non-condensable gases from the turbine gland
18 seal condenser during operation of the vacuum pump
19 during startup and passes them through holdup piping
20 prior to release to the stack. During power operation
21 the gland seal off-gas subsystem provides a 1.75 minute
22 hold-up time to allow decay of N-16 and short-lived
23 Xenon and Krypton isotopes.

0 2 3 3 9 0 3 1 3

1 Both the thirty minute hold-up pipe and
2 the turbine gland seal off-gas pipe discharge into
3 the base of the station main stack where the effluent
4 streams are mixed with dilution air by high flow
5 fans and pass up the main stack for dispersion into
6 the atmosphere. Radiation monitors on the main stack
7 continuously monitor and record the activity of the
8 discharge.

9 The annual average release rates of radio-
10 activity from the Pilgrim Nuclear Power Station will be
11 maintained by Boston Edison Company significantly below
12 the limits allowed by 10 CFR Part 20.

13 8.10.4 Solid Radwaste System⁽²⁶⁾

14 The solid radwaste system processes the dry
15 and wet solid radioactive wastes from the station. Wet
16 solid wastes include backwash sludge wastes from the
17 reactor water cleanup system and all spent resins from
18 radwaste, spent fuel pool, and condensate demineralizers.
19 Dry solid wastes include rags, paper, small equipment
20 parts, solid laboratory wastes, etc. All solid radwastes
21 are collected, processed, packaged and temporarily
22 stored on the site to permit accumulation and radio-
23 active decay prior to shipment to a licensed burial site

1 in accordance with applicable regulations.

0 2 3 3 9 0 3 1 4

TABLE 8-1

SUMMARY OF STATION ENGINEERED SAFEGUARDS

<u>System or Component</u>	<u>Function</u>
Control Rod Velocity Limiter	To limit control rod velocity during free fall to less than five feet per second.
Control Rod Drive Housing Support	To prevent a control rod drive mechanism from falling away from the reactor primary vessel in the unlikely event of failure of a housing assembly.
Standby Liquid Control System	To provide a redundant, independent control mechanism in the event the control rod drive system becomes inoperable.
Main Steam Line Flow Restrictor	To provide a constriction in each main steam line to limit the rate of steam flow in the event of a postulated severance of a main steam line.

TABLE 8-1 (Continued)

<u>System or Component</u>	<u>Function</u>
Reactor Core Spray Cooling System	To cool and/or reflood the reactor core after a postu- lated loss-of-coolant accident.
Low Pressure Coolant Injection System	To restore the water level in the reactor vessel after a postulated loss-of-coolant accident.
Containment Spray and Cooling System	To provide for cooling of the primary containment system.
High Pressure Coolant Injection System	To provide adequate core cooling for a spectrum of reactor primary system breaks smaller than those covered by the reactor core spray cooling and low pressure coolant injection systems.
Auto-Depressurization System (ADS)	To provide automatic depres- surization of the reactor primary system, if necessary, to

TABLE 8-1 (Continued)

<u>System or Component</u>	<u>Function</u>
Auto-Depressurization System (ADS) (Cont.)	allow core spray and RHR operation. The ADS coupled with the LPCI and/or the Core Spray System provide a back-up to the HPCI.
Primary Containment	To isolate the primary contain- ment system automatically, if required, under postulated accident conditions.
Reactor Building Isolation and Control System	To isolate the normal reactor building ventilation system and initiate the standby gas treat- ment system under postulated accident conditions.



[illegible]

FIGURE 8-1
SIMPLIFIED STATION PROCESS FLOW DIAGRAM

FIGURE 8-2

REACTOR VESSEL ISOMETRIC



References for Section 8.0

1. FSAR, Section 12.2.3
2. FSAR, Section 5.2
3. FSAR, Section 5.3
4. FSAR, Sections 3 and 4
5. FSAR, Sections 3.4 and 3.7
6. FSAR, Section 7.9 and 7.11
7. FSAR, Section 7.11
8. FSAR, Section 7.2
9. FSAR, Section 7.3
10. FSAR, Section 7.4
11. FSAR, Section 7.18
12. FSAR, Section 8.5
13. FSAR, Section 7.5
14. FSAR, Section 6.4.3
15. FSAR, Section 6.4.1
16. FSAR, Sections 4.4 and 6.4.2
17. FSAR, Sections 4.8 and 6.4.4
18. FSAR, Section 10.5
19. FSAR, Section 10.7
20. FSAR, Section 11
21. FSAR, Section 8
22. FSAR, Sections 7.12 and 7.13
23. FSAR, Section 12.3

24. FSAR, Section 9.2

25. FSAR, Section 9.4

26. FSAR, Section 9.3

0 2 3 3 9 0 8 2 1

1 9.0 QUALITY ASSURANCE AND STATION TESTING PROGRAMS

2 9.1 Quality Assurance(1)

3 Pilgrim Nuclear Power Station is owned and will be
4 operated by Boston Edison Company. The applicant
5 assumes full responsibility and authority for the
6 project and has ultimate responsibility for quality
7 assurance.

8 Bechtel Corporation is architect-engineer with
9 additional responsibility for all construction on site.

10 General Electric Company provides design engineer-
11 ing and procurement of equipment associated with the
12 Nuclear Steam Supply System, together with technical
13 direction of installation for this system.

14 The applicant's Nuclear Quality Assurance Organiza-
15 tion has the responsibility to assure that quality
16 requirements of essential items affecting the integrity
17 and safety of the station are identified, specified,
18 and performed in accordance with sound engineering
19 principles, appropriate codes and standards, specifica-
20 tions, regulations, and procedures. This NQA organiza-
21 tion consists of a Senior Quality Assurance Engineer
22 who reports to the Assistant Vice President - Nuclear.
23 Reporting to the Senior Quality Assurance Engineer are

1 the Quality Assurance Engineers assigned with mechanical
2 and electrical experience and background.

3 Programs in Quality Control and Quality Assurance
4 have been established by the Architect-Engineer, Bechtel,
5 and by the Nuclear Steam System Supplier, General Elec-
6 tric. Control of quality is accomplished through
7 communications with project contractors, consultants,
8 inspectors, and equipment manufacturers, and by surveil-
9 lance and audit of quality control records, inspection
10 reports and audits, test reports, certifications of code
11 compliance, and by any other means necessary to accom-
12 plish the quality assurance objectives.

13 Functional responsibility for quality control,
14 quality assurance, engineering design, procurement,
15 expediting, inspection, construction, systems checkout,
16 and acceptance testing are indicated on Table 9-1,
17 Project Functional Responsibility Summary. This table
18 covers the nuclear steam supply system, nuclear fuel,
19 and balance of plant.

20 Figure 9-1, Quality Assurance - Quality Control
21 Responsibility Chart, presents the organizational
22 quality assurance responsibility covering materials and
23 equipment subvendors, through various contractors,

0 2 3 3 9
0 2 3 3 4
0 8 2 4
1 suppliers, architect-engineer, constructor, and
2 ultimately to the prime responsible company, Boston
3 Edison.

4 Figure 9-2 - Site Construction Quality Assurance
5 Organization Chart, presents the organization and
6 interrelationships of quality-oriented personnel at
7 the Pilgrim construction site. Functional lines of
8 reporting and communication are established to coordi-
9 nate quality control and quality assurance, and to
10 assure that all site construction activities are car-
11 ried out in accordance with project requirements for
12 inspection, testing, and documentation.

13 Structures, systems, and components are classified
14 for purposes of identifying and assigning quality con-
15 trol and quality assurance requirements. The classifi-
16 cation is made to identify "essential items" and to
17 establish quality levels consistent with the require-
18 ments of Boston Edison Company and to comply with the
19 intent of the quality-related AEC General Design Criteria.

20 The "essential items" that are controlled by the
21 Quality Assurance Program are those structures and
22 systems identified as Class I in the FSAR. A summary
23 of Class I structures and equipment is included in

0 2 3 3 9
1 subsection 12.2.1.2 of the FSAR. A summary of the
2 Class I protection instrument and control systems is
3 included in subsection 7.1.1 of the FSAR. The "essen-
4 tial items" are identified on the Q(Quality)-List.
5 Within the Class I mechanical and clerical systems,
6 every item or component is not Q-listed. Rather, each
7 component is reviewed to determine which of the follow-
8 ing categories it falls into:

9 Category A

10 Its function is essential for the operation
11 of a Class I component or system to meet the
12 Class I criteria (e.g., pumps and switches that
13 must operate to accomplish their safety objective).
14 If so, it is included on the Q-List.

15 Category B

16 Its pressure boundary integrity is essential
17 for the operation of a Class I component to meet
18 the Class I criteria. If so, it is included on
19 the Q-List and, if required for clarity, it is
20 given a note (pressure boundary only) on the Q-List.

21 Category C

22 It is not essential for either functioning
23 or pressure boundary integrity of A or B above

1 (e.g., pressure, temperature, and position
2 indicators or alarms, computer inputs etc.). If
3 so, it is not included on the Q-List.

4 9.2 Pre-Operational and Startup Testing (2)

5 The Station will be made operational by Boston
6 Edison operating personnel under the technical direction
7 of General Electric and Bechtel using written test
8 procedures and operating instructions.

9 The applicant is responsible for all station opera-
10 tions from the start of preoperational testing and is
11 responsible for providing properly licensed personnel
12 to operate the station. General Electric personnel
13 will provide technical guidance for preoperational
14 testing, initial core loading, startup, and precommercial
15 operation. Prior to initial fuel loading, General Elec-
16 tric will have a sufficient number of their startup
17 personnel obtain AEC licenses to properly assist the
18 applicant's licensed personnel during the period pre-
19 ceding commercial operation.

20 The Pilgrim Division Head is responsible for the
21 safe operation of the facility. A training program
22 has been established which will provide a properly
23 trained staff of technical, maintenance, and licensed

0 2 3 3 9
0 9 2 7

1 operating personnel to accomplish all of the various
2 station functions within their respective disciplines
3 as shown on the station organization chart (see Figure
4 9-3).

5 Preoperational and acceptance test procedures
6 identify the systems and equipment which are to be
7 tested and state the requirements of the tests. Test
8 procedures and test results are reviewed and approved
9 by Boston Edison and either Bechtel or General Elec-
10 tric, as appropriate, based upon original design
11 responsibility.

12 The purpose of the preoperational test program is
13 three-fold: confirm that construction is complete to
14 the extent that equipment and systems can be put into
15 use during completion of other construction; adjust
16 and calibrate the equipment to the extent possible in
17 the "cold" plant; assure that all process and safety
18 equipment is operational, and in compliance with
19 license requirements, to the extent necessary to pro-
20 ceed into initial fuel loading and the startup program.
21 The foregoing is achieved by construction tests,
22 formal written preoperational tests on systems related
23 to nuclear safety, and acceptance tests on systems not

1 related to nuclear safety.

2 The formal preoperational and acceptance tests
3 are an important phase in the training of operating
4 personnel. Experience and understanding of station
5 systems and components is gained with a minimum of
6 risk to the equipment or personnel. This gives
7 maximum opportunity to evaluate and train individual
8 operators and to troubleshoot systems. In addition,
9 equipment and systems are operated for a sufficient
10 period of time to discover and correct any design,
11 manufacturing, or installation errors, and to adjust
12 and calibrate the equipment.

13 After each preoperational test is completed, Gen-
14 eral Electric or Bechtel and Boston Edison operating
15 personnel check off that the tests have been completed
16 and that the results are in accordance with acceptance
17 criteria of the test procedure.

18 Initial fuel loading and startup testing are per-
19 formed by Boston Edison operating personnel under the
20 technical direction of General Electric. Startup test
21 specifications define the test program for startup with
22 defined limits and changes permitted during startup
23 test activities.

1 Startup test procedures present the recommended
2 test method and describe the steps necessary to per-
3 form the tests defined in the startup test specifica-
4 tion.

5 The applicant's Quality Assurance Organization
6 audits the preoperational and startup testing programs
7 for satisfactory completion of test program require-
8 ments.

References for Section 9.0

1. FSAR, Appendix D and Amendment 20, Part 5.
2. FSAR, Appendix D and Section 13.1 and 13.4.

Table 9-1

PROJECT FUNCTIONAL RESPONSIBILITY SUMMARY

PILGRIM NUCLEAR POWER STATION

PROJECT PART	Quality Control	Quality Assurance	Engineering Design	Procurement	Mfg. Inspection	Mfg. Expediting	QC Construction	QA Construction	Systems Checkout and Acceptance Testing
I Nuclear Power Station*	B	Edison	B	B	B	B	B	B	Edison(1)
II Nuclear Steam Supply System	G.E.	Edison	G.E.	G.E.	G.E., B	G.E., B	B(2)	B(2)	Edison(2)
III Nuclear Fuel	G.E.	Edison	G.E.	G.E.	G.E. Edison	G.E.	-	-	Edison(2)

Notes:

Edison = Boston Edison Company


B = Bechtel Corporation

G.E. = General Electric Company

* Except Parts II and III


(1) Technical direction provided by Bechtel Corp.

(2) Technical direction provided by G.E. Corp.




PILE
NUCLEAR POWER STATION

Quality Assurance - Quality Control
Responsibility Chart
FIGURE 9-1



0 2 3 3 9 0 3 3 2




PILGRIM
NUCLEAR POWER STATION

Site Construction
Quality Assurance Organization Chart

FIGURE 9-2

0 2 3 3 9 0 3 3 3



(a) AEC SENIOR REACTOR OPERATORS LICENSE

(b) AEC REACTOR OPERATORS LICENSE

ORC-MEMBERS OF THE OPERATIONS REVIEW COMMITTEE.
COMMITTEE CHAIRMAN IS THE DIVISION HEAD

PILGRIM
NUCLEAR POWER STATION

Pilgrim Nuclear Power
Station Organization Chart
FIGURE 9-3

1 10.0 COMMENTS ON ACRS REPORT

2 In its letter of April 7, 1971 to the Chairman of the
3 Atomic Energy Commission on Pilgrim Nuclear Power Station,
4 the Advisory Committee on Reactor Safeguards identified
5 certain areas requiring further consideration and resolution
6 and made several recommendations with respect to the re-
7 quested operating license. These recommendations and the
8 actions taken by Boston Edison Company are summarized
9 below:

10 (1) Liquid Radwaste System

11 "The applicant has not provided equipment for concen-
12 trating and separating radioactivity from liquid wastes,
13 and he states that the radioactivity concentration in
14 the condenser circulating water discharge will not
15 exceed that permitted by 10 CFR 20. During the first
16 reactor shutdown for refueling, the applicant will
17 install an evaporator designed to permit the holdup
18 of liquid wastes and thereby reduce the gross radio-
19 activity discharged. The Committee believes that the
20 design and operation of this evaporator system should
21 be such as to reduce to levels as low as practicable
22 the amount of long-lived radioisotopes discharged.
23 The Regulatory Staff should review and approve the

1 design and operating mode of this equipment. The
2 Committee also believes that prior to the installa-
3 tion of this equipment, effort should be made to
4 reduce the radioactivity released."

5 The liquid radwaste concentrator is expected to be
6 operable during the summer of 1972. Boston Edison Company
7 recognizes its obligation prior to and following the in-
8 stallation of the concentrator, to keep levels of radio-
9 active materials in liquid effluents as low as practicable.
10 Boston Edison Company intends to operate Pilgrim Nuclear
11 Power Station in a manner consistent with that obligation
12 compatible with its legal mandate to furnish a dependable
13 source of power. In accordance with this obligation Boston
14 Edison Company will operate the station such that, when
15 discharges are controlled on a radionuclide basis, the
16 maximum concentration (above background) in the condenser
17 cooling water discharge canal after mixing with the service
18 water and circulation water will be limited to values which
19 do not exceed 0.25 times the MPC* values stated in Appen-
20 dix B, Table II, Column 2 of 10 CFR Part 20 and note 1
21 thereto. (1)

22

23 *MPC - Maximum Permissible Concentration

1 (2) Gaseous Radwaste System

2 "The applicant proposes that the gaseous and particu-
3 late radioactivity discharged through the stack will
4 not exceed 10 CFR 20 limits. The Committee believes
5 the applicant should set a much lower operating limit
6 and should make such equipment changes as may be
7 necessary to accomplish this."

8 Boston Edison Company, in its Technical Specifications
9 for PNPS, has set a limit on the annual average release rate
10 of radioactivity to be discharged through the station main-
11 stack which, based upon the applicant's analysis presented
12 in Appendix E of the FSAR, will maintain the exposure levels
13 to approximately one quarter of those allowed in 10 CFR
14 Part 20, paragraph 105(a). Concurrently the applicant has
15 initiated a program of selecting, designing and installing
16 additional equipment to reduce radioactivity releases from
17 the station mainstack to comply with the requirements of
18 10 CFR Part 50 Appendix I, and plans to initiate installa-
19 tion of that equipment when approved by the USAEC and to
20 complete installation as soon as practicable.*

21 (3) Primary Containment Integrity

22 "The applicant proposes to protect the containment
23 against breaching that may be caused by whipping of

* Refer to footnotes on p. 8-38

1 unrestrained piping in the event of a pipe rupture,
2 and also to guard against missiles that could be
3 generated from the biological shield by rupture of
4 pipes, including safe-ends, within the shield."

5 Boston Edison Company is installing at selected loca-
6 tions inside the Pilgrim primary containment system on the
7 drywell shell an energy absorbing/load transmitting system
8 of steel plates and I-beams which will significantly reduce
9 the possibility of the mechanical effects associated with
10 a rupture of a high pressure pipe resulting in breaching
11 the primary containment system. The protective system being
12 installed distributes the mechanical energies over a wider
13 area allowing the drywell to deform through the two inch
14 air gap between the drywell and the outer biological shield
15 without rupture.

16 The inner biological shield's capability to withstand
17 internal pressures resulting from the failure of vessel
18 nozzle safe-ends within the annular space between the
19 reactor vessel and the shield has been evaluated, and the
20 capability is greater than the maximum internal pressure
21 which could be generated. The restraints for the shield
22 plugs surrounding pipes penetrating the biological shield
23 are designed with the same capability as the inner biological

1 shield itself. Thus the design effectively precludes the
2 possibility of missile generation as a result of pipe or
3 safe-end ruptures within the shield. (2)

4 (4) Fuel Cask Drop

5 "The applicant proposes to assure that accidental
6 dropping of the spent-fuel cask into the fuel stor-
7 age pool will not cause leakage in excess of the
8 make-up capacity, and will make such modifications
9 as may be necessary."

10 Boston Edison Company has conducted studies to determine
11 the effects of a spent-fuel cask dropped into the fuel stor-
12 age pool. In order to assure that any resultant leakage
13 from the pool will be within the pool makeup capability, an
14 energy absorbing/load distributing pad will be installed in
15 the cask loading area which will be capable of absorbing,
16 distributing, and dispatching the kinetic energy associated
17 with a loaded cask drop from the maximum height. (3)

18 (5) Confirmatory Vibration Testing

19 "The applicant said he would make tests adequate to
20 confirm the predicted vibrational characteristics of
21 the vessel internals."

22 A program of confirmatory vibration measurements will
23 be implemented for the Pilgrim reactor. Both cold and hot

1 tests will be conducted over a range of power and flow
2 conditions to verify the applicability of more extensive
3 data obtained from previous tests conducted on other similar,
4 operating boiling water reactors. (3)

5 (6) Failure to Scram

6 "The Committee believes the applicant should make
7 timely proposals for resolution of the problem of
8 possible failure to scram on anticipated transients."

9 A common mode failure study was completed and has been
10 documented in Topical Report NEDO-10189, "An analysis of
11 Functional Common Mode Failures in General Electric BWR
12 Protection and Control Instrumentation." This Report was
13 submitted in October 1970 to the AEC and includes a complete
14 analysis of common mode failures in the initiation of scram
15 signals.

16 Studies are continuing to evaluate the consequences of an
17 incredible, undefined failure of the scram protection system.
18 A report on failure to scram has recently been documented
19 as a General Electric Topical Report, NEDO-10349, "Analysis
20 of Anticipated Transients Without Scram," and submitted to
21 the AEC for review. (4)

22 (7) ECCS Performance Evaluation

23 "The applicant should reevaluate, before routine

1 operation at full power, the performance of the
2 emergency core cooling system, using recent heat
3 transfer data and calculational methods."

4 The core standby cooling systems for Pilgrim Nuclear
5 Power Station have been recently reevaluated in accordance
6 with the USAEC's INTERIM ACCEPTANCE CRITERIA FOR EMERGENCY
7 CORE COOLING SYSTEMS FOR LIGHT-WATER POWER REACTORS,
8 adopted on June 19, 1971. The results of this analysis
9 show that the PNPS core standby cooling systems, when
10 evaluated in strict accordance with Appendix A, Part 2 of
11 the interim policy statement, do meet the interim acceptance
12 criteria. (These criteria are listed in section 8.5.1 of
13 this summary.) (5)

14 (8) Station Instrumentation and Electrical Systems

15 "Several items regarding plant instrument systems
16 and electrical systems are under review by the
17 Regulatory Staff. All these matters should be
18 resolved to the satisfaction of the Regulatory Staff;
19 the Committee wishes to be kept informed."

20 Additional discussions have been held with the Regula-
21 tory Staff, and all items regarding station instrument
22 systems and electrical systems have been resolved. (6)

1 (9) Inservice Inspection

2 "The Committee believes the applicant should continue
3 to explore means of improving access to vessel welds
4 for inservice inspection."

5 The design of the removable vessel insulation and
6 shield plugs have been modified to facilitate access to
7 selected vessel welds for inservice inspection.

8 (10) Reactor Vessel Temperature and Pressure Limitations

9 "The Committee also believes that the reactor vessel
10 pressure should be limited in accordance with current
11 AEC bases when the vessel temperature is below 180°F."

12 The proposed Technical Specifications have been revised
13 to comply with current AEC bases for vessel pressurization
14 when vessel temperature is below 180°F. (7)

15 (11) Offsite Electrical Power Systems

16 "The site is served by two 345 kV electrical trans-
17 mission lines on the same towers and a separate 23 kV
18 line. Over a short distance, the lines are adjacent
19 and it is physically possible for the fall of a
20 tower to break the 23 kV line. The Committee believes
21 that the applicant should explore the feasibility of
22 using an alternative 23 kV supply or of making local
23 changes to reduce the possibility of losing the 345

1 and 23 kV lines simultaneously."

2 The 23 kV line supplying the Pilgrim Station will be
3 placed underground at selected locations to prevent loss
4 of the 23 kV supply as a result of 345 kV tower failures.

References for Section 10.0

1. FSAR, Amendment 29
2. FSAR, Amendment 29
3. FSAR, Amendment 29
4. FSAR, Amendment 29
5. Boston Edison Company, letter to the USAEC,
6. July 22, 1971.
7. FSAR, Amendment 29
8. FSAR, Amendment 29

1 11.0 OTHER GOVERNMENTAL AGENCIES

2 In addition to applying to the Atomic Energy Commis-
3 sion for the requisite licenses under the Atomic Energy Act
4 of 1954, as amended, Boston Edison Company has applied for
5 other necessary federal, state and local approvals. Boston
6 Edison Company has applied for and received permits and
7 licenses as discussed in the following paragraphs.

8 The Town of Plymouth through its Board of Approvals has
9 issued to the Company a special permit under Town zoning
10 ordinances to authorize the building of a nuclear powered
11 generating station at the site where the Pilgrim Station is
12 located.

13 The Massachusetts Department of Natural Resources,
14 Division of Water Pollution Control, has issued an interim
15 industrial discharge permit dated January 8, 1969 and the
16 certification required under the Water Quality Improvement
17 Act of 1970. The Department of Natural Resources through
18 its Division of Marine Fisheries has also worked with the
19 Applicant regarding permit matters within the jurisdiction
20 of the Division.

21 The Applicant has received from the Massachusetts
22 Department of Public Works a license relative to various
23 station undertakings including construction and maintenance

1 of a breakwater and dredging.

2 The Company has received a permit from the U.S. Army
3 Corps of Engineers similar to that issued by the Massachu-
4 setts Department of Public Works which allows the Company
5 to build and maintain the station breakwaters and to con-
6 struct and maintain the intake and discharge channels and
7 to dredge. Application has also been made to the Corps
8 for a discharge permit under the New Federal Refuse Act
9 Permit Program.

10 Boston Edison Company has applied to the Massachusetts
11 Department of Public Health for such approvals as may be
12 required to permit operation of the station under the
13 "Regulations for the Control of Air Pollution in the South-
14 eastern Massachusetts Air Pollution Control District."

15 Applicant has sought and will continue to seek all
16 other required federal, state and local approvals necessary
17 to the operation of the station. Furthermore, the applicant
18 will continue its program of information and liaison with
19 federal, state and local officials (see e.g., Section 6.1).

1 12.0 TECHNICAL QUALIFICATIONS

2 12.1 Boston Edison Company

3 Boston Edison Company has been engaged over the
4 past 85 years as a public utility in the business of
5 generation, transmission and retail and wholesale
6 distribution of electricity and has accumulated in-depth
7 experience in the construction and operation of
8 fossil-fueled generating stations and the related
9 transmission and distribution facilities.

10 Boston Edison operates four major fossil-fueled
11 generating stations; Mystic Station with 6 generating
12 units and 1 unit under construction, Edgar Station with
13 3 generating units, L Street Station with 5 generating
14 units, and New Boston Station with 2 generating units.
15 In addition Edison operates several stations that supply
16 steam for commercial sale and also operates several
17 generating installations utilizing combustion turbines.

18 Boston Edison is part owner of the Yankee Nuclear
19 plant in Rowe, Massachusetts and of the Connecticut
20 Yankee nuclear plant in Haddam Neck, Connecticut.
21 Boston Edison is represented on the Board of Directors
22 of these two companies and has participated technically
23 by working assignments of Edison personnel during the

1 design and startup phases at these plants.

2 Boston Edison personnel from the Engineering and
3 Construction Department and from the Operations Department
4 have participated in the Pilgrim Station project through-
5 out the engineering, construction and pre-operational
6 test phases. Operating personnel permanently assigned
7 to the Pilgrim Station Organization have participated
8 in special training programs and in the pre-operational
9 test programs in preparation for startup of the station.
10 In addition to the training and experience obtained by
11 Edison personnel during the Pilgrim Station project,
12 many of these personnel have prior nuclear experience
13 totalling about 70 man-years obtained at other nuclear
14 facilities which include: Yankee Rowe, Connecticut
15 Yankee, Vallecitos, Dresden 1, Humboldt Bay, Oyster
16 Creek, KRB (West Germany), Nuclenor (Spain), Millstone 1,
17 Elk River, Hallam, Piqua, Hanford, Savannah River, SM-1,
18 Westinghouse Reactor Evaluation Center, and the Walter
19 Reed Medical Reactor.

20 12.2 Bechtel Corporation

21 The Boston Edison Company retained Bechtel
22 Corporation as the Architect/Engineer and Constructor
23 for Pilgrim Nuclear Power Station. Working under the

0 2 3 3 3 9 0 3 4 7
1 overall direction of Boston Edison Company and in
2 close coordination with the General Electric Company,
3 Bechtel has designed or furnished (or both) all
4 portions of the station except the turbine generator,
5 nuclear steam supply system, and nuclear fuel.

6 Bechtel has been continuously engaged in
7 construction or engineering activities since 1898. For
8 more than 20 years, Bechtel has been active in the
9 fields of petroleum, power generation and distribution,
10 harbor development, mining and metallurgy, and chemical
11 and industrial processing.

12 Since the close of World War II, Bechtel has
13 been responsible for the design of over 186 power
14 generating units, representing more than 73 million
15 kilowatts of thermal generating capacity, which includes
16 units of the largest and most modern types. Of this
17 number, more than 32 million kilowatts are produced
18 by nuclear-fueled units.

19 For over 20 years, Bechtel has been engaged in
20 the study, design and construction of nuclear installations.
21 Its experience includes design or construction, or both,
22 of such facilities as accelerators, nuclear research
23 laboratories, hot cells, experimental reactors and

1 nuclear fuel processing plants, as well as nuclear
2 power plants.

3 12.3 General Electric Company

4 The supplier of the nuclear steam supply system
5 and the turbine-generator is the General Electric Company.
6 The General Electric Company has been engaged since 1955
7 in the design, construction, and operation of boiling
8 water reactors. Among the operating reactors with which
9 the General Electric Company has been associated are the
10 Vallecitos, Dresden 1, 2, and 3, Humboldt Bay, Big Rock
11 Point, Oyster Creek, Nine Mile Point, Millstone,
12 Monticello and a number of reactors in foreign countries.
13 They are also designing and have under various stages
14 of construction many other BWR reactors, similar to the
15 Pilgrim plant. Thus, General Electric has a substantial
16 knowledge, capability, and experience with this type of
17 reactor.

1 13.0 EMERGENCY PLAN

2 The potential for incidents resulting in the release
3 of significant radioactivity is extremely low. Several
4 independent barriers exist between the source of activity
5 and station personnel or the general public. The consequences
6 of any postulated accident and the extent of any resultant
7 radiation emergency are dependent upon the degree of viola-
8 tion of these barriers. Information on the status of these
9 barriers is continuously available in the control room.
10 Annunciation and automatic protective action is initiated
11 when necessary to maintain barrier integrity. Direct infor-
12 mation is also available in the control room as to the
13 effectiveness of these protective actions.

14 Even though the chances are extremely low that any
15 accidental release of significant quantities of radioactivity
16 will ever occur, nevertheless, a plan of action has been
17 formulated to deal with any such occurrence. This plan will
18 function to confine and minimize the consequences of any
19 incident involving the uncontrolled or unplanned release
20 of radioactive materials, in order to protect the health
21 and safety of the general public and the applicant's sta-
22 tion personnel.

23 Details of the emergency plan are given in Amendment 22

1 of the FSAR. Procedures for abnormal operating conditions,
2 emergency operating conditions and radiation emergency pro-
3 cedures are available. Station supervisory personnel are
4 trained so that authority, responsibilities and functions
5 are properly defined and implemented in emergency or poten-
6 tial emergency situations.

7 Prior to startup of the station, every station employee
8 will be trained and required to understand the detailed
9 emergency plan and his individual responsibilities as
10 required by the Emergency Procedures. All new employees
11 at the station will undergo the same training.

12 The applicant has made provisions so that local, state
13 and federal authorities can appropriately respond in the
14 case of an emergency. The agencies involved include the
15 Massachusetts State Police, the U.S. Coast Guard, the State
16 Department of Public Health, the Civil Defense Agency, the
17 Plymouth Police, the Plymouth Fire Department, and the New
18 York Operations Office of the Atomic Energy Commission.
19 Reliable communications are provided for and training has
20 been provided where necessary.

21 The applicant has provided approximately 14 hours train-
22 ing each, for the local police and fire departments on radio-
23 logical safety and on the applicant's emergency plans and

1 procedures.

2 An Emergency Medical Plan has been established to insure
3 adequate medical expertise and facilities in the event of
4 injuries concomitant with contamination. Physicians trained
5 in the specialized techniques required in the treatment of
6 radiation patients are on call at the local medical facili-
7 ties.

8 Drills on the emergency procedures will be conducted
9 annually to assure that employees of the applicant are
10 familiar with their specific duties, and to provide other
11 persons and/or agencies whose assistance may be needed in
12 the event of an emergency, the opportunity to participate
13 in the drills. The continued validity and appropriateness
14 of agreements with outside agencies will be reviewed in
15 connection with the drills. The status of emergency equip-
16 ment will be checked at least annually to insure continued
17 availability.

1 14.0 COMMON DEFENSE AND SECURITY

2 Boston Edison Company is a corporation organized under
3 the laws of the Commonwealth of Massachusetts. It is
4 engaged in the generation, transmission, and retail and
5 wholesale distribution of electricity. All of the Directors
6 and principal Officers of the applicant are citizens of the
7 United States; and the applicant is not owned, controlled,
8 or dominated by any alien, foreign corporation or foreign
9 government.

10 The applicant is acting solely on its own behalf and
11 is not acting as an agent for anyone else.

12 The application contains no restricted or other defense
13 information, and the applicant has agreed that it will not
14 permit any individual to have access to any Restricted Data
15 until an investigation and report on such individual has
16 been made by the Civil Service Commission and the Atomic
17 Energy Commission shall have determined that permitting
18 access to such Restricted Data by such individual will not
19 endanger the common defense and security.

20 The applicant will, as a licensee, be subject to regu-
21 lations of the Atomic Energy Commission relating to the
22 possession, use, transfer and accountability for special
23 nuclear material in its possession; to the possession, use

1 and transfer of source and byproduct material; and to the
2 possession, use and transfer of the utilization facility
3 designed as Pilgrim Nuclear Power Station.

4 For the reasons stated above, the issuance of an operat-
5 ing license for Pilgrim Nuclear Power Station will not be
6 inimical to the common defense and security.

0 2 3 3 9
0 8 5 3

1 15.0 FINANCIAL QUALIFICATIONS

2 Boston Edison Company is the major retail supplier of
3 electricity in the greater Boston area, and in addition
4 supplies electricity at wholesale for resale to other
5 utilities (see Sec. 2.1). Net income derived from all
6 the Company's operations for the period 1966-1970 is as
7 follows:

8 Net Income (000's)

9 <u>1970</u>	<u>1969</u>	<u>1968</u>	<u>1967</u>	<u>1966</u>
10 \$37,455	\$33,886	\$31,664	\$29,361	\$26,818

11 At current net operating income levels, combined with
12 expected fuel savings due to its Pilgrim investment, Boston
13 Edison Company believes it will have sufficient revenues to
14 meet the annual costs of operating Pilgrim.

1 16.0 FINANCIAL PROTECTION

2 Boston Edison Company has taken the following action
3 to comply with the requirements of the Commission's Rules
4 and Regulations relating to financial protection in 10 CFR
5 Part 140:

6 a) Nuclear Energy Liability Insurance Association
7 (NELIA) has issued to Boston Edison Policy No. NF-188,
8 providing nuclear fuel storage liability in the amount of
9 \$1,000,000.

10 b) Indemnity Agreement No. B-48 dated 11/20/70,
11 effective 11/20/70, has been issued by the Commission to
12 Boston Edison in the amount of \$500 million.

13 c) In addition, Boston Edison has obtained commitments
14 from the private sector of the insurance industry to provide
15 liability insurance in the aggregate amount of \$82 million,
16 which is the amount required by 10 CFR 140. NELIA is
17 committed to provide \$63,550,000 and Mutual Atomic Energy
18 Liability Underwriters is committed to provide \$18,450,000.
19 These policies will be issued before issuance of the operat-
20 ing license.

1 17.0 CONCLUSION

2 On the basis of the application as summarized herein,
3 the applicant respectfully submits that:

4 1. Construction of Pilgrim Nuclear Power Station has
5 been substantially completed in conformity with the construc-
6 tion permit and with the application, as amended, the pro-
7 visions of the Atomic Energy Act of 1954, as amended (the
8 Act), and the rules and regulations of the Commission.

9 2. Pilgrim Nuclear Power Station will operate in con-
10 formity with the application, as amended, the provisions of
11 the Act, and the rules and regulations of the Commission.

12 3. There is reasonable assurance (i) that the acti-
13 vities authorized by the operating license can be conducted
14 without endangering the health and safety of the public,
15 and (ii) that such activities will be conducted in compli-
16 ance with the regulations of the Commission.

17 4. Boston Edison Company is technically and finan-
18 cially qualified to engage in the activities authorized by
19 the operating license in accordance with the regulations
20 of the Commission.

21 5. The applicable provisions of 10 CFR Part 140,
22 "Financial Protection Requirements and Indemnity Agreements"
23 of the Commission's Regulations have been satisfied.

1 6. The issuance of the license will not be inimical
2 to the common defense or security or to the health or safety
3 of the public.

0 2 3 3 9 0 8 5 7

FINAL

1.9.9
3/69

A G R E E M E N T

Agreement entered into this 14th day of March 1969, between and among the Massachusetts Division of Marine Fisheries of the Department of Natural Resources (Hereinafter referred to as the Commonwealth), and Boston Edison Company (Hereinafter referred to as the Company).

WITNESSETH:

Whereas, the Company is constructing a power plant in Plymouth, Massachusetts adjacent to the Rocky Neck area; and

Whereas, it is the consensus of the parties that a biological investigation of marine life both before and after the plant is in operation in this area be undertaken; and

Whereas, it is the consensus that the Commonwealth acting under authority of G.L. Chapter 130, Section 17 (3) and (9) should conduct or have conducted such biological investigation; and

Whereas, the Commonwealth has developed and proposes to implement a Work Program, attached hereto as Exhibit A and made a part hereof; and

Whereas, the Company is willing to provide to the Commonwealth under the provisions of G. L. Chapter 130, Section 17 (9) monies hereinafter set forth for the implementation of the Work Program for the benefit of the economy and general welfare of the area as a whole:

Now Therefore It Is Agreed:

1. Upon payment of the sums hereinafter set forth, the Commonwealth agrees to implement the Work Program substantially in accordance with the time schedule, methods, and techniques outlined herein.

2. The Company will provide the Commonwealth with a sum not to exceed \$60,000 during the First Year of the biological investigation, payment to be made quarterly in advance. The Company will provide the Commonwealth with a sum not to exceed \$73,000 during the Second Year of the biological investigation, \$73,000 for the Third Year and \$73,000 for the Fourth Year in equal advance quarterly payments. All sums provided by the Company shall be deposited in the State Treasury as a trust fund to be expended only for the purposes set forth herein.

3. The Company shall be under no obligation to contribute any funds in excess of those set forth in paragraph 2 above, except that if the plant has not been in operation for 50% or more of the time during the January-March quarter of at least one of the four contract years, then the contract shall be extended to cover the next subsequent January-March quarter after the expiration of the four-year period; and similarly, if the plant has not been in operation for 50% or more of the time in the April-June, or the July-September, or the October-December quarter, of at least one of the four contract years, then the contract shall be extended to cover the comparable quarter of the next subsequent year; the Company agrees to provide the Commonwealth with the sum of \$15,500 in advance payments for each quarter year of the extension. If the actual cost of the items set forth in Exhibit A are less than the estimated cost, the Company's obligation hereunder shall be appropriately reduced and the advance quarterly payments adjusted to reflect such cost savings.

4. The Company shall cooperate with personnel of the Commonwealth in connection with such personnel's work hereunder.

05006300

- 00000

- 1
0
8
0

6
3
3
0
- (c) Within six months after the Preliminary Work Program shall have been implemented a draft copy of the regular Work Program, to be finalized after conference(s) with the Company;
 - (d) Draft reports summarizing the Work Program, the data gathered, and the evaluation of such data as required to support the Company in obtaining permits and licenses for the Pilgrim Station;
 - (e) As soon as practicable after the ascertainment thereof, any facts obtained pursuant hereto which would suggest a modification of design or construction of the intake and discharge;
 - (f) Within six months after completion of the Work Program a draft copy of a topical report describing the Work Program, the data gathered, and the final evaluation of such data, to be finalized after conference(s) with the Company and prior to the public issuance of any final report. The Company shall be entitled to use copies of said reports and data in the furtherance of its operation of the Pilgrim plant.
 - (g) Except for the first quarter, one month prior to the date that advance quarterly payments are payable to the Commonwealth by the Company, a statement of expenditures incurred to-date with an estimate of the expenditures anticipated through the next succeeding quarter. The advance quarterly payment shall be adjusted to reflect the actual and projected quarterly expenditure rate.

6. The Company shall have the right to observe activities being undertaken by the Commonwealth hereunder.

7. Neither the Company nor any of its officers, agents, or employees shall be liable for any loss of or damage to property and/or injuries, including death, to any person or persons which may arise directly or indirectly from the implementation by the Commonwealth of the Work Program.

8. In all matters relating to the administration of this agreement, the representative of the Commonwealth shall be the Director, Division of Marine Fisheries or his designated representative; and the representative of the Company shall be whoever the Company designates or his representative.

9. This agreement shall become effective as of March 14th 1969.

Date _____

Boston Edison Company

by February

APPROVED: _____
Commissioner, Department
of Natural Resources

Commonwealth of Massachusetts

by Price
Director
Division of Marine Fisheries

023390862

Exhibit A

Preliminary Work Program of
Fishery Investigations

Introduction

It is agreed by the Boston Edison Company (the Company) and the Commonwealth of Massachusetts (the Commonwealth) that:

1. The construction and operation of the Pilgrim Nuclear Power Station (the plant) may change the ecological environment of the marine life in the waters of Cape Cod Bay in the proximity of the Plant (the Area)
2. The operation of the Plant may have an adverse effect on some important commercial or sports species of finfish, crustacea or shellfish in the Area and may have a beneficial effect on others and,
3. Every reasonable precaution must be taken in the operation of the Plant to prevent a significant overall reduction in the commercial or sport fishery resources in the Area.

The Company and the Commonwealth, therefore, agree that biological fishery studies will be undertaken or arranged for by the Commonwealth to determine the changes in the distribution of important fish species in the Area that may be brought about by the construction and operation of the Plant. These studies will include a determination of the life stages and distribution of important fish species, their ability to avoid, survive or benefit from the heat discharge waters, the currents generated by the operation of the Plant and the fish screens at the intake structures.

One of the objectives of the above studies is to develop bases for recommendations relative to the design and operation of the Plant that would prevent a significant overall reduction in the commercial or sport fishery resources in the Area.

১৫০

635

9

100

B. Field Investigations:

Objectives:

1. To determine the seasonal distribution, concentration and utilization of marine life in the Plymouth area and, more specifically, in the proximity of the proposed power plant.
2. To determine the water temperature pattern at various tidal stages before the plant is in operation and to measure the thermal pattern which results after the warmed water discharge commences in order to evaluate possible effects on the marine biota.
3. To study the intake and discharge structures and their operation to determine their effect on the various forms of marine life in the area.

Explanation:

It is known that the seasonal and spatial distribution of marine fishes in the Plymouth area vary considerably. Fish species have significant variations of distribution in time and space depending upon their stage of growth. The Plant site is on an exposed, rocky section of coastline quite different from areas previously studied in coastal Massachusetts or New England. For this reason basic fish inventories will be included in the field studies.

Fishes are highly sensitive to temperature changes, particularly those which occur suddenly. In order to properly evaluate the effect of the warm water effluent on the fishery, temperature patterns in the Rocky Neck area at various tidal stages will be determined before and after the plant goes into operation.

Procedures:

Qualitative and quantitative collections of marine life throughout each year of the program at selected stations in the Plymouth area will be made. This activity will be designed to sample both the vertical and horizontal distribution of marine organisms at various distances from the plant site including

selected control locations which are sufficiently remote from the plant site to be unaffected by plant operation.

A survey of existing fisheries will be made to determine what species are involved, the magnitude of the catch, seasonality of the fishery and amount of effort expended. A comparison of these pre-operational data in conjunction with similar statistics from control locations collected while the plant is in operation will provide a reference from which any significant changes in the fishery, due to plant operation or other causes, can be detected and evaluated.

The thermal patterns for the various tidal stages and seasons will be determined through the use of thermographs and electrical resistance thermometers both before and after the plant is put into operation. Where available, temperature records from other sources will be utilized as much as possible. Records of fish distribution and relative abundance will be correlated with these data. When operating thermal contours have been established for the area of discharge, this information will be applied to the laboratory investigations concerning the effects of increased water temperatures on various species.

Factors such as intake velocity, type of screening employed, effect of turbulence and other physical features will be studied with a view towards modification, if warranted.

Duration of Study:

March 15, 1969 to February 28, 1973

Cost: \$147,000

<u>Principal Features</u>	<u>First*</u> <u>Year</u>	<u>Second</u> <u>Year</u>	<u>Third</u> <u>Year</u>	<u>Fourth</u> <u>Year</u>
Personnel Salaries: Project leader, marine biologist, marine technician temporary help secretarial service	\$15,000	\$32,000	\$32,000	\$32,000

<u>Principal Features (con't)</u>	<u>First*</u> <u>Year</u>	<u>Second</u> <u>Year</u>	<u>Third</u> <u>Year</u>	<u>Fourth</u> <u>Year</u>
Major Equipment	6,000	2,000	2,000	2,000
Travel Expenses	1,000	1,000	1,000	1,000
Equipment Maintenance & Miscellaneous Supplies	2,000	2,000	2,000	2,000
Vessel Time (30 days at \$100/day)	3,000	3,000	3,000	3,000
Totals	\$27,000	\$40,000	\$40,000	\$40,000

*During the first year of the project, personnel will work on a half-time basis.

C. Laboratory and Specialized Investigations:

Laboratory investigations and specialized studies will be conducted under subcontract to the Commonwealth.

Objectives:

To determine the effect of both short term and long range temperature changes on important species of finfish, crustacea and algae in the Plymouth area.

Explanation:

The laboratory studies will be designed to provide detailed information not capable of being derived from the field investigations. This will include laboratory analysis of exposure panels recovered from the waters off the plant site to determine growth of various fouling organisms and seasonal variations in these organisms both before and after plant operation.

Long term temperature changes on selected organisms will be carried out in the laboratory to determine whether exposure to these above normal temperatures may seriously interfere with or benefit the life history of any given species. Special emphasis on the effects of temperature on Irish moss and lobsters will be included in these studies. The results of the laboratory

analysis will be correlated with data collected in the field.

Procedures:

Exposure panels will be collected on a regular monthly basis by the field investigators and turned over to the laboratory for detailed analysis. These panels will be taken from a minimum of three different sites and will include both short term and long term exposure panels. Short term panels will be utilized to determine which attaching organisms attach during each month and the long term panels will be used to gain growth information over extended periods.

Using specialized laboratory equipment, studies on the long term effects of temperature on various species will be conducted in the laboratory. Such studies will include histological analysis of various tissues, especially gonadal tissues, to determine possible effects on these organs by the changed temperature regime.

A special detailed study of the life history of the Irish moss will be conducted since very little is known of the basic processes of this valuable marine product. Studies on the effect of temperature on growth rates, reproduction, etc. will be carried out. Special attention will be given to those factors which may be significantly altered by the construction and operation of the plant.

Duration of Study:

March 1, 1969 to February 28, 1973

	<u>First Year</u>	<u>Second Year</u>	<u>Third Year</u>	<u>Fourth Year</u>
Cost:	\$30,000*	\$30,000*	\$30,000*	\$30,000*
Total Cost:	\$120,000			

*Includes \$10,000 for each year for special study of Irish moss.

MAR. 11, 1969

To Study Effect Of Nuclear Plant On Marine Life

STATE HOUSE, BOSTON. — Gov. Sargent today accepted the contribution from the Boston Edison Co. to finance a study of the effect of the Plymouth Power Plant on Marine Resources.

Sargent granted approval to Commissioner of Natural Resources Arthur Brownell to accept \$277,000 from Boston Edison to finance a four-year study of the biological effects of the new Plymouth Nuclear Power Station at Rocky Neck, Plymouth, on the Marine Resources of the area.

The Governor said these studies will result in recommendations to protect Marine Resources of the Commonwealth from any harmful effect that might result from the operation of this plant.

0 2 3 3 9 0 8 6 9



OFFICE OF THE DIRECTOR
DIVISION OF WATER
POLLUTION CONTROL

The Commonwealth of Massachusetts

Water Resources Commission

State Office Building, Government Center

100 Cambridge Street, Boston 02202

January 8, 1969

Boston Edison Company
800 Boylston Street
Boston, Massachusetts 02199

Gentlemen:

Upon receipt of your application on October 17, 1968 for a Permit Pursuant to Section 43, Chapter 21 of the Massachusetts General Laws for the discharge of industrial wastes from Pilgrim Station into Cape Cod Bay, this Division has reviewed your report entitled "Pilgrim Station No. 600, Boston Edison Company, Salt Water Use and Waterfront Development for Pilgrim Nuclear Power Station."

This Division hereby issues to the Boston Edison Company an interim permit, having an expiration date three years following the Power Station's initiation of operation date. However, the interim permit is subject to the following provisos:

1. That radiological and ecological studies of the receiving waters as previously discussed with members of the Department of Public Health and the Division of Marine Fisheries, indicate to the satisfaction of these agencies that the discharge of effluents from the station will not be harmful to human or marine life. The permittee shall advise this Division as to who will perform the studies and the starting dates. Further, the permittee shall make any modifications to equipment and/or operations that may be necessary to comply with recommendations resulting from the aforementioned studies.
2. That a method be developed satisfactory to this Division for the operation and control of the use of chlorine in the circulation cooling water system.
3. That the permittee maintain and make available to members of this Division operating records pertaining to the treatment of liquid wastes including levels of radioactivity and to the discharge of effluents to Cape Cod Bay, as are considered necessary by the Division.

Very truly yours,

Thomas C. McMahon
Director

TCM/RC/mpf

0 3 7 0
0 3 3 9
9 2 3

01

March 31, 1969

Mr. H. L. Price
Director of Regulations
Atomic Energy Commission
Washington, D.C. 20545

Dear Mr. Price:

We are pleased to comply with your request for a summary of our program concerning the thermal discharge from the Pilgrim Nuclear Power Station. As you know, the Pilgrim Station is rated at 655,000 kilowatts (net) and is scheduled to be operational in October, 1971. It is located on the shores of Cape Cod Bay near Rocky Point some five miles east and south of Plymouth.

STATEMENT OF THE PROBLEM

The Pilgrim Station will use a portion of the off-shore sea water for condenser cooling. The design flow through the condenser is 311,000 gallons per minute. The full-power temperature rise across the condenser is 28 degrees Fahrenheit and the full-power thermal discharge is 4.3×10^9 BTU's per hour.

It has been determined by the Commonwealth of Massachusetts that the most sensitive use of the off-shore waters is commercial and sport fishing for certain species of finfish, crustacea (lobsters) and shellfish. There is also a commercial harvest of Irish moss in the area.

SUMMARY OF THE PROGRAM

A six-year program of studies on the thermal discharge from the Pilgrim Station was begun in early 1967 and is scheduled to be completed in January 1973.

The objective of the program is to assure that every reasonable precaution is taken in the operation of the Pilgrim Station to prevent a significant overall reduction in the commercial or sport fishery resources in the area.

The program can be divided into two, overlapping phases. The Phase-1 studies were used to establish the design of the breakwaters, intake structure and discharge canal. These studies were guided by consultants that are recognized authorities in the fields of coastal engineering, physical oceanography, cooling water dispersion and marine ecology as well as by comments and suggestions from the Division of Marine Fisheries of the Commonwealth of Massachusetts and the Fish and Wildlife Service of the Department of the Interior. Phase-1 included model studies at the Alden Research Laboratories and the Massachusetts Institute of

March 31, 1969

Technology.

The Phase-2 work consists of a four-year, before-and-after operation, field and laboratory study. This work is being conducted by the Massachusetts Division of Marine Fisheries under a \$279,000 grant to the Commonwealth of Massachusetts by the Boston Edison Company. They are expected to confirm the predictions made at the conclusion of the Phase-1 studies. These studies will document, through field surveys, any changes in the distribution of important fish species that may be brought about by the construction and operation of the plant.

An administrative and Technical Committee will coordinate the work, review the results and provide overall supervision of the program. The committee will include representatives of the Commonwealth and Boston Edison and, to the extent possible, representatives of the Massachusetts Division of Water Pollution Control, the U.S. Bureau of Commercial Fisheries, the U.S. Bureau of Sport Fisheries and Wildlife and the Federal Water Pollution Control Agency.

DOCUMENTATION

Documentation of the planning, conduct and results of the several tasks and sub-tasks that make up the total six-year program occur in several interim reports and in correspondence among the parties involved. It also includes testimony taken at the Public Hearing that was held by the AEC before the issuance of the construction permit.

We believe that the most complete and factual information is contained in the following documents:

1. Salt Water Use and Waterfront Development for the Pilgrim Nuclear Power Station; Bechtel Corporation, October 1968
2. Agreement between the Commonwealth of Massachusetts and Boston Edison Company; March 14, 1968 and the
3. Interim Permit for the Discharge of Industrial Wastes issued by the Water Resources Commission, Commonwealth of Massachusetts; January 8, 1969.

Two copies of each of the above three documents are enclosed. We are also enclosing two copies each of two newspaper clippings that give an indication of the local interest in the Pilgrim Station and the thermal discharge from the station.

THE CONDUCT OF THE PROGRAM

The program began by establishing the existing temperature distributions in Cape Cod Bay and how these temperatures are affected by the winds, the tides and the daily and seasonal variation in air temperatures. We then

March 31, 1969

made a prediction of the direction and the extent of the three-dimensional thermal plume resulting from the discharge of the condenser-cooling water with due consideration for the topography of the bottom of Cape Cod Bay adjacent to the plant and the proposed design of the breakwaters, the discharge canals and the intake structures. With this information we made a prediction of the effects of the thermal discharge on existing sport and commercial fisheries and modified the proposed designs as required until we reached a satisfactory solution.

In performing these studies we have been guided by our consultants and the valued suggestions of the Department of Marine Fisheries of the Commonwealth of Massachusetts and the Fish and Wild Life Service of the Department of the Interior. Our consultants are:

Coastal Engineering - R. O. Eaton and Dr. A. T. Ippen,
both of the Massachusetts Institute of Technology;

Physical Oceanography and Cooling Water Dispersion -
Dr. D. W. Pritchard, Chesapeake Bay Institute;

Ecology - Dr. John H. Ryther, Woods Hole Oceanographic
Institute.

The original oceanographic studies of the existing conditions were made by Dames and Moore. Later studies were made by Marine Advisers under the direction of Dr. Pritchard through literature searches, drogue and dye (ocean current) studies, and the installation and operation of off-shore instrumentation to measure sea temperatures and currents.

Hydraulic studies using a scale model of the topography of Cape Cod Bay in the vicinity of the Pilgrim Station were conducted to establish the height, contours, and location of the breakwaters and discharge canal. These were performed at the Alden Research Laboratories of the Worcester Polytechnic Institute at Holden, Massachusetts under the direction of Dr. L. J. Hooper and Dr. L. C. Neale.

Using this information and a second scale model, that included the proposed design of the off-shore structures, a hydraulic thermal model study of the cooling water dispersion in Cape Cod Bay was performed at the Hydrodynamics Laboratory of the Massachusetts Institute of Technology at Cambridge, Massachusetts under the direction of Dr. A. T. Ippen and the technical supervision of Professor Donald R. F. Harleman.

Dr. D. W. Pritchard, of the Chesapeake Bay Institute, used the results of the oceanographic and scale model studies to estimate the distribution of the temperature rise above ambient in the Cape Cod Bay under a range of tide and weather conditions.

Dr. John H. Ryther, of the Woods Hole Oceanographic Institute, then used

March 31, 1969

Dr. Pritchard's work, together with his own knowledge of the marine ecology of Cape Cod Bay and adjacent waters; to predict the effects of the operation of the Pilgrim Station on the commercial and sport fisheries in the area adjacent to the plant discharge.

Finally, we authorized the four year, before-and-after studies of the oceanographic distribution and the commercial "catches" of the important marine fisheries, the food chains that support these fisheries and a more basic study of Irish moss, an article of commerce that is harvested near the Plant site.

RESULTS TO DATE

The results of the studies to date have enabled us to choose a design for the off-shore breakwaters, intake structure and discharge canal that, to the best of our belief as well as the belief of recognized experts, will serve the combined functions of: (1) protecting the plant from wave actions due to the worst foreseeable combinations of high tides and storms at sea, (2) effectively separating the warm water in the discharge and cool water in the intake and (3) assuring that the operation of the Pilgrim Station will not have an adverse effect on the important commercial and sport species of finfish, crustacea and shellfish.

There is some reason to expect, but no assurance at this time, that the resulting warmer waters may have a beneficial effect on some important species, in particular the lobster population.

Intake Structure

The design of the intake structure is such that the condenser cooling water will be taken below minus 12 feet, mean sea level. The design inlet velocity of the entering sea water is about 1 ft/sec.

The Salt Water Use Report contains the following comments on the design of the intake structure; "The velocity into the intake structure is about 1 ft/sec., this being low enough to prevent fish being forced into the structure. Trash racks . . . will prevent fish from reaching the pump chambers.", and "The low velocity of the intake will also help prevent fish and other marine organisms from being attracted to, concentrated by, and eventually caught up in the intake . . . most of the lobster larvae will (avoid being entrained in the condenser cooling water) because the cooling water will be taken below minus 12 ft. mean sea level".

Effects on Commercial and Sport Fishing

The most important commercial and sport fishing that now takes place in the off-shore waters is lobstering. Selected quotes on this subject from the Salt Water Use Report are: "Most of the pot fishing (for lobsters)

March 31, 1969

is done within a mile from the shore in depths of 30' or less Several independent estimates placed the annual landings from the area under consideration (the one square mile described above) at above 200,000 lobsters." and "Sport fishing does not appear to be an important recreational resource of the area under consideration. Few, if any, shell fish are taken commercially from the intertidal shore line in the vicinity of the Pilgrim Station".

The Effects of the Thermal Discharge

The effects of the thermal discharge from the Pilgrim Station, based upon the design of the discharge structure that evolved as a result of the model studies, are best summarized by the following quotations from the Salt Water Use Report:

"In view of the fact that most, if not all, of the marine species of commercial importance are bottom living organisms, it is preferable to discharge the heated water as a thin surface layer over a large area rather than confining it to a smaller area by mixing it vertically."

"Pritchard's evaluation of thermal and radiological dispersion . . . indicates that the desirable objective of rapid mixing, combined with a relatively thin surface of warmer water, appears to have been achieved by the proposed design."

"Generally speaking, few if any harmful effects to the commercially important species of the area are to be expected as a result of the warm water discharge, at least beyond a mixing area in the immediate vicinity of the discharge. There are two reasons for making this assumption. First, the temperature of the water in Cape Cod Bay is, on the whole, rather cold, averaging no more than just above 60°F in mid-summer. Most of the marine species of commercial importance are representatives of a temperature-water fauna which also occur south of Cape Cod in considerably warmer water. The above statement holds true for lobster, the most important commercial species of the region. The one possible exception to the above generalization is the Irish moss. This seaweed is a northern species which cannot survive in warm water. Surprisingly, for a species of its commercial importance, its temperature tolerances are not known."

CONCLUSIONS

All of the above predictions will be tested and evaluated during the four-year, before-and-after field studies.

The biggest open question at this time is the effect of the operation of the Pilgrim Station on the Irish moss harvest. This uncertainty is largely

Mr. H. L. Price

- 6 -

March 31, 1969

due to the scarcity of scientific information about this marine alga. The before-and-after studies to be conducted by the Commonwealth include basic studies on the growth habits of Irish moss. It is known that Irish moss attaches itself to rocks and that it prefers to grow in cool water. We believe that it will find the rocks used for the breakwater compatible with its needs and that it will flourish on both the inlet and outlet sides of the breakwaters.

The harvest of Irish moss in the Rocky Point area is now a one-family industry. The owner of this industry, or his attorney, has appeared at two public hearings concerning the issuance of permits for the off-shore work and he has gone on record to the effect that he does not oppose the work that is to be performed.

A final matter that bears on the subject of the effects of the operation of the Pilgrim Station on sport fishing is that, at the suggestion of the Commonwealth, we plan to construct an access road, a parking lot and a bridge across the discharge canal to the longer breakwater so that the public can take fish from both sides of the breakwater.

Very truly yours,

Claude A. Purse
Ass't Vice President

CAP/1h

Encls.

Edison replies in detail to queries by Plymouth Conservation Commission

The Plymouth Conservation Commission has been active during the past months in determining the effects of heated water discharge from the nuclear Pilgrim Station on the flora and fauna of the bay. John Loupos, commission vice chairman, has taken the initiative in this effort.

Mr. Loupos says that he has received 100 per cent cooperation from Boston Edison in replying to all his questions, some of which came up after a meeting of 35 area lobstermen concerned about possible effect of heated water on what they estimate to be a \$250,000 yearly business.

In response to queries from Mr. Loupos, Boston Edison, over the signature of William F. Hamm, district manager, sent the following information in a letter to the commission vice chairman.

"We want to thank you for forwarding the item from the 'Maine Coast Fisherman' about the conditions imposed on the discharge from the Maine Yankee Atomic Power Plant.

"We believe that the net effort of the conditions that we have already voluntarily imposed on the discharge from the Pilgrim Station are at least as stringent as those re-

quired of Maine Yankee. We divided our consideration of the effects of the Pilgrim Station discharge into three parts. These are — the discharge of toxic materials, the discharge of radionuclides and the discharge of heated water.

"The potentially toxic materials are used to control the growth of algae and mussels in the intake and discharge pipes. We will assure that these materials are diluted to such levels that they are not toxic to the aquatic life in Cape Cod Bay.

"The radioactivity of the
(Continued on Page 8)

7
SOLD COLONY MEMORIAL
CO (PLYMOUTH)

0 Sept. 12, 1968

0 2 3 3 9

Edison gets okay

(Continued from Page 1)

condenser cooling water discharge will be monitored and kept well below the levels that would make them unfit for drinking water (if the water were fresh). We will begin a program of radioactivity measurement about two years before the plant starts up and plan to continue these measurements throughout the operating life of the plant. In the beginning we will measure the radioactivity that is now present in the shellfish due to the concentration of radionuclides that naturally occurs in all sea water. The measurements after plant startup will determine the amount that is added due to the discharge from the Pilgrim Station. We will not permit any reconcentration to render the shellfish or other edible aquatic life unfit for human consumption. Our work will be monitored by the Atomic Energy Commission and by the Commonwealth of Massachusetts.

"As for the thermal effects, our goal is to assure that the net effect is beneficial or at least not harmful when one considers all of the fish and shellfish that are used for food and sport in the surrounding waters.

"We and our consultants expect that the warmer water will float to the surface of the bay and will be directly beneficial to some species such as stripers. We expect

it may be indirectly beneficial to lobsters by increasing their food supply. The temperature in the water at the depths normally inhabited by the lobsters will not be affected. On the other hand, we expect that the warmer water may be harmful to some species in the region immediately adjacent to the outlet of the discharge. We now have detailed studies under way at Alden Laboratories, MIT, and Woods Hole Oceanographic Institute. The purposes of these studies is to predict the net effects on aquatic life and to develop a program of measurements to test our predictions. During the year immediately prior to startup, we will measure the population density of the species of fish and shellfish that are important for food or sport in the vicinity of the plant discharge. We will continue this program for about a year after startup to measure any changes in the population of aquatic life that may have occurred.

"In summary, we believe that the goals that we have imposed upon ourselves are as stringent as those imposed on the Maine Yankee Plant. We further believe that our planned programs will permit us to document that we have reached our goals.

"If we can be of any further assistance please write or call this office.

PILGRIM STATION NO. 600
BOSTON EDISON COMPANY

SALT WATER USE AND WATERFRONT
DEVELOPMENT FOR PILGRIM NUCLEAR
POWER STATION

0 2 3 3 9 0 8 7 8

Bechtel Corporation
San Francisco, California
October, 1968

TABLE OF CONTENTS

PAGE

1.0	INTRODUCTION	
1.1	Location	1-1
1.2	Scope	1-1
1.3	Consultants	1-1
2.0	SITE ARRANGEMENT	
2.1	Station Arrangement	2-1
2.2	Waterfront Development	2-1
3.0	PHYSICAL OCEANOGRAPHY	
3.1	Introduction	3-1
3.2	Oceanographic Study Program	3-1
3.3	Tide Levels	3-2
3.4	Ocean Temperatures	3-2
3.5	Ocean Currents	3-6
4.0	HYDRAULIC STUDIES	
4.1	Introduction	4-1
4.2	Wave Action Study	4-1
4.3	Thermal Model Study	4-3
5.0	STATION LIQUID EFFLUENTS	
5.1	Introduction	5-1
5.2	Thermal Effluents	5-1
5.3	Radioactive Liquid Effluents	5-1
5.4	Non-Radioactive Liquid Effluents	5-5
6.0	COOLING WATER DISPERSION (By Dr. D. W. Pritchard)	
6.1	Introduction	6-1
6.2	Oceanographic Factors Pertinent to Problem	6-1
6.3	Renewal of Waters of Cape Cod Bay	6-7
6.4	Cooling Water Dispersion	6-8
6.5	Distribution of Excess Temperature	6-9
6.6	Distribution of Radioactive Isotopes	6-13
7.0	ECOLOGY (By Dr. John H. Ryther)	
7.1	Introduction	7-1
7.2	General Description of Region	7-1
7.3	Hydrography	7-2
7.4	Commercial and Sport Fisheries of the Area	7-3
7.5	Predicted Marine Biological Effects	7-6
7.6	Recommendations	7-8
7.7	Conclusions	7-10

TABLE OF CONTENTS (Continued)

PAGE

8.0 ENVIRONMENTAL PROGRAMS

8.1 Environmental Radiology Program

8-1

8.2 Environmental Ecology Program

8-2

9.0 REFERENCES

9-1

10.0 PLATES

Plate 1 Site Plan

Plate 2 Temperature Stations

Plate 3 Oceanographic Instrumentation

Plate 4 Breakwater and Shore Protection

0 8 8 0
0 3 3 9
0 2 3 3 9

SALT WATER USE AND WATERFRONT DEVELOPMENT

FOR

PILGRIM NUCLEAR POWER STATION

1.0 INTRODUCTION

1.1 Location

The site of the Pilgrim Nuclear Power Station is in the town of Plymouth on the west coast of Cape Cod Bay near Rocky Point, Massachusetts. It is about 4-1/2 miles east of the town center, as shown on Plate 1. The power station is to be owned and operated by the Boston Edison Company.

1.2 Scope

This document describes the proposed waterfront development; gives the results of model studies and analyses of the action of waves, storms and tides, and thermal effects; presents an analysis of the ecological effects and discusses programs proposed to verify the analysis.

Section 2: A general description of the Pilgrim Station arrangement, with descriptions of offshore and waterfront construction and of the circulating water system.

Section 3: Physical oceanography, incorporating data from existing sources and from recent studies for Pilgrim Station.

Section 4: Pilgrim Station hydraulic model studies performed to assist in evaluating storm protection and dispersion of plant effluents.

Section 5: Chemical, thermal and radioactive characteristics of station liquid effluents.

Section 6: Dr. D. Pritchard's analysis of cooling water dispersion.

Section 7: Dr. John D. Ryther's analysis of marine ecology and effects of station operation.

Section 8: Proposed environmental programs.

1.3 Consultants

This report was prepared with the assistance of the following consultants:

Coastal Engineering

- R. O. Eaton
Dr. A. T. Ippen, Mass.
Institute of Technology

Physical Oceanography and
Cooling Water Dispersion -

Dr. D. W. Pritchard,
Chesapeake Bay Institute

Ecology

- Dr. John H. Ryther, Woods
Hole Oceanographic Institute

Radiology

- Professor Merrill Eisenbud,
New York University Medical
Center

0 2 3 3 9 0 8 8 2

2.0 SITE ARRANGEMENT

2.1 Station Arrangement

The general arrangement of the proposed Pilgrim Power Station is shown on Plate 4. The major buildings on the site include the reactor building, the turbine building, the administration building, the intake and discharge structure for plant cooling water, and the switchyard. Station grade is at +20 feet MSL (+24.8 feet MLW).

2.2 Waterfront Development

Shoreline and offshore structures are required to provide the functional requirements of the cooling water systems in the plant and the necessary protection of the plant under storm conditions. They will consist of: 1) a pump house and screen well near the shoreline with protective breakwaters along a dredged intake channel; 2) a discharge head works near the shoreline with a dredged outlet channel which is protected by short jetties. The waterfront development is shown on Plate 4.

The breakwaters and jetties will be of rubble mound construction; both will be protected by heavy capstone. The breakwater on the north-west will be approximately 2000 feet long and the breakwater on the south-east will be approximately 930 feet long. Top elevation of both breakwaters is +11 feet MSL. (approx. +16 feet MLW).

The breakwaters are required to prevent rapid siltation of the dredged channels. They also provide a first line of defense, to protect the intake structure and sea wall from excessive wave action and overtopping due to wave run-up, and to limit storm flooding of the plant site.

The sea walls on either side of the intake structure will provide shore stabilization and prevent flooding of the reactor building by wave overtopping during severe storms. They are designed to act as a second line of defense in conjunction with the breakwaters such that any overtopping that might occur under the extreme design storm tide level of +13.5 feet MSL (+18.3 feet MLW) would not affect the reactor building or the emergency systems required to safeguard the reactor.

The cooling water intake structure houses two sets of pumps. One set provides cooling water for the condenser (circulating water system) and the other set provides cooling water for the service water system. The service system pumps supply cooling water for the reactor and turbine building closed cooling systems. These systems remove heat during normal, shutdown, and accident conditions. It is essential that the service water pumps function properly even under extreme storm or tide conditions. The waterfront development is designed to prevent overtopping of the intake structure, and assure continuous operation of the service system.

To minimize mixing of warm surface water with cooler bottom water and thus improve plant efficiency it is necessary to maintain low velocities inside the breakwaters. To maintain such velocities, the dredged channel width at the entrance between the breakwater crests will be 675 feet. Channel invert will vary from -25 feet MSL just in front of the intake structure to -20 feet MSL at the entrance. Channel depths, the transition slopes between them, and channel widths are shown on Plate 4.

A skimmer wall at the front of the intake structure is designed to assist in preventing the warmer surface water from entering the intake structure; the skimmer also acts as a trash and ice barrier. The bottom of the skimmer wall is at Elevation (-) 12 MSL. The velocity into the intake structure is about 1 ft/sec, this being low enough to prevent fish from being forced into the structure. Trash racks (3" clear between bars) and traveling screens (3/8" square openings) will prevent fish from reaching the pump chambers.

The discharge structure and channel are to the northwest of the intake structure as shown on Plate 4. The circulating water system and the service water system will discharge through this channel back to the sea. Other process system liquid effluents from the station are discharged into the circulating water system for dilution before entering the discharge channel.

The discharge channel is approximately 870 feet long and is extended over the beach to mean low water by rock-fill breakwaters. The breakwaters have a nominal elevation of +16 MLW (approximately +11 MSL) sloping down to a height of 4 ft. at MLW. The elevation of the bed of the discharge channel is 0 ft. MLW.

The water velocity at the outlet of the channel will be about 8 ft/sec at mean low water and 2 ft/sec at mean high water. These high water velocities in the discharge channel are provided to promote mixing of the heated water with colder sea water at the point of discharge from the channel.

The discharge channel jetties will also serve as protection of the intake and discharge structures from wave action.

3.0 PHYSICAL OCEANOGRAPHY

3.1 Introduction

General oceanographic data from outside sources has been supplemented by Boston Edison's Oceanographic Study Program conducted specifically for the Pilgrim Station Site.

3.2 Oceanographic Study Program

3.2.1 Scope

The Physical Oceanography Program at Pilgrim Station has included:

- (a) Preliminary drogue studies and collection of sea temperature data by Dames and Moore (1967).
- (b) Interim drogue studies (November, 1967).
- (c) Extended drogue and dye studies (August, 1968).
- (d) Installation and operation of an offshore instrumentation station to measure sea temperatures and currents.

Condensed data developed by the program is included in this section of the Report.

3.2.2 Offshore Instrumentation Station

The location and details of the Offshore Instrumentation Station, "Station B", are shown on Plates 2 and 3. The instrumentation station site, at the -30 foot contour (Mean Low Water Datum), has been selected as highly representative of the area in which a thermal plume will be created.

The station consists of an elastically moored buoy, supporting an equipment array which includes thermistors and current meters, with a submarine cable connection to an onshore recorder.

Temperature measurements are made by three sensors or thermistors located 2-feet, 9-feet, and 15-feet respectively below still-water level, and by a fourth located 2-feet off the bottom.

Instrumentation for current magnitude and direction measurements consists of one Marine Advisers Q-15 meter close to the surface and one Marine Advisers Q-16 meter 3-feet above the sea-bed.

Recording instruments on shore print out a digital record of readings from the current meters and temperature sensors.

The instrumentation was installed in late April, 1968 but following four weeks of service, it was damaged by wave action, and recording was temporarily suspended. Multi-level temperature records were obtained by hand sampling between June 29, 1968 and August 10, 1968, at which time the offshore station was returned to service.

3.3 Tide Levels

Tides at the Pilgrim Station site are of the semi-diurnal type, with two highs and two lows occurring each day. Tide records for this area are available from Coast and Geodetic Survey Tide Stations in Boston Harbor and at the eastern entrance to Cape Cod Canal. Tide levels at the Pilgrim Station site are similar to those at Boston. The mean tidal range is 9.1 feet and the spring tidal range is 10.6 feet. The datum relationship at the Pilgrim Station site is that Mean Sea Level is 4.78 feet above Mean Low Water.

The highest still-water tide level ever recorded in this area is +10.5 feet MSL. This level occurred at Boston on February 24, 1723 and has not been repeated. Tide levels of +10.0 feet MSL have occurred twice; once in 1851 and again in 1909. The extreme design storm tide level selected for Pilgrim Station of +13.5 feet MSL is 3.0 feet higher than has been observed in the Boston Harbor area in 244 years of record.

The estimated average yearly maximum astronomical high tide is +11.5 feet MLW, and the estimated average yearly minimum astronomical low tide is -2.3 feet MLW. These water elevations are expected to occur once every year.

It has been calculated that the 100-year storm could produce a still-water level of +15.8 feet MLW. This is a combination of storm surge combined with astronomical high tide. This tide level is based on tide data for 1922 to 1960 and is from Figure 27 of NHRP Report No. 68, "Criteria for a Standard Project Northeaster for New England North of Cape Cod," Hydrometeorological Section, Hydrologic Services, Washington, D.C. This tide level is 0.5 feet higher than the high tide of 1723.

Studies have shown that in the Cape Cod area, northeast gales produce higher storm surge than do hurricanes due to their longer fetch and longer duration. The Hydrometeorological Section of the U. S. Weather Bureau, which has conducted these studies, has established a Standard Project Northeaster for New England. Using this storm, the peak storm surge, having a return frequency of 1,000 years, is 6.6 feet. The concurrence of peak storm surge with an astronomical high tide of +11.7 feet MLW would give an extreme storm tide level of +18.3 feet MLW, with a probability of occurrence of once every 4,000 years. This extreme storm tide level of +18.3 feet MLW has been used as the maximum design tide level.

3.4 Ocean Temperature

3.4.1 Introduction

This sub-section reviews ocean temperature records for the Cape Cod Bay Area and presents some recent data obtained offshore, adjacent to the Pilgrim Station. The locations of temperature stations are shown on Plate 2.

3.4.2 Data Sources

The longest term measurements of sea-water temperatures in Cape Cod Bay are those made at Coast and Geodetic Survey Tide Stations. (1,2). Two Tide Stations were considered in this study: Boston, north of the site and the eastern entrance of Cape Cod Canal, south of the site. Surface temperatures are measured daily at each station by a single bucket thermometer. The depth of water at both tide stations is about 10 feet at mean low water. Records are available for Boston from 1922 to 1962, and for Cape Cod from 1955 to 1962. In addition, there has been continuous measurements of bottom water temperature at Boston since 1955.

The World Atlas of Sea Surface Temperatures (3) is a source of mean monthly temperatures for the Cape Cod area. Published in 1944, these figures are the results of a number of temperature surveys in the North Atlantic.

Data is available from the Woods Hole Oceanographic Institute, Woods Hole, Massachusetts (4). The data consists of bathythermograph records for stations throughout the western half of Cape Cod Bay. These measurements were made by oceanographic research vessels, and records date back to about 1880. None of these measurements are continuous recordings. All are spot measurements made on one day. Similarly, there is rarely more than one measurement for any particular point in the Bay. Also available are monthly averages of all the Woods Hole Data.

Two sets of data are available from the Division of Marine Fisheries of the Massachusetts Department of Natural Resources (5,6). The first set is daily midwater temperature ranges at buoy No. 1, Duxbury Channel, from June to October, 1964. Mid-water Duxbury Channel is approximately 15-feet below the surface. The second set is surface and bottom temperatures made in conjunction with Otter Trawl Samples between 1964 and 1966. The measurements were made mainly during the winter months between Gurnet Point and the entrance to Cape Cod Canal, just off the coast. A total of 18 samples was made.

Data for Station "A", approximately 3.5 nautical miles northeast of the site, is presented in a report by Dames and Moore. (7) The water depth at this location is 115 feet. Temperature profiles were recorded at Station "A" between December, 1924 and June, 1925. A total of 12 readings were made.

3.4.3 Pilgrim Station Records

Sea-water temperatures have been recorded for this project close offshore at Plymouth during August 1967, between April 26, 1968 and May 21, 1968 (Offshore Station "B"), between June 29, 1968 and August 10, 1968 (Manual), and between August 12, 1968 and August 29, 1968 (Offshore Station "B").

3.4.4 Data

Figure 1

Figure 1 shows maximum, minimum, and mean temperatures for the Cape Cod Canal and Boston Tide Stations. Also plotted are mean temperatures from the World Atlas of Sea Surface Temperatures. The maximum at Boston is 75°F, while Cape Cod Canal is slightly cooler with a maximum of 74°F during the summer. The mean temperature at Cape Cod Canal is less than at Boston due to much lower minimum temperatures.

The mean temperatures from the World Atlas follow closely the means for the two Tide Stations. The difference in temperatures between Boston and Cape Cod Canal is possibly due to Boston's large estuary and Cape Cod's more exposed location.

Figure 2

Figure 2 shows the temperature structure at Station "A" from December, 1924 to June, 1925. The temperature structure was isothermal between December and April. The warming trend commenced in May and by mid-June a strong thermocline (a water layer of high temperature gradient) had developed between depths of 30 and 60 feet. No data is available to tell how long this thermocline remains. It is important to note that this figure is based on 12 readings and there is, therefore, a good deal of extrapolation of temperature structure.

Figure 3

Figure 3 is similar to Figure 2. The temperatures plotted are from the Woods Hole data for the western half of Cape Cod Bay. Here a temperature stratification is developed about the beginning of June and lasts into October. The thermocline is very weak; however, it must be remembered that these temperatures are averages over the Bay. For each station the thermocline is well-developed and occurs between depths of 30 and 60 feet. Therefore, Station "A" is considered to be fairly typical of Cape Cod Bay at the greater depths encountered further offshore than Station "B".

Figure 4

Figure 4 shows average sea-water temperature measurements recorded at the Pilgrim Station site for the month of August, 1967 and comparable records from Boston U.S.C.&G.S. Station.

The Plymouth temperatures plotted are daily averages of the highest and lowest readings. The highest single reading was 66°F and within a 24-hour period, surface temperature differences of up to 9°F were observed. The differences between Plymouth surface and sea-bed temperatures ranged

between 10°F and 7.5°F. The Plymouth surface temperatures are typically more than 5°F less than those recorded at Boston. However, it must be noted that Boston temperatures between August 7 and August 11 were taken during the early afternoon and are probably close to the daily peaks, leading to relatively poor correlation with Plymouth on those days.

Figure 5

Figure 5 presents 1968 average surface and sea-bed water temperature records from Pilgrim Station and U.S.C.&G.S. surface records for a comparable period at Boston. The site records were obtained from the offshore instrumentation for the periods April 26 to May 21 and August 12 to August 24. Hand samples were used between June 29 and August 10, 1968.

The records show good correlation, with a consistently higher temperature at Boston and a typical differential of about 5° above the surface temperature at Plymouth. The difference between surface and sea-bed temperatures at Plymouth ranges between zero and 10°F, indicating the instability of the thermocline. The incidence of a high surface temperature is accompanied by a relatively low sea-bed temperature. During August, a sharp reduction in both surface temperature and an increase in sea-bed temperature occur together, implying that the vestigial thermocline was lost due to increased mixing of surface and lower water.

3.4.5 Conclusions

The collected sea-water temperature data for Pilgrim Station indicates a temperature pattern similar to both the eastern entrance of Cape Cod Canal and Boston. The temperatures will be cooler at Pilgrim Station than at Boston, where long term records are available.

In deep water a thermocline develops at depths of between 30 and 60 feet during the months of June through October. At -30 MLW, the temperature stratification is less consistent. Although a differential of up to 10°F commonly exists between surface and bottom temperatures, the temperature stratification is very sensitive to disruption by turbulence following wind action when differential temperatures of 1° - 2° are commonly observed. However, the decrease in temperature differential is accompanied by a drop in absolute surface temperature.

Short term natural temperature fluctuations exceeding 7°F are routinely observed at the site within 24-hour periods.

3.5 Ocean Currents

3.5.1 General

The general current regime in Cape Cod Bay is discussed by Dr. Pritchard in Section 6 of this report. Currents more directly related to Pilgrim Station site have been measured and recorded by a series of drogue studies, a dye study and by the offshore instrumentation, which is described earlier in this section.


The regime close to the site is much less well-defined than is the case farther out. Current velocities are much lower. During a period of four weeks during April and May, 1968, currents measured 5-feet below the surface exceeded 0.6 knots for less than 1% of the total time. The counterclockwise movement within the Bay is reduced but not entirely eliminated by the reduction in depth, and proximity of submarine ledges offshore from Rocky Point and Manomet. This basic southeasterly direction is modified but not reversed by tidal action and the resultant currents are small on the surface and almost negligible close to the bottom.

A close correlation between wind and surface water motion was observed in all the drogue tests and also by the dye test. During the latter, conditions were almost wind-free for the early part of the test and the southeasterly movement persisted throughout the tidal cycle. During the latter part of the test, offshore winds approached 10 knots and the direction of dye dispersion closely followed the wind.

The behavior of near-surface currents during four weeks of April and May, 1968, has also been compared with wind records from Boston Edison's on-shore weather station. Close correlation was established between wind and surface water movements. Wind influences normally decrease sharply with depth and are occasionally offset by upwellings and reversals in direction of lower level flow.

3.5.2 Conclusion


The correlative movement of water at the site is southeasterly in direction and corresponds to the well defined counterclockwise movement farther out. The basic direction is modified but not reversed by tidal action. The net southeasterly movement probably averages less than 0.1 knots over the entire depth. Short-term surface currents are closely correlated to wind action which is more readily detected than tidal effects. The currents at the site are relatively small and highly irregular in magnitude and direction.



FILE 4879-001
 BY J. J. J. J.
 CHECKED BY: _____
 DATE: 10/10/55

0 2 3 3 9 0 8 9 2


INFORMATION
 BY: _____
 DATE: _____
 BY: _____
 DATE: _____
 PLATE: _____
 OF: _____



WINTER AND SPRING TEMPERATURE STRUCTURE
 1924-1925 AT STATION "A" SECTION 3 - FIGURE 2

K&E 10 X 10 TO THE CENTIMETER 46 1512
 MADE IN U.S.A.
 KEUFFEL & ESSER CO. 3 3 9

0 8 9 3




Temperature Structure in Western Half of Cape Cod Bay (°F.)

Data is from Woods Hole Oceanographic Institute

SECTION 3-FIGURE 3

0 2 3 3 9 0 3 9 4




1967 TEMPERATURES

Pilgrim Station & Boston

Pilgrim Temps. are averages of highest & lowest daily readings.
SECTION 3 - FIGURE 4

0 2 3 3 9 0 8 9 5



For Instrumentation Site
& Details
See Plate 3

1968 TEMPERATURES
Pilgrim Station & Boston.

4.0 HYDRAULIC STUDIES

4.1 Introduction

Hydraulic Model Studies performed for waterfront development at Pilgrim Station have investigated the following:

- (a) Wave action and site storm protection.
- (b) Thermal dispersion of circulating water effluent.

4.2 Wave Action Study

A series of wave action model studies has been performed in two phases at the Alden Research Laboratories of Worcester Polytechnic Institute at Holden, Massachusetts under the direction of Dr. L. J. Hooper and Dr. L. C. Neale.

4.2.1 Objectives

The purpose of the Alden Model Studies has been to assist in developing the design of the waterfront development including the breakwaters and jetties, the intake and discharge channels and the on-shore revetments. The effectiveness of the selected design in protecting the plant site and circulating water system against wave action has been demonstrated and evaluated.

4.2.2 Model Construction

The Alden Model has been constructed to an undistorted scale of 1:50. It is a fixed bed model, with topography simulated by a thin layer of cement mortar on compacted sand. Vertical control is provided for the topography and the improvements by wooden templates spaced at 3-foot intervals.

Crushed rock has been used to simulate the armor protection of the breakwaters, shoreline, and discharge channel. The reinforced concrete intake structure is modeled in wood. Water circulation through the intake structure is provided by a small electrically driven pump, flow being measured using an orifice plate and manometer. Station buildings protected by the waterfront improvements are simulated in the model.

4.2.3 Wave Generation

Wave generation is by means of a paddle maker 40-feet long, with a variable stroke and speed capable of producing waves of variable heights and periods, including wave periods of 8, 10 and 12 seconds, which are those most likely to occur at the site during a severe storm. Preliminary tests indicated that an 8-second wave period produced less severe conditions than 10 and 12 second periods.

Wave heights are measured with 9 variable resistance probes and recorded on a 10 channel moving mirror galvanometer oscillograph.

4.2.4 Test Program

The proposed design has been subjected to tests at four still-water elevations:

- (a) El. +11.5 MLW, the estimated average yearly maximum astronomical tide.
- (b) El. +15.8 MLW, the level of the 100 year storm, expected not more than once during the life of the installation.
- (c) El. +18.3 MLW, the design maximum tide level with a 4,000 year return frequency.
- (d) El. +19.5 MLW, an arbitrary elevation which exceeds any postulated design condition and is the highest elevation at which the model can be operated satisfactorily.

Slope protection and the effectiveness of the breakwaters were evaluated by tests at all four still-water elevations during which waves were simulated from due north and from N 60 E, with wave periods of 10 and 12 seconds. The wave heights were adjusted to give maximum run-up at the intake structure and revetments. The critical condition was obtained with a 12 second period.

4.2.5 Test Results

Test results indicated adequate reduction of the generated wave at the intake structure. Minor overtopping of the adjacent seawall occurred at the higher elevations (18.3 MLW and 19.5 MLW) but flooding was limited to the open space north of the reactor building, which was itself at no time subjected to flooding. The limited overtopping which occurred would have no effect on the emergency core cooling water pumps or the service water pumps which are enclosed in a structure water protected to an elevation of approximately +28 MLW.

Test results were documented by moving and still photography.

4.2.6 Intake Structure Oscillations

A special series of tests was conducted to insure that unduly adverse conditions for intake pump operation could not be generated by wave action. It was observed that with typical still-water elevations even severe wave action produced very minor fluctuation of the water surface elevation. It was possible to develop a resonant condition with

0 2 3 3 9
0 3 9 8

wave periods of approximately 14 seconds at still-water levels of 18.3 MLW and 19.5 MLW, but even the greatest amplitudes of surface movement obtainable were within the range tolerated by the pumps.

4.3 Thermal Model Study

A hydraulic scale model simulation of cooling water dispersion has been performed at the Hydro-Dynamics Laboratory of Massachusetts Institute of Technology at Cambridge, Massachusetts, under the general direction of Dr. A. T. Ippen and the technical supervision of Professor Donald R. F. Harleman.

4.3.1 Objectives

The primary objectives of the M.I.T. Model Study have been:

- (a) To demonstrate the locations of isotherms in the thermal plume.
- (b) To determine the magnitude of recirculation of the cooling water, if any.

4.3.2 Thermal Model Construction

The Thermal Hydraulic Model has been constructed within the confines of an existing 27-foot by 46-foot model basin in the M.I.T. Laboratory. The horizontal scale is 1:250 and the vertical scale is 1:40. Approximately 11,000-feet of coastline has been reproduced with a distance from shore of 5,000 to 6,000 feet and a water depth of approximately 40 feet.

Currents are simulated by pumping and draining from either end of the model. Water temperatures are measured by thermistor probes.

4.3.3 Thermal Model Test Program

The Thermal Model of the proposed design has been tested for the following simulated conditions, each with a simulated circulating water flow of 720 c.f.s. and a nominal temperature rise of 28.7°F.

- (a) Still-water Elevation: MLW (0.0)
Current: southeasterly direction, 0.2 knots.
- (b) Still-water Elevation: MHW (+9.4)
Current: southeasterly direction, 0.2 knots.
- (c) Still-water Elevation: MHW
Current: southeasterly direction, 0.6 knots.
- (d) Still-water Elevation: MHW
Current: south-southeasterly direction, 0.6 knots.

- (e) Still-water Elevation: MHW
Current: 0.0 knots.

The tests selected are considered to simulate the most critical conditions for temperature rise and recirculation.

4.3.4 Thermal Model Test Results

Behavior of the model was considered very satisfactory under all test conditions. The following characteristics of the thermal plume were observed:

- (a) The great energy of the discharge was a dominant feature in ensuring thermal mixing and dispersion under all current conditions.
- (b) Double (two-sided) entrainment of cold water was observed in all tests.
- (c) Thermal mixing and dispersion was essentially identical with water surface elevation at Mean High Water and at Mean Low Water.
- (d) Thermal mixing and dispersion were relatively unaffected by currents which included simulated wind-generated movements corresponding to those detected at the site. Thermal dispersion is discussed more fully in Section 6.
- (e) The heated plume extended to a depth of approximately five feet from the surface.
- (f) In none of the tests was significant recirculation observed.

5.0 STATION LIQUID EFFLUENTS

5.1 Introduction

The station utilizes salt water from Cape Cod Bay as cooling water in the circulating water system and in the service water system. The cooling water used in these two systems is separated from potentially radioactive fluids in the process systems by the condenser and by the service system salt water heat exchangers.

The salt water returned to Cape Cod Bay from the station has been modified by the addition of heat or thermal energy and by the addition of liquid wastes discharged from the station. Station liquid effluents are categorized below for discussion as thermal effluents, radioactive effluents and non-radioactive effluents. Table 5-1 is a summary of the station effluents expected to be discharged annually to Cape Cod Bay.

5.2 Thermal Effluents

The thermal effluents consist mainly of condenser circulating water and service water system cooling water. The circulating water system has a normal flow rate of about 311,000 gpm and removes approximately 4.3×10^6 Btu/hr of heat from the condenser resulting in a water temperature rise of about 28°F at rated load. The service water system has a normal flow rate of about 10,000 gpm and removes approximately 7.8×10^7 Btu/hr from the salt water heat exchangers resulting in a water temperature rise of about 16°F during normal station operation. Under emergency conditions postulated for station design, the service water system flow rate could be reduced to about 5,000 gpm while removing about 65×10^6 Btu/hr of heat resulting in a water temperature rise of approximately 25°F in this system. Service water flow rates may be reduced when inlet water temperatures are low in order to regulate temperatures in the station closed loop cooling systems.

Radioactive Liquid Effluents

- 5.3 The liquid radwaste system in the station is designed to collect, process, monitor and dispose of all the potentially radioactive wastes generated in the reactor and turbine systems. The design basis for this system is described below.

5.3.1 Collection of Liquid Radwastes

The liquid radioactive wastes are classified at their point of origin into either of two separate drainage and processing systems, the clean radwaste or the chemical radwaste. The wastes are collected in sumps or drain tanks and are then transferred into either the clean waste receiver tanks or the chemical waste receiver tanks in the radwaste building for processing. Clean radwastes are defined as those liquid

TABLE 5-1

SUMMARY OF ESTIMATED ANNUAL STATION EFFLUENTS

DISCHARGED TO CAPE COD BAY

Type	Annual Volume	Annual Radioactivity Additions	Chemical or Heat Additions
(C.F. = 0.92)			
A. <u>THERMAL</u> (1)			
Circulating Water	1.5×10^{11} gals.	Below limits of 10 CFR20 (2)	4.3×10^9 Btu/hr (3)
Service Water	5.5×10^9 gals.	Below limits of 10 CFR20 (2)	7.8×10^7 Btu/hr (3)
B. <u>RADIOACTIVE</u>			
Clean Radwastes	Normally reused in station..		
Chemical Radwastes	4.0×10^6 gals. = 11,900 GPD	7-50 curies	8.6×10^5 lbs. of Na_2SO_4
C. <u>NON-RADIOACTIVE</u>			
Make-up System	2.9×10^6 gals. = 8,650 GPD = 1 Regen/day	None	66,000 lbs. of dissolved solids and 2,200 lbs. of particulates.

Notes: (1) Normal operation at rated load.

(2) Ocean cooling water is naturally radioactive. The radioactive content of the station effluent will be increased slightly during the controlled release of liquids from the radioactive waste system. The liquid effluent from the radioactive waste system will be below the limits specified in 10CFR20 after mixing with the cooling water.

(3) Addition of hypochlorite to these systems is expected for about one hour each day resulting in residual chlorine of approximately 1 ppm in the effluent during this period.

wastes which have a low conductivity and are potentially turbid. Chemical radwastes have a high conductivity and can be slightly turbid. Floor drainage from those building areas which are under access control are processed as chemical wastes.

5.3.2 Treatment of Liquid Radwastes

Clean radwastes are normally treated in a batch process by first filtering to remove suspended particulate matter followed by demineralization to remove dissolved contaminants. After treatment, clean radwastes are collected in the treated waste storage tanks for sampling and analysis. If this water meets the water quality requirements for condensate, it may be returned to the condensate storage tanks for reuse in the station. If this water is not suitable for reuse in the station, it may be released at a controlled rate to the circulating water effluent.

Chemical radwastes are normally treated in a batch process by first neutralizing the acid and caustic solutions followed by filtering to remove any suspended particles. After treatment, chemical radwastes are collected in the monitor waste storage tanks for sampling and analysis. After analysis, this water will be released at a controlled rate to the circulating water effluent.

Prior to discharge from the station, each batch of liquid radwaste is sampled and analyzed for radioactivity to determine the allowable rate of discharge, ~~of the batch to the circulating water system.~~ In addition, the liquid radwaste discharge line is provided with a continuous radioactivity monitor to record the activity of any liquids released to the circulating water system. After mixing with the circulating water, the radioactivity of liquid wastes discharged from the station will be below the limits specified in 10 CFR 20, Standards for Protection Against Radiation.

5.3.3 Sources and Estimated Amounts of Liquid Radwastes

The radioactive liquid wastes consist mainly of wastes produced during regeneration of the condensate demineralizers and wastes from floor washdown and floor drainage. Additional radwastes are collected from laboratory drains, decontamination wastes, and equipment drainage for maintenance. All laundry will be sent to outside commercial facilities. Clean radwastes are normally reused in the station rather than being discharged. Chemical radwastes produce an estimated annual volume of about 4,000,000 gallons which contains an estimated 862,000 pounds of Na_2SO_4 (from regeneration wastes) to be discharged to the circulating water system.

5.3.4 Radioactivity of Liquid Effluents

The annual release of radioactive substances to Cape Cod Bay from Pilgrim Station is estimated to be between 7 and 50 curies of mixed fission and activation products. This mixture can be expected to include radioactive isotopes of Cobalt-60, Cobalt-58, Manganese-54, Iron-59, Chromium-51, and Zinc-65, with possible additional fission products of Iodine-131 and Cesium-137, Technetium-99, and Molybdenum-99. Depending on the ratios of the various nuclides present, the maximum permissible concentration of such radioactive mixture in water supplies is expected to be in the range of 10^{-6} to 10^{-5} $\mu\text{c/ml}$.

Assuming that 50 curies per year are released at a uniform rate, the average radioactivity of the circulating water at the point of discharge into Cape Cod Bay will be increased by approximately 9×10^{-8} $\mu\text{c/ml}$ (90 picocuries/liter). This radioactivity release is on the order of 2% of the maximum permissible concentration in potable water according to AEC regulations for the mixture of radionuclides anticipated.

It must, of course, be recognized that the ocean water is not potable and that the factors that limit the amount of radioactivity that can be discharged safely into Cape Cod Bay are related to the tendency of certain radionuclides to concentrate biologically. However, the disparity between the permissible concentration in drinking water and the expected concentration of radioactive substances released from the station is a useful starting point in attempting to assess the significance of the radioactive substances that will be discharged from the Pilgrim Station.

Ocean water is naturally radioactive having an activity of about 300 picocuries per liter on the New England coast. The annual release of radioactive liquids from the station, as estimated above, would increase the activity of the salt water effluent from the station by an average of about 90 picocuries per liter representing an increase of about 30% of the original radioactivity of the ocean. In Dr. Pritchard's analysis (Section 6.0), he finds that the flushing action of Cape Cod Bay is such that not more than ten days of discharge from the station could be accumulated in the Bay and that this accumulated discharge would be diluted by a factor of 1:2580 because of the large volume of the Bay relative to the circulating water flow rate. Therefore, the radioactive releases from the station would increase the activity of water in the Cape Cod Bay by less than 0.04 picocuries per liter or an increase of about 0.01% above the natural radioactivity level of the water.

It has been estimated that in the seven year period since 1961, about 80 curies of Manganese-54 and Cesium-137 and about 40 curies of Strontium-90 have been deposited in the

0 2 3 3 9 0 9 0 4

Bay from fallout from nuclear weapons tests. The two situations arising from coolant discharge and fallout from nuclear weapons tests are not exactly comparable, as in one case, the material is released from a point source and in the other, fallout from nuclear weapons is diffuse. Nevertheless, the comparison of these figures is useful in illustrating relative amounts of radioactive substances under consideration. With the possible exception of Cobalt-60, the nuclides to be discharged from the Pilgrim Station are among those which have been present in fallout from nuclear weapons and there is extensive experience from these nuclides in a wide variety of aquatic situations.

The controlling effect on allowable radiological discharges will be the possible biological reconcentration of radioisotopes in edible marine organisms. Limitations on allowable radiation exposure to man are established at levels far below those at which any radiation damage to wildlife would be observed.

The environmental radiology program (Section 8.1) will provide factual assurance that the accumulated effects of radiological discharges from Pilgrim Station are not significant from a Public Health point of view.

5.4 Non-Radioactive Liquid Effluents

The non-radioactive liquid process wastes are produced mainly from backwash of the make-up filters and from regeneration of the make-up demineralizers. The make-up water system processes water obtained from the Town of Plymouth for use in the station. The make-up system produces an estimated annual liquid volume for discharge of 2,900,000 gallons which contains an estimated 2,200 pounds of suspended particulates (suspended material filtered from the town water supply) and 66,000 pounds of dissolved solids which includes Na_2SO_4 from regeneration as well as dissolved solids removed from the town water supply. These liquid wastes are neutralized before being discharged.

The salt water used for station cooling water (condenser circulating water and service water systems) will require chlorination to assist in controlling marine growth in these systems. Chlorination of the salt water into the station is expected for about one hour each day with residual chlorine of approximately 1 ppm expected in the station salt water effluent during this period.

Sanitary sewage will be treated by a septic tank and leaching field located northwest of the main station buildings. This system will be constructed in accordance with the requirements of the Massachusetts Department of Public Health with particular attention to clearances from open waterways.

6.0 COOLING WATER DISPERSION

6.1 Introduction

This study of condenser cooling water discharge has been prepared by Dr. D. W. Pritchard of the Chesapeake Bay Institute.

6.1.1 Scope

Dispersion of condenser cooling water discharged from the Pilgrim Nuclear Power Station in waters of Cape Cod Bay including predicted distributions of temperature rise above ambient.

6.2 Oceanographic Factors Pertinent to Problem

6.2.1 Physical Description of Cape Cod Bay

The U. S. Coast and Geodetic Survey Chart 1208 shows Cape Cod Bay to be a broad, open mouthed water body formed by the eastward and then northward extension of Cape Cod out from the coast of Massachusetts. The Bay faces to the north, with Race Point, the westward extension of the hook of Cape Cod, distinctively marking the mouth of the Bay on its eastern side. The mouth is not well marked on the western side, but for purposes of this brief description a line extending from Race Point westward to Bartlett Rock, just off the entrance to Green Harbor, is considered to designate the mouth of Cape Cod Bay. The length of this line is $17\frac{1}{2}$ nautical miles, and the Bay has its greatest width of 24 nautical miles along an east-west line near the southern limits of the Bay. The north-south dimension of the Bay is just under 20 nautical miles.

Cape Cod Bay has a surface area of approximately 430 square miles (nautical), or 365,000 acres. Except for the southeast corner of the Bay, where Billingsgate shoal is found, depths generally increase rapidly from shore. The largest depths, about 180 feet, occur at the mouth of the Bay. About one-half the surface area of the Bay has depths greater than 100 feet, and the volume-mean depth is also about 100 feet. The volume of Cape Cod Bay is therefore about 1.6×10^{12} cubic feet.

6.2.2 Tide and Tidal Currents

Information compiled by the U. S. Coast and Geodetic Survey (1, 2) indicates that the tidal wave entering Cape Cod Bay from the north proceeds southward along the western shore of the Bay and then eastward along the southern shore of the Bay somewhat faster than the southward movement of the wave along the eastern shore of the Bay. The following lists the time difference between the time of high water at several locations around the Bay and the time of the corresponding high water at Boston. Also listed is the time difference between the time of low water at these locations and the time of low water at Boston, as well as the average of these

two differences for each location. The locations are listed in order of increasing distance from Boston, proceeding along the shoreline of Cape Cod Bay in a counter-clockwise direction.

<u>Location</u>	Time Difference	Time Difference	Average
	<u>High Water</u> (minutes)	<u>Low Water</u> (minutes)	<u>Time Difference</u> (minutes)
Gurnet Pt.	+ 02	+ 07	+ 04 $\frac{1}{2}$
Plymouth	+ 05	+ 20	+ 12 $\frac{1}{2}$
Barnstable	+ 09	+ 28	+ 18 $\frac{1}{2}$
Wellfleet	+ 12	+ 28	+ 20
Provincetown	+ 14	+ 16	+ 15
Race Pt.	- 03	- 04	- 03 $\frac{1}{2}$

The data for the northern end of Cape Cod Canal have not been included in this compilation, since the canal produces anomalous time differences at that location. The above data show that the tide is progressively later for successive locations proceeding southward along the western shore of the Bay, and then eastward along the southern coastline of the Bay. Likewise, the tide is progressively later for successive positions proceeding southward along the eastern shore of the Bay from Race Point at the mouth of the Bay as far as Wellfleet, which appears to be close to the location of the nodal point for the tide in Cape Cod Bay.

If high water occurred simultaneously throughout the Bay, the tide in Cape Cod Bay would have the characteristics of a pure standing wave. In this case high water would occur at the time of slack water (that is, zero tidal current) between flood and ebb flows, and low water would occur at the time of slack water between ebb and flood flows. The observed progressive differences in the time of high water and in the time of low water at the several locations along the shore of Cape Cod Bay indicate that the tide in the Bay departs slightly from a pure standing wave. We would therefore expect that high water would not occur at the same time as slack before ebb in the tidal current, but rather a short time before slack water during the later half of the flood current phase. Likewise, low water should occur at a time between the time of maximum ebb current and the succeeding slack water.

The results of the measurement and analysis of tidal currents made off Gurnet Point, off Manomet Point, and a mile east of Elllisville Harbor have been published by the U. S. Coast and Geodetic Survey (2). Tidal currents along the western and southwestern sides of Cape Cod Bay are generally directed parallel to the coast, except in or near the entrances to appended harbors. Flood current is directed down the coastline, that is toward the southeast, while ebb flow is directed northerly up the coastline. A comparison of the times of the various stages of the tide and of the tidal current show that for the coastline in the vicinity of the plant site, high water occurs approximately one hour before

the end of flood flow, and low water occurs approximately one hour before the end of ebb flow. Maximum ebb and flood current speeds appear to vary considerably with location. For the three locations nearest the plant site for which tidal current data are given by the U. S. Coast and Geodetic Survey (2) (that is, for Gurnet Point, Manomet Point, and off Ellisville Harbor) the maximum predicted tidal current speeds varied from 0.3 knots to 1.4 knots.

As will be discussed more fully in Section 6.2.5, a current measurement program was initiated in the immediate vicinity of the plant site as part of an overall environmental study. The results of these measurements to date indicate that in the inshore waters off the plant site, out to a distance of about 3/4 mile from shore (i.e., in water depths of 40 feet and less), the tidal component of the currents is quite weak, being certainly less than 0.1 knot and probably less than 0.05 knot. The local water movement near the plant site appears to be primarily related to wind action.

Tidal data compiled from a number of locations around the periphery of Cape Cod Bay show that the range in tide is reasonably uniform throughout the Bay, with a mean value of about 9.3 feet. Even though the departure of the tidal wave in Cape Cod Bay from a pure standing wave leads to a measurable phase difference between high water and slack current, the actual differences in the time of high water from one location to another in the Bay are small compared to a quarter tide period. Consequently, the net fractional change in volume of the Bay due to the rise and fall of the tide is closely approximated by the ratio of the mean tidal range to the mean depth of the Bay. Since, as stated in the previous section, the mean depth of the Bay is about 100 feet, the fractional change in the volume of the Bay during one tidal cycle is then 0.093 or 9.3%.

6.2.3 General Circulation Pattern

Available information on the general pattern of flow in the northwest Atlantic off the coasts of the New England States and the Maritime Provinces of Canada, as summarized in Oceanographic Atlas of the North Atlantic Ocean, Section I, Tides and Currents, U. S. Naval Oceanographic Office Publication No. 700, shows that a coastal current flows southward along the coast of Maine and Massachusetts. A portion of the flow enters Cape Cod Bay along the western shore of the Bay, circulates in a counter-clockwise direction, and leaves the Bay on the eastern side. The flow then swings eastward around the Cape and then southward again. Interpolation of the isopleths of mean speed given in the above cited reference suggests that the probable average speed of this counter-clockwise flow in the Bay is not less than 0.3 ft.sec⁻¹.

6.2.4 Wind Induced Motion

The speeds associated with the tidal motion and with the general circulation pattern in Cape Cod Bay are in a range which suggests that wind-induced motion will at times dominate the flow. Wind blowing over deep water produces a direct wind-driven motion in the surface layers directed to the right of the wind in the Northern Hemisphere. In shallow water the wind-induced flow is more nearly in the direction of the wind. The speed of the surface wind-induced flow has been shown to be about 2% of the wind speed. Thus, a wind speed of 15 knots would produce a wind-induced surface current of about 0.3 knot or 0.5 ft. sec^{-1} .

The variation of wind velocity in time and space over Cape Cod Bay should produce relatively rapid large scale exchange and mixing of the surface waters within the Bay. Also, prolonged winds from the northwest quarter should produce an additional mechanism for exchange of waters in the Bay with adjacent open coastal waters. The wind-induced surface layer flow into the Bay under such wind conditions would be accompanied by a sub-surface counter-flow out of the Bay. A sustained wind from the south would produce a surface flow out of the Bay and a sub-surface counter-flow into the Bay.

The rate at which the waters of the Bay are renewed by this mechanism can be only very grossly estimated, and will in any case be of an intermittent character. From a long-term standpoint, however, wind-induced flushing of Cape Cod Bay certainly contributes to the renewal of the waters of the Bay.

6.2.5 Water Movements Near Plant Site

An oceanographic observational program was initiated in the vicinity of the plant site to provide information on the temperature regime and on the movement and mixing of the waters off the plant site. As part of this program an anchored, buoy-supported instrument array has been established about one-half mile offshore from the plant site where the water depth is about 30 feet at MLW. In addition to temperature sensors set at several depths, this array includes two recording current meters, one located near the bottom and the other located near the surface. The instrument array is connected to the shore by cable, and a digital printout of speed and direction at the two current meters is provided every one-half hour.

This instrument station has been carried out by storms twice since first being installed. However, records for the period 26 April through 20 May 1968 have been analyzed. During this period approximately 1150 individual measurements of current speed and direction near the surface and near the bottom were obtained.

These observations show that both the speed and direction of the current at this location are highly variable. The speed of the current decreases with depth, with the mean speed near the bottom less than one-half that near the surface. During this period of observation, the current was directed down the coast (i.e., roughly toward the SE) about twice as frequently as in the up-coast, or north-westerly direction. The shoreline at the plant site is approximately parallel to the line 310°T to 130°T. Thus, currents having a direction falling in the quadrant 40°T to 130°T would have components both downcoast and off-shore; those falling in the quadrant 130°T to 220°T would have components both downcoast and onshore; those falling in the quadrant 220°T to 310°T would have components both upcoast and onshore; and those falling in the quadrant 310°T to 40°T would have components both upcoast and off-shore. The same 1150 individual measurements of the surface current off the plant site were subjected to a frequency sort into these four quadrants, depending on the observed direction, with the results as shown in Table 6-1. The magnitude of the current velocity varied from below the threshold of the current meter to a high of 1.1 knots. The average of the approximately 1150 measures of the near surface current was 0.15 knot. The statistical distribution of speeds as shown by a frequency sort is given below:

<u>Speed Range (knots)</u>	<u>% of Total Observations</u>
<0.09	40.7
0.10 - 0.19	31.9
0.20 - 0.29	16.0
0.30 - 0.39	7.9
0.40 - 0.49	2.0
0.50 - 0.59	0.8
>0.60	0.7

Table 6-1

Statistical Distribution of Observed Surface

Current Direction off Station Site

for Period 26 April - 20 May 1968

(Approximately 1150 individual measures)

Quadrant 1	}	
Down-coast* and off-shore	}	36.9%
Quadrant 2	}	
Down-coast and on-shore	}	29.4%
Quadrant 3	}	
Up-coast* and on-shore	}	12.9%
Quadrant 4	}	
Up-coast and off-shore	}	20.8%
Total with Down-coast Component	-	66.3%
Total with Up-coast Component	-	33.7%
Total with Off-shore Component	-	57.7%
Total with On-shore Component	-	42.3%

* Note: Down-coast is roughly towards the SE, while Up-coast
is roughly towards the NW.

Both current speed and direction appear to be related most closely to the wind. In the absence of the wind, a weak tidal oscillation is superimposed on a small net drift down the coast toward the southeast. This weak southeastward drift is associated with the general counter-clockwise circulation of Cape Cod Bay described in Section 6.2.3 of this report.

6.3 Rate of Renewal of the Waters of Cape Cod Bay

The waters of Cape Cod Bay are exchanged for "new" water from outside the Bay by at least three processes: (1) tidal exchange, (2) the general counter-clockwise circulation, and (3) wind-induced motion. The first two of these are amenable to first order numerical estimates of the fractional rate at which the waters of the Bay are replaced by new water.

6.3.1 Tidal Flushing

As described in Section 6.2.2 of the intertidal volume (that is, the difference in the volume of the Bay at high water and at low water), represents about 9.3% of the mean volume of the Bay. This means that 9.3% of the volume of the Bay moves in and out through the mouth each tidal cycle. Experience in other coastal water bodies has shown that perhaps as much as 70 to 80% of the water which leaves the Bay on ebb tide returns to the Bay on the next flood. The remaining 20 to 30% represents "new" water. Taking the lower limit of this range, and also taking into account the fact that two tidal cycles occur each 24.84 hours, the fractional rate of renewal of the waters of the Bay per day by tidal action is given by:

$$2 \times 0.093 \times 0.2 \times \frac{24.00}{24.84} = 0.035 \text{ or } 3.5\% \text{ per day}$$

Thus, tidal flushing provides a renewal rate of about 3.5% per day of the volume of the water in Cape Cod Bay.

6.3.2 Rate of Renewal of the Waters of Cape Cod Bay by the General Counter-Clockwise Circulation Pattern

The general counter-clockwise circulation pattern in Cape Cod Bay was described in Section 6.2.3. The inflowing current at the mouth of the Bay having a mean speed of at least $0.3 \text{ ft} \cdot \text{sec}^{-1}$ is conservatively estimated to occupy at least one-third of the cross-section at the mouth. The mean depth at the mouth of the Bay is 150 feet, and the width is 17.5 nautical miles, or $1.064 \times 10^5 \text{ ft}$. The cross-sectional area of the mouth is therefore $1.6 \times 10^7 \text{ ft}^2$. The volume rate of inflow of new water into the Bay with the current is then given by:

$$\begin{aligned} 0.3 \text{ ft} \cdot \text{sec}^{-1} \times \frac{1.6 \times 10^7 \text{ ft}^2}{3} &= 1.6 \times 10^6 \text{ ft}^3 \cdot \text{s}^{-1} \\ &= 1.4 \times 10^{11} \text{ ft}^3 \cdot \text{day}^{-1} \end{aligned}$$

Since the volume of the Bay is $1.6 \times 10^{12} \text{ft}^3$, the fractional rate of renewal by this process is given by:

$$\frac{1.4 \times 10^{11} \text{ft}^3 \cdot \text{day}^{-1}}{1.6 \times 10^{12} \text{ft}^3} = 0.088 \text{ day}^{-1} \text{ or } 8.8\% \text{ per day}$$

Considering that, in addition to the combined effect of tidal flushing and renewal by the general circulation pattern, wind-induced flows will also, in the long run, contribute to renewal of water in the Bay, we can assume that the mean renewal rate is at least on the order of 10% per day and probably larger. A renewal rate of 10% per day would provide a mean residence time for water, or for any water-borne component, of 10 days.

This means that no more than 10 days of discharge from the plant could accumulate in the Bay before being effectively flushed out of this water body. During a 10-day period, the volume of water discharged from the plant at full load would be given by:

$$10 \text{ days} \times 720 \text{ ft}^3 \cdot \text{sec}^{-1} \times 0.864 \times 10^5 \text{ sec} \cdot \text{day}^{-1} = 6.2 \times 10^8 \text{ft}^3$$

This volume, mixed into the volume of the Bay ($1.6 \times 10^{12} \text{ft}^3$) would be diluted by the ratio:

$$\frac{6.2 \times 10^8 \text{ft}^3}{1.6 \times 10^{12} \text{ft}^3} = 1:2580$$

This dilution is sufficiently large, so that in computing the close in pattern of concentration of excess heat (temperature) or of any other component of the condenser cooling water discharge, we can consider that the discharge is made into a water body of infinite size.

6.4 General Description of the Fate of the Rejected Heat and of Other Components of the Cooling Water after Discharge into Cape Cod Bay

The Pilgrim Station has a rated output of 655 MW of electrical energy and will reject about 4.3×10^9 BTU per hour of heat to the condensers at this load. The analysis and evaluations reported in this section were made assuming a total salt water flow of 720 cfs and a temperature rise in the station of 28.7°F which result in a total heat rejection of about 4.5×10^9 BTU per hour. Periodically, very low levels of radioactive isotopes will be discharged with the cooling water. We are here concerned with the dispersion within and ultimate loss from the Bay of the rejected heat and of any other contaminants carried with the cooling water effluent.

The dispersion (that is, the movement and mixing of the condenser discharge in and with the receiving waters), is considered in three stages. First, the excess momentum associated with the condenser cooling water as it is discharged into the waters of Cape Cod Bay will produce an entraining jet which will be diluted by the mechanical entrainment required to reduce the velocity of the jet

to that of the surrounding waters. Secondly, natural turbulent diffusion will further mix the waters of the diluted condenser water plume as it moves downcurrent with the natural flow. Finally, the large scale circulation pattern coupled with tidal flushing, as discussed in the previous section, will carry any conservative component out of the Bay. In the case of the rejected heat, surface cooling will have returned the temperatures to ambient long before the large-scale circulation pattern will have carried the condenser cooling water out of the Bay.

6.5 Distribution of Temperature in the Vicinity of the Plant Site

The most important mechanism for rapid reduction of the temperature rise above ambient of the condenser cooling water discharge from the plant is the mechanical entrainment required to reduce the initial momentum of the discharge to that of the receiving waters. Both theoretical and empirical studies of momentum entrainment in a jet discharge provide a means of computing the probable temperature distribution in the vicinity of the plant site. Note that here the term "temperature distribution" is used in place of the longer expression "temperature rise above ambient." The temperature distribution in the vicinity of the discharge will be somewhat higher than the ambient water temperature because of the heat content of the station cooling water discharge.

There are two factors at Pilgrim Station which restrict the degree of confidence which can be placed on the use of existing momentum entrainment relationships for the prediction of the temperature distribution off the plant site resulting from the discharge of the heated condenser cooling water. First, in the presence of a current flow directed along the coast in the Bay waters off the plant site, the plume of mixed, heated water will be bent in the direction of the current, ultimately becoming parallel to the coastline. It is not possible to determine on theoretical basis alone whether or not entrainment will occur on the inshore side of such a bent jet. Secondly, the effective velocity of the discharge for this design, an important parameter in considering the effectiveness of momentum entrainment, is not readily determined from theory alone.

In order to determine the effective velocity of discharge, as well as to determine the shape and extent of the plume of heated water in the vicinity of the discharge, an hydraulic model of a segment of Cape Cod Bay, centered on the plant site, has been constructed and a series of model tests have been run. This model is built on a scale of 1:250 in the horizontal and 1:40 in the vertical. It extends along the shore for a distance equivalent to about 11,000 feet in the prototype, and outward from the plant site for an equivalent prototype distance of about 6,000 feet.

Currents off-shore from the plant site are simulated in the model by introducing water through a control structure running approximately perpendicular to the general trend of the shoreline in the vicinity of the plant, and located at the northwesterly end of the model (prototype direction), and withdrawing water from a control structure extending along the southeasterly end of the model. The plant intake and discharge structures are properly scaled in the

0 9 1 4
0 3 3 9

model. Water is withdrawn from the model through the intake structure, and heated water is introduced to the model through the discharge structure, to simulate plant operations.

A series of tests under the most critical conditions has been completed. These tests show three significant features: (1) Even when a current flow near the maximum observed at the site is simulated in the model, and directed down-coast, thus bending the plume of heated water toward the intake structure, very effective two-sided entrainment of cool diluting water occurs. The circulation pattern set up by the entraining jet actually brings new water at near ambient temperature to the intake. (2) There is little significant difference in the effectiveness of the jet entrainment between low tide and high tide conditions. In both cases, the heated plume appears confined primarily to the upper five feet of the water column, and the areas within given temperature isolines appear to be essentially independent of tidal height. (3) There is little difference in the shape and size of the heated plume for ambient current conditions varying from 0.2 knot, which is near the average observed off the plant site, to 0.6 knot, a speed exceeded in the observations to date less than 1% of the time.

As described in a previous section, the tidal oscillations and the residual net southeastward drift off the plant site are quite small, and at any given time the speed and direction of the current depend primarily on the time history of the wind. Thus, the current may extend either up-coast in a northwesterly direction or down-coast in a southeasterly direction, and in either case may have components directed either on-shore or off-shore. The current observations to date show that a flow in a southeasterly direction, with an off-shore component, occurs most frequently; however, flows in other directions are of sufficient frequency so as to require consideration.

Predictions of the distribution of excess temperature resulting from operation of the Pilgrim Station have been prepared using the results of the hydraulic model tests combined with theory to take into account the finite size of the model, and to extend the distribution beyond the model boundaries. Because only a finite segment of the Cape Cod Bay can be modeled in this way, and because the water withdrawn from the model to simulate the current regime must be recirculated to provide the inflow at the upstream end, care must be taken in applying the model results directly to the prototype. In the predictions of the temperature distributions given here, the model results have been modified to take into account the finite renewal rate of the segment of the coastal waters represented by the model. Thus, in all cases, the predicted distributions of the temperature rise above ambient given here are conservative compared to the model results; that is, the plume of heated water is here shown to be more extensive than is shown by direct application of the model results to the prototype. The analysis assumed a total cooling water flow of 720 fps and a temperature rise in the station of 28.7°F. Two cases are considered, the first with the off-shore current directed toward the ESE (Figure 1), and the second with the off-shore current directed toward the WNW (Figure 2). As pointed out above, the temperature

distributions appear to be relatively independent of tidal stage and of the strength of the current in the range from 0.2 knot to 0.6 knot, at least with respect to the general shape of the temperature isotherm and the area within a given isotherm. The strength of the current will influence the rate of bending of the plume from the initial off-shore directed jet discharge to a plume extending downcurrent. Thus, for the weaker current speeds, the heated discharge will extend somewhat farther off-shore than in the case of a strong current parallel to shore.

The shoal extending out from Rocky Point appears to exert considerable influence on the currents flowing past the plant site inshore of about the -25 foot MLW depth contour. As a consequence of the sheltering effect of this shoal, the model studies showed that the plume of heated water extends outward from the point of discharge very nearly along the extension of the axis of the discharge canal for about 1200 feet before starting to bend in a down-current direction, even in the presence of a 0.6 knot current directed toward the ESE. This feature is shown in Figure 3, in which the temperature distribution in the vicinity of the discharge canal, as observed in the model studies, is depicted. The size, shape and orientation of the plume as defined by the 10°F temperature isotherm apparently depend primarily on the dynamics of the discharge and are insignificantly influenced by the ambient currents in the Bay waters adjacent to the Plant site.

Measurements of the vertical distribution of temperature in the model tests have shown that for the conditions studied, the temperature rise above ambient is primarily restricted to the upper five feet. Figure 4 shows three representative vertical profiles of temperature distribution vs. depth from the model studies. Somewhat greater vertical mixing will probably occur in the presence of wind waves, but on the basis of the evidence now available, it is very unlikely that the temperatures at 10 feet below the water surface will exceed 4°F above ambient, and then only in the very small area in the vicinity of the discharge. In Figure 5 the predicted distribution of maximum temperatures, above ambient, on the bottom is shown. Isotherms are drawn for temperatures, above ambient, of 3°F and greater. Areas outside the 3°F isotherm as shown should have bottom temperatures less than 3°F above ambient.

Table 6-2 summarizes the area inside each of the surface temperature isotherms shown in Figures 1, 2 and 3. To indicate the importance of dilution due to momentum entrainment and natural diffusion, the last column of this table gives the area inside each isotherm which would be required if the effluent were to gently spread over the surface without mixing with the receiving waters, and lost heat only by surface cooling.

The predicted temperature distributions given here apply to an ambient temperature of 75°F, which represents the extreme ambient temperatures observed in the waters of Cape Cod Bay adjacent to the plant site. While the ambient temperature will influence both the amount of entrainment and the rate of surface cooling slightly, these effects would not significantly alter the shape and size of the individual temperature isotherms, and for all practical purposes, the predicted temperature distribution above ambient given here can be applied to any ambient temperature from 50°F up to 80°F.

TABLE 6-2

Dimensions of and Area within the Predicted
Isotherms for Surface Temperature Rises above
Ambient Temperatures for the Pilgrim Station

<u>Temperature Rise above Ambient (°F)</u>	<u>Length of Area (ft.)</u>	<u>Width of Area (ft.)</u>	<u>Predicted Area (Acres)</u>	<u>Comparable Area * Surface Cooling Only (Acres)</u>
20°	430	110	1.1	248
10°	1100	250	6.3	725
5°	3400	900	70.3	1203
3°	5900	1300	176	1557
2°	8400	2200	425	1834

* This column is shown for purposes of comparison only, and represents the area within the designated isotherms which would be required if the temperature reduction resulted only from surface cooling.

6.6 Concentration Distribution of Radioactive Isotopes Released in the Condenser Cooling Water


Under normal operating conditions, introduction of any radioactive isotopes into the condenser cooling water discharge would be controlled so that after mixing, the concentration in the cooling water effluent would not exceed the maximum concentrations specified for off-site areas in 10 CFR 20, "Standard for Protection Against Radiation." We are here concerned with the further physical dilution of such radioisotopes in the natural environment. Such further dilution serves as an additional safety factor which is not, however, used in computing allowable release rates.

There is no physical process which would lead to reconcentration of the radionuclides within the receiving waters of Cape Cod Bay nor in any of the tributary embayments. The temperature distributions above ambient shown in Figures 1 and 2 result primarily from physical dilution of the condenser cooling water discharge by the receiving waters. For the situation studied here, surface cooling does not become a significant contributor to the reduction of temperature except for surface temperatures less than 2°F above ambient.) ?

The isotherms given in Figures 1 and 2 may therefore be interpreted as dilution lines for radioisotopes discharged with the condenser cooling water, by dividing the labeled temperature rise values by 28.7°, the initial temperature rise in the station. Thus, the isotherms of 20°, 10°, 5°, 3° and 2° shown in Figures 1 and 2 represent dilutions of 1:1.43, 1:2.87, 1:5.74: 1:9.56 and 1:14.35, respectively. Dilution will continue with distance from the site, producing a decrease in concentration approximately in proportion to the inverse of the distance from the source. On this basis the concentration of any component in the condenser cooling water discharge would be reduced by a factor of 100 at a distance of 11 nautical miles from the point of discharge.

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, utilized, or used except in the limited way and for the purposes permitted by the lender to the borrower.


SURFACE CURRENT
0.2 TO 0.6 KNOTS



PILGRIM STATION PLANT
BOSTON EDISON CO.

PREDICTED TEMPERATURE RISE DISTRIBUTION
IN °F FOR CONDENSER COOLING WATER FLOW AT
720 CFS - TEMPERATURE RISE AT CONDENSERS
OF 28.7° F
OFF-SHORE CURRENT TOWARDS E.S.E. AT 0.2 TO 0.6
KNOTS.
BASED ON COMBINED MODEL STUDIES AND
ANALYTICAL TREATMENT AUG. 1968

FIGURE 1



NO.	DATE	REVISIONS	BY	CHK	DESIGN SUPV.	ENG'S	CHIEF ENG'S	APPRD
SCALE		DESIGNED			DRAWN			
BECHTEL SAN FRANCISCO								
SECTION G - FIGURE 1								
JOB No.		DRAWING No.			REV.			
649B.3								

SIZE B 11X17

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and for the purpose intended by the lender to the borrower.




FIGURE 2

500 0 1000 2000
SCALE IN FEET

PILGRIM STATION PLANT
BOSTON EDISON CO.


PREDICTED TEMPERATURE RISE DISTRIBUTION
IN °F FOR CONDENSER COOLING WATER FLOW AT
720 CFS. TEMPERATURE RISE AT CONDENSERS
OF 28.7°F
OFF-SHORE CURRENT TOWARDS N.W. AT 0.2 TO 0.3
KNOTS.
BASED ON COMBINED MODEL STUDIES AND
ANALYTICAL TREATMENT AUG. 1968

NO.	DATE	REVISIONS	BY	CHK	DESIGN SUPV.	ENG'R	CHIEF ENG'R	APP'D
SCALE		DESIGNED		DRAWN				
BECHTEL SAN FRANCISCO								
SECTION 6 - FIGURE 2								
		JOB No.		DRAWING No.		REV.		
		6498-3						

SIZE 6 11x17

PILGRIM STATION PLANT BOSTON EDISON CO.

PREDICTED TEMPERATURE RISE ABOVE AMBIENT
IN °F, IN VICINITY OF DISCHARGE, FOR CONDENSER
COOLING WATER FLOW OF 720 CFS, TEMPERATURE
RISE AT CONDENSER OF 28.7°F BASED ON
MODEL STUDIES.



This drawing and the design it covers are the property of BECHTEL. They are merely loaned and on the borrowers' express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by the lender to the borrower.

△									
△									
△									
NO.	DATE	REVISIONS			DR.	SUPVR.	ENG.	PROJ. ENG.	CLIENT



SECTION 6 - FIGURE 3.

JOB No. 6498-3

DRAWING No.

REV.

This drawing and the design it covers are the property of BECHTEL. They are merely loaned and on the borrowers' express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by the lender to the borrower.

0 2 3 3 9 0 9 2 1





FIGURE 4

△									
△									
△									
NO.	DATE	REVISIONS			DR.	SUPVR.	ENG.	PROJ. ENG.	CLIENT
		SECTION 6 - FIGURE 4				JOB No. 6498-3			
						DRAWING No.			REV.

PILGRIM STATION PLANT BOSTON EDISON CO.

PREDICTED MAXIMUM TEMPERATURE RISE
DISTRIBUTION ON THE BOTTOM FOR CONDENSER
COOLING WATER DISCHARGE OF 720 CFS,
TEMPERATURE RISE AT THE CONDENSER OF 28.7°F





FIGURE 5

0 100 200 300 400 500
SCALE IN FEET

This drawing and the design it covers are the property of BECHTEL. They are merely loaned and on the borrowers' express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by the lender to the borrower.

△									
△									
△									
NO.	DATE	REVISIONS			DR.	SUPVR.	ENG.	PROJ. ENG.	CLIENT
 <i>SECTION G - FIGURE 5</i>					JOB No. <i>6498-3</i>				
					DRAWING No.				REV.

SECTION 6 - FIGURE 5

7.0 ECOLOGY

7.1 Introduction

This section of the report has been prepared by Dr. John H. Ryther, of the Woods Hole Oceanographic Institution.

7.1.1 Scope

The ecology of the inshore water of Plymouth, Massachusetts and vicinity with special reference to the marine fisheries of the region and their relationship to the Pilgrim Nuclear Power Station.

7.2 General Description of the Region

Cape Cod Bay is a nearly circular embayment having a north-south demension of about 20 nautical miles. Plymouth is located at the north-western extremity of the Bay where it opens onto Massachusetts Bay, and the Rocky point site of the Pilgrim Nuclear Power Station constitutes the western lip of the bowl-shaped embayment. Farther to the north and west of Rocky Point, the coastline recedes into the region of Plymouth Bay and the harbors of Plymouth, Kingston, and Duxbury. These harbors are formed by two spits of land, Duxbury Beach terminating as Gurnet Point on the north and Plymouth Beach on the south, enclosing a shallow, soft-bottom area of some 25 square miles, much of which is intertidal.

The depth of Cape Cod Bay at its center ranges from about 100 feet in the southern portion to about 180 feet at the northern, open part of the Bay. Beyond the immediate intertidal shoreline, the bottom drops off rapidly to its maximum depth. This is especially true of the western side of Cape Cod Bay (near Rocky Point) where a depth of 50 feet at mean low water is found about one mile and 100 feet less than two miles offshore.

The sediments in the central basin consist of fine sand and/or mud and the same material characterizes most of the intertidal bottom of the Bay. However, along the western edge of the Bay, from Plymouth to the Cape Cod Canal, the sand beaches are interspersed with regions of gravel, stones, rocks and boulders. Where these occur, they may extend out from the shoreline to depths of 25 feet or more.

The site of the Pilgrim Nuclear Power Station, just south of Rocky Point, lies between two rock ledges, Rocky Hill or Tautog Ledge to the north and White Horse Ledge to the south. These ledges extend out a mile or more from shore. Between them, for a distance of about one mile, lies an area which is rocky along the immediate shoreline but of sandy bottom a few hundred feet offshore.

7.3 Hydrography

The effects of tides, winds and currents on the general hydrography of the region have been discussed in some detail by Dr. Pritchard (Section 6 of this report) and will therefore only be summarized here.

The mean tidal excursion in Cape Cod Bay is 9.3 feet. The tidal wave enters the Bay from the north producing a southerly-flowing current on the rising tide which reaches a maximum velocity of about 1.5 knots, and a northerly flow of comparable velocity on the ebbing tide. Tidal action alone is estimated to exchange 3.5% of the volume of Cape Cod Bay during each tidal cycle.

Superimposed upon the tidal effect is the general coastal current system which flows southward along the New England shore. This coastal current enters Cape Cod Bay on its western side, describes a counter-clockwise path within the Bay, and leaves it from the eastern side, swinging around Race Point and thence southward. The average velocity of this current is of the order of 0.5 knots or less. This coastal current, which is a southerly extension of the Labrador Current, is responsible for the universally low temperatures which characterize coastal New England waters from Maine to Cape Cod. The diversion of this current to the east and offshore by the Cape Cod peninsular results in a sharp increase in the summer seashore temperatures on the south side of Cape Cod and to its south. As a result Cape Cod is a faunal barrier, marking the northern or southern distributional limit of many species of marine life.

Conditions offshore at Pilgrim Station are greatly modified by proximity to shore and the existence of rock ledges which reduce currents, resulting in a much less well-defined regime.

Depending upon its speed, direction and velocity, the wind may have a pronounced effect upon the circulation of Cape Cod Bay and may, in fact, overshadow the combined effects of the tides and coastal currents. As Pritchard points out, the effects of the winds can be predicted only in general and qualitative terms. If they blow from the south, the over-all effect will be to produce a surface flow out of Cape Cod Bay which will be compensated for by a subsurface flow into the Bay. As the subsurface waters rise to replace the surface water which is wind-driven from the Bay, the surface temperature may drop sharply, particularly in summer.

On the other hand, a strong, prevailing wind out of the north quarter will tend to produce a surface current into and a subsurface current out of the Bay. This will have the effect of 'piling-up' surface water along the shore to considerable depths and, at times, to the bottom. Lobster pound operators in Plymouth Harbor complain that their intake water, taken from as deep as is possible in order to achieve minimum temperatures, may increase by 10°F or more during periods of strong, onshore winds.

While the prevailing winds of the region are from the southwest, northeast storms are not uncommon and their possible effect in driving a surface layer of heated cooling water from the power plant inshore along the coast and to the bottom is an important consideration which will be discussed later.

Pritchard has estimated that the combined effects of tides, winds and currents result in a mean flushing rate of Cape Cod Bay of at least 10% per day, and probably more. A renewal rate of 10% per day would provide a mean residence time for water, or for any water-borne component, of 10 days.

Some exchange of water between Cape Cod Bay and Buzzards Bay takes place through the Cape Cod Canal as a result of the reversing tidal flow in the Canal. This exchange is believed to be small and its effects localized. Published data (Anraku, 1964) indicates that the net flow is to the west, from Cape Cod Bay to Buzzards Bay.

The existing seawater temperature data for Cape Cod Bay have been collected, summarized and reviewed in Section 3 of this report, in which it is concluded that the water temperature of Cape Cod Bay in the vicinity of the Pilgrim Nuclear Power Station is similar to that at the eastern entrance of the Cape Cod Canal, the closest location for which appropriate long-term data are available. These were taken at the tide station operated by the Coast and Geodetic Survey at the Canal entrance, records from which are available for the period 1955-1962. Because they are pertinent to the discussion which follows, the mean surface temperature data from that station are reproduced in this section in Figure 1. Shown on the same graph are the 60-year mean surface water temperature (for an unspecified period) of the rearing tanks in the Massachusetts Division of Marine Fisheries Lobster Hatchery at Oak Bluffs, Martha's Vineyard (from Hughes and Matheissen, 1967). The significance of these data will be discussed later in this report.

In summer, the surface waters of Cape Cod Bay increase in temperature due to solar heating, and a well-developed thermocline (a zone of rapid decrease in temperature) develops between 30 and 50 feet. The temperature-depth profile in late summer is shown in Figure 2 of Section 7 of this report for a position 4.5 miles east of the Center Hill Point (data from D. Grant, Marine Biological Laboratory, Woods Hole, Massachusetts). This is probably typical of the whole of Cape Cod Bay, though the thermocline may be somewhat shallower nearer shore and in more shallow water. On the basis of the available information, one would expect substantially lower water temperatures at depths below about 50 feet throughout the year and throughout the Bay, or at a distance of about 1 mile offshore from the Pilgrim Station site.

7.4 Commercial and Sport Fisheries of the Area

The most important commercial marine species of the area is the lobster, for which there is a small but intensive local pot fishery. The lobsters are normally found on rocky bottom and

are numerous on the two ledges (Rocky Hill and White Horse Ledges) which bracket the Pilgrim Station site. They also occur inshore on the rocky-bottom area between the ledges and, at times, are taken further offshore on the sand-bottom between the ledges. When found in the latter area, the lobsters are believed to be undertaking a migration, the nature of which is unknown.

Most of the pot fishing is done within a mile from shore in depths of 30 feet or less, before the bottom begins to drop off sharply. At the opposite extreme, pots are set along the shore in water where they are barely covered at low tide.

Within the area of roughly one square mile between (and including) the two ledges and the 50-foot bottom contour it is estimated that some 10,000 pots are fished at the height of the season. These are operated by approximately 25 full-time, professional fishermen (whose principal income derives from lobstering), and by an undeterminate, but large number of part-time, "summer fishermen". The former operate a larger number (i.e., several hundred) of pots per capita and probably account for 75% or more of the total catch.

The lobsters are relatively inactive and do little if any feeding during the winter months. This fact plus the unfavorable weather restricts the lobstering season to 8-9 months a year, from mid-April to December. The lobsters in the area under consideration moult (or shed) in June, and they reach their peak of feeding activity and growth at that time. Most of the year's catch is landed during the summer months of June - August.

Several independent estimates place the annual landings from the area under consideration (the one square mile described above) at about 200,000 lobsters. Statistics for the lobster fishery for the Town of Plymouth for 1966 compiled by the Massachusetts Division of Marine Fisheries, placed the total landings at 556,815 lobsters. On that basis the areas off the Pilgrim Station site produce about half of the lobsters landed in Plymouth.

Little is known of the ecology of the lobsters except in general terms. One important aspect of their life history in connection with the power plant operation is the behavior of the lobster larvae. Spawning takes place during the late spring or early summer. The newly-hatched larvae are planktonic or free-swimming during the first 2-3 weeks of their life, often swimming at the very surface of the water during that period. After the larvae have moulted four times, they assume the appearance of an adult lobster and take up a bottom-living existence for the remainder of their lives. It is not known, however, whether the population of adult lobsters in the Rocky Point area grow up from larvae which developed in the same waters or whether they have migrated as adults into the region over the bottom from offshore populations, as many people believe.

There are several species of fin fishes which are fished commercially in Cape Cod Bay. These are all bottom-living species and include cod, haddock, flounder and hake. They are fished wherever there is sufficiently smooth, sand bottom to operate the bottom trawls. However, this type of fishing is restricted to a distance of at least three miles from shore from April 1 to November 1. During the five winter months (November - April) there is some trawling in the sandy-bottom area between Rocky Point and White Horse Ledges. Catch statistics are not available for the fish landed from this area.

Sports fishing does not appear to be an important recreational resource of the area under consideration. There is some bottom fishing around the ledges for tautog and other species which inhabit rocky bottoms. Pelagic species such as tunas, striped bass and mackerel are no more numerous near Rocky Point than elsewhere in Cape Cod Bay and the density of lobster - pot floats during the fishing season makes the area a difficult and hence unpopular one for trolling, the popular local method of sports fishing.

Few if any shellfish are taken commercially from the intertidal shoreline in the vicinity of the Pilgrim Station, primarily because of the rocky bottom but also because the exposed nature of the coast and the resulting instability of the intertidal sediments discourages the establishment of mollusc populations. The closest commercial shellfish beds are located within the Plymouth-Kingston-Duxbury Bay areas, in those places where pollution has not closed them to digging. The same region also supports a modest commercial seaworm industry. In the opposite direction from Rocky Point, the first shellfish-producing area encountered is the White Cliffs section of Manomet. Based on the isotherms developed by Pritchard, both of the above regions are too far from the Pilgrim Station to be directly affected by its operation.

The remaining species of commercial importance in the area is the marine alga Chondrus crispus, known variously as "Irish moss" or "sea moss." This plant grows attached to rocks or stones from the low water level to a depth of 25-30 feet. Because of its requirement for an attachment site, it is restricted in its distribution to rocky bottom areas. The principle "belt" of the sea moss extends from Plymouth Beach to Priscilla Beach with its center of abundance off Rocky Point. A secondary center of abundance occurs off Ellenville.

The sea moss fastens to the rocks by an organ of attachment called a holdfast. It is harvested by means of a special steel rake which breaks the plant off near its base, leaving the holdfast on the rock. When harvested in this way, a new plant is regenerated from the holdfast. In the Plymouth area three crops of sea moss can be grown in a year. The first crop is ready for harvesting in mid-May or June, the second is taken in July and the third and final crop is harvested in early September.

0 9 2 8
0 9 2 8
0 2 3 3 9

The Plymouth sea moss industry is a family business. For the past 28 years the family has carried out this operation, with the help of a crew of some 25-30 college students employed each summer for the harvesting. They operate a fleet of roughly 20 dories and a dozen trucks throughout the summer. The algae are delivered to their plant in Kingston, Massachusetts, where it is machine dried and baled. It is then sold under contract to Marine Colloids, Inc., of New Jersey, where the colloids are extracted from the algae and used as a filler or suspending agent in medicines, paints, foods, and a great variety of other products.

The annual harvest of sea moss from the Plymouth beaches amounts to about 1.5 million pounds (dry weight), nearly half of which comes from the one-mile stretch from Rocky Hill Ledge to White Horse Ledge.

7.5 Predicted Marine Biological Effects of the Pilgrim Nuclear Power Station Operation

Not including the subject of radioactivity, which will be considered elsewhere, the impact of the Pilgrim Nuclear Power Station upon the ecology of the adjacent marine environment may be expected to result from the following causes: (1) physical effects from construction, (2) effects associated with the cooling water intake, (3) chemical additions to the cooling water discharge, and (4) thermal addition to the cooling water discharge.

During construction of the breakwaters and the cooling water intake and discharge systems, sediments will be stirred up, the water will become turbid and silting will occur on lobster pots, Irish moss plants, etc. Some destruction of life or avoidance of the area by motile species may occur. The extent of such possible damage can hardly be predicted, but it would be expected to be highly localized and temporary.

No significant adverse biological effects are expected to result from or be associated with the intake of cooling water per se. The broad intake channel between the breakwaters will insure low intake velocities in order to avoid mixing of the warm surface water with the cooler bottom water. The low velocity of the intake will also help to prevent fish and other marine organisms from being attracted to, concentrated by, and eventually caught up in the intake. Some planktonic and free-swimming larval forms or marine organisms will inevitably be entrained in the cooling water and many of these will undoubtedly be killed from the thermal or chemical alterations of the water, as will be discussed below. Any such mortality will be minimized, however, by taking water from subsurface levels, the reduction being generally in direct proportion to the depth of the intake. For example, most of the lobster larvae will be avoided because the cooling water will be taken below elevation (-) 12MSL. As a matter of practical importance to the plant operation, the majority of fouling organisms (barnacles, mussels, algae) will also be avoided in the same way, again in direct proportion to the depth of the intake.

Even if all the microorganisms entrained in the cooling water were killed by its passage through the plant, the volume of water so involved per day is less than 1/10,000 of the volume of Cape Cod Bay and less than 1/1000 of the new water which is brought into the Bay each day by the flushing action of winds, tides and currents.

Chemical pollution of Cape Cod Bay by materials added to the cooling water will also be negligible for the same reasons given above. As stated in Section 5, the only significant chemical addition to the cooling water will be sodium sulfate (Na_2SO_4) which will be discharged into Cape Cod Bay at a rate of 8.6×10^5 pounds per year. However, the volume of cooling water which passes through the plant each day contains some 130×10^6 pounds of salts including 10×10^6 pounds of sulfate and 46×10^6 pounds of sodium ion.

The sodium hypochlorite to be used as an antifouling agent in the salt water cooling system will result in a residual concentration of free chlorine in the discharge water of approximately 1 ppm. This is 5-10 times the lethal concentration for most bacteria and is very close to the lethal threshold for the majority of plants and animals of the plankton, if they were exposed continuously to that concentration. Since the cooling water is diluted by a factor more than tenfold within a few hours of the time of its discharge, no toxic effects from chlorine in the discharge would be expected to occur to the organisms in the receiving water.

The discharge will consist of 311,000 gallons per minute of water, the temperature of which will be approximately 28°F above that of the intake water. In his report, Pritchard has constructed isotherms showing the predicted distribution at high and low tide of water which is 20° , 10° , 5° , and 3°F above the ambient surface temperature. The areas enclosed by these isotherms range from 1.1 acres of $+20^\circ$ water to 176 acres of $+3^\circ$ water.

Generally speaking, few if any harmful effects to the commercially important species of the area are to be expected as a result of the warm water discharge, at least beyond a mixing area in the immediate vicinity of the discharge. There are two reasons for making this assumption. First, the temperature of the water in Cape Cod Bay is, on the whole, rather cold, averaging no more than just above 60°F in mid-summer. Most of the marine species of commercial importance are representatives of the temperate water fauna which also occur south of Cape Cod in considerably warmer water.

The above statement holds true for the lobster, the most important commercial species of the region. Figure 1 shows the mean annual surface temperatures for Cape Cod Bay and Woods Hole. Lobsters are taken from both areas but the summer temperature in Woods Hole averages some 10°F warmer than in Cape Cod Bay. As also shown in Figure 1, even higher late summer temperatures occur in Lagoon Pond, Martha's Vineyard and in the rearing tanks of the State Lobster Hatchery which that body of water supplies. Presumably the Hatchery is located in a favorable environment for lobsters. While the curves show only monthly mean temperatures, the extremes are much greater in the shallow waters of Lagoon Pond than in Cape Cod Bay.

0 9 3 0

Actually lobsters are much more tolerant of warm water than is generally believed. Figure 1 also shows the lethal temperature for lobsters which have acclimated to high temperatures, which is about 85°F (at optimal conditions of salinity and oxygen). The research on which this statement is based is that of McLeese (1956). The same studies showed that temperature tolerance is independent of the size or age of the lobsters and applies equally well to both the free-swimming larvae and the benthic adults.

The decline in lobster production in Maine during the past several years has, in fact, been attributed to the current climatic cooling trend, according to Robert L. Dow, Research Director of the Maine Sea and Shore Fisheries Department (Dow, 1967). Mr. Dow is presently engaged in a research project in Casco Bay, Maine, in which an attempt is being made to utilize the warm water discharge from the Cousins Island Station of the Maine Central Power Company for the artificial cultivation of lobsters.

Similar statements may be made with respect to the finny fishes and shellfish of commercial or sports fishing importance to the region. The range of all of these species extends well down the east coast of the United States south of Cape Cod.

The one possible exception to the above generalization is the Irish moss, Chondrus crispus. This seaweed is a northern species which cannot survive in warm water. Although its range extends at least as far south as Rhode Island, it does not grow as abundantly or follow the same seasonability in its life history south of Cape Cod as it does in the Plymouth area. Surprisingly, for a species of its commercial importance, its temperature tolerances are not known.

0 9 3 3 9

The second reason for believing that the warm water discharge will not be harmful to the commercially important species of the region is that all the latter are bottom-living organisms. The warm water, being less dense, will float on the surface of the untreated cooler water. Pritchard has reported that the excess temperature is primarily restricted to the upper five feet of water; therefore, bottom organisms outside the mixing zone should be completely unaffected by its presence. The only forms of life which might be influenced under these circumstances would be planktonic larvae, such as those of the lobster. As stated above, the latter can withstand temperatures as high as 85°F, more than 10° above the maximum temperature recorded for Cape Cod Bay. In addition, near-shore, where the water is more shallow, the sea moss, though attached to the bottom, may extend its fronds (leaves) near or into the surface layer, particularly at low tide, and thereby become exposed to the warm water.

7.6 Recommendations

In view of the fact that most if not all of the marine species of commercial importance are bottom-living organisms, it is preferable to discharge the heated water as a thin, surface layer over a large area rather than confining it to a smaller area by mixing it vertically. This method has the added advantage that dissipation of heat from the water to the atmosphere is more rapid.

lethal conditions for many of the local species will be reached or passed if the water temperature exceeds 85°F. As summer surface temperatures may be greater than 70°F, an increase of more than 10°F beyond a reasonable mixing zone should be avoided. The presence of water at or above lethal temperature levels, no matter how confined geographically or vertically, is always a threat to the biota. An unusual combination of hydrographic or meteorological conditions (such as onshore winds during a north-east storm, as mentioned earlier) could potentially move such water to the organisms.

In view of the above considerations, the immediate mixing of the discharged water to the extent necessary to create sub-lethal temperature conditions is recommended. In that connection, however, it would not appear to be necessary to discharge the cooling water at a depth below the summer thermocline, as has been recommended by the U. S. Department of the Interior, Fish and Wildlife Service. Adequate mixing with surface water, through appropriate mechanical means, should be able to achieve the same objective.

In order to verify these predictions of the effects of station effluents on the marine ecology, an ecological study of the region both before and after the plant goes into operation is recommended. Such a survey should consist of two parts:

1. Hydrographic and hydrodynamic studies of the effects of winds, tides, and currents on the surface circulation and flushing rate of Cape Cod Bay. Such studies are, in fact, already underway. They should also be continued for a reasonable period of time after the plant is in operation, when the actual distribution of the effluent can be examined directly, vertically and horizontally, under different environmental conditions.
2. A biological survey of the abundance and distribution of marine organisms of commercial importance in representative areas which are likely to be affected by or exposed to the power plant effluent. Sampling or observation of the biota should be carried out at different times of the year and for a period of at least two years before and after the plant goes into operation. The biological survey should include a careful collection of the landing statistics of the commercial species of importance from the area or areas in question. The environmental survey should include the radiological assay of marine organisms as has already been planned.


The biological survey need not be large or extensive in order to provide the necessary information. Local organizations which would be qualified to undertake such a study, include, the Marine Laboratory of the Battelle Memorial Institute in Duxbury, the Systematics and Ecology Program of the Marine Biological Laboratory of Woods Hole, and the Division of Marine Fisheries of the Massachusetts Department of Natural Resources. The Division of Marine Fisheries has recently completed a survey of the Plymouth-Kingston-Duxbury Bay region and is now participating, together with the U. S. Department of the Interior, Bureau of Sport Fisheries, in a "before-and-after" study of the ecology of the Cape Cod Canal and the influence of the new power company at Sandwich, Massachusetts upon its biota. Any one of the above-mentioned organizations would be capable of carrying out the type of ecological survey which is proposed.

7.7 Conclusions

Pritchard's evaluation of thermal and radiological dispersion, expressed in Section 6 of this report, indicates that the desirable objective of rapid mixing, combined with a relatively thin surface layer of warmer water, appears to have been achieved by the proposed design.

The recommended hydrographic and hydrodynamic studies have been completed or initiated. A summary of the proposed ecological survey is included in Section 8 of this report.


0 2 3 3 9 0 9 3 3



SURFACE WATER TEMPERATURES

(MONTHLY MEANS)

SECTION 7-FIGURE 1.



TEMPERATURE-DEPTH PROFILE
(August 18, 1967, 4.5 Miles East of Center Hill Pt.)

SECTION 7-FIGURE 2

8.0 ENVIRONMENTAL PROGRAMS

8.1 Environmental Radiology Program

The environmental radiology program for Pilgrim Station is being developed in cooperation with the Massachusetts Department of Public Health and will provide measurements of radiation levels in the site area prior to operation for comparison with similar measurements to be made after the station begins operation.

Preliminary measurements of the environmental radiation levels are scheduled to begin about July, 1969 to verify that procedures and equipment are satisfactory. Routine measurements will be obtained starting about April, 1970 to obtain one year of pre-operational data. Measurements will be continued during startup and after normal operation of the station.

This program will include measurement of the radiation and radioactivity present in the local air, land and marine environment as necessary to obtain adequate information concerning background radiation levels. The data obtained from the pre-operational environmental radiology surveys in conjunction with control data obtained during operation will provide a reference from which any increase in radiation, due to station operation or other causes, can be detected and evaluated.

A continuing evaluation of the program will be performed, and modifications will be made as necessary to insure the adequacy and applicability of the data produced and to provide assurance that the environmental radiology program satisfies Public Health requirements.

A detailed description of the environmental radiology program is now being prepared and should be available for review by the Department of Public Health during November, 1968. Test results from this program will be made available to the Department of Public Health.

8.2 Environmental Ecology Program

The environmental ecology program for Pilgrim Station will be developed in cooperation with the Massachusetts Department of Marine Fisheries and will provide surveys of the ecology in the offshore areas near the site prior to operation for comparison with similar surveys to be made after the station begins operation.

The pre-operational ecology surveys in conjunction with data from control locations during operation will provide a reference from which any changes in ecology, due to station operation or other causes, can be detected and evaluated.

From predictions of the degree and distribution of the heated effluent, it is recommended that environmental ecology surveys be concentrated in an offshore area within a radius of approximately one mile from the discharge location. Topographic features may dictate some slight modification of this area definition, but this is the region within which surface temperature increases of a few degrees Fahrenheit or more would ever be expected to occur and is generally the region within which ecological changes might be statistically determinable. In addition, control locations outside the study area should be established for selected biological sampling to permit detection of changes not related to the operation of Pilgrim Station. The location of these control stations should vary depending upon the particular kind of organism being studied. The collection of selected marine samples for the environmental radiology program will extend beyond the area proposed for ecology studies because of the reconcentration potential of certain marine species.

The physical environment within the ecological study area should be monitored during the period of the ecology studies and should include the measurement of water temperature, salinity and currents. Measurements of the distribution of these physical parameters in the study area should be obtained whenever the ecology surveys are made.

It is recommended that the ecology surveys include studies of plankton, lobsters, Irish moss, and any selected game and commercial fish species which are later determined to be important in the study area.

0 9 3 7

The plankton (floating plant and animal microorganisms) either directly or indirectly constitutes the basic food for all marine life. It is particularly susceptible to environmental changes and occurs in the surface waters where the heated effluent predominates. Plankton also includes the free-swimming larvae of many species of commercial importance including lobster, shellfish, worms, and seaweeds. It is, therefore, recommended that quantitative samples of plankton be taken routinely from both surface and subsurface (near bottom) waters in the study area for:

1. Identification and enumeration of the quantitatively important species of both phytoplankton and zooplankton.
2. Total quantity (biomass) of both phytoplankton and zooplankton.
3. Identification and quantitative estimation of larval forms of commercial importance, with special attention to lobster larvae.

Similar samples should be obtained from a representative control location for comparison with those obtained in the study area. Sampling is recommended throughout the year at intervals of approximately one-month from April through October and at approximately two-month intervals at other times.

0 2 3 3 9

As lobsters are the most important commercial species of the region, an intensive study of the abundance and distribution of lobsters in the study area should be carried out. This should include the study of lobster larvae which was discussed above as part of the plankton study. Studies on adult lobsters in the study should include:

1. Estimates of natural abundance and distribution of lobsters on the bottom by scuba diving.
2. Compilation of "landing statistics" for lobsters.

Similar information should be obtained from a representative control location for comparison with that obtained in the study area. Obtaining a valid comparison of harvest statistics for the study area and the control area will probably require a statistical approach using data from a large number of pots within each area. No measurable changes in the lobster harvest are expected as a result of operation of the station; however, historical confirmation of this is considered essential because of the large economic value of the lobster harvest off the station site. It may be desirable to perform experimental studies regarding temperature effects on lobsters under controlled laboratory conditions to supplement information currently available. Such laboratory information might be valuable in predicting effects of water temperature changes on lobsters which would not be

discernable in the field studies. Additional information regarding the temperature effects on lobsters may be available from other studies being conducted in the New England area.

Irish moss (the seaweed, Chondrus crispus) is probably the second most important commercial species taken from the study area. Compilation of "landing statistics" for Irish moss harvested in the study area should be compared to similar information from a control area. Ellisville is another commercially important area for Irish moss that might be considered as a control location. Laboratory studies and monitoring of experimental plots of Irish moss may be desirable to permit evaluation of temperature effects which might not be detectable from field studies. A student from Cornell University plans independently to begin an ecological study of this alga in the Rocky Point area during the spring of 1969 and it is recommended that he assist in any studies done for Pilgrim Station. Studies of Irish moss are also being done at other New England locations and information may become available from these programs.

Game and commercial fishing in the study area is not extensive and information concerning these activities is difficult to obtain. Some semi-quantitative data could be gathered periodically by the following methods, but such information is not considered to be essential:

1. Creel census of sports fishermen working from boat liveries or marinas in the Plymouth area. The striped bass sports fishing should be emphasized in this type of study. Information obtained in such a study might include number of hours fished in the study area, number of fish caught, and catch per unit effort, within, as compared to outside, the study area.
2. Interviews with commercial bottom trawlers who fish the study areas, obtaining the same type of information as above.
3. General abundance and distribution of bottom fishes, as observed by scuba diving. This can be accomplished at the same time as the scuba lobster survey.

It is recommended that the proposed environmental ecology surveys begin in the spring of 1969 and continue through the summer of 1973 to provide two years of data before and two years of data after initial power operation of Pilgrim Station which is scheduled for the summer of 1971.

9.0 REFERENCES


1. Surface Water Temperature & Salinity - Atlantic Coast of N. & S. America. Pub. 31-1, 2nd Edition, 1965 U. S. Dept. of Commerce, Coast and Geodetic Survey.
2. Surface Water Temperatures at Tide Stations - Atlantic Coast, N. & S. America, Sp. Pub. No. 278, 1954. U. S. Department of Commerce, Coast and Geodetic Survey.
3. World Atlas of Sea Surface Temperatures, H. O. Pub. No. 225, Second Edition, 1944, Hydrographic Office, U. S. Navy.
4. Sea Water Temperatures for Western Half of Cape Cod Bay; Bumpus, D. F., Woods Hole Oceanographic Institute (unpublished).
5. Commonwealth of Massachusetts, Department of Natural Resources, Division of Marine Fisheries. Data taken at Buoy No. 1, Duxbury Channel, June to October 1964 (unpublished).
6. Ditto 5, Temperatures taken during Otter Trawls in Cape Cod Bay, 1964 - 1966 (unpublished).
7. Site Environmental Studies for Pilgrim Station, Dames & Moore, 1967.
8. Tide Tables, High and Low Water Prediction, 1967 East Coast, North and South America Including Greenland, U. S. Department of Commerce, Coast and Geodetic Survey.
9. Tidal Current Tables, 1967, Atlantic Coast of North America, U. S. Department of Commerce, Coast and Geodetic Survey.
10. "10 CFR 20": United States Atomic Energy Commission Rules and Regulations. Title 10 - Atomic Energy Part 20 Standards for Protection Against Radiation.
11. Anraku, M. 1964. Influence of the Cape Cod Canal on the hydrography and on the copepods in Buzzards Bay and Cape Cod Bay, Massachusetts. I. Hydrography and Distribution of Copepods. Limnology and Oceanography 9:46-60.
12. Bumpus, D.F. 1967. Surface water temperatures along Atlantic and Gulf Coasts of the United States. U. S. Department Interior, Fish and Wildlife Service. Special Scientific Report - Fisheries No. 214.
13. Dow, R. L. 1967. The influence of temperature on Maine lobster supply. Published by Maine Sea and Shore Fisheries under Appropriation 7745. September 1967.
14. Hughes, J. T. and G. C. Matthiessen. 1967. Observations on the biology of the American lobster, Homarus americanus. Massachusetts Division of Marine Fisheries, Department of Natural Resources. Technical Series No. 2, Publication No. 594.

15. McLeese, D. W. 1956. Effects of temperature, salinity, and oxygen on the survival of the American lobster. Journal of the Fisheries Research Board of Canada 13:247-274.

0 9 4 0

0 2 3 3 9


0 2 3 3 9 0 9 4 1




LOCATION MAP
NOTES
1. ELEVATIONS SHOWN REFER TO U.S.C. 3 DATUM
MEAN SEA LEVEL EQUALS 0.00 FEET
2. COORDINATES REFER TO MASSACHUSETTS
GRID COORDINATE SYSTEM

DATE	BY	CHECKED	APPROVED
6/1/68	J. H. B.	J. H. B.	J. H. B.
BECHTEL SAN FRANCISCO			
PROJECT: STATIONING AND BOSTON EDISON COMPANY			
SITE PLAN			
6498	PLATE 1	2	

0 2 3 3 9 0 9 4 2




02339 0943



REVISIONS		DATE	BY	CHKD	DESIGNED	DRAWN	REV.
1	AS SHOWN						
BECHTEL SAN FRANCISCO PILGRIM STATION NO. 600 BOSTON EDISON COMPANY LOCATION OF OCEANOGRAPHIC INSTRUMENTATION							
JOB NO.		DRAWING NO.		REV.			
6498		PLATE 3		3			

0 2 3 3 9 0 9 4 4



Enclosure 2

Department of Army, Corps of Engineers

Application for Permit to Discharge or Work in Navigable Waters and Their Tributaries

September 30, 1971

DEPARTMENT OF THE ARMY, CORPS OF ENGINEERS

APPLICATION FOR PERMIT TO DISCHARGE OR WORK IN NAVIGABLE WATERS AND THEIR TRIBUTARIES

SECTION I. GENERAL INFORMATION

1. State M A	Application Number (to be assigned by Corps of Engineers) 01Y 000 3 000084		
Div.	Dist.	Type	Sequence No.

2. Name of applicant and title of signing official

Boston Edison Company

Maurice J. Feldmann, Vice President - Operations and Engineering

3. Mailing address of applicant

Boston Edison Company
800 Boylston Street
Boston, Massachusetts 02199

4. Name, address, telephone number and title of applicant's authorized agent for permit application coordination and correspondence.

Claude A. Pursel

Assistant Vice President - Nuclear

Boston Edison Company

800 Boylston Street

Boston, Massachusetts 02199

(617) 424-2477

William M. Irving
J.E. Howard V.P.
P.J. McSwiney, Plant Mgr

NOTE TO APPLICANT: Refer to the pamphlet entitled "Permits for Work and Structures in and for Discharges or Deposits into Navigable Waters" before attempting to complete this form.

Required Information

- All information contained in this application will, upon request, be made available to the public for inspection and copying. A separate sheet entitled "Confidential Answers" must be used to set out information which is considered by the applicant to constitute trade secrets or commercial or financial information of a confidential nature. The information must clearly indicate the item number to which it applies. Confidential treatment can be considered only for that information for which a specific written request of confidentiality has been made on the attached sheet. However, in no event will identification of the contents and frequency of a discharge be recognized as confidential or privileged information.
- The applicant shall furnish such supplementary information as is required by the District Engineer in order to evaluate fully an application.
- If additional space is needed for a complete response to any item on this form, attach a sheet entitled "Additional Information." Indicate on that sheet the item numbers to which answers apply.
- Drawings required by items 20 and 21 should be attached to this application. Other papers which must be attached to this application include, if applicable, copies of a water quality certification or a written communication which describes water quality impact (see Item 22 and Item 10 of Section II below), the additional information sheet(s) in "c" above, and the confidential information sheet described in "a" above.

Fees

If any discharge or deposit is involved, an application fee of \$100 must be submitted with this application. An additional \$50 is required for each additional point of discharge or deposit.

Signature

- If a discharge is involved, an application submitted by a corporation must be signed by the principal executive officer of that corporation or by an official of the rank of corporate vice president or above who reports directly to such principal executive officer and who has been designated by the principal executive officer to make such applications on behalf of the corporation. In the case of a partnership or a sole proprietorship, the application must be signed by a general partner or the proprietor. Other signature requirements are discussed in the pamphlet.
- If no discharge is involved, an application may be signed by the applicant or his authorized agent.

Application is hereby made for a permit or permits to authorize the activities described herein. I certify that I am familiar with the information contained in this application, and that to the best of my knowledge and belief such information is true, complete, and accurate.

Signature of Applicant

18 U.S.C. Section 1001 provides that:

Whoever, in any matter within the jurisdiction of any department or agency of the United States knowingly and wilfully falsifies, conceals or covers up by any trick, scheme, or device a material fact, or makes any false, fictitious or fraudulent statements or representations, or makes or uses any false writing or document knowing same to contain any false, fictitious or fraudulent statement or entry, shall be fined not more than \$10,000 or imprisoned not more than five years, or both.

FOR CORPS OF ENGINEERS USE ONLY

Acronym name of applicant

Are discharge structures

Date received, form not complete

Date received, form complete
but without certificate

Date received, form complete

Date of Cert./Ltr.

Major? ☐Minor? ☐N/A? ☐

Date sent to EPA, form not complete

Date sent to EPA, NOAA, D/I, AEC,
FPC in complete form

day mo yr

day mo yr

Sept. 29 mo day yr	(Office use only)																																										
Check type of application: a. Original <input type="checkbox"/> b. Revision <input checked="" type="checkbox"/>	7. Number of original application 3-000084																																										
8. Name of facility where discharge or construction will occur. <u>Pilgrim Nuclear Power Station, No. 600</u>																																											
9. Full mailing address of facility named in item 8 above. <u>Boston Edison Company</u> <u>Pilgrim Nuclear Power Station</u> <u>RFD #1, Rocky Hill Road</u> <u>Plymouth, Massachusetts 02360</u>																																											
10. Names and mailing addresses of all adjoining property owners whose property also adjoins the waterway. 1. (Northwest) Joint Property Owners (3) - Francis W. Sears, Charlotte Sears, Marion V. Sears - Pine Tree Road, Norwich, Vermont 2. (Southeast) Property Owner (1) - Richard N. Greenwood, RFD #1, Plymouth, Massachusetts 02360																																											
11. Check to indicate the nature of the proposed activity: a. Dredging <input checked="" type="checkbox"/> * b. Construction <input type="checkbox"/> c. Construction with Discharge <input checked="" type="checkbox"/> ** d. Discharge only <input type="checkbox"/>																																											
12. If activity is temporary in nature, estimate its duration in months. <u>Permanent</u>																																											
If application is for a discharge: List intake sources																																											
Source	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="6">Estimated Volume in Million Gallons Per day or Fraction Thereof</th> </tr> </thead> <tbody> <tr> <td>Municipal or private water supply system</td> <td>0</td> <td>0</td> <td>2</td> <td>6</td> <td>5</td> </tr> <tr> <td>Surface water body (sea water)</td> <td>4</td> <td>7</td> <td>4</td> <td></td> <td></td> </tr> <tr> <td>Ground water</td> <td></td> <td>0</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td>0</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Estimated Volume in Million Gallons Per day or Fraction Thereof						Municipal or private water supply system	0	0	2	6	5	Surface water body (sea water)	4	7	4			Ground water		0				Other		0															
Estimated Volume in Million Gallons Per day or Fraction Thereof																																											
Municipal or private water supply system	0	0	2	6	5																																						
Surface water body (sea water)	4	7	4																																								
Ground water		0																																									
Other		0																																									
Describe water usage within the plant																																											
Type	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="6">Estimated Volume in Million Gallons Per day or Fraction Thereof</th> </tr> </thead> <tbody> <tr> <td>Cooling water</td> <td>4</td> <td>7</td> <td>4</td> <td></td> <td></td> </tr> <tr> <td>Boiler Feed water (recycled)</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> <tr> <td>Process water (recycled)</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> <tr> <td>Sanitary system*</td> <td></td> <td></td> <td>0</td> <td>0</td> <td>2 5</td> </tr> <tr> <td>Other (make-up to process flows)</td> <td></td> <td></td> <td>0</td> <td>2</td> <td>4</td> </tr> </tbody> </table>	Estimated Volume in Million Gallons Per day or Fraction Thereof						Cooling water	4	7	4			Boiler Feed water (recycled)			0			Process water (recycled)			0			Sanitary system*			0	0	2 5	Other (make-up to process flows)			0	2	4						
Estimated Volume in Million Gallons Per day or Fraction Thereof																																											
Cooling water	4	7	4																																								
Boiler Feed water (recycled)			0																																								
Process water (recycled)			0																																								
Sanitary system*			0	0	2 5																																						
Other (make-up to process flows)			0	2	4																																						
volume of discharges or losses other than into navigable waters.																																											
Type	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="6">Estimated Volume in Million Gallons Per day or Fraction Thereof</th> </tr> </thead> <tbody> <tr> <td>Municipal waste treatment system</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> <tr> <td>Surface containment</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> <tr> <td>Underground disposal</td> <td></td> <td></td> <td>0</td> <td>0</td> <td>2 5</td> </tr> <tr> <td>Waste Acceptance firms</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> <tr> <td>Evaporation</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> <tr> <td>Consumption</td> <td></td> <td></td> <td>0</td> <td></td> <td></td> </tr> </tbody> </table>	Estimated Volume in Million Gallons Per day or Fraction Thereof						Municipal waste treatment system			0			Surface containment			0			Underground disposal			0	0	2 5	Waste Acceptance firms			0			Evaporation			0			Consumption			0		
Estimated Volume in Million Gallons Per day or Fraction Thereof																																											
Municipal waste treatment system			0																																								
Surface containment			0																																								
Underground disposal			0	0	2 5																																						
Waste Acceptance firms			0																																								
Evaporation			0																																								
Consumption			0																																								
Indicate number employees served per day																																											
100																																											

4345 *Maintenance dredging as indicated in Item 24.

**Construction complete. See Item 22.

a. Name the corporate boundaries within which activity will occur. structures exist or the

State

County

City or Town

16. Massachusetts

17. Plymouth

18. Plymouth

b. Name of waterway at the location of the activity

19. Cape Cod Bay

20. Maps which show the location of each structure or activity, including any and all outfall devices, dispersive devices, and non-structural points of discharge, must be attached to this application.

21. The character of each structure must be fully shown on plans to be submitted with this application. Note on the drawings those structures for which separate discharge information (Section II of this form) has been submitted.

22. List all approvals or denials granted by Federal, interstate, State or local agencies for any structures, construction, discharges or deposits described in this application.

Type of document

Id. No.

Date

Issuing Agency

See Attachment No. 1

23. Check if facility existed or was lawfully under construction prior to April 3, 1970.

☒

4. If dredging or filling will occur:

State the type of materials involved, their volume in cubic yards, and the proposed method of measurement.

Maintenance dredging of intake channel, (unscheduled) on a contingency basis, measured by disposal barge capacity and number of barges filled.

Describe the proposed method of instrumentation which will be used to measure the volume of any solids deposited and to determine its effect upon the waterway.

Only suspended and dissolved solids will be discharged. These are expected to remain in suspension indefinitely and will not effect the waterway. Total volumes of all such solids will be determined periodically from effluent samples and the plant operations log books which will include records of all discharge volumes.

rates and periods of deposition described in Item 25.

liquid discharges are continuous, but no deposition is expected.

Attachment 2 for further information on rates of discharge.)

SECTION II. LAINT PROCESS AND DISCHARGE DESCRIPTION

1. Discharge described below is a. Present <input checked="" type="checkbox"/> b. Proposed new or changed <input type="checkbox"/>		2. Implementation schedule <input type="checkbox"/>	(Office use only)
Name of corporate boundaries within which the point of discharge is located. State <u>Massachusetts</u> County <u>Plymouth</u> City or Town <u>Plymouth</u>			6. Discharge Serial No. <u>001</u>
3. <u>Massachusetts</u>		4. <u>Plymouth</u>	5. <u>Plymouth</u>
State the precise location of the point of discharge. 7. Latitude <u>41</u> Degrees; <u>56</u> Min; <u>51</u> Sec. 8. Longitude <u>70</u> Degrees; <u>34</u> Min; <u>48</u> Sec.		9. Name of waterway at the point of discharge. <u>Cape Cod Bay</u>	
10. Has application for water quality certification or description of impact been made? If so, give date: Date <u>Aug. 24 71</u> mo day yr Check if certificate is attached to form <input type="checkbox"/> Name Issuing Agency <u>The Commonwealth of Mass. Water Resources Commission Div. of Water Pollution Control</u>			
11. Narrative description of activity (include terms of general 4-digit Standard Industrial Classification, and specific manufacturing process). <u>Production of electric power by steam turbine generator; steam supplied by boiling water nuclear reactor.</u>			
12. Standard industrial classification number. <u>SIC-491</u>	13. Principal product. <u>Electric power</u>		14. Amount of principal product produced per day. <u>16.45 million</u> <u>kilowatt hours</u>
15. Principal raw material. <u>Uranium</u>	16. Amount of principal raw material consumed per day. <u>Approximately</u> <u>6 lbs./day</u> <u>irretrievable</u>		17. Number of batch discharges per day. <u>See Attachment 2</u>
18. Average gallons per batch discharge. <u>See Attachment 2</u>	19. Date discharge began. <u>See Attachment 2</u> mo day yr	20. Date discharge will begin. <u>See Attachment 2</u> mo day yr	
21. Describe waste abatement practices. <u>Dispersion and loss from the bay of the rejected heat from the discharge is enhanced by the discharge structure design as follows: The excess momentum associated with the condenser cooling water as it is discharged into the waters of Cape Cod Bay produces an entraining jet which is diluted by the mechanical entrainment required to reduce the velocity of the jet to that of the surrounding waters. Surface discharge promotes conductive and convective cooling to the air over the receiving body. Prior to discharge from the station each batch of liquid radwaste is sampled and analyzed for radioactivity to determine the allowable rate of discharge. In addition, the liquid radwaste discharge line is provided with a continuous radioactivity monitor to record the activity of any liquids released to the circulating water system. After mixing with the circulating water, the radioactivity of liquid wastes discharged from the station will be below the limits specified in 10 CFR 20, Standards for Protection Against Radiation. The Station</u>			

22.

PHYSICAL DESCRIPTION OF INTAKE WATER AND DISCHARGE

Intake	Discharge		(Office use only)				
Parameter and Code	(1)	(2)	(3)	(4)	(5)	(6)	(7)
Flow (Gallons per day) 00050 50050	474 <i>MBD</i>		474	474	474		ABS
pH 00400	7.7 ± 0.5		7.7	7.2	8.2	MNLY	ABS
Temperature (Winter) (°F) 74028	35		64	32	69	DYLY	MON*
Temperature (Summer) (°F) 74027	60 <i>average</i>		89	36 <i>actually water</i>	99	DYLY	MON*

Discharge Serial No.

001

23.

DISCHARGE CONTENTS

(See Item 25)

PARAMETER	PRESENT	ABSENT	PARAMETER	PRESENT	ABSENT	PARAMETER	PRESENT	ABSENT
Color 00080		X	Aluminum 01105		X	Nickel 01067		X
Turbidity 00070		X	Antimony 01097		X	Selenium 01147		X
Radioactivity 74050	X		Arsenic 01002		X	Silver 01077		X
Hardness 00900		X	Beryllium 01012		X	Potassium 00937		X
Solids 00500	X		Barium 01007		X	Sodium 00929	X	
Ammonia 00610		X	Boron 01022	X		Titanium 01152		X
Organic Nitrogen 00605		X	Cadmium 01027		X	Tin 01102		X
Nitrate 00620		X	Calcium 00916		X	Zinc 01092		X
Nitrite 00615	X		Cobalt 01037		X	Algicides 74051	X	
Phosphorus 00665		X	Chromium 01034		X	Oil and Grease 00550		X
Sulfate 00945	X		Copper 01042		X	Phenols 32730		X
Sulfide 00745		X	Iron 01045		X	Surfactants 33260		X
Sulfite 00740		X	Lead 01051		X	Chlorinated Hydrocarbons 74052		X
Bromide 71870		X	Magnesium 00927		X	Pesticides 74053		X
Chloride 00940	X		Manganese 01055		X	Fecal Streptococci Bacteria 74054		X
Cyanide 00720		X	Mercury 71900		X	Coliform Bacteria 74056		X
Fluoride 00951		X	Molybdenum 01062		X			

ENG FORM

MAY 71

4345-1

* Values recorded, but not continuously.

24a. Have all known hazardous or potentially hazardous substances in your plant been inventoried?

☒ Yes

☐ No

24b. If yes, have steps been taken to insure that there exists no possibility of any such known hazardous or potentially hazardous substance entering this discharge?

☒ Yes

☐ No

25. Remarks. Parts A & B-2, Column 4 - Units are pounds/day per million kWhr/day.

Item 22 - pH and temperature values for discharge are based on measurements of intake water properties and changes predicted to occur after full power operation is initiated.

Item 23 - "Discharge Contents," lists only those discharges which are added to the normal sea water inventory.

The information above completes the basic reporting requirements which are required of all applicants. Those applicants whose discharge results from an activity included within any of the Standard Industrial Classification Code (SIC Code) categories listed below must complete Part A of this form as well.

CRITICAL INDUSTRIAL GROUPS

SIC 098	FISH HATCHERIES, FARMS, AND PRESERVES	SIC 285	PAINTS, VARNISHES, LACQUERS, ENAMELS, AND ALLIED PRODUCTS
SIC 10-14	DIVISION B - MINING	SIC 2871	FERTILIZERS
SIC 201	MEAT PRODUCTS	SIC 2879	AGRICULTURAL PESTICIDES, AND OTHER AGRICULTURAL CHEMICALS, NOT ELSEWHERE CLASSIFIED
SIC 202	DAIRY PRODUCTS	SIC 2891	ADHESIVES AND GELATIN
SIC 203	CANNED PRESERVED FRUITS, VEGETABLES (EXCEPT SEAFOODS, SIC 2031 AND 2036)	SIC 2892	EXPLOSIVES
SIC 2031, 2036	CANNED AND CURED FISH AND SEAFOODS; FRESH OR FROZEN PACKAGED FISH AND SEAFOODS	SIC 29	PETROLEUM REFINING AND RELATED INDUSTRIES
SIC 204	GRAIN MILL PRODUCTS	SIC 3011, 3069	TIRES AND INNER TUBES; FABRICATED RUBBER PRODUCTS, NOT ELSEWHERE CLASSIFIED
SIC 206	SUGAR	SIC 3079	MISCELLANEOUS PLASTICS PRODUCTS
SIC 207	CONFECTIONARY AND RELATED PRODUCTS	SIC 311	LEATHER TANNING AND FINISHING
SIC 208	BEVERAGES	SIC 32	STONE, CLAY, GLASS, AND CONCRETE PRODUCTS
SIC 209	MISCELLANEOUS FOOD PREPARATIONS AND KINDRED PRODUCTS	SIC 331	BLAST FURNACES, STEEL WORKS, AND ROLLING AND FINISHING MILLS
SIC 22	TEXTILE MILL PRODUCTS	SIC 332	IRON AND STEEL FOUNDRIES
SIC 23	APPAREL AND OTHER FINISHED PRODUCTS MADE FROM FABRICS AND SIMILAR MATERIALS	SIC 333, 334	PRIMARY SMELTING AND REFINING OF NON-FERROUS METALS; SECONDARY SMELTING AND REFINING OF NONFERROUS METALS
SIC 242	SAWMILLS AND PLANING MILLS	SIC 336	NONFERROUS FOUNDRIES
SIC 2432	VENEER AND PLYWOOD	SIC 347	COATING, ENGRAVING, AND ALLIED SERVICES
SIC 2491	WOOD PRESERVING	SIC 35	MACHINERY, EXCEPT ELECTRICAL
SIC 26	PAPER AND ALLIED PRODUCTS	SIC 36	ELECTRICAL MACHINERY, EQUIPMENT, AND SUPPLIES
SIC 281	INDUSTRIAL INORGANIC AND ORGANIC CHEMICALS (EXCEPT SIC 2818)	SIC 37	TRANSPORTATION EQUIPMENT (EXCEPT SHIP BUILDING AND REPAIRING, SIC 3731)
SIC 2818	INDUSTRIAL ORGANIC CHEMICALS	SIC 3731	SHIP BUILDING AND REPAIRING
SIC 282	PLASTICS MATERIALS AND SYNTHETIC RESINS, SYNTHETIC RUBBER, SYNTHETIC AND OTHER MAN-MADE FIBERS, EXCEPT GLASS	SIC 491	ELECTRIC COMPANIES AND SYSTEMS
SIC 283	DRUGS	SIC 493	COMBINATION COMPANIES AND SYSTEMS
SIC 284	SOAP, DETERGENTS, AND CLEANING PREPARATIONS, PERFUMES, COSMETICS, AND OTHER TOILET PREPARATIONS		

(Note: Submission of Part A is required of all applic
on page 3 above.)

ose processes are listed

(Office use only)

000084

Discharge Serial No.

001

INFORMATION REQUIRED OF SPECIFIED INDUSTRIES *

Intake		Discharge										
PARAMETER AND CODE	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)
	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)	(DAILY AVG. CONCENTRATION) (1)
ALKALINITY (as Ca CO ₃) 00410	109.±1.		110.				109.		Aver.	Wkly.	Stand.	ABS
B.O.D. 5-DAY 00310	9.±7.		12.				7.		Aver.	Wkly.	Stand.	ABS
CHEMICAL OXYGEN DEMAND (C.O.D.) 00340	426. ± 58.		520.				373.		Aver.	Wkly.	Stand.	ABS
TOTAL SOLIDS 00500	37,705 ±1,585		38,444				37,535		Aver.	Wkly.	Stand.	ABS
TOTAL DISSOLVED SOLIDS 70300	37,704 ±1,585		38,444				37,533		Aver.	Wkly.	Stand.	ABS
TOTAL SUSPENDED SOLIDS 00530	2.± 1.		4.				3.		Aver.	Wkly.	Stand.	ABS
TOTAL VOLATILE SOLIDS 00505	4,008 ±1,632		4,008				3,997		Aver.	Wkly.	Stand.	ABS
AMMONIA (as N) 00610	0.07 ±0.05		0.20				0.10		Aver.	Wkly.	Stand.	ABS
KJELDAHL NITROGEN 00625	0.00		0.00				0.00		Aver.	Wkly.	Stand.	ABS
NITRATE (as N) 00620	0.00		0.00				0.00		Aver.	Wkly.	Stand.	ABS
PHOSPHORUS TOTAL (as P) 00665	Trace		Trace				Trace		Aver.	Wkly.	Stand.	ABS

ENG FORM
MAY 71 4345-1

* Supplementary information on chemical additions in liquid
discharge is given in Attachment 3.

PART B DISCHARGE DESCRIPTION

(Note: Submission of Part B is required of all applicants who are also required to submit Part A. Only those parameters specifically indicated in the instructions are to be reported by a particular industry)

(Office use only)

000084

Discharge Serial No.

001

B-1. PHYSICAL AND BIOLOGICAL PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-1)

Intake	Discharge						
PARAMETER AND CODE	UNTREATED INTAKE WATER	TREATED INTAKE WATER	AVERAGE (DAILY)	MINIMUM (OPERATING YEAR)	MAXIMUM (OPERATING YEAR)	SAMPLE FREQUENCY	CONTINUOUS MONITORING
	(1)	(2)	(3)	(4)	(5)	(6)	(7)
COLOR 00080			NC				
SPECIFIC CONDUCTANCE 00095			NC				
TURBIDITY 00070			NC				
FECAL STREPTOCOCCI BACTERIA 74054			NC				
FECAL COLIFORM BACTERIA 74055			NC				
TOTAL COLIFORM BACTERIA 74056			NC				

NOTE: NC - No Change occurs in these parameters.

PART B

(Office use only)

000084

Discharge Serial No.

001

B-2. CHEMICAL PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-2)

PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-2)											
Intake	Discharge (See Remarks)										
PARAMETER AND CODE	UNTREATED INTAKE WATER	TREATED INTAKE WATER	MAXIMUM CONCENTRATION	MAXIMUM POUNDS PER DAY PER PROCESS UNIT	MAXIMUM POUNDS PER DAY	DAILY AVG. CONCENTRATION	AVERAGE POUNDS PER DAY	SAMPLE TYPE	METHOD OF ANALYSIS	CONTINUOUS MONITORING	
	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
ACIDITY (as CaCO ₃) 00435			NC								
TOTAL ORGANIC CARBON (T.O.C.) 00680			NC								
TOTAL HARDNESS 00900			NC								
NITRITE (as N) 00615	0.0		0.0 (0.3)	0.0 (6.1)	0.0 (100)	0.0 (0.0)	0.0 (8.)	A	W	S	A
ORGANIC NITROGEN 00605			NC								
PHOSPHORUS-ORTHO (as P) 70507			NC								
SULFATE(as SO ₄) 00945	2386.0 ±115.		2583.5 (2.2)	(180.)	(2900.)	2402.8 (0.2)	(1000.)	A	W	S	A
SULFIDE 00745			NC								
SULFITE 00740			NC								
BROMIDE 71870			NC								

ENG FORM

PART B

(Office use only)

000084

Discharge Serial No.

001

B-2. (cont.)

CHEMICAL PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-2)

Intake		Discharge									
PARAMETER AND CODE	UNTREATED INTAKE WATER	TREATED INTAKE WATER	MAXIMUM CONCENTRATION	MAXIMUM POUNDS PER DAY PER PROCESS UNIT	MAXIMUM POUNDS PER DAY	DAILY AVG. CONCENTRATION	AVERAGE POUNDS PER DAY	SAMPLE TYPE	METHOD OF ANALYSIS	CONTINUOUS MONITORING	
	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
CHLORIDE 00940	17,867. + 695. - 695.	(≤ 4 .) as NaOCl	18,400. (4.)	(500.)	1600. (8100.)	18,100. (≤ 1 .)	8. (≤ 4100 .)	A	W	S	A
CYANIDE 00720			NC								
FLUORIDE 00951			NC								
ALUMINUM-TOTAL 01105			NC								
ANTIMONY-TOTAL 01097			NC								
ARSENIC-TOTAL 01002			NC								
BARIUM-TOTAL 01007			NC								
BERYLLIUM-TOTAL 01012			NC								
BORON-TOTAL 01022	2,900. $\pm 1,200$.		3,600. (870.)	(29.)	(480.)	2,800. (30.)	(48.)	A	W	S	A
CADMIUM-TOTAL 01027											

PART B

(Office use only)

000084

Discharge Serial No.

001

B-2. (cont.)

CHEMICAL PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-2)

Intake	Discharge										
PARAMETER AND CODE	UNTREATED INTAKE WATER	TREATED INTAKE WATER	MAXIMUM CONCENTRATION	MAXIMUM POUNDS PER DAY PER PROCESS UNIT	MAXIMUM POUNDS PER DAY	DAILY AVG. CONCENTRATION	AVERAGE POUNDS PER DAY	SAMPLE TYPE	SAMPLE FREQUENCY	METHOD OF ANALYSIS	CONTINUOUS MONITORING
	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
CALCIUM-TOTAL 00916			NC								
CHROMIUM-TOTAL 01034	52. +61.		110			42.		A	W	S	A
COBALT-TOTAL 01037			NC								
COPPER-TOTAL 01042			NC								
IRON-TOTAL 01045			NC								
LEAD-TOTAL 01051			NC								
MAGNESIUM-TOTAL 00927			NC								
MANGANESE-TOTAL 01055			NC								
MERCURY-TOTAL 71900			NC								
MOLYBDENUM-TOTAL 01062			NC								

PART B

(Office use only)

000084

Discharge Serial No.

001

B-2. (cont.)

CHEMICAL PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-2)

Intake	Discharge										
	UNTREATED INTAKE WATER	TREATED INTAKE WATER	MAXIMUM CONCENTRATION	MAXIMUM POUNDS PER DAY PER PROCESS UNIT	MAXIMUM POUNDS PER DAY	DAILY AVG. CONCENTRATION	AVERAGE POUNDS PER DAY	SAMPLE TYPE	METHOD OF ANALYSIS	CONTINUOUS MONITORING	
PARAMETER AND CODE	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
NICKEL-TOTAL 01067			NC								
POTASSIUM-TOTAL 00937			NC								
SELENIUM-TOTAL 01147			NC								
SILVER-TOTAL 01077			NC								
SODIUM-TOTAL 00929		9,520. ± 278. (1.)	9,840. (4.)	(440.)	1,400. (7,300.)	9,520. (1.)	57. (3,300.)	A	W	S	A
THALLIUM-TOTAL 01059			NC								
TIN-TOTAL 01102			NC								
TITANIUM-TOTAL 01152			NC								
ZINC-TOTAL 01092	40. ± 23.		70.			57.		A	W	S	A
OIL AND GREASE 00550			NC								

PART B

(Office use only)

000084

Discharge Serial No.

001

B-2. (cont.)

CHEMICAL PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-2)

Intake	Discharge										
PARAMETER AND CODE	UNTREATED INTAKE WATER	TREATED INTAKE WATER	MAXIMUM CONCENTRATION	MAXIMUM POUNDS PER DAY PER PROCESS UNIT	MAXIMUM POUNDS PER DAY	DAILY AVG. CONCENTRATION	AVERAGE POUNDS PER DAY	SAMPLE TYPE	METHOD OF ANALYSIS	CONTINUOUS MONITORING	
	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
PHENOLS 32730	0.		0.			0.					
SURFACTANTS 38260			NC								
ALGICIDES* 74051 Chlorine	A	<1.000 (2.000) (NaOCl)	<0.100 (0.100)	<24. (24)	<400. (400)	<0.050 (0)	<200 (0)	X	D	O	R
CHLORINATED HYDRO-CARBONS* (EXCEPT PESTICIDES) 74052			NC								
PESTICIDES* 74053			NC								

*Name specific compound(s) and fill in the required data for each. Use extra blanks at the end of the form and the "Remarks" space as necessary.

PART B

(Office use only)

000084

Discharge Serial No.

001

B-3. RADIOACTIVE PARAMETERS OF INTAKE WATER AND DISCHARGE (See Table B-3)

Intake	Discharge (See Remarks)						
PARAMETER AND CODE	UNTREATED INTAKE WATER	TREATED INTAKE WATER	AVERAGE (DAILY)	MINIMUM (OPERATING YEAR)	MAXIMUM (OPERATING YEAR)	SAMPLE FREQUENCY	CONTINUOUS MONITORING
	(1)	(2)	(3)	(4)	(5)	(6)	(7)
ALPHA-TOTAL 01501	3100.					0	A
ALPHA COUNTING ERROR 01502	3500.					0	A
BETA-TOTAL (3) 03501	< 35.					M	A
BETA COUNTING ERROR 03502	10.					M	A
GAMMA-TOTAL (4) 05501	< 50.					M	A
GAMMA COUNTING ERROR 05502	50.					M	A
TRITIUM-TOTAL 07000	0.0					M	A
TRITIUM COUNTING ERROR 07001	0.0					M	A

B-4. REMARKS

See Attachment 4.

ITEM #22

<u>Type of Document</u>	<u>I.D. No./Date</u>	<u>Agency</u>
Permit to construct and maintain intake structure, breakwaters, & dredge intake and discharge channels.	DACW33-69-6-0178 April 17, 1969	U.S. Army Engineer Div. New England Corps of Engineers
Interim permit for Salt Water Use and Waterfront Development.	Letter from the Agency Director Jan. 8, 1969	Massachusetts Water Resources Commission
License to construct and maintain intake structure and breakwaters and dredge intake and discharge channels.	License No. 5504 April 3, 1969	Mass. Department of Public Works
Construction Permit	Construction Permit No. CPPR-49 August 26, 1968	U.S. Atomic Energy Commission
Order of Conditions for breakwater construction and dredging.	DF-329 March 5, 1969	Massachusetts Department of Natural Resources
Water Quality Standards Certification.	Letter from the Director April 23, 1971 (attached)	Massachusetts Water Resources Commission

Attachment 2

Items 17 through 20 -

Discharge will consist of three components as listed in the following table. These components are will mixed in the discharge canal prior to entering the receiving body of water. They are listed separately here because of the different volumes and different initial dates of discharge, as presented in the table. Values shown represent expected yearly averages. Maximum daily volumes could be as much as twice these values.

	Item 17		Item 18		Item 19		Item 20	
	No. of Batch Discharges Per Day		Avg. Gallons Per Batch Discharge		Date Discharge Began		Date Discharge Will Begin	
(a) Circulating sea water for cooling.	Continuous*				3-20-71		**	
(b) Radwaste system effluents (potentially radioactive)	1		20,000				7-71***	
(c) Make-up system effluents (non-radioactive)	1-5		20,000		11-15-70			

* 474,000,000 gallons per day.

** Discharge which began 3-20-71 has negligible temperature increase. Temperature rise in this discharge will increase about January, 1972 when power operation is initiated.

*** Discharge which will begin about July, 1971 contains no added radioactivity. Radioactivity in this discharge will increase about December, 1971 when reactor operation is initiated.

NOTE: Values reported in Part A (page 4) are estimates taken from the literature cited below. Actual quantities will be measured periodically during plant operation.

Reference 1

Sverdrup, H. U., The Oceans, Their Physics, Chemistry, and General Biology. Prentice Hall, Inc., New York (1946).

Reference 2

Hodgman, C. D., Handbook of Physics and Chemistry, 42nd Edition, Chemical Rubber Publishing Co., 1960.

Reference 3

Koczy, F. F., "Seawater," International Science and Technology, December, 1966.

ATTACHMENT 3

PRINCIPAL CHEMICAL ADDITIONS TO LIQUID

<u>Chemical</u>	<u>Normal Discharge Volume (Gallons)</u>	<u>Average Flow Duration</u>	<u>Average Discharge Frequency</u>	<u>Average Concentration (mg/liter) *</u>	<u>Maximum Discharge Volume (Gallons)</u>
1. Sodium Pentaborate	400	75 minutes	1 per yr.	3.4	4,000
2. Sodium Nitrite from CCW System ***	5,000	25 minutes	1 per yr.	0.77	25,000
3. Sodium Nitrite from Plant Heating Sys.	2,400	12 minutes	1 per yr.	0.77	12,000
4. B ₂ O ₃ from CCWS ***	5,000	25 minutes	1 per yr.	1.4	25,000
5. B ₂ O ₃ from Plant Heating System	2,400	12 minutes	1 per yr.	1.4	12,000
6. Dissolved Sodium Sulfate from Makeup System	16,000	80 minutes	1 per 5 days	0.8	16,000
7. Suspended Solids From Makeup System	2,800	15 minutes	1 per 5 days	0.4	2,800
8. Dissolved Solids (Sodium sulfate) from the Condensate Demineralizer Sys.	450/day	Continuous	Continuous	0.3	20,000
9. Sodium Hydroxide	-	-	-	Trace	
10. Sulfuric Acid	-	-	-	Trace	
11. Chlorine From Hypochlorite Addition	10 GPM	As required	As required	0	10

* Based on circulating water flow of 3.2 x 10⁵ GPM; concentrations listed are tho:

** Predictions for time periods after full power operation is initiated (currently s

*** CCWS - Closed cooling water systems.

MONTHLY TEMPERATURE AVERAGES

JUNE 1970 THROUGH JUNE 1971

DERIVED FROM DATA COLLECTED AT MONITORING STATIONS 2' BELOW
THE SURFACE, 10' BELOW THE SURFACE, AND ON THE BOTTOM (-30' MLW)

	<u>2'</u>	<u>10'</u>	<u>Bottom</u>
June 1970	53	46	45
July	54	53	46
August	63	60	54
September	50 ^a	58	53
October	55	55	45 ^b
November	52	45	44 ^c
December	35	38 ^b	39
January 1971	—	No Data	—
February	— ^d	33 ^e	32 ^e
March	37	36	37
April	41 ^f	40 ^f	37 ^f
May	45	47	41
June	55	53	44

a Only 7-day's data

b Based on 29-day's data

c Based on 26-day's data


d Apparent instrument malfunction

e Based on 18-day's data




f Based on 21-day's data

Rec
3/29/72

DAILY TEMPERATURE RANGES & AVERAGES FROM 2-FC STATION (°F)




DAILY TEMPERATURE RANGES & AVERAGES FROM 2-F STATION (°F)



DAILY TEMPERA


RANGES & AVERAGES FROM 10-F

TATION (°F)




JUNE 1970

JULY 1970



AUGUST 1970

SEPTEMBER 1970






OCTOBER 1970

NOVEMBER 1970




DAILY TEMPERATURE

RANGES & AVERAGES FROM 10-F

STATION (°F)



DAILY TEMPERATURE R. & AVERAGES FROM BOTTOM (-30 LW) STATION (°F)



ORIGIN OF LIQUID DISCHARGE COMPONENTS


- Thermal - Cooling water to condense steam
(same as in any thermal - electric
generating station)
- Radioactivity - (a) Neutron activation products
 (1) originating in water
 (2) originating in reactor equipment
- (b) Fission Products
 (1) minor leakage from fuel
 (2) tramp uranium

THERMAL DISCHARGE

1. Leakage of process streams into Sea Water cooling system is virtually impossible due to Δp effects.
2. Discharge system designed to promote rapid mixing of heated effluent with ambient bay water and minimize bottom effects:
 - . High exit velocity
 - . Short discharge canal
 - . Surface discharge
 - . Provides 3-sided entrainment of cold water
 - . Minimizes time at ΔT max. for entrained organisms

LIQUID RADWASTE TREATMENT SYSTEM


A. "CLEAN" RADWASTE



LIQUID RADWASTE TREATMENT SYSTEM

Final figure

B. "CHEMICAL" RADWASTE



Attachment 4

Principal Chemical Additions
in Liquid Discharge

<u>Chemical</u>	<u>Amount Discharged (lbs./yr.)</u>	<u>Annual Average Concentration (mg/liter)</u>
1. Sodium Pentaborate (Boron)	2.5×10^2	1.9×10^{-4}
2. Sodium Nitrite	4×10^4	3×10^{-2}
3. Sodium Hydroxide (NaOH)	-	Trace Amounts
4. Sulfuric Acid (H ₂ SO ₄)	-	Trace Amounts
5. Dissolved Solids (Na ₂ SO ₄)	4.2×10^5	0.3
6. Sodium Hypochlorite (Free Chlorine Algicide)	Not Applicable	< 0.1

ATTACHMENT 4B-4 REMARKS

- (1) The values listed at the top of the fill-in space in Parts A and B-2 were derived from laboratory analyses performed on grab samples taken weekly in the time period August 18, 1971 through September 8, 1971. The values in parentheses at the bottom of the space are predictions of the quantities that will be added to the sea water in the discharge after full power operation is initiated (currently scheduled for April, 1972).

- (2) Parts A and B-2, Columns (4), (5) and (7) -

No chemicals other than sodium sulfate and sodium hypochlorite have been added to date. The differences between values listed in Columns (1) and (6) are due primarily to uncertainties in the analyses and/or normal sea water variations as indicated by the standard deviations in the measured values reported in Column 1.

- (3) Parts A and B-2, Column 4 -

Values listed are based on 16.45 process units, where 1 process unit equals 10^6 kilowatthours, and maximum pounds per day added to the discharge.

- (4) Parts A and B-2, Column (7) -

Predicted values of average pounds per day added to the discharge apply for days in which that particular parameter is added to the discharge. Yearly averages will, of course, be lower than the reported values in column 7 for those parameters whose discharge frequency is less than one per day (see Attachment 3).

- (5) Part B-2 -

Residual chlorine in discharge could result from addition of sodium hypochlorite and is monitored continuously during and after periods of hypochlorite addition using a Wallace and Ternin Residual Chlorine Analyzer, Series 50-236.

- (6) Part B-3 -

Present discharge contains no added radioactivity (see Attachment 2). Measurements listed for radioactivity in intake water were obtained as part of pre-operational test program during the period September 1970 through September 1971. Meaningful predictions of radioactive parameters prior to full power operation cannot be made. The plant will be operated to maintain all radioactive effluents as low as practicable and, in all cases, will be less than the maximum permissible levels specified in 10 CFR 20 (Title 10 of the Code of Federal Regulations, Part 20).

(7) Part B-3 -

Beta activity reported is the summation of fractional gross beta activities.

(8) Part B-3 -

Gross gamma activity reported is based on assumption that gamma activity is due entirely to cesium-137.

(9) Part B-3, Column (6)

Alpha activity measurement is based on a single sample of intake water taken on August 18, 1971. Alpha measurements of sea water are not normally performed due to the large counting error associated with such measurements.