



CHARLES D. BAKER
GOVERNOR

KARYN E. POLITO
LIEUTENANT GOVERNOR

MIKE KENNEALY
SECRETARY OF HOUSING AND
ECONOMIC DEVELOPMENT

**Commonwealth of Massachusetts
Division of Professional Licensure**

1000 Washington Street, Suite 710
Boston, Massachusetts 02118

EDWARD A. PALLESCHI
UNDERSECRETARY OF CONSUMER
AFFAIRS AND BUSINESS
REGULATION

LAYLA R. D'EMILIA
COMMISSIONER, DIVISION OF
PROFESSIONAL LICENSURE

BOARD OF STATE EXAMINERS OF PLUMBERS AND GAS FITTERS

NOTICE OF MEETING

October 7, 2020 BOARD MEETING

In accordance with the provisions of G.L. c. 30A § 20, notice is hereby given that the Board of State Examiners of Plumbers and Gas Fitters will convene a regular monthly meeting via Gotomeeting conference on:

Board of State Examiners of Plumbers and Gas Fitters
Wed, Oct 7, 2020 9:00 AM - 1:00 PM (EDT)

Please join my meeting from your computer, tablet or smartphone.
<https://global.gotomeeting.com/join/401836557>

You can also dial in using your phone.
United States (Toll Free): [1 877 309 2073](tel:18773092073)
United States: [+1 \(646\) 749-3129](tel:+16467493129)

Access Code: 401-836-557

New to GoToMeeting? Get the app now and be ready when your first meeting starts:
<https://global.gotomeeting.com/install/401836557>

It is anticipated that the topics shown below will be discussed at the aforementioned meeting:

9:00 A.M. AGENDA REVIEW: By Chairman Joseph McNamee



BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 2, 2020

It is anticipated that the topics shown below will be discussed at the aforementioned meeting:

Member and Staff Attendance

MEMBERS	APPOINTMENT	PRESENT	ABSENT
Mr. Joseph McNamee	Member, Master Gas Fitter		
Mr. Dan Kilburn	Member, DPL Designee		
Mr. Harold Knight	Member, Journeyman Plumber		X
Mr. John Cruz	Member, LP Installer		
Mr. Bahig A. Kaldas, P. E.	Member, Plumbing Engineer		
Mr. Joseph V. Waskiewicz	Member, Master Plumber		
Mr. Wayne Thomas	Member Journeyman Gasfitter		
Ms. Ruth Alfasso	Member, Dept. of Public Health		
Ms. Sarah Badway	Public Member		
STAFF			
Mr. Charles Kilb	Board Legal Counsel		
Ms. Karen Brann	Board Executive Director		
Ms. Mary Collins-McCarthy	Associate Executive Director		
Mr. Taylor Roth	State Plumbing Investigator		
Mr. Scott Padden	State Plumbing Investigator		
Mr. Fredrick Lima	State Plumbing Investigator		
Mr. James O'Reilly	State Plumbing Investigator		
Mr. Joseph Peluso	Board Consultant		

9:00 A.M. AGENDA REVIEW: By Chairman Joseph McNamee

UP COMING MEETING VENUE

Due to the COVID-19 State of Emergency upcoming meeting venue may change

APPROVAL OF PREVIOUS MEETING MINUTES**Board Meeting Minutes**

September 2, 2020

DISCUSSION

D1 - Lack of availability of code compliant construction trailers

D2 - Possible delegation to allow the office to renew apprentice licenses that are ineligible to renew without special permission.

D3 - Fixture requirements for Buildings/Structures at Campgrounds

VARIANCE REQUEST(S)

PV-51 – AVON FIRE DEPARTMENT – 150 MAIN STREET –AVON

The Petitioner (Leroy Wallace from Building Engineering Resources) is seeking a variance from 248 CMR, Section 10.10(10)(a)5.b, to allow the use of a trap guard in lieu of a trap primer to a trench drain. The town of Avon is renovating their Fire Station. There will be a new outbuilding constructed for remote parking of Fire Department vehicles. The building will not have heat. There will be a trench drain provided for the parking area within the building with the waste terminating to a monitored tight tank.

PV-53 – ALLA DUPONT – 1885 WESTFIELD STREET – WEST SPRINGFIELD

This is a Post-Installation variance. The Petitioner (Gregory Fishfile from Greg's Plumbing) is seeking a variance from 248 CMR, Section 3.09

Product, Design and Testing Standards (0) product acceptance, for a shower unit that does not have Mass approval.

GV-54 – TOWN OF BRIDGEWATER – 25 SOUTH STREET – BRIDGEWATER

The Petitioner (town of Bridgewater) is seeking a Gas Variance from the requirement of two accessible bathrooms and is seeking to allow a single user facility to be placed in a corner of the building due to the historic nature of the building. The town is making historic renovations to the upper level of the Memorial Building to preserve the interior and exterior and to adapt it to be used as meeting and office space. The upper level is expected to have four to six staff members utilizing the area as their primarily office space. The area will be accessible to the public. The Board of Health petition has been received.

PV-56 GOOGLE LLC – 325 MAIN STREET – CAMBRIDGE

The Petitioner (Todd Pearson from Jensen Hughes) is seeking a variance from 248 CMR, Sections 10.10(18)(i)(1) and 10.10 (18)(r) to allow the use of a multiuser gender-neutral toilet room in place of separate male and female designated rooms on floors 7 and 13 of a new high rise mixed use office building. The Board of Health petition has been received.

PV-57 BAYSTATE WING HOSPITAL – 40 WRIGHT STREET – PALMER

The Petitioner (Nicole Parker from BVH Integrated Services) is seeking a variance from 248 CMR, Section 3.04(1) for a sink at the pharmacy at Baystate Wing Hospital. The Petitioner has been unable to find an approved MA plumbing fixture for use within ISO classified Ante Rooms which supports specific operational and procedural requirements with ante room gowning, hand washing and cleaning procedures while also adhering to USP797 and MA Draft Sterile Compounding regulations. The specific hardship has been to find a particular fixture which meets the exact dimensional requirements required for hand and fore-arm washing while not impeding on ante room material and personnel circulation needs. The Pharmacy Team and Facilities Engineering Department designed a custom stainless steel plumbing fixture which meets regulatory requirements as well as Baystate Pharmacy procedural requirements. The sink is a 16 ga. Type 304 s/s work surface. 16 ga. Type 304s/s sink bowl 15 ¾" x 19 ¾" deep with ¾" radius corner construction. 19 ga. Type 304 s/s bottom enclosure with a removable ¾" channel edge gasketed door panel and turning in flanges for securing to the wall. The Board of Health petition has been received.

PV61 WHITEMORD ORMITORY – 374 ROBIN HILL ROAD – MARLBOROUGH

The Petitioner (Pete McKenna from Hillside School) is seeking a variance from 248 CMR, Section 10.10, Table 1, not to require any female bathrooms in a new, all male prep school dormitory for grades 6-9. The total fixture count will meet the total occupancy of the building. The Board of Health petition has been received.

GV-62 JOSEPH G. KIJOWSKI, JR. – 18 BATES POINT ROAD – WEBSTER

The Petitioner (Joseph G. Kijowski, Jr.) is seeking a gas variance to install a Sterling stove equipped with a Robertshaw 4350 oven control CSA US certification number 164327-1177534. The safety is a Robertshaw TS-11 CSA US number 164327-1970372. The stove was pressure and leak tested and set for LP gas.

PV-63 SOLDIERS HOME HOLYOKE – 110 CHERRY STREET – HOLYOKE

The Petitioner (Jeremy Meade from the Soldiers Home Holyoke) is seeking a variance from 248 CMR, Section 10.10 Table 1, to allow the removal of existing water fountains and install drop down tempered eye wash stations in their place. The current water fountains in the hallways of the Veterans care centers do not meet the needs of the facilities infection control standards. There are chilled water stations with ice and water filling stations monitored by staff, in a central location on the unit. As this is a State project, no Board of Health petition is required as it is a State project.

GV-67 HOLYOKE SOLDIERS HOME – 110 CHERRY STREET - HOLYOKE

The Petitioner (Edward Quinn) is seeking a gas variance to install a new natural gas fired generator to be used for emergency backup at a chiller plant. The proposed generator is a Winco90 kW generator with a maximum gas input of 1,230 Scfh. The generator will be used to provide standby power to the chillers only between June 1 through October of each year. The existing 2" piping from the meter to the building needs to be increased to 3". The gas to the generator has to be shut off by October 31. The Petitioner would like to ask the Board if the generator supplier can perform his start up before the piping is modified.

PV-64 HOLLISTON WATER DEPARTMENT – GREENSAND FILTRATION FACILITY FOR WELL NO. 5 – 748 CENTRAL STREET – HOLLISTON

The Petitioner (Sean Reese from the Town of Holliston Water Department) is seeking a variance from 248 CMR, Section 10.10 from the requirement of separate female and male toilet facilities. The proposed water treatment facility is considered unmanned and will only have one and occasionally two operators at a time. The water treatment facility will incorporate the use of one unisex toilet room which will be compliant with 248 CMR. The Board of Health petition has been received.

PV-68 ARRIANTA BIO – 650 PLEASANT STREET – WATERTOWN

The Petitioner (Michael Pensack from DPS Group Global) is seeking a variance from 248 CMR, Section 10.15(10) Sumps and Ejectors to use individual process waste lift stations for each room in lieu of a central lift station for all rooms of the pharmaceutical manufacturing suites. The purpose of this is to avoid any possible cross contamination between the suites. The local Plumbing Inspector has raised a concern regarding the individual process waste transfer pumps designed and has requested that the Petitioner apply for a variance to get approval for a process waste transfer pumping arrangement that doesn't comply with the Plumbing Code 248 CMR 10.15 (10) Sumps and Ejectors.

SPECIAL PERMISSION PLUMBING REQUEST

SPP-58 – SIMONE SHEN- 12 Wellington Street - #3 – ARLINGTON

The Petitioner (Simone Shen) is requesting permission to install an air admittance valve on the first floor of a subdivided 2 story house with an unfinished basement. The Petitioner would like to install a small ventless washier dryer combo unit as she cannot vent the unit through the roof as the plumbing would need to go through the unit above.

APPEALS

A3 – APPEAL OF INSPECTOR'S DECISION – 113 BURLEY STREET - DANVERS

FYI – Board Delegated Staff Approvals – Board Vote Not Required

DAGV -215 – LAUAANDROMAX 54-64 CHANDLE STREET, LLC – 54 CHANDLER STREET – WORCESTER

The Petitioner (Marcus Jankie from Laundromax 54-56 Chandler St., LLC) is seeking an unlisted gas equipment variance to allow the installation and testing of 39 double stacked unlisted Dexter gas dryers (models DDBD50KC and DDBD30KC) at the above referenced location. The unlisted gas equipment shall be operated for testing purposes only.

DAPV-49 ED WINSLOW – 37 WHITTIER DRIVE – AMESBURY

The Petitioner (Clint Mauche from Newpro) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

DAPV-50 FR. MICHAEL RACINE – HOLY NAME OF THE SACRED HEART PARISH -121 MOUNT PLEASANT STREET – NEW BEDFORD

The Petitioner (Fr. Michael Racine from the Holy Name of the Sacred Heart Paris) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

DAPV-52 JOAN MULREAN – 339 E STREET - BOSTON

The Petitioner (Joan Mulrean) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

DAPV-55 DOROTHY HIGGINS – 148 MAIN STREET, A407 – NORTH ANDOVER

The Petitioner (Dorothy Higgins) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

DAPV-59 SUZANNE COLLAZZO – 39 SADDLEBROOK ROAD – MILFORD

The Petitioner (Suzanne Collazzo) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

DAPV – 65 NEWPRO - ELAINE NETO, JORGE ALBUQUERQUE – 61 FAIRMONT STREET – MARLBOROUGH

The Petitioner (Ryan Spar from Newpro for Elaine Neto and Jorge Albuquerque) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

DAPV-67 –ELIZABETH LESTAGE – 110 BRINGHAM STREET – NEW BEDFORD

The Petitioner (Elizabeth Lestage) is seeking a variance from 248 CMR, Section 10.10 (7) (c) 4 to allow the continued use of an existing 1 ½” bathtub drain for a new proposed shower. The Petitioner states that a 2” drain is not accessible, there will only be one 2.5 GPM showerhead and there will be a 6” minimum threshold shower pan installed. The local Board of Health petition has been received.

EXECUTIVE SESSION

CHARACTER REVIEW(S)

CR – N.C.

QUASI JUDICIAL SESSION

BOARD WILL CONSIDER ANY MATTERS NOT REASONABLY ANTICIPATED BY THE CHAIR:

ADJOURNMENT

Note:

Reasonable accommodations or modifications will be provided to enable individuals with disabilities to participate in this Plumbing Board meeting. **All requests should be submitted to Cheryl Yebba at (617)-727-4992 no later than one (1) week prior to the scheduled Board Meeting.** While the Board of Examiners of Plumbers & Gas Fitters will attempt to honor all requests, those requests received after that date may not be provided due to feasibility.