



The Commonwealth of Massachusetts  
Executive Office of Health and Human Services  
Department of Public Health  
Bureau of Environmental Health  
Community Sanitation Program  
5 Randolph Street, Canton, MA 02021  
Phone: 781-828-7700 Fax: 781-828-7703

CHARLES D. BAKER  
Governor

KARYN E. POLITO  
Lieutenant Governor

MARYLOU SUDDERS  
Secretary

MONICA BHAREL, MD, MPH  
Commissioner

Tel: 617-624-6000  
[www.mass.gov/dph](http://www.mass.gov/dph)

March 24, 2017

Joseph D. McDonald, Jr., Sheriff  
Plymouth County Correctional Facility  
26 Long Pond Road  
Plymouth, MA 02360

Re: Facility Inspection - Plymouth County Correctional Facility

Dear Sheriff McDonald:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Plymouth County Correctional Facility on February 22 and 23, 2017 accompanied by Captain Eugene Irvine, Environmental Health and Safety Officer. Violations noted during the inspection are listed below including 68 repeat violations:

**HEALTH AND SAFETY VIOLATIONS**

(\* indicates conditions documented on previous inspection reports)

**Administration/Entrance Area**

**Front Lobby**

*Main Area*

No Violations Noted

*Janitor's Closet*

No Violations Noted

*Male Bathroom*

No Violations Noted

*Female Bathroom*

No Violations Noted

**Main Hallway**

105 CMR 451.350

Structural Maintenance: Roof leaking outside male locker room

*Janitor's Closet – 1027*

No Violations Noted

**Female Locker Room**

105 CMR 451.123

Maintenance: Ceiling vent dusty above toilets

*Showers*

No Violations Noted

**Male Locker Room**

105 CMR 451.123\*

Maintenance: Ceiling vent dusty

*Showers*

No Violations Noted

**Staff Gym**

No Violations Noted

**Administration Area – 1018***Break Room – 1014*

No Violations Noted

*Male Bathroom – 1013*

No Violations Noted

*Female Bathroom – 1015*

105 CMR 451.123

Maintenance: Ceiling vent dusty

*IPS Office*

No Violations Noted

**Kitchen**

FC 6-201.11\*

Design, Construction and Installation: Floor not easily cleanable, floor damaged in many areas

*Staff Dining Area*

No Violations Noted

*Staff Serving Line*

No Violations Noted

*Kitchen Entrance*

No Violations Noted

*Warming Units*

No Violations Noted

*Ice Machine*

No Violations Noted

*Office*

No Violations Noted

*Office Bathroom*

No Violations Noted

*Dry Storage*

No Violations Noted

*Tool Closet*

No Violations Noted

*Cooler # 2*

No Violations Noted

*Inmate Break Area*

No Violations Noted

*Inmate Bathroom*

No Violations Noted

*Janitor's Closet*

No Violations Noted

*Freezer # 1*

No Violations Noted

*Cooler # 3*

No Violations Noted

*Cooler # 4*

No Violations Noted

*Cooler # 5*

No Violations Noted

*Freezer # 6*

No Violations Noted

**Prep Area**

*Kettle Area*

No Violations Noted

*Bakery Area*

No Violations Noted

**3-Bay Sink Area**

No Violations Noted

**Dishwashing Machine Area**

FC 6-201.11\*

Design, Construction and Installation: Floor not easily cleanable, floor damaged

**Chapel/Contact Room**

105 CMR 451.350\*

Structural Maintenance: Water leak behind wall

105 CMR 451.353\*

Interior Maintenance: Carpet dirty

**Medical Corridor**

105 CMR 451.350\*  
105 CMR 451.353\*

Structural Maintenance: Ceiling leaking  
Interior Maintenance: Ceiling tiles damaged

**HSU**

*Kitchen*

No Violations Noted

*Nurse's Station – M106*

No Violations Noted

*Soiled Utility – M133*

No Violations Noted

*Room – M132*

No Violations Noted

*Autoclave – M131*

No Violations Noted

*Staff Bathroom – M130*

No Violations Noted

*Pharmacy – M128*

No Violations Noted

*Janitor's Closet – M127*

No Violations Noted

*Laboratory – M126*

No Violations Noted

*Dentist – M124*

No Violations Noted

*X-Ray Room – M123*

No Violations Noted

*Inmate Bathroom – M122*

No Violations Noted

*Exam Room – M121*

No Violations Noted

*Room – M119*

105 CMR 451.353

Interior Maintenance: Exam table surface damaged

*Handicap Bathroom*

No Violations Noted

*Waiting Room – M103*

No Violations Noted

*Cells M113 - M116*

No Violations Noted

**Laundry**

105 CMR 451.353\* Interior Maintenance: Ceiling vent dirty

*Janitor's Closet*

No Violations Noted

*Office*

No Violations Noted

*Chemical Closet*

No Violations Noted

**Maintenance - 1053**

*Small Tool Room*

No Violations Noted

*Bathroom*

No Violations Noted

*Office*

No Violations Noted

*Office Bathroom*

No Violations Noted

**Inmate Bathroom – 1058**

No Violations Noted

**Loading Dock**

No Violations Noted

**Gymnasium**

No Violations Noted

**Main Hallway**

*Female Staff Bathroom – 1039*

No Violations Noted

*Male Staff Bathroom – 1040*

No Violations Noted

*Janitor's Closet - 1084*

105 CMR 451.353\* Interior Maintenance: Ceiling vent dusty

*Staff Bathroom – 1090*

No Violations Noted

*Janitor's Closet – 1095*

105 CMR 451.353\* Interior Maintenance: Ceiling vent dusty  
105 CMR 451.353 Interior Maintenance: Unlabeled chemical bottle

*Staff Bathroom – 1098*

No Violations Noted

*Staff Bathroom – 1099*

No Violations Noted

*Staff Bathroom – 1107*

105 CMR 451.123

Maintenance: Ceiling vent dusty

*Janitor's Closet – 1108*

No Violations Noted

*Unit Manager's Office – 1112*

No Violations Noted

*Classroom – 1102*

No Violations Noted

*Staff Bathroom – 1102*

No Violations Noted

*Classroom – 1110*

No Violations Noted

**Library**

No Violations Noted

**Human Services - 1079**

105 CMR 451.353\*

Interior Maintenance: Floor tiles damaged at cubicles

105 CMR 451.350\*

Structural Maintenance: Ceiling leaking

105 CMR 451.353\*

Interior Maintenance: Appearance of mold on floor

*Break Room*

105 CMR 451.200\*

Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, unlabeled food in the refrigerator

105 CMR 451.200\*

Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, outdated food stored in refrigerator

105 CMR 451.200

Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, cabinet under sink dirty

105 CMR 451.200

Food Storage, Preparation and Service: Food preparation not in compliance with 105 CMR 590.000, interior of microwave oven dirty

105 CMR 451.200

Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, no functioning thermometer in refrigerator

*Offices*

105 CMR 451.353

Interior Maintenance: Appearance of mold on floor

*Staff Bathroom – 1069*

105 CMR 451.123

Maintenance: Ceiling vent dusty

*Janitor's Closet – 1064*

105 CMR 451.353

Interior Maintenance: Wet mop stored in bucket

**Booking**

*Main Area*

No Violations Noted

*Office – R112*

No Violations Noted

*Records – R106*

No Violations Noted

*Inmate Toilet – R105*

No Violations Noted

*Inmate Bathroom – R118*

No Violations Noted

*Janitor's Closet – R126*

No Violations Noted

*Showers*

No Violations Noted

*Staff Bathroom – R127*

No Violations Noted

*Kitchen Area*

No Violations Noted

*Officer's Landing*

No Violations Noted

*Cells*

105 CMR 451.353

Interior Maintenance: Ceiling vent blocked in cell # R102, R107, and R123

**Property**

No Violations Noted

**Cell Blocks/Pods**

**A1**

*Trap*

105 CMR 451.353\*

Interior Maintenance: Ceiling dirty

*Main Area - Bunks*

105 CMR 451.322\*

Cell Size: Inadequate floor space in dorm area

*Slop Sink*

No Violations Noted

*Showers*

105 CMR 451.123

Maintenance: Mold on walls in caged shower

105 CMR 451.123

Maintenance: Mold on ceiling in caged shower

105 CMR 451.123

Maintenance: Ceiling vent dusty outside showers

*Bathroom*

No Violations Noted

*Cells A107 - A110*

105 CMR 451.140

Adequate Ventilation: Inadequate ventilation, ceiling vent blocked in cell # A107

## **E1**

### *Main Area*

No Violations Noted

### *Slop Sink*

105 CMR 451.353\*  
105 CMR 451.353

Interior Maintenance: Wall vent dusty  
Interior Maintenance: Ceiling rusted

### *Showers*

105 CMR 451.123  
105 CMR 451.123

Maintenance: Mold on ceiling outside showers  
Maintenance: Wall dirty in shower # 4, 5, 6, 7, 8, and 9

### *Recreation Area*

No Violations Noted

### *Cells*

105 CMR 451.321\*  
105 CMR 451.353\*  
105 CMR 451.140  
  
105 CMR 451.353

Cell Size: Inadequate floor space in all cells  
Interior Maintenance: Ceiling tiles damaged in cell # 238  
Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 105, 130, 219, 225, and 233  
Interior Maintenance: Light fixture blocked in cell # 106, 121, 130, and 221

## **H1**

### *Main Area*

No Violations Noted

### *Slop Sink*

No Violations Noted

### *Showers*

105 CMR 451.123\*

Maintenance: Appearance of mold outside showers

### *Recreation Area*

No Violations Noted

### *Cells*

105 CMR 451.321\*  
105 CMR 451.353\*  
105 CMR 451.353  
105 CMR 451.353  
105 CMR 451.140

Cell Size: Inadequate floor space in all cells  
Interior Maintenance: Ceiling tiles damaged in room # 238  
Interior Maintenance: Ceiling tiles dirty in room # 238  
Interior Maintenance: Light fixture blocked in cell # 118, 122, 130, 223, 225, and 234  
Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 118 and 125

## **FN1**

### *Main Area*

No Violations Noted

### *Slop Sink*

No Violations Noted

### *Recreation Area*

No Violations Noted



*Showers – 1<sup>st</sup> Floor*

No Violations Noted

*Showers – 2<sup>nd</sup> Floor*

105 CMR 451.123\*

Maintenance: Ceiling tiles rusted outside showers

*Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

105 CMR 451.353

Interior Maintenance: Ceiling tiles rusted outside cell # 208

**FS1**

*Main Area*

105 CMR 451.353\*

Interior Maintenance: Ceiling tiles damaged near recreational door

105 CMR 451.353\*

Interior Maintenance: Ceiling tiles rusted outside cell # 208

*Slop Sink*

No Violations Noted

*Toilet Area*

No Violations Noted

*Showers – 1<sup>st</sup> Floor*

No Violations Noted

*Showers – 2<sup>nd</sup> Floor*

No Violations Noted

*Recreation Area*

No Violations Noted

*Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

**DN1**

*Main Area*

105 CMR 451.353

Interior Maintenance: Wall stained near recreational door

*Slop Sink*

105 CMR 451.353

Interior Maintenance: Mold on wall above door

*Toilet Area*

No Violations Noted

*Showers – 1<sup>st</sup> Floor*

No Violations Noted

*Showers – 2<sup>nd</sup> Floor*

105 CMR 451.123

Maintenance: Floor surface damaged outside shower # 5

105 CMR 451.123

Maintenance: Ceiling tiles rusted outside showers

*Recreation Area*

No Violations Noted

*Cells*

105 CMR 451.321\*  
105 CMR 451.353  
105 CMR 451.353

Cell Size: Inadequate floor space in all cells  
Interior Maintenance: Ceiling paint peeling in cell # 101 and 204  
Interior Maintenance: Light fixture blocked in cell # 106

**DS1**

*Main Area*

No Violations Noted

*Slop Sink*

105 CMR 451.353

Interior Maintenance: Wet mop stored in bucket

*Showers – 1<sup>st</sup> Floor*

No Violations Noted

*Showers – 2<sup>nd</sup> Floor*

105 CMR 451.123\*  
105 CMR 451.123\*  
105 CMR 451.123

Maintenance: Appearance of mold outside showers  
Maintenance: Ceiling tiles rusted outside showers  
Maintenance: Soap scum on walls in shower # 4, 5, 6, and 7

*Recreation Area*

No Violations Noted

*Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

**BN101**

*Main Area*

105 CMR 451.353\*

Interior Maintenance: Ceiling vents dusty

*Bunks*

105 CMR 451.322\*

Cell Size: Inadequate floor space in dorm area

*Bathroom*

105 CMR 451.123\*

Maintenance: Ceiling tiles rusted outside bathroom

*Showers*

105 CMR 451.123\*

Maintenance: Ceiling vent dusty outside showers

**BS101**

*Main Area*

105 CMR 451.353

Interior Maintenance: Ceiling vent dusty

*Bunks*

105 CMR 451.322\*

Cell Size: Inadequate floor space in dorm area

*Bathroom*

105 CMR 451.130\*

Plumbing: Plumbing not maintained in good repair, slop sink leaking

*Showers*

105 CMR 451.123\*  
105 CMR 451.130  
105 CMR 451.130

Maintenance: Ceiling tiles rusted at bathroom entrance  
Plumbing: Plumbing not maintained in good repair, shower # 7 leaking  
Plumbing: Plumbing not maintained in good repair, shower # 6 out-of-order

105 CMR 451.123  
105 CMR 451.123

Maintenance: Soap scum on walls in shower # 4 and 5  
Maintenance: Curtain missing in shower # 1 and 2

## **BS201**

### *Main Area*

105 CMR 451.353\*

Interior Maintenance: Ceiling vent rusted near television area

### *Bunks*

105 CMR 451.322\*

Cell Size: Inadequate floor space in dorm area

### *Bathroom*

105 CMR 451.123\*

Maintenance: Ceiling tiles rusted outside bathroom

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, slop sink leaking

### *Showers*

105 CMR 451.123

Maintenance: Wall dirty in shower # 4 and 5

## **BN201**

### *Main Area*

105 CMR 451.353

Interior Maintenance: Ceiling vent dusty

### *Bunks*

105 CMR 451.322\*

Cell Size: Inadequate floor space in dorm area

### *Bathroom*

105 CMR 451.123\*

Maintenance: Ceiling tiles rusted outside bathroom

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, sink # 1 out-of-order

### *Showers*

105 CMR 451.123

Maintenance: Ceiling vent dusty outside showers

## **C1**

### *Main Area*

105 CMR 451.353

Interior Maintenance: Trash bag knotted on stairs

### *Slop Sink*

No Violations Noted

### *Showers*

105 CMR 451.123

Maintenance: Soap scum on walls in shower # 5 and 7

### *Recreation Area*

105 CMR 451.353\*

Interior Maintenance: Bird nests in rafters

### *Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

105 CMR 451.353\*

Interior Maintenance: Ceiling paint peeling in cell # 228

105 CMR 451.353

Interior Maintenance: Ceiling paint peeling in cell # 201

105 CMR 451.140

Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 104 and 120

105 CMR 451.353

Interior Maintenance: Ceiling tiles rusted outside cell # 236

## **G Block**

### *Main Area*

No Violations Noted

### **GE South**

105 CMR 451.353

Interior Maintenance: Ceiling dirty

105 CMR 451.353\*

Interior Maintenance: Appearance of mold on wall

### *Slop Sink*

105 CMR 451.353\*

Interior Maintenance: Wet mop stored in bucket

### *Showers*

No Violations Noted

### *Chemical Storage*

No Violations Noted

### *Cells*

105 CMR 451.321

Cell Size: Inadequate floor space in all cells

105 CMR 451.353

Interior Maintenance: Ceiling surface cracking in cell # 207

### **GE North**

105 CMR 451.350

Structural Maintenance: Ceiling leaking in main area

### *Slop Sink*

No Violations Noted

### *Showers*

105 CMR 451.123

Maintenance: Ceiling vent dusty outside showers

### *Recreation Deck*

No Violations Noted

### *Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

105 CMR 451.140\*

Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 218

105 CMR 451.140

Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 111, 115, 116, 117, 118, 213, and 216

105 CMR 451.353

Interior Maintenance: Light fixture blocked in cell # 109

### **GW North**

### *Slop Sink*

105 CMR 451.353

Interior Maintenance: Chemical bottles not labeled appropriately

### *Showers*

105 CMR 451.123\*

Maintenance: Ceiling vent dusty in shower # 1, 2, and 3

### *Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

105 CMR 451.140

Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 114 and 117

105 CMR 451.353

Interior Maintenance: Light fixture blocked in cell # 110

## **GW South**

### *Slop Sink*

105 CMR 451.353

Interior Maintenance: Ceiling paint peeling outside slop sink

### *Showers*

No Violations Noted

### *Cells*

105 CMR 451.140

Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 202, 203, 204, 205, 206, and 207

105 CMR 451.353

Interior Maintenance: Light fixture blocked in cell # 107

## **3<sup>rd</sup> Floor**

### **Main Hallway**

#### *Janitor's Closet – 3022*

No Violations Noted

#### *Staff Bathroom – 3021*

105 CMR 451.123

Maintenance: Ceiling vent dusty

#### *Storage – 3020*

No Violations Noted

#### *Janitor's Closet – 3018*

No Violations Noted

#### *Classroom – 3015*

No Violations Noted

#### *Storage – 3011*

No Violations Noted

#### *Janitor's Closet - 3010*

No Violations Noted

#### *Staff Bathroom – 3009*

No Violations Noted

#### *Storage – 3008*

No Violations Noted

#### *Janitor's Closet – 3006*

No Violations Noted

#### *Classroom – 3005*

No Violations Noted

#### *Staff Bathroom – 3003*

No Violations Noted

### FS3

#### *Main Area*

105 CMR 451.353\* Interior Maintenance: Wall stained near recreational door

#### *Slop Sink*

105 CMR 451.353 Interior Maintenance: Wet mop stored in bucket

#### *Medical Room*

No Violations Noted

#### *Toilet Area*

No Violations Noted

#### *Showers – 1<sup>st</sup> Floor*

No Violations Noted

#### *Showers – 2<sup>nd</sup> Floor*

105 CMR 451.123 Maintenance: Ceiling tiles rusted outside showers

105 CMR 451.123 Maintenance: Ceiling tiles dirty outside showers

#### *Cells*

105 CMR 451.321\* Cell Size: Inadequate floor space in all cells

### FN3

#### *Main Area*

105 CMR 451.353\* Interior Maintenance: Ceiling vents dusty

105 CMR 451.353 Interior Maintenance: Ceiling tiles water damaged

105 CMR 451.350 Structural Maintenance: Ceiling leaking

#### *Slop Sink*

No Violations Noted

#### *Toilet Area*

No Violations Noted

#### *Showers – 1<sup>st</sup> Floor*

No Violations Noted

#### *Showers – 2<sup>nd</sup> Floor*

No Violations Noted

#### *Cells*

105 CMR 451.321\* Cell Size: Inadequate floor space in all cells

### H3

#### *Main Area*

105 CMR 451.350 Structural Maintenance: Ceiling leaking in back stairwell

#### *Slop Sink*

105 CMR 451.353\* Interior Maintenance: Ceiling vent dusty

#### *Showers*

No Violations Noted

<i>Cells</i>	
105 CMR 451.321*	Cell Size: Inadequate floor space in all cells
105 CMR 451.140*	Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 306
105 CMR 451.140	Adequate Ventilation: Inadequate ventilation, wall vent blocked in cell # 305, 327, 329, 426, and 432
105 CMR 451.353	Interior Maintenance: Light fixture blocked in cell # 302, 419, 426, and 430

**DN3**

<i>Main Area</i>	No Violations Noted
------------------	---------------------

<i>Slop Sink</i>	
105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, slop sink leaking

<i>Toilet Area</i>	No Violations Noted
--------------------	---------------------

<i>Showers – 1<sup>st</sup> Floor</i>	No Violations Noted
---------------------------------------	---------------------

<i>Showers – 2<sup>nd</sup> Floor</i>	Unable to Inspect – In Use
---------------------------------------	----------------------------

<i>Recreation Deck</i>	No Violations Noted
------------------------	---------------------

<i>Cells</i>	
105 CMR 451.321*	Cell Size: Inadequate floor space in all cells

**DS3**

<i>Main Area</i>	No Violations Noted
------------------	---------------------

<i>Slop Sink</i>	
105 CMR 451.353	Interior Maintenance: Ceiling vent dusty

<i>Toilet Area</i>	Unable to Inspect – In Use
--------------------	----------------------------

<i>Showers – 1<sup>st</sup> Floor</i>	No Violations Noted
---------------------------------------	---------------------

<i>Showers – 2<sup>nd</sup> Floor</i>	No Violations Noted
---------------------------------------	---------------------

<i>Recreation Deck</i>	No Violations Noted
------------------------	---------------------

<i>Cells</i>	
105 CMR 451.321*	Cell Size: Inadequate floor space in all cells
105 CMR 451.353	Interior Maintenance: Ceiling paint peeling in cell # 302, 306, and 307

### E3

#### *Main Area*

105 CMR 451.353\*  
105 CMR 451.350

Interior Maintenance: Wall paint peeling near phones  
Structural Maintenance: Ceiling leaking in back stairwell

#### *Slop Sink*

No Violations Noted

#### *Showers*

105 CMR 451.123

Maintenance: Soap scum on walls in shower # 6 and 7

#### *Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

### C3

#### *Main Area*

No Violations Noted

#### *Slop Sink*

105 CMR 451.130  
105 CMR 451.353

Plumbing: Plumbing not maintained in good repair, slop sink leaking  
Interior Maintenance: Ceiling vent dusty

#### *Showers*

105 CMR 451.123\*  
105 CMR 451.130

Maintenance: Soap scum on walls in shower # 9  
Plumbing: Plumbing not maintained in good repair, shower # 3 leaking

#### *Recreation Deck*

No Violations Noted

#### *Cells*

105 CMR 451.321\*

Cell Size: Inadequate floor space in all cells

### **Warehouse -- Support Building**

#### *Freezer*

No Violations Noted

#### *Fridge # 1*

No Violations Noted

#### *Fridge # 2*

No Violations Noted

#### *Male Bathroom*

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, hot water out-of-order

#### *Female Bathroom*

No Violations Noted

#### *Inmate Bathroom*

No Violations Noted

#### *Janitor's Closet*

No Violations Noted



**Uniforms**

No Violations Noted

**Work Crew Area***Bathroom*

No Violations Noted

*Break Area*

No Violations Noted

**K9 Unit***Female Bathroom*

No Violations Noted

*Bathroom # 2*

No Violations Noted

*Janitor's Closet*

105 CMR 451.353

Interior Maintenance: Wet mop stored in bucket

*Kitchen Area*

105 CMR 451.200

Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, interior of white refrigerator dirty

**Garage***Bathroom – W124*

No Violations Noted

*Janitor's Closet – W123*

No Violations Noted

**Print Shop**

No Violations Noted

*Inmate Bathroom*

No Violations Noted

*Staff Bathroom*

No Violations Noted

*Janitor's Closet*

No Violations Noted

*Janitor's Closet – W111*

105 CMR 451.353

Interior Maintenance: Unlabeled chemical bottle

**Observations and Recommendations**

1. The inmate population was 1179 at the time of inspection.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at [www.mass.gov/dph/dcs](http://www.mass.gov/dph/dcs) and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at [www.mass.gov/dph/fpp](http://www.mass.gov/dph/fpp) and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

To review the Labeling regulations please visit the Food Protection website at [www.mass.gov/dph/fpp](http://www.mass.gov/dph/fpp) and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Nicholas Gale  
Environmental Health Inspector, CSP, BEH

cc: Jan Sullivan, Acting Director, BEH  
Steven Hughes, Director, CSP, BEH  
Timothy Miley, Director of Government Affairs  
Marylou Sudders, Secretary, Executive Office of Health and Human Services  
Thomas Turco, Commissioner, DOC  
Antone Moniz, Superintendent  
Captain Eugene Irvine, EHSO  
Michelle Roberts, MA, CHO, Health Director, Plymouth Health Department  
Clerk, Massachusetts House of Representatives  
Clerk, Massachusetts Senate  
Daniel Bennett, Secretary, EOPSS  
Jennifer Gaffney, Director, Policy Development and Compliance Unit