

**Issue/Title:** Pilgrim Nuclear Power Station (PNPS): Tritium in Groundwater Monitoring Wells

**Topic:** PNPS Updates as of August 5, 2011

**Previous Plans:** Results from groundwater monitoring well samples collected during the weeks of July 19<sup>th</sup> and July 27<sup>th</sup>, 2011 were reported by Entergy (see tables below). Split sample results for the week of July 19<sup>th</sup> and July 27<sup>th</sup>, 2011 are currently being analyzed by MERL.

**Current Status:**

Table 1<sup>1</sup>: July 19<sup>th</sup>

Table 2: July 27<sup>th</sup>

Location	Date	MERL <sup>2</sup> pCi/L	GEL <sup>3</sup> pCi/L	Location	Date	MERL pCi/L	GEL pCi/L
MW 201	7/19/2011	**	588	MW 201	7/27/2011	**	572
MW 202	7/19/2011	-	-	MW 202	7/27/2011	-	-
MW 202 I	7/19/2011	-	-	MW 202 I	7/27/2011	-	-
MW 203	7/19/2011	-	-	MW 203	7/27/2011	-	-
MW 204	7/19/2011	-	-	MW 204	7/27/2011	-	-
<b>MW 205</b>	<b>7/19/2011</b>	<b>**</b>	<b>1,710</b>	<b>MW 205</b>	<b>7/27/2011</b>	<b>**</b>	<b>9,100</b>
<b>MW 206</b>	<b>7/19/2011</b>	<b>**</b>	<b>845</b>	<b>MW 206</b>	<b>7/27/2011</b>	<b>**</b>	<b>1,220</b>
MW 207	7/19/2011	-	-	MW 207	7/27/2011	-	-
MW 208-S	7/19/2011	-	-	MW 208-S	7/27/2011	-	-
MW 208-I	7/19/2011	-	-	MW 208-I	7/27/2011	-	-
MW 209 new	7/19/2011	**	1,160	MW 209 new	7/27/2011	**	736
MW 210 new	7/19/2011	-	-	MW 210 new	7/27/2011	-	-
MW 211 new	7/19/2011	**	847	MW 211 new	7/27/2011	**	1,030
MW 212 new	7/19/2011	-	-	MW 212 new	7/27/2011	-	-
MW 213 new	7/19/2011	-	-	MW 213 new	7/27/2011	-	-
MW 214 new	7/19/2011	-	-	MW 214 new	7/27/2011	-	-
MW 3	7/19/2011	-	-	MW 3	7/27/2011	-	-
MW 4	7/19/2011	-	-	MW 4	7/27/2011	-	-
SW-boat ramp	7/19/2011	-	-	SW-boat ramp	7/27/2011	-	-
SW-intake	7/19/2011	-	-	SW-intake	7/27/2011	-	-

\* NDA = not detected at less than activity value listed

\*\* results pending

\*\*\* well inaccessible due to scheduled equipment use

- not analyzed this week

<sup>1</sup> PNPS screening level for tritium in groundwater monitoring wells is 3,000 pCi/L, which is 1/10<sup>th</sup> of the NRC-approved Pilgrim Offsite Dose Calculation Manual standard for tritium in non-drinking water sources. The EPA drinking water standard is 20,000 pCi/L. The nearest drinking water wells are approximately 2.5 miles from the plant.

<sup>2</sup> Results from the Massachusetts Environmental Radiation Laboratory (MERL)

<sup>3</sup> GEL Laboratories are a radioanalytical laboratory contracted by PNPS

The latest groundwater monitoring results reported by Entergy show an increase in MW205, which had a level of 1,710 pCi/L of tritium detected on July 19<sup>th</sup> and increased to 9,100 pCi/L of tritium detected on July 27<sup>th</sup> (the previous result on July 13<sup>th</sup> was 3,240 pCi/L). Results for MW206 show 845 pCi/L of tritium detected on July 19<sup>th</sup> and 1,220 pCi/L of tritium detected on July 27<sup>th</sup> (the previous result on July 13<sup>th</sup> was 804 pCi/L). Results for MW201 indicated 588 pCi/L of tritium detected on July 13<sup>th</sup> and 572 pCi/L of tritium detected on July 27<sup>th</sup>. Tritium results for MW209 and MW211 continue to be detected in the 1,000 pCi/L range. Specifically, for MW209, 1,160 pCi/L of tritium was detected on July 19<sup>th</sup>, and 736 pCi/L of tritium was detected on July 27<sup>th</sup>. For MW211, 847 pCi/L of tritium was detected on July 19<sup>th</sup>, and 1,030 pCi/L of tritium was detected on July 27<sup>th</sup>. For the weeks of July 19<sup>th</sup> and July 27<sup>th</sup> split sample results are currently being analyzed by MERL.

The charcoal samplers placed in monitoring wells for the dye testing effort continue to be collected weekly to determine whether the dyes are present in the groundwater. MDPH has requested, received, and evaluated additional information on detection criteria from the lab conducting this work and concurs that results to date indicate no dye has been detected in groundwater including the dye that was introduced directly to the soil beneath the French drain in February to help characterize groundwater flow in the area between the reactor building and the ocean.

As previously reported, MDPH continues to explore with Entergy the possible reason for ongoing fluctuations in tritium detected in MW205 and MW206. A potential source that remains under active investigation is the radwaste discharge line, which is upstream from the affected groundwater monitoring wells. Future actions currently being considered may include the installation of additional monitoring wells, excavations near the radwaste discharge line in order to inspect and test it, and/or additional soil sampling in the radwaste discharge line area. MDPH anticipates more discussion about these activities and other planned investigational activities during the upcoming meeting with Entergy and agency staff on August 15<sup>th</sup>, 2011.

**Looking Forward:**

A meeting between agency staff and Entergy has been confirmed for Monday, August 15<sup>th</sup>, 2011. Groundwater monitoring data collected over the past year will be reviewed, and next steps for the tritium investigation will be discussed, which may include installation of new monitoring wells, more soil sampling, or other activities. A comprehensive site visit at PNPS is also planned as part of the August 15<sup>th</sup> meeting that will include the spent fuel pool area, the radwaste processing area, and other areas within the reactor building.