



Commonwealth of Massachusetts  
Executive Office of Energy & Environmental Affairs

## Department of Environmental Protection

One Winter Street Boston, MA 02108 • 617-292-5500

Charles D. Baker  
Governor

Karyn E. Polito  
Lieutenant Governor

Matthew A. Beaton  
Secretary

Martin Suuberg  
Commissioner

### **APPROVAL FOR CERTIFICATION FOR GENERAL USE**

Pursuant to Title 5, 310 CMR 15.000

Name and Address of Applicant:

**Norwesco, Inc./Snyder Industries  
P.O. Box 439  
St. Bonifacius, MN 55375-0439**

Trade name of new technology and model:

1,000 gallons low profile one compartment with gasket and tee

1,250 gallons low profile one compartment with gasket and tee

1,500 gallons low profile one compartment with gasket and tee

1,500 gallons low profile two compartment with gasket and tee

(hereinafter called the "System" or "Tank") Schematic drawings of the Tanks and an installation instruction checklist are attached.

Transmittal Number: X267334

Date of Issuance: March 3, 2016

### **Authority for Issuance**

Pursuant to Title 5 of the State Environmental Code, 310 CMR 15.000, the Department of Environmental Protection hereby issues this Certification to: Norwesco, Inc./Snyder Industries, PO Box 439, St. Bonifacius, MN 55375-0439 (hereinafter "the Company"), for General Use in the Commonwealth of Massachusetts of the Tank described herein. Sale and use of the Tanks are conditioned on and subject to compliance by the Company and the Tank owner with the terms and conditions set forth below. Any noncompliance with the terms or conditions of this Certification constitutes a violation of 310 CMR 15.000.

/signed/

\_\_\_\_\_  
David Ferris, Director  
Wastewater Management Program  
Bureau of Water Resources

March 3, 2016  
Date

**I. Purpose**

1. The purpose of this Certification is to allow the use of the System in Massachusetts on a General Use basis.
2. With the necessary permits and approvals required by 310 CMR 15.000, this Certification authorizes the use of the System in Massachusetts.
3. The System may be installed on all facilities where a system in compliance with 310 CMR 15.000 exists on site or could be built and for which a site evaluation in compliance with 310 CMR 15.000 has been approved by the local approving authority; or by DEP if DEP approval is required by 310 CMR 15.000.

**II. Design Standards**

1. The models listed below are covered under this Certification.

| <b>Name &amp; Model</b>                         | <b>Dimensions<br/>L x W x H<br/>(Inches)</b> | <b>Capacity<br/>(gallons)</b> |
|---|--|-------------------------------|
| low profile one compartment with gasket and tee | 127 x 60 x 51                                | 1,000                         |
| low profile one compartment with gasket and tee | 157 x 60 x 51                                | 1,250                         |
| low profile one compartment with gasket and tee | 157 x 69 x 51                                | 1,500                         |
| low profile two compartment with gasket and tee | 157. x 69 x 51                               | 1,500                         |

2. The Tanks approved includes the 1000, 1250, 1500 gallon polyethylene septic tanks, designated by the Company manufactured with either single or double compartments. *The tanks are exempted from three manholes required under 310 CMR 15.228(2) as well as the four-foot liquid depth and pumping on an annual basis under 310 CMR 15.223(2). The two compartment septic tanks also are exempted from the requirement of the inverted U-shaped pipe inter-connection under 310 CMR15.224 (4). The System must be pumped and have routine maintenance in accordance with 310 CMR 15.351. The tanks comply Uniform plumbing Code (UPC<sup>®</sup>), International Plumbing Code (IPC<sup>®</sup>), the National Standard of Canada CAN/CSA-B66-M90, and the International Association of Plumbing and Mechanical Officials (IAPMO)/ANSI Z1000-2013 standards for prefabricated polyethylene septic tanks. The tanks shall also comply the standards for polyethylene tanks list under 310 CMR 15.226(2)(c). The tanks shall also be subject to any future applicable requirements in amendments or changes to Title 5 regulations, 310 CMR 15.000.*

3. Tank(s) manufactured by the Company with less than a 1,000gallon capacity are not approved for use under this Certification.
4. The Tank shall be installed between the building sewer and the distribution box and soil absorption system (SAS), of a conventional Title 5 system. The Tank(s) may also be installed between a building sewer and a DEP approved I/A system. The Tank shall be installed in a manner which will not adversely affect the operation of a Title 5 system as constructed in accordance with 310 CMR 15.100 through 15.279, subject to the provisions of this Certification.
5. The manhole over the inlet and outlet tees shall have a minimum cover opening of 20 inches in diameter, which shall provide access to the tanks for inspection, maintenance or pumping in general accordance with the intent of 310 CMR 15.228 (2). Inlet and outlet tees shall be accessible for inspection and maintenance with covers over the access ports to within six inches of finish grade. When manholes are brought to and maintained at final grade, the manhole covers shall be secured to prevent unauthorized access in accordance with the intent of 310 CMR 15.228 (2).
6. The System will require tie downs and associated anchors to prevent tank floatation in locations with a high groundwater elevation. If applicable, buoyancy calculations shall be provided on the Title 5 septic system plans for each System installation. System buoyancy calculations shall include consideration of the high groundwater elevation developed as required by 310 CMR 15.100 through 15.105. Design plans prepared in accordance with 310 CMR 15.220 shall include System anchoring and backstay details when required by the presence of high groundwater.
7. No Tank(s) shall be installed or located in a location subject to vehicular loading. Where vehicles can possibly access the tank site, suitable warnings including bollards shall be installed.
8. Inlet and outlet tees shall be constructed of schedule 40 PVC or equivalent, and meet the requirements of 310 CMR 15.224 and 15.227.
9. The System shall be field tested to ensure it is watertight prior to backfill and burial and final cover.
10. The maximum burial depth for the tanks shall not exceed 36 inches.
11. The minimum effective depth of the tanks, measured from the invert elevation to the tank bottom, shall be at least 40 inches.

### **III. General Conditions**

1. The provisions of 310 CMR 15.000 are applicable to the use of the System, except those that specifically have been varied by the terms of this Certification.
2. The facility served by the System, and the System itself, shall be open to inspection and sampling by the Department and the local approving authority at all reasonable times.
3. In accordance with applicable law, the Department and the local approving authority may require the System owner to cease use of the System and/or to take any other action as it deems necessary to protect public health, safety, welfare or the environment.

4. The Department has not determined that the performance of the System will provide a level of protection to the environment that is at least equivalent to that of a sewer. Accordingly, no new System shall be installed if it is feasible to connect the facility to a sanitary sewer, unless as allowed by 310 CMR 15.004.
5. Design, installation and use of the System shall be in strict conformance with the Company's DEP approved plans and specifications and 310 CMR 15.000, subject to this Certification.

#### **IV. Conditions Applicable to the System Owner**

1. The System is approved for use in the treatment and disposal of sanitary sewage only. Any wastes that are non-sanitary sewage, generated or used at the facility served by the System, shall not be introduced into the on-site sewage disposal system and shall be lawfully disposed of.
2. The System owner shall at all times properly operates and maintains the System and the onsite sewage disposal system in which the System is installed.
3. The System owner shall furnish the Department any information that the Department requests regarding the operation and performance of the System, within 21 days of the date of receipt of that request.
4. No System owner shall authorize or allow the installation of the System other than by a person trained by the Company to install the System.

#### **V. Conditions Applicable to the Company**

1. The Company shall notify the Department's Program Director of Wastewater management Program at least 30 days in advance of any proposed transfer of ownership of the technology for which this Certification is issued. Said notification shall include the name and address of the proposed new owner and a written agreement between the existing and proposed new owner containing a specific date for transfer of ownership, responsibility, coverage and liability between them. All provisions of this Certification applicable to the Company shall be applicable to successors and assigns of the Company, unless the Department determines otherwise.
2. The Company shall furnish the Department any information that the Department requests regarding the System, within 21 days of the date of receipt of that request.
3. Prior to any sale of the System, the Company shall provide the purchaser with a copy of this Certification. In any contract for distribution or sale of the System, the Company shall require the distributor or seller to provide the purchaser of the System, prior to any sale of the System, with a copy of this Certification.
4. The Company shall prepare an installation manual specifically detailing procedures for installation of the System. The Company shall institute and maintain a training program in the proper installation of the System in accordance with the manual and provide a training course at least annually for prospective installers. The Company's distributor(s) may fulfill this training program on behalf of the Company. The Company shall certify

that installers have passed the Company’s training qualifications, maintain a list of certified installers, submit a copy to the Department, and update the list annually.

5. Neither the Company nor its distributor shall sell the Tank to installers unless they are trained to install these Systems by the Company or its’ distributors as noted above.

#### **VI. Conditions Applicable to Installers of the System**

1. Each Installer shall install the System in accordance with Company training on the installation of the System and the conditions of this Certification.
2. No Installer shall install the Tank unless the Installer has been trained by the Company, pursuant to Section V.5., on installation of the System.

#### **VII. Reporting**

1. All submittals of notices and documents to the Department required by this Certification shall be submitted to:

Director  
Wastewater Management Program  
Department of Environmental Protection  
One Winter Street – 5th floor  
Boston, Massachusetts 02108

#### **VIII. Rights of the Department**

1. The Department may suspend, modify or revoke this Certification for cause, including, but not limited to, non-compliance with the terms of this Certification, non-payment of an annual compliance assurance fee, for obtaining the Certification by misrepresentation or failure to disclose fully all relevant facts or any change in or discovery of conditions that would constitute grounds for discontinuance of the Certification, or as necessary for the protection of public health, safety, welfare or the environment, and as authorized by applicable law. The Department reserves its rights to take any enforcement action authorized by law with respect to this Certification, the System, the owner, or operator of the System and the Company.