

CHARLES D. BAKER Governor

KARYN E. POLITO Lieutenant Governor

## The Commonwealth of Massachusetts Executive Office of Health and Human Services Department of Public Health Bureau of Environmental Health Community Sanitation Program 180 Beaman Street, West Boylston, MA 01583 Phone: 508-792-7880 Fax: 508-792-7706 TTY: 508-835-9796

MARYLOU SUDDERS Secretary

MONICA BHAREL, MD, MPH Commissioner

Tel: 617-624-6000 www.mass.gov/dph

June 1, 2015

Douglas DeMoura, Superintendent Pondville Correctional Center P.O. Box 146 Norfolk, MA 02056

Re: Facility Inspection - Pondville Correctional Center, Norfolk

Dear Superintendent DeMoura:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of Pondville Correctional Center on May 15, 2015 accompanied by Jeffrey Arruda, EHSO. Violations noted during the inspection are listed below including 16 repeat violations:

## **HEALTH AND SAFETY VIOLATIONS**

(\*indicates conditions documented on previous inspection reports)

## **FOOD SERVICE**

Hallway

FC 6-501.16 Maintenance and Operation; Cleaning: Wet mop stored in bucket

Dining Area

No Violations Noted

Kitchen

No Violations Noted

Mechanical Warewashing Area

FC 5-202.12(A) Plumbing System, Design: Handwashing sinks water temperature recorded at 102°F

Front Dry Storage

No Violations Noted

Rear Dry Storage

No Violations Noted

pondville-report-6-15.docx Page 1 of 6

Walk-in Refrigerator/Freezer

FC 4-601.11(C)\* Cleaning of Equipment and Utensils, Objective: Non-food contact surface dirty, ice

build-up on freezer ceiling

Exterior Freezer

No Violations Noted

Toxic Caustic Room

No Violations Noted

**WAREHOUSE** 

Bulk Storage (Outside) 105 CMR 451.353\*

Interior Maintenance: Light shields missing

Toxic Caustic

No Violations Noted

Linens and Toiletries

No Violations Noted

Laundry

No Violations Noted

Barber Shop

No Violations Noted

House Manager's Office

No Violations Noted

**PROPERTY** 

No Violations Noted

**CONTROL** 

Female Bathroom

No Violations Noted

Male Bathroom

No Violations Noted

Work Assignment Office

No Violations Noted

Staff Break Room

No Violations Noted

Staff Bathroom (in Hall) 105 CMR 451.110(A)

Hygiene Supplies at Toilet and Handwash Sink: No toilet paper

Page 2 of 6

Holding Cell

No Violations Noted

DAY ROOM

FC 4-204.112(A) Design and Construction, Functionality: No functioning thermometer in refrigerator

pondville-report-6-15.docx

FC 4-501.114(C)(2)\* Maintenance and Operation; Equipment: Quaternary ammonium solution lower than

the manufacturers recommended concentration

Library

No Violations Noted

**VISITING ROOM** 

105 CMR 451.350 Structural Maintenance: Cracked windows on hallway side

**H.S.U.** 

Medical Records/Treatment Room

105 CMR 451.353\* Interior Maintenance: Ceiling tiles water stained

105 CMR 451.126 Hot Water: Hot water temperature 102°F

Conference Room

No Violations Noted

Director of Security's Office

No Violations Noted

Hallway

No Violations Noted

Staff Bathroom

No Violations Noted

Medical Waste Storage (Boiler Room)

No Violations Noted

**ADMINISTRATION AREA** 

No Violations Noted

**HOUSING UNITS** 

1-1

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

Bathroom

105 CMR 451.123\* Maintenance: Vent fan dirty

105 CMR 451.130\* Plumbing: Plumbing not maintained in good repair, missing drain cover in shower # 4

105 CMR 451.123\* Maintenance: Ceiling paint peeling in shower # 1 and 2

105 CMR 451.126 Hot Water: Hot water temperature 100°F Hot Water: Shower water temperature 92°F

Cells

105 CMR 451.353\* Interior Maintenance: Window shade tattered in cell # 114

105 CMR 451.353 Interior Maintenance: Window shade tattered in cell # 115, 116, & 119

105 CMR 451.353 Interior Maintenance: Wall damaged in cell # 120 105 CMR 451.353 Interior Maintenance: Loose junction box in cell # 113 105 CMR 451.350 Structural Maintenance: Floor damaged in cell # 120

Training Office

No Violations Noted

pondville-report-6-15.docx Page 3 of 6

Mail Room

Unable to Inspect - Locked

Laundry

No Violations Noted

1-2

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

Bathroom

105 CMR 451.123\* Maintenance: Vent fan dusty 105 CMR 451.123\* Maintenance: Ceiling paint peeling

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, shower drain loose in shower # 1

105 CMR 451.123\* Maintenance: Tile damaged in shower # 2 105 CMR 451.123 Maintenance: Shower # 2 out-of-order 105 CMR 451.123 Maintenance: Shower lights rusted

105 CMR 451.123 Maintenance: Soap scum on walls in shower # 1

105 CMR 451.110(A)\* Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink

Cells

No Violations Noted

Laundry

No Violations Noted

1-3

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

Bathroom

No Violations Noted

Handicapped Bathroom

No Violations Noted

Cells

105 CMR 451.353\* Interior Maintenance: Unfinished wall in cell # 146

2-1

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

2<sup>nd</sup> Floor Laundry

No Violations Noted

Bathroom

No Violations Noted

Slop Sink

No Violations Noted

Cells

No Violations Noted

Work Release

No Violations Noted

2-2

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

**Showers** 

105 CMR 451.123\* Maintenance: Ceiling vent dusty

105 CMR 451.130\* Plumbing: Plumbing not maintained in good repair, missing drain cover in shower # 2 Plumbing: Plumbing not maintained in good repair, missing drain cover in shower # 3

Bathroom

No Violations Noted

Cells

105 CMR 451.353 Interior Maintenance: Window shade tattered in cell # 217, 222, 226, & 227

2-3

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

Showers

105 CMR 451.130 Plumbing: Plumbing not maintained in good repair, shower # 2 out-of-order

**Bathroom** 

105 CMR 451.126 Hot Water: Hot water temperature 100°F

Cells

No Violations Noted

2-4

105 CMR 451.320\* Cell Size: Inadequate floor space in all cells

Bathroom

No Violations Noted

Cells

No Violations Noted

Classification

No Violations Noted

**DUMPSTER AREA** 

No Violations Noted

**GYM** 

105 CMR 451.353 Interior Maintenance: Ceiling light out

**CLASSROOMS** 

Dog Classroom

105 CMR 451.353 Interior Maintenance: Two lights out

## **Observations and Recommendations**

1. The inmate population was 173 at the time of inspection.

2. The Department recommends numbering all showers and toilets throughout the facility for identification purposes.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps

pondville-report-6-15.docx Page 5 of 6

to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

This inspection report is signed and certified under the pains and penalties of perjury.

Paul Halfinann, MPH

Assistant Director, CSP, BEH

Suzanne K. Condon, Associate Commissioner, Director, BEH cc: Steven Hughes, Director, CSP, BEH Jay Youmans, Director of Government Affairs Marylou Sudders, Secretary, Executive Office of Health and Human Services Carol Higgins O'Brien, Commissioner, DOC Jeffrey Arruda, EHSO Betsy Fijol, Administrative Assistant, Norfolk Board of Health Clerk, Massachusetts House of Representatives

Clerk, Massachusetts Senate Daniel Bennett, Secretary, EOPS