

Self-Audit Checklist for Employee Safety in Pool Mechanical Areas

Purpose:

This checklist is a guide to reduce the risk of work-related injuries and contains common items included in an OSHA safety inspection.

Scope: This checklist is designed for employee safety in Pool Mechanical Areas. This checklist does not alter or supercede DPH regulations for safety of pool patrons.

Building Name: _____ Date: _____

Address: _____

Conducted by: _____

Facility Inspection – Pool Facilities	Standard	Y	N	Correction Required
Electrical				
Electrical outlets and switches– cover plates installed.	1910.305(b)			
Receptacles are grounded.	1910.304(b)(2)(i)			
Receptacles in wet locations have GFCI.	1910.304(b)			
Extension cords are not used for permanent wiring.	1910.305(g)(1)(ii)			
Power cords - Electrical grounding pins (3-prong) intact	1910.335(a)(3)(i)			
Circuit panels have circuits labeled.	1910.303(f)(2)			
Circuit panels and boxes - unused openings are covered.	1910.305(b)(1)(ii)			
Circuit panels – access to panels is kept clear.	1910.303(g)(1)			
Hazardous Chemicals				
Containers kept closed, labeled.	1910.1200(f)(6)			
Safety Data Sheet available for each product.	1910.1200(g)(8)			
Eyewash is provided if chemical products are corrosive.	1910.151(c)			
Carbon Dioxide room has ventilation to prevent oxygen deficiency in event of leak.	1910.1000 (e)			
Ladders				
Portable ladders are inspected before use.	1910.23 (b)(9)			
Employees trained in ladder use.	1910.30(b)(1)			
Lockout-Tagout				
Power is shut off and locked before equipment maintenance (i.e., pumps, filters, lighting)	1910.333(a)(1); 1910.333(b)(2)			
Lockout-tagout equipment is available: tags, locks	1910.333(b)(2)(iii)			
Mechanical Pits				
Railing when edge is more than 4 feet above next level.	1910.28(b)(1)			
Personal Protective Equipment (PPE)				
Gloves and goggles are supplied for tasks with exposure to chlorine, acid, bases, and housekeeping chemicals.	1910.132(a)			
Slip, Trip Prevention				
Floors are maintained as dry as feasible.	1910.22(a)(2)			
“Wet Floors” signs used.	1910.22(a)(2)			

Signature _____

Date: _____

For additional resources or to contact DLS, visit: mass.gov/info-details/safetyworks-resources.