




# Crescent Ridge Dairy

Request for Determination  
of Insignificance





# Crescent Ridge Dairy is Located on Bay Road in Sharon

The Town Boundary between Sharon and Stoughton is Bay Road

## Facts Pertaining to the Request

- First Request under new regulations for projects of 10,000 gallons per day (gpd) or less (313 CMR 4.08(2)(b))
- 6,500 gpd is the jurisdictional amount (from the Neponset River basin)
- Total transfer will be no more than 10,000 gpd of milk waste
- Basin of discharge will be the Massachusetts Coastal basin, via the MWRA system

# Staff Recommendation

- Staff Recommends that the WRC find this project to be insignificant under the ITA
- Connection to Stoughton wastewater system limited to no more than 10,000 gpd
- Specific to CRD: No other properties in the vicinity can hook into this connection
- No increase in capacity with the Sharon water supply system; therefore no additional impacts to resources near these sources.
- Human sanitary waste will continue to be discharged through the CRD groundwater discharge system.

# Next Steps

- A vote will be requested at the April meeting
- The regulatory deadline for a vote is April 29, 2019