

# Processing Code Committee Agenda 3.11.2019

---

**NFPA 1 Code Adoption  
Processes Code Committee  
Agenda  
9:00 a.m. – 3pm  
March 11, 2019 in Stow  
Boards and Commissions Room**

- 1) Opening remarks
  - a) Introductions
- 2) Agenda Items:
  - a) Work Group
    - (i.) Regarding NFPA 241, Standard for Safeguarding Construction, Alteration, and Demolition Operations
  - b) 2019 Amendments to the 2015 edition of NFPA1
    - (i.) **41.1.1.1 (3) Qualified Person**
    - (ii.) **41.2.5.1 Certificates.**
    - (iii.) **N 42.3.3.6.7** Storage tank appurtenances shall be installed and calibrated in accordance with the manufacturer's instructions, published industry practices, or equivalent methods approved by the AHJ. [30A:4.3.6.7]
    - (iv.) **41.3.5.2** A fire watch shall be maintained for at least 1 hour
    - (v.) **41.4** Sole Proprietors and Individual Operators edification.
    - (vi.) **41.7** Qualifications edification
    - (vii.) **N 42.7.2.2.2** No separation shall be required between the delivery vehicle and the fill connection of an underground storage tank. [30A:9.2.2.2]
    - (viii.) **N 42.7.2.2.3.2\*** Means shall be provided to prevent an accidental release originating from the delivery vehicle from flowing under the aboveground tank. [30A:9.2.2.3.2]
    - (ix.) **N** Table 42.7.2.2.3 Minimum Separation Distances Between Delivery Vehicles and Aboveground Tanks Aboveground Tank Type Separation Distance Between Delivery Vehicle and Aboveground Tank
    - (x.) **N 42.7.2.5\* Display of Materials.** The storage or placement for display or sale of products shall be prohibited within 20 ft of any fuel dispenser. [30A:9.2.5.5]
    - (xi.) **N 42.7.2.10 Maintenance of Aboveground Storage Tank Appurtenances.** Storage tank appurtenances shall be maintained and operated in accordance with manufacturer's instructions, published industry practices, or equivalent methods approved by the AHJ. [30A:9.2.9]
    - (xii.) **42.7.4.5** The use of automatic credit card reading devices as a means of payment at the pump island.
    - (xiii.) **42.7.4.5(1)U(i)** Activation of such fire extinguishing system shall be electrically supervised by a listed fire alarm control unit and such alarm signal shall be automatically transmitted in accordance with the requirements of 780 CMR 903.4.1 "
    - (xiv.) **N 42.7.6.8** A means for bonding the tank vehicle to the motor vehicle shall be provided. Such bonding means shall be employed during fueling operations. [30A:9.6.8]

## Processing Code Committee Agenda 3.11.2019

---

- (xv.) **N 42.7.6.9** A spill kit designed for motor vehicle fuels shall be carried on the tank vehicle and employed in case of a fuel spill. [30A:9.6.9]
  - (xvi.) **42.9.9.8** Delete Massachusetts provision.
    - *Delete 42.9.9.8 (1), (2), (3), (4)*
  - (xvii.) **42.12** On-Demand Mobile Fueling
  - (xviii) Chapter 2 Referenced Publications-2.1 General- when a referenced code or standard, called for within a chapter of this *Code* is deleted, replaced or revised- global
  - (xix) Chapter 3 NFPA Official Definitions- 3.2.2\* Authority Having Jurisdiction (AHJ) - global
  - (xx) **1.12.8.25** Removal of requirements relative to permitting, placards and inspections regarding cargo and transfer tanks.
    - *Delete 1.12.8.25.3.3*
    - *Delete 1.12.8.25.3.3.1*
    - *Delete 1.12.8.25.3.4*
    - *Delete 1.12.8.25.3.4.1*
    - *Delete 1.12.8.25.3.4.2*
    - *Delete 1.12.8.25.3.6*
    - *Delete 1.12.8.25.3.6.1*
    - *Delete 42.9.9.8 above*
    -
  - (xxi) **1.12.50** as it applies to Quantities, Permits, License and Storage Requirements – global
- 3) Next Meeting
- 4) Adjournment