



MAURA T. HEALEY  
GOVERNOR

KIMBERLEY DRISCOLL  
LIEUTENANT GOVERNOR

TERRENCE M. REIDY  
SECRETARY

*The Commonwealth of Massachusetts*  
*Executive Office of Public Safety and Security*  
*Department of Fire Services*

*P.O. Box 1025 ~ State Road*

*Stow, Massachusetts 01775*

*Telephone (978) 567~3100*

*[www.mass.gov/dfs](http://www.mass.gov/dfs)*



LARRY S. FISHER  
CHAIRMAN

April 4, 2024

*Official use Only*

Rule 3

[REDACTED]

[REDACTED]

[REDACTED]

Board of Fire Prevention Regulations  
527 CMR 12:00 Interpretation Committee  
Department of Fire Services  
PO Box 1025, State Road  
Stow, MA 01775

**Background:**

Code Change Proposal submitted by [REDACTED], on February 22, 2024.

**Question #1:** In an existing panel that is not listed for tandem breakers but contains existing tandem breakers, can you add listed breakers and circuits without replacing the existing tandem breakers, per Rule 3? (All other code requirements are met regarding load calculations, conductor fill, etc.)

**Response:** Yes

If you have any questions or need any additional information, please contact me.

Sincerely,

*Larry S. Fisher*

Larry S. Fisher, Chairman  
Board of Fire Prevention Regulations