



Department of Fire Services  
Commonwealth of Massachusetts

**Self-Service Motor Fuel Facility Inspection**

Facility \_\_\_\_\_ Date of Inspection \_\_\_\_\_

Address \_\_\_\_\_ City/Town \_\_\_\_\_

Owner/Manager \_\_\_\_\_ Tel. # \_\_\_\_\_

<b>MGL, Chapter 148 §13 Requirements</b>	<b>Yes</b>	<b>No</b>
License (FP-002) to store flammable liquids posted - MGL, Chapter 148 §13		
Certificate of Registration (FP-005) posted - MGL, Chapter 148 §13		
<b>527 CMR 1.00: Chapter 66 Requirements</b>	<b>Yes</b>	<b>No</b>
Permit to store flammable and combustible liquids – 527 CMR 1: Chapter 66, Section 66.1.5		
<b>527 CMR 1.00: Chapter 1 Requirements</b>	<b>Pass</b>	<b>Fail</b>
Fire suppression system inspected semi-annually - 527 CMR 1: Chapter 1, Section 1.1.4		
<b>527 CMR 1.00: Chapter 42 Requirements</b>	<b>Pass</b>	<b>Fail</b>
Fuel nozzles shall not surpass outer PLB grooves (see guidelines for self-service stations) In no event fuel height shall exceed 18ft - 527 CMR 1: Chapter 42, Section 42.5.5.1		
Automatic shutoff fuel dispensing nozzles installed with hold/latch open device (new and under maintenance facilities) 527 CMR 1: Chapter 42, Section 42.5.6.1		
Portable fire extinguisher on island(s) minimum 80 BC rating inspected annually by a company with Certificate of Registration - 527 CMR 1: Chapter 42, Section 42.7.2.5.2		
Fire suppression system installed, according to State Fire Marshal - 527 CMR 1: Chapter 42, Section 42.7.2.5.3		
Console operator has been instructed and trained on operations of the service facility including the suppression system emergency controls - 527 CMR 1: Chapter 42, Section 42.7.4		
Positive Limiting Barrier (PLB) installed/maintained according to site plans. (Free of dirt and debris) 527 CMR 1: Chapter 42, Section 42.7.4.5		
“Extinguish All Smoking Materials & Stop Engine While Refueling” sign posted on both ends of pump dispensing island. Shall consist of block letters no less than 2 inches in height and either be red letters on white background or white letters on red background - 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(c)		
Controlling console in constant attendance by operator during pump operations-527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(d)		
Intercom system maintained in proper operating conditions on each island-527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(e)		
Convex mirrors or CCTV cameras & monitors are installed and maintained to provide visibility 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(f)		
Clear and unobstructed view to dispensing island from console operator-527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(f)		
Controlling console includes an emergency shut off switch which instantly cuts all pumping power to all fuel pumps - 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(g)		
Automatic credit card reading device installed and does not activate dispenser- 527 CMR 1: Chapter 42, Section 42.7.4.5 (1) (k)		
Split island facility: Emergency switch installed and accessible on full service islands, which activate fire suppression system and deactivate power to self-service dispensers - 527 CMR 42.7.4.5 (2) (a) (b)		

Comments: \_\_\_\_\_

Inspected By: \_\_\_\_\_ Date: \_\_\_\_\_

Operator Name (print): \_\_\_\_\_ Operator Signature \_\_\_\_\_