



Commonwealth of Massachusetts
Executive Office of Energy & Environmental Affairs

Department of Environmental Protection

One Winter Street Boston, MA 02108 • 617-292-5500

DEVAL L. PATRICK
Governor

MAEVE VALLELY BARTLETT
Secretary

DAVID W. CASH
Commissioner

GENERAL USE CERTIFICATION

Pursuant to Title 5, 310 CMR 15.00

Name and Address of Applicant:

Presby Environmental, Inc.
143 Airport Road
Whitefield, NH 03598

Trade name of technology and models: **Simple-Septic® Wastewater Treatment System** (hereinafter called the “System”). The *Massachusetts Simple-Septic® Wastewater Treatment System Design and Installation Manual* including Owner’s Manual and System Installation Form are part of this Certification.

Transmittal Number: X259788

Date of Issuance: September 11, 2014

Authority for Issuance

Pursuant to Title 5 of the State Environmental Code, 310 CMR 15.000, the Department of Environmental, Protection hereby issues this Certification for General Use to: Presby Environmental, Inc., 143 Airport Road, Whitefield, NH 03598 (hereinafter “the Company”), certifying the System described herein for General Use in the Commonwealth of Massachusetts. The sale, design, installation, and use of the System are conditioned on compliance by the Company, the Designer, the Installer and the System Owner with the terms and conditions set forth below. Any noncompliance with the terms or conditions of this Certification constitutes a violation of 310 CMR 15.000.

David Ferris, Director
Wastewater Management Program
Bureau of Resource Protection

September 11, 2014
Date

Technology Description

The System is an alternative subsurface Soil Absorption System (SAS) that replaces a conventional SAS designed in accordance with 310 CMR 15.000. The System consists of an 11 5/8-inch diameter corrugated, high-density plastic pipe with a 9.5-inch interior diameter and a standard length per unit of 10 feet. The pipe is perforated with eight holes equally distributed around its inner circumference at each corrugation. Each hole has a plastic skimmer extending inwards. The exterior of the pipe has ridges on the peak of each corrugation and is wrapped with a layer of non-woven geo-textile fabric. The System includes required connectors designed to connect pipe units together. The System also includes six inches of sand (also called ‘System sand’) specified as concrete sand meeting ASTM C-33 (with no more than 3% passing a #200 sieve) placed above, below and between rows of System pipe, and twelve inches of sand around the perimeter of the System. A high and low vent must be provided as part of System installation.

Conditions of Approval

The term “System” refers to the Alternative Soil Absorption System in combination with the other components of an on-site treatment and disposal system that may be required to serve a facility in accordance with 310 CMR 15.000.

The term “Approval” refers to the technology-specific Special Conditions (herein), the *Standard Conditions for Alternative Soil Absorption Systems with General Use Certification and/or Approved for Remedial Use*, the *General Conditions for Use of Alternative Systems* per 310 CMR 15.287, and any Attachments.

For Alternative Soil Absorption Systems that have been issued General Use Certification for the installation of Systems to serve facilities where the site meets the requirements for new construction, the Department authorizes reductions in the effective leaching area (310 CMR 15.242), subject to the Standard Conditions that apply to all Alternative Soil Absorption Systems with General Use Certification and subject to the Special Conditions below applicable to this Technology.

Special Conditions

1. The System is an approved Patented Sand Filter System for use as an Alternative Soil Absorption System. In addition to the Special Conditions contained in this Approval, the System shall comply with all Standard Conditions for Alternative Soil Absorption Systems, except where stated otherwise in these Special Conditions.
2. The System is approved for facilities where a conventional system with a reserve area exists or can be built on-site in full compliance with the new construction requirements of 310 CMR 15.000 and has been approved by the local approving authority.
3. This Certification shall not be used for the installation of a System to upgrade or replace an existing failed or nonconforming system, unless the facility meets the siting requirements for new construction, including a reserve area.

4. The separation distance to the estimated seasonal high groundwater elevation shall be measured from the bottom of the System sand below the Simple-Septic Wastewater Treatment System.
5. The System shall only be installed in bed or field configuration, as described in 310 CMR 15.252. The System shall not be installed in trench configuration and no sidewall area shall be considered in the total effective leaching area provided. The effective leaching area shall be the bottom area only (length times width) of the sand bed.
6. Systems shall be installed with differential venting for aeration and inspection access at end of each run of pipe, section or serial bed and whenever the System is installed under impervious surfaces.
7. Serial distribution laterals or sections shall be limited to no more than 500 gpd with each lateral a maximum of 100 feet, and must be laid level. Multi-level systems shall not be allowed.
8. System component material specifications for the pipe, plastic components, fabric and sand shall comply with the specifications identified in the initial I/A technology approval. Prior approval from the Department for any change from these specifications shall be requested in writing.
9. Any changes to the approved plans must receive prior Local Approving Authority (LAA) approval. Before a Certificate of Compliance can be issued by the LAA the System Designer must include any changes to the approved plan into the as-built plans.