

SINGULAIR® BIO-KINETIC®

WASTEWATER TREATMENT SYSTEM

SERVICE INSPECTION CHECKLIST

Address: _____

Owner: _____

Operator: _____

Date: _____

This checklist summarizes the service procedures to be performed during a routine Singulair Bio-Kinetic service inspection. Refer to the Singulair Service Manual for a detailed explanation of each service procedure and an O & M troubleshooting guide.

CONTROL CENTER SERVICE

NOTES / COMMENTS

- Check operation of control center
- Adjust time clock when required

AERATOR SERVICE

- Check aerator operation
- Check aerator power consumption
- Check aerator air delivery
- Clean stainless steel aspirator shaft
- Clean aspirator tip
- Clean fresh air vent in concrete cover
- Inspect aeration chamber contents

CLARIFICATION CHAMBER SERVICE

- Remove the Bio-Kinetic system
- Scrape the clarification chamber
- Inspect the Bio-Static sludge return
- Inspect outlet coupling
- Install a clean Bio-Kinetic system
- Fill Blue Crystal feed tube (if installed)
- Fill Bio-Neutralizer feed tube (if installed)

GENERAL SERVICE

- Inspect effluent pump chamber
- Inspect effluent quality
- Inspect outlet line
- Inspect ground water relief point (if installed)
- Inspect effluent disposal system
- Complete owner service record
- Complete health department notification
- Complete distributor service record
- Mail health department notification

PROGRESS THROUGH

SERVICE SINCE 1906

www.norweco.com