

Re: Comments on SMART 4/15/20 Regulations

Robert Cherdack <robertcherd@gmail.com>

Wed 5/27/2020 1:38 PM

To: SMART, DOER (ENE) <doer.smart@mass.gov>

Cc: Kristen Sykes <KSykes@outdoors.org>; Brant Cheikes <bcheikes@outdoors.org>; Zara Dowling <zara.dowling@gmail.com>; Heidi Ricci <hricci@massaudubon.org>; Robert Cherdack <robertcherd@gmail.com>

CAUTION: This email originated from a sender outside of the Commonwealth of Massachusetts mail system. Do not click on links or open attachments unless you recognize the sender and know the content is safe.

It is important to define the 5 MW limit in terms of solar panel capacity not the capacity of the energy storage unit. A battery can feed 5 MW into the grid around the clock taking the output of 35 MWs of panels with their 14% capacity factor. This would be a way to circumvent the limit I believe DoER meant to impose. The intent should be to keep the panel capacity to be about 5 MWs

Robert Cherdack,

Ashfield, MA