

I work for an energy storage company and have a question regarding the wording of your requirements: Does the wording below refer to the round trip efficiency requirement in the beginning of life through commissioning, or past commissioning through the years and until end of lifecycle?

Minimum Efficiency Requirement: The Energy Storage System paired with the solar photovoltaic Generation Unit must have at least a 65% round trip efficiency in normal operation

**Luke Peleggi** *Sales Representative*

**Eos Energy Storage**

3920 Park Ave Edison, NJ 08820

p. +1.518.424.1419

[www.eosenergystorage.com](http://www.eosenergystorage.com)

*This message and any attachments are solely for the use of intended recipients. The information contained herein may include trade secrets, protected health or personal information, privileged or otherwise confidential information. Unauthorized review, forwarding, printing, copying, distributing, or using such information is strictly prohibited and may be unlawful. If you are not an intended recipient, you are hereby notified that you received this email in error, and that any review, dissemination, distribution or copying of this email and any attachment is strictly prohibited. If you have received this email in error, please contact the sender and delete the message and any attachment from your system. Thank you for your cooperation.*