MASS/DEPARTMENT OF PUBLIC HEALTH DAILY FLUORIDATION REPORT						
Month of	December Year 2006	Page 1	of <u>1</u> (Use the	he same form dail	y for one month for ea	ch source or manifolded or combined sources)
Section I. PWS INFORMATION:						
1. PWS Na	me: Riverdale Water I	Department	2. PWS ID# :	9999000 3. City/Town or District: <b>Riverdale, MA</b>		
4. Source(s) Fluoridated/MassDEP Source Code/Location ID: -01FW						
5. Is the Source(s) Manifold? Yes No X List location or Mass DEP location ID# for the daily sample: WTP Finished Water						
Section II.	PWS CHEMICAL US	E INFORM	MATION:			
1. Type of fluoride chemical used: NaF Na <sub>2</sub> SiF <sub>6</sub> X H <sub>2</sub> SiF <sub>6</sub>						
2. What is the purity of the fluoride chemical? 99 % (From shipping container or hydrometer test rounded to nearest unit).						
3. Are all fluoride-metering pumps protected by two (2) operating anti-siphon (back-pressure) valves?  Yes X No						
4. Was each anti-siphon valve disassembled and inspected in the last 12 months?  Yes X Date: 1/23/2006 No						
Expain:  5. Was the fluoride test meter calibrated each day before use? (See Note 2)  Yes X No						
Expain:						
6. Do you require on site technical assistance? Yes No X If yes, explain:						
Section III. DAILY RESULT:						
	Gallons of Water Treated	Amt. Fluoride	Saturator <sup>1</sup>	Calculated	Results of	Name of tester and Comments
of the	(to the nearest 1,000	Added (Lbs)	Volume of Make	Fluoride Ion	Fluoride Tests by	E.g. Reason(s) for not fluoridating or sampling.
Month	gallons)		Up Water Added	Dosage (ppm)	PWS (ppm) 2,3	Changes in product or batch mixing day etc.
			Gals or Cu Ft			
1	2,878,000 2,978,000			1.17 1.42	1.1	DS SN
3	4,080,000			1.22	1.1	TM
4	3,698,000			1.13	1.0	SN
5	3,353,000	50.7		1.19	1.1	DS
6 7	2,674,000 2,975,000			1.04 1.14	1.1	DS SN
8	3,180,000			1.26	1.2	TM
9	2,904,000	50.1		1.34	1.2	SN
10	3,865,000	56.6		1.15	1.1	DS DS
11 12	3,953,000 2,695,000			1.25 0.98	1.0	DS
13	2,753,000			1.22	1.1	DS
14	2,462,000			1.01	1.0	SN
15 16	2,681,000 4,565,000			1.05 1.16	1.1	TM SN
17	3,554,000			1.12	1.0	DS
18	3,805,000	44.7		0.95	0.9	DS
19	2,909,000			1.22	1.3	SN
20 21	2,667,000 2,857,000			1.42 1.25	1.2 1.1	TM SN
22	2,750,000			1.15	1.0	DS
23	4,219,000	67.2		1.25	1.3	DS
24 25	3,977,000	68.6		1.34	1.3	DS DS - Plant Offline
26	4,921,000	81.4		1.29	1.2	DS S S S S S S S S S S S S S S S S S S
27	5,039,000			1.41	1.3	DS
28 29	5,054,000			1.34	1.4	DS Chamical nump was air bound
30	4,622,000 2,910,000			0.10 1.16	0.9 1.2	DS - Chemical pump was air bound SN
31	3,980,000			1.24	1.2	SN
Totals	104,958,000					If you use a saturator: calculate monthly
Average	3,498,600	51.7		1.17	1.1	Fluoride Ion Dosage ppm
Notes: 1) If you use a saturator you must calculate a monthly fluoride ion dosage based on pounds used.						
2) If you use a Mass. certified lab. for daily sampling, attach a copy of your Mass. approved lab analytical report form to this report.						
3) All pumping fluoridated sources <u>MUST</u> be tested daily for fluoride at the entry point to the distribution system or near the point of fluoride application.  4) The optimum fluoride level is 0.7 mg/L.  5) Report all Fluoride results to the nearest tenth.						
6) For Fluoride issues that require reporting, notify DPH at 617-624-5573 AND MassDEP Drinking Water Program Regional Office or 617-292-5770.						
I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and						
complete to the best of my knowledge and belief.						
Name of PWS certified operator or responsible party:  Phone #: (978) 999-9999  Fax#: (978) 999-9998  Email address: xxx@xxxx.com						
Section IV: DPH LISE:  Data received:  Commente:						