



DEVAL L. PATRICK
GOVERNOR

TIMOTHY P. MURRAY
LIEUTENANT GOVERNOR

JUDYANN BIGBY, MD
SECRETARY

JOHN AUERBACH
COMMISSIONER

The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program

5 Randolph Street

Canton, MA 02021

Telephone: 781-828-7910

Facsimile: 781-828-7703

lauren.molotnikov@state.ma.us

February 2, 2012

Andrea J. Cabral, Sheriff
Suffolk County Jail
200 Nashua Street
Boston, MA 02214

Re: Facility Inspection

Dear Sheriff Cabral:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, and Department of Public Health Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Suffolk County Jail on January 24, 2012 accompanied by Deputy Michael Chisholm. Violations noted are listed below (* indicates conditions documented on previous inspection reports).

Entry Level

Front Lobby

No Violations Noted

Men's Room

Occupied at the time of inspection

Women's Room

105 CMR 451.123

105 CMR 451.126

Maintenance: Ceiling vent dirty

Hot Water: Hot water temperature recorded at 72°F

7th Floor

Hallway

No Violations Noted

Visiting Rooms

105 CMR 451.353

Interior Maintenance: Baseboard missing in visit room # 701

Floor 6.5

Gym

105 CMR 451.344*

105 CMR 451.353*

Illumination in Habitable Areas: Inadequate lighting, one light fixture not functioning properly

Interior Maintenance: Wall dirty near water fountain

105 CMR 451.353

Interior Maintenance: Arm pad surface damaged on weight machine

Staff Bathroom # 6503

No Violations Noted

Storage Room # 6504

105 CMR 451.353

Interior Maintenance: Wet mop left in bucket

105 CMR 451.353

Interior Maintenance: Light shield cover loose

Inmate Bathroom # 6505

105 CMR 451.110(A)

Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink

105 CMR 451.123

Maintenance: Ceiling vent dirty

105 CMR 451.126*

Hot Water: Hot water temperature recorded at 64°F

Inmate Bathroom # 6506

105 CMR 451.126

Water Supply: No hot water supplied to handwash sink fixture

6th Floor

Staff Bathroom 6-1 & 6-2

105 CMR 451.110(A)

Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink

105 CMR 451.123*

Maintenance: Floor dirty

Staff Bathroom 6-3 & 6-4

No Violations Noted

Unit 6-1A

Common Area

No Violations Noted

Kitchenette

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink

Slop Sink Room # 61B

105 CMR 451.353

Interior Maintenance: Vent dirty

Storage Room # 61G

No Violations Noted

Shower Area

105 CMR 451.123

Maintenance: Shower vent dirty

105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123

Maintenance: Vent, light, and sprinkler head rusted

Cells

No Violations Noted

Unit 6-1

Common Area

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, excess water pressure at water fountain

105 CMR 451.353*

Interior Maintenance: Window dirty near cell # 36

105 CMR 451.353

Interior Maintenance: Window dirty near cell # 20

Kitchenette

No Violations Noted

Slop Sink Room

No Violations Noted

Second Floor Storage Room

No Violations Noted

Shower # 617

105 CMR 451.123

Maintenance: Floor tiles missing near drain

105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123

Maintenance: Possible mold growth between wall times

105 CMR 451.123

Maintenance: Shower vent dirty

105 CMR 451.123

Maintenance: Ceiling paint damaged

Shower # 618

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Shower vent dirty

105 CMR 451.123*

Maintenance: Ceiling dirty

105 CMR 451.123

Maintenance: Wall tiles damaged

105 CMR 451.123

Maintenance: Possible mold growth between wall times

Shower # 711

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Shower vent dirty

105 CMR 451.123*

Maintenance: Shower tiles damaged

105 CMR 451.123*

Maintenance: Soap scum on walls in shower

105 CMR 451.123

Maintenance: Possible mold growth between wall times

Shower # 712

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Shower vent dirty

105 CMR 451.123*

Maintenance: Walls dirty

105 CMR 451.123*

Maintenance: Possible mold growth between wall tiles

Cells

105 CMR 451.103*

Mattresses: Mattress damaged in cell # 36

105 CMR 451.103

Mattresses: Mattress damaged in cell # 22 and 23

105 CMR 451.101

Blankets: Blanket damaged in cell # 37

Unit 6-2

Common Area

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, excess water pressure at water fountain

105 CMR 451.345

Illumination in Common Passage Ways and Areas: Inadequate lighting, one light fixture not functioning properly outside Storage Room # 62C

105 CMR 451.353

Interior Maintenance: Stairways dirty

105 CMR 451.353*

Interior Maintenance: Window dirty near cell # 6

105 CMR 451.353

Interior Maintenance: Window dirty near cell # 33

Kitchenette

FC 4-602.12(B)*

Cleaning of Equipment and Utensils; Frequency: Interior of both microwave oven dirty

Slop Sink Room # 62B

105 CMR 451.353*

Interior Maintenance: Wet mop left in bucket

Shower # 625

105 CMR 451.123*

105 CMR 451.123

105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting

Maintenance: Soap scum on walls in shower

Maintenance: Possible mold growth observed between wall tiles

Shower # 626

105 CMR 451.123

105 CMR 451.123

105 CMR 451.123

105 CMR 451.123

105 CMR 451.123

Maintenance: Shower ceiling dirty

Maintenance: Shower vent dirty

Maintenance: Shower walls and floor need re-grouting

Maintenance: Soap scum on walls in shower

Maintenance: Possible mold growth observed between wall tiles

Meeting Room # 627

No Violations Noted

Storage Room # 62C

105 CMR 451.353

Interior Maintenance: Vent dirty

Visit Rooms

No Violations Noted

Shower # 721

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123

105 CMR 451.130*

Maintenance: Ceiling vent dirty

Maintenance: Shower head missing

Maintenance: Floor dirty

Maintenance: Soap scum on walls in shower

Plumbing: Plumbing not maintained in good repair, shower out-of-order

Shower # 722

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123

105 CMR 451.123

105 CMR 451.130

Maintenance: Shower walls and floor need re-grouting

Maintenance: Shower vent dirty

Maintenance: Shower walls dirty

Maintenance: Possible mold growth observed between wall tiles

Maintenance: Soap scum on walls in shower

Plumbing: Plumbing not maintained in good repair, shower head leaking

Shower # 723

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123

105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting

Maintenance: Shower vent dirty

Maintenance: Soap scum on walls in shower

Maintenance: Shower ceiling dirty

Maintenance: Possible mold growth observed between wall tiles

Cells

105 CMR 451.101

Blankets: Blanket damaged in cell # 17

Unit 6-3

Common Area

105 CMR 451.353*

105 CMR 451.353

Interior Maintenance: Window dirty near cell # 12, 17, and 29

Interior Maintenance: Stairways dirty

Kitchenette

105 CMR 451.125

Drinking Water: Insufficient supply of drinking water, not water provided to water fountain

Meeting Room # 63B

No Violations Noted

Shower # 63C

105 CMR 451.123*

Maintenance: Shower walls need re-grouting

105 CMR 451.123*

Maintenance: Step tiles missing

105 CMR 451.123*

Maintenance: Wall tiles damaged near door frame

105 CMR 451.123

Maintenance: Shower vent dirty

105 CMR 451.123

Maintenance: Floor tiles damaged and missing around drain

Slop Sink Room # 63D

105 CMR 451.353*

Interior Maintenance: Vent dirty

105 CMR 451.353

Interior Maintenance: Wet mop left in bucket

Shower # 63E

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

Storage Room # 63F

105 CMR 451.353*

Interior Maintenance: Vent cover missing

Shower # 63G

105 CMR 451.123*

Maintenance: Shower vent dirty

105 CMR 451.123*

Maintenance: Access panel rusted

105 CMR 451.123

Maintenance: Floor tiles damaged around drain

Shower # 63H

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Shower vent dirty

105 CMR 451.123

Maintenance: Floor tiles damaged and missing around drain

Shower # 63J

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Floor tiles damaged and missing around drain

105 CMR 451.123

Maintenance: Floor dirty

Visiting Rooms

105 CMR 451.353

Interior Maintenance: Baseboard damaged in visiting room # 709

Cells

105 CMR 451.101

Blankets: Blanket damaged in cell # 22 and 32

Unit 6-4

Common Area

105 CMR 451.353*

Interior Maintenance: Window sill dirty near cell # 5

Kitchenette

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink, no paper towels at handwash sink

FC 3-501.16(B)

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk temperature recorded at 69°F

Shower #64B

No Violations Noted

Slop Sink Room # 64C

105 CMR 451.353

Interior Maintenance: Outlet cover not secured properly

Shower # 64D

105 CMR 451.123*

105 CMR 451.123

105 CMR 451.123

Maintenance: Ceiling paint damaged

Maintenance: Shower floor need re-grouting

Maintenance: Soap scum on walls in shower

Shower # 64E

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

Maintenance: Floor tiles missing near drain cover

Maintenance: Shower tiles dirty

Maintenance: Door frame rusted

Maintenance: Shower vent dirty and rusted

Maintenance: Soap scum and possible mold growth on walls in shower

Maintenance: Ceiling paint damaged

Storage Room # 64F

105 CMR 451.345

Illumination in Common Passage Ways and Areas: Inadequate lighting, one light fixture not functioning properly

Shower # 64G

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

Maintenance: Shower tiles dirty

Maintenance: Door frame rusted

Maintenance: Soap scum and possible mold growth on walls in shower

Shower # 64H

105 CMR 451.123*

105 CMR 451.123*

Maintenance: Upper edge of tiles not sealed properly to ceiling

Maintenance: Shower floor dirty

Visiting Rooms

No Violations Noted

Cells

FC 3-501.16(B)

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 12 and 33

5th Floor

Hallway

No Violations Noted

Visiting Rooms

No Violations Noted

Medical Area

Waiting Room

No Violations Noted

Nurses Area

No Violations Noted

Omni Cell Room # 5041

105 CMR 451.353

Interior Maintenance: Vent dirty

Diabetic Room 5044

No Violations Noted

Male Staff Locker and Bathroom # 5093

No Violations Noted

Female Staff Locker and Bathroom # 5124

No Violations Noted

Staff Break Room # 5033

FC 4-204.112(A)*

Design and Construction, Functionality: No functioning thermometer in refrigerator

FC 6-501.12(A)

Maintenance and Operation; Cleaning: Facility not cleaned properly, drawers dirty

Dental Office

No Violations Noted

Exam Room # 1 and Bathroom #5032

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, no water provided to handwash sink in the bathroom

Exam Room # 2 and Bathroom #5030

No Violations Noted

X-Ray Room

105 CMR 451.344

Illumination in Habitable Areas: One light fixture not functioning properly

Medical Waste Storage Room # 5507

No Violations Noted

Medical Housing Unit

Common Area

105 CMR 451.353

Interior Maintenance: Vent dirty

Kitchenette

FC 6-301.12

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink, no paper towels at handwash sink

FC 6-301.11

Numbers and Capacity; Handwashing Facilities: No soap at handwash sink

Slop Sink Room # 5511

105 CMR 451.353

Interior Maintenance: Vent dirty

Shower # 5512

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Ceiling vent dirty

105 CMR 451.123

Maintenance: Soap scum on walls in shower

105 CMR 451.123

Maintenance: Light fixture rusted

Isolation Cell # 5514

105 CMR 451.110(A)*

Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink

105 CMR 451.110(B)*

Hygiene Supplies at Toilet and Handwash Sink: No waste receptacle at handwash sink

Storage Room # 5522

105 CMR 451.353

Interior Maintenance: Floor dirty

Shower # 5523

105 CMR 451.353

Used for storage at the time of inspection

Interior Maintenance: Floor dirty

Shower # 5524

Used for storage at the time of inspection

Shower # 5554

105 CMR 451.123*

105 CMR 451.140*

Maintenance: Shower walls and floor need re-grouting

Adequate Ventilation: Inadequate ventilation, vent painted over

Cells

105 CMR 451.353

Interior Maintenance: Vent dirty in cell # 16, 18, and 19

Psychiatric Housing Unit # 5552

Storage # 5553

105 CMR 451.353

Interior Maintenance: Light shield loose

Room # 5555

No Violations Noted

Kitchenette

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink

Shower # 5573

105 CMR 451.123*

105 CMR 451.123*

105 CMR 451.123

105 CMR 451.123

Maintenance: Shower walls need re-grouting

Maintenance: Wall tiles damaged near doorway

Maintenance: Shower vent dirty

Maintenance: Soap scum on walls in shower

Slop Sink Room

105 CMR 451.353

Interior Maintenance: Vent dirty

Cells

No Violations Noted

4th Floor

Staff Bathroom 4-1 & 4-2

105 CMR 451.110(A)

105 CMR 451.123*

Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink

Maintenance: Ceiling vent dirty

Staff Bathroom 4-3 & 4-4

105 CMR 451.123

Maintenance: Ceiling vent dirty

Unit 4-1

Common Area

105 CMR 451.353

Interior Maintenance: Window dirty near cell # 14 and 31

Kitchenette

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink

FC 5-205.15(B)

Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, excess water pressure at water fountain

FC 5-205.15(B)

Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, water fountain leaking

Slop Sink Room # 41N

No Violations Noted

Room # 41M

No Violations Noted

Shower # 41G (near cell # 10)

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Interior access door finish damaged

105 CMR 451.123*

Maintenance: Floor tiles dirty

Shower # 41H (near cell # 27)

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Interior access door paint damaged

Shower # 41I

105 CMR 451.123

Maintenance: Shower vent dirty

105 CMR 451.140*

Adequate Ventilation: Inadequate ventilation, vent painted

Shower # 41J

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, shower head leaking

105 CMR 451.140*

Adequate Ventilation: Inadequate ventilation, vent painted

Shower # 41K

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Shower vent dirty

Cells

105 CMR 451.103*

Mattresses: Mattress damaged in cell # 31

105 CMR 451.103

Mattresses: Mattress damaged in cell # 11, 17, 23, and 32

Unit 4-2

Common Area

105 CMR 451.353*

Interior Maintenance: Ceiling vent dirty outside shower # 42D

105 CMR 451.353

Interior Maintenance: Window dirty near cell #6

105 CMR 451.353

Interior Maintenance: Floor dirty

105 CMR 451.353

Interior Maintenance: Stairways dirty

Kitchenette

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink

Meeting Room # 42B

No Violations Noted

Slop Sink Room # 42C

105 CMR 451.353

Interior Maintenance: Wet mop left in bucket

105 CMR 451.353

Interior Maintenance: Floor dirty

105 CMR 451.353

Interior Maintenance: Vent dirty

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, slop sink faucet leaking

Shower # 42D

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Shower vent dirty
Maintenance: Floor tiles missing
Maintenance: Soap scum on walls in shower

Shower # 42E

105 CMR 451.123*
105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting
Maintenance: Shower vent dirty

Room # 42F

No Violations Noted

Shower # 42G

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123
105 CMR 451.123
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Doorframe rusted
Maintenance: Shower vent dirty
Maintenance: Ceiling dirty
Maintenance: Soap scum and possible mold growth on shower wall and floor tiles

Shower # 42H

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting
Maintenance: Shower vent dirty
Maintenance: Soap scum on wall and floor tiles

Shower # 42J (near cell # 32)

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Door frame rusted
Maintenance: Soap scum and possible mold growth on shower wall and floor tiles
Maintenance: Shower vent dirty

Cells

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, toilet not functioning properly in cell # 28

FC 3-501.16(B)

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 2, 3, 5, 10, 12, 14, 22, 25, 29, and 31

Unit 4-3

Common Area

105 CMR 451.353
105 CMR 451.353

Interior Maintenance: Window dirty near cell #12, 17, and 29
Interior Maintenance: Vent dirty outside shower # 43D

Kitchenette

FC 4-602.12(B)*
FC 6-301.12*

Cleaning of Equipment and Utensils; Frequency: Interior of microwave oven dirty
Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink

Shower # 43C

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.130

Maintenance: Shower walls and floor need re-grouting
Maintenance: Soap scum on walls in shower
Maintenance: Shower access panel and door frame rusted
Maintenance: Shower vent dirty
Maintenance: Wall tile damaged
Plumbing: Plumbing not maintained in good repair, shower head leaking

Slop Sink Room # 43D

105 CMR 451.353*

Interior Maintenance: Vent dirty

Shower # 43E

105 CMR 451.123*

Maintenance: Shower walls need re-grouting

105 CMR 451.123*

Maintenance: Drain flies observed in shower unit

105 CMR 451.123

Maintenance: Floor drain cover missing

105 CMR 451.123

Maintenance: Soap scum on walls in shower

105 CMR 451.123

Maintenance: Shower vent dirty

Storage Room # 43F

No Violations Noted

Shower # 43G

105 CMR 451.123*

Maintenance: Floor tiles damaged

105 CMR 451.123

Maintenance: Soap scum and possible mold growth on shower wall tiles

105 CMR 451.123

Maintenance: Shower vent dirty

Shower # 43H

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Ceiling vent dirty

105 CMR 451.123*

Maintenance: Wall tiles damaged

105 CMR 451.123*

Maintenance: Soap scum and possible mold growth on wall tiles

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, shower continuously running water

Shower # 43I

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Possible mold growth on ceiling

105 CMR 451.123*

Maintenance: Door frame rusted

105 CMR 451.123*

Maintenance: Ceiling vent dirty

105 CMR 451.123*

Maintenance: Floor tiles missing near drain

105 CMR 451.123*

Maintenance: Soap scum and possible mold growth on wall tiles

105 CMR 451.123*

Maintenance: Floor dirty

Cells

FC 3-501.16(B)*

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 11

FC 3-501.16(B)

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 6, 8, 10, 12, 29, 30, 32, and 33

Unit 4-4

Common Area

105 CMR 451.353*

Interior Maintenance: Windows dirty near cell # 5

Kitchenette

FC 3-304.14(B)(2)*

Preventing Contamination from Linens: Wet cloth not stored in sanitizer bucket and no sanitizer solution available

105 CMR 451.110(A)

Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink

FC 2-402.11

Hygienic Practices; Hair Restraints: Food service personnel not wearing appropriate hair restraints, beard guards not in use at the start of food service

Shower # 44B

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*	Maintenance: Drain flies observed in shower area
105 CMR 451.123*	Maintenance: Wall tiles damaged
105 CMR 451.123	Maintenance: Possible mold growth observed between wall tiles
105 CMR 451.123	Maintenance: Step tiles damaged

Slop Sink Room # 44C

105 CMR 451.353*	Interior Maintenance: Wet mop left in bucket
------------------	--

Shower # 44D

105 CMR 451.123*	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123*	Maintenance: Wall tiles damaged
105 CMR 451.123	Maintenance: Drain flies observed in shower
105 CMR 451.123	Maintenance: Door frame rusted
105 CMR 451.123	Maintenance: Possible mold growth observed between wall tiles
105 CMR 451.123	Maintenance: Soap scum on walls in shower

Meeting Room # 44E

No Violations Noted

Closet # 44G

105 CMR 451.353*	Interior Maintenance: Ceiling fire-retardant insulation not intact
------------------	--

Shower # 44H

105 CMR 451.123	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123	Maintenance: Possible mold growth observed between wall tiles
105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, shower head leaking

Shower # 44I

105 CMR 451.123*	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123*	Maintenance: Ceiling paint damaged
105 CMR 451.123*	Maintenance: Shower vent dirty
105 CMR 451.123*	Maintenance: Step tiles missing
105 CMR 451.123	Maintenance: Possible mold growth observed on ceiling
105 CMR 451.123	Maintenance: Shower floor dirty
105 CMR 451.123	Maintenance: Possible mold growth observed between wall tiles
105 CMR 451.123	Maintenance: Soap scum on walls in shower

Shower # 44J

105 CMR 451.123*	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123*	Maintenance: Ceiling vent dirty
105 CMR 451.123	Maintenance: Possible mold growth observed between wall tiles
105 CMR 451.123	Maintenance: Soap scum on walls in shower

Cells

105 CMR 451.102	Pillows and Linens: Pillow uncovered in cell # 11
FC 3-501.16(B)*	Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 1 and 30
FC 3-501.16(B)	Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 2, 4, 21, 24, 27, 34, and 36

3rd Floor
Hallway

No Violations Noted

Visiting Rooms

No Violations Noted

Floor 3.5

Office Area

No Violations Noted

Slop Sink Room # 3503

105 CMR 451.353

Interior Maintenance: Vent dirty

Female Staff Bathroom

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, faucet on handwash sink # 1 and 2 leaking

Male Staff Bathroom

No Violations Noted

File Room Kitchen

FC 4-602.12(B)

Cleaning of Equipment and Utensils; Frequency: Interior of microwave oven dirty

2nd Floor

Staff Bathroom 2-1 & 2-2

No Violations Noted

Staff Bathroom 2-3 & 2-4

105 CMR 451.123*

Maintenance: Toilet paper and paper towel holder damaged

105 CMR 451.123*

Maintenance: Light shield damaged

Unit 2-1

Common Area

105 CMR 451.353*

Interior Maintenance: Window dirty near cell # 15 and 34

Kitchenette

FC 3-304.14(B)(2)*

Preventing Contamination from Linens: Wet cloth not stored in sanitizer bucket and no sanitizer solution available

FC 5-202.12(A)*

Plumbing System, Design: Handwashing sinks water temperature recorded at 60°F

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink, no paper towels

Shower # 21B

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Shower vent rusted

105 CMR 451.123*

Maintenance: Light fixture rusted

105 CMR 451.123*

Maintenance: Wall tiles damaged

105 CMR 451.123*

Maintenance: Soap scum on shower wall tiles

105 CMR 451.123

Maintenance: Possible mold growth observed between shower wall tiles

Slop Sink Room # 21C

105 CMR 451.345

Illumination in Common Passage Ways and Areas: Inadequate lighting, one light fixture not functioning properly

Shower # 21D

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Wall tiles damaged

105 CMR 451.123*

Maintenance: Ceiling paint damaged

105 CMR 451.123*	Maintenance: Handicap shower head hose damaged, no holder provided
105 CMR 451.123*	Maintenance: Ceiling vent dirty
105 CMR 451.123	Maintenance: Flying insects observed in shower
105 CMR 451.123	Maintenance: Soap scum on shower wall tiles
105 CMR 451.123	Maintenance: Possible mold growth observed between shower wall tiles

Meeting Room # 21E

No Violations Noted

Shower # 21F (near cell # 11)

105 CMR 451.123*	Maintenance: Shower walls need re-grouting
105 CMR 451.123*	Maintenance: Ceiling vent dirty
105 CMR 451.123	Maintenance: Soap scum on shower wall tiles

Shower # 21G

105 CMR 451.123*	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123*	Maintenance: Possible mold growth on ceiling
105 CMR 451.123*	Maintenance: Shower head loose
105 CMR 451.123*	Maintenance: Wall tiles damaged
105 CMR 451.123*	Maintenance: Ceiling paint damaged

Closet # 21H

No Violations Noted

Shower # 21J

105 CMR 451.123*	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123*	Maintenance: Wall tiles missing and damaged near door frame
105 CMR 451.123*	Maintenance: Ceiling paint damaged
105 CMR 451.123	Maintenance: Soap scum on shower wall tiles
105 CMR 451.123	Maintenance: Possible mold growth observed between shower wall tiles

Cells

FC 3-501.16(B)*	Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 5
-----------------	--

FC 3-501.16(B)	Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 7, 10, 12, 16, and 28
----------------	--

Unit 2-2

Common Area

105 CMR 451.353*	Interior Maintenance: Window dirty near cell # 6
105 CMR 451.353*	Interior Maintenance: Vent dirty outside slop sink room # 22D
105 CMR 451.353*	Interior Maintenance: Stairways dirty

Kitchenette

FC 6-301.12	Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink, no paper
-------------	---

Meeting Room # 22B

No Violations Noted

Shower # 22C

105 CMR 451.123*	Maintenance: Shower walls and floor need re-grouting
105 CMR 451.123*	Maintenance: Shower vent dirty
105 CMR 451.123*	Maintenance: Soap scum on walls in shower

Slop Sink Room # 22D

105 CMR 451.353*

Interior Maintenance: Wet mop left in bucket

Shower # 22E

105 CMR 451.123*

Maintenance: Shower walls need re-grouting

105 CMR 451.123*

Maintenance: Wall tiles dirty

105 CMR 451.123

Maintenance: Soap scum on walls in shower

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, shower drain clogged

Closet # 22F

No Violations Noted

Shower # 22H

105 CMR 451.123*

Maintenance: Shower walls need re-grouting

105 CMR 451.123*

Maintenance: Floor tiles missing near drain

105 CMR 451.123*

Maintenance: Shower vent dirty

105 CMR 451.123

Maintenance: Floor dirty

Shower # 22I

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Wall tiles dirty

105 CMR 451.123*

Maintenance: Soap scum on shower wall tiles

105 CMR 451.123*

Maintenance: Shower vent dirty

Shower # 22J

105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting

105 CMR 451.123*

Maintenance: Door frame rusted

105 CMR 451.123*

Maintenance: Step tiles damaged

105 CMR 451.123*

Maintenance: Shower head loose

105 CMR 451.123

Maintenance: Light fixture not functioning properly

Cells

105 CMR 451.130

Plumbing: Plumbing not maintained in good repair, toilet not functioning properly in cell # 22

FC 3-501.16(B)*

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 3 and 7

FC 3-501.16(B)

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 4, 11, 14, 16, 25, 27, and 28

Unit 2-3

Common Area

105 CMR 451.353*

Interior Maintenance: Stairways dirty

105 CMR 451.353

Interior Maintenance: Vent dirty outside shower # 23C

105 CMR 451.353

Interior Maintenance: Window dirty near cell # 12 and 29

Kitchenette

FC 6-301.11

Numbers and Capacity; Handwashing Facilities: No soap at handwash sink

FC 6-301.12

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink, no paper towels provided

Meeting Room # 23B

No Violations Noted

Shower # 23C

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting
Maintenance: Possible mold growth observed between shower tiles
Maintenance: Shower vent dirty

Slop Sink Room # 23D

105 CMR 451.353
105 CMR 451.353

Interior Maintenance: Wet mop left in bucket
Interior Maintenance: Vent dirty and damaged

Shower # 23E

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Floor tiles missing
Maintenance: Soap scum on walls in shower

Closet # 23F

105 CMR 451.353*
105 CMR 451.353

Interior Maintenance: Vent dirty
Interior Maintenance: Floor dirty

Shower # 23G

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Ceiling paint damaged
Maintenance: Access panel rusted
Maintenance: Sprinkler head cone rusted
Maintenance: Shower vent dirty
Maintenance: Wall tiles damaged

Shower # 23H

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Floor tiles missing near floor drain
Maintenance: Shower tiles damaged
Maintenance: Possible mold growth on shower tiles
Maintenance: Soap scum on walls in shower

Shower # 23J

105 CMR 451.123*
105 CMR 451.123*

Maintenance: Shower walls and floor need re-grouting
Maintenance: Soap scum with possible mold growth on shower tiles

Visiting Rooms

No Violations Noted

Cells

105 CMR 451.103

Mattresses: Mattress damage in cell # 4, 13, 19, 24, 25, and 26

Unit 2-4

Common Area

105 CMR 451.350
105 CMR 451.353*
105 CMR 451.353*
105 CMR 451.353*

Structural Maintenance: Floor tiles damaged near stairway
Interior Maintenance: Water fountain dirty
Interior Maintenance: Stairway dirty
Interior Maintenance: Windows dirty near cell # 5 and 24

Kitchenette

FC 6-501.12(A)

Maintenance and Operation; Cleaning: Facility not cleaned properly, handwash sink dirty

FC 6-301.11*

Numbers and Capacity; Handwashing Facilities: No soap at handwash sink

FC 6-301.12*

Numbers and Capacity; Handwashing Facilities: No hand drying method available at handwashing sink, no paper towels

Shower # 24B

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123
105 CMR 451.123
105 CMR 451.123
105 CMR 451.130

Maintenance: Shower walls and floor need re-grouting
Maintenance: Door frame rusted
Maintenance: Shower vent dirty
Maintenance: Soap scum on walls in shower
Maintenance: Possible mold growth observed between shower tiles
Maintenance: Floor tiles damaged
Plumbing: Plumbing not maintained in good repair, shower head leaking

Slop Sink Room # 24C

No Violations Noted

Shower # 24D

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123
105 CMR 451.123
105 CMR 451.123
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Shower head loose
Maintenance: Door frame rusted
Maintenance: Sprinkler head cone rusted
Maintenance: Soap scum on walls in shower
Maintenance: Possible mold growth observed between shower tiles
Maintenance: Floor tiles missing

Meeting Room # 24E

No Violations Noted

Shower # 24F

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123
105 CMR 451.123
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Ceiling paint damaged
Maintenance: Shower head loose
Maintenance: Soap scum on walls in shower
Maintenance: Possible mold growth observed between shower tiles
Maintenance: Shower tiles damaged

Closet # 24G

105 CMR 451.350*
105 CMR 451.353*

Structural Maintenance: Wall damaged
Interior Maintenance: Vent cover missing

Shower # 24H

105 CMR 451.123*
105 CMR 451.123*

Maintenance: Shower walls need re-grouting
Maintenance: Shower floor dirty

Shower # 24J

105 CMR 451.123*
105 CMR 451.123*
105 CMR 451.123
105 CMR 451.123
105 CMR 451.123

Maintenance: Shower walls and floor need re-grouting
Maintenance: Soap scum on wall tiles
Maintenance: Possible mold growth observed on ceiling and in between wall tiles
Maintenance: Floor tiles missing
Maintenance: Drain flies observed in shower

Cells

FC 3-501.16(B)*

Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 22

FC 3-501.16(B) Limitation of Growth of Organisms, Temperature and Time Control: Potentially hazardous food not held at the proper cold holding temperature, unrefrigerated milk in cell # 4, 10, 31, 35, and 38

Entry Level (Inside)

Staff Cafeteria # 1066

FC 3-306.11

Preventing Contamination from Consumer: Food display not protected by an appropriate guard, no lid provided for self-serve soup kettle

FC 4-204.112(A)*

Design and Construction, Functionality: No functioning thermometer in refrigerator

FC 4-501.11(A)

Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, refrigerator gasket damaged

FC 4-601.11(A)*

Cleaning of Equipment and Utensils, Objective: Food contact surface dirty, nozzles on juice machine dirty

FC 6-301.20*

Numbers and Capacity; Handwashing Facilities: No waste receptacle provided for disposable towel at handwash sink

FC 6-501.12(A)*

Maintenance and Operation; Cleaning: Facility not cleaned properly, floor dirty behind vending machines

Weight Room # 1070

105 CMR 451.353*

Interior Maintenance: Exercise equipment damaged making the equipment no longer easily cleanable

105 CMR 451.353

Interior Maintenance: Floor padding damaged

Slop Sink Room # 1072

105 CMR 451.350*

Structural Maintenance: Wall damaged above slop sink

Water Fountain

No Violations Noted

Blue Shirt's Locker Room # 1075

105 CMR 451.110(A)

Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink

105 CMR 451.123*

Maintenance: Floor dirty

Female Staff Locker Room # 1076

105 CMR 451.123*

Maintenance: Toilet paper holders damaged

105 CMR 451.126*

Hot Water: Hot water temperature recorded at 74°F

Captain and Lieutenants' Locker Room # 1077

No Violations Noted

Outside Administration Bathrooms

Female Bathroom # 1013

No Violations Noted

Male Bathroom # 1015

No Violations Noted

Ground Level

Canteen # G10

Locked at the time of inspection

Hallway Bathrooms

Staff Bathroom # G5

105 CMR 451.123

Maintenance: Vent dirty

Staff Bathroom # G6

Locked at the time of inspection

<i>Storage Room # G11</i>	Locked at the time of inspection
<i>Maintenance # G12</i> 105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, slop sink faucet leaking
<i>Locker Room # G13</i>	No Violations Noted
<i>Laundry Room # G23</i>	No Violations Noted
<i>Loading Dock # G26</i>	No Violations Noted
<i>Garbage Room # G37</i> 105 CMR 451.353*	Interior Maintenance: Walls no longer easily cleanable, wall paint damaged
<i>Staff Bathroom # G44</i> 105 CMR 451.123	Maintenance: Vent dirty
<i>Staff Bathroom # G46</i> 105 CMR 451.123	Maintenance: Vent dirty
<i>Female Booking Area</i> <i>Holding Cells</i> 105 CMR 451.353* 105 CMR 451.353	Interior Maintenance: Vent in holding cell # 1 and 3 Interior Maintenance: Ceiling dirty in holding cell # 1
<i>Male Booking Area</i> <i>Control</i>	No Violations Noted
<i>Property Room # G62</i>	No Violations Noted
<i>Staff Bathroom # G64</i> 105 CMR 451.126	Hot Water: Hot water temperature recorded at 64 ⁰ F
<i>Male Intake Cells # G74</i>	No Violations Noted
<i>Holding Cage</i>	No Violations Noted
<i>Holding Cells</i> 105 CMR 451.353	Interior Maintenance: Ceiling vent dirty in cell # 1, 2, 3, and 4
<i>Back Gate Control # G80</i> FC 4-102.11(B)(2)	Materials for Construction and Repair; Multiuse: Unused single-service article not protected against contamination, utensils not stored with handles up
<i>Staff Bathroom # G81</i>	No Violations Noted

Food Service Area

Office # G38

FC 4-501.11(A)*

Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, gasket damaged

Sanitizer Buckets near Office # G38

FC 4-501.114(C)(2)

Maintenance and Operation; Equipment: Quaternary ammonium solution greater than the manufacturers recommended concentration

Trash Area

No Violations Noted

Oven and Steamer Hood Area

No Violations Noted

Grease Hood

No Violations Noted

Dry Storage

FC 6-501.11*

Maintenance and Operation; Repairing: Facility not in good repair, fire retardant coating on ceiling loose

Storage Cage

No Violations Noted

Inmate Dining Area

FC 6-501.11*

Maintenance and Operation; Repairing: Facility not in good repair, baseboard tiles damaged

Inmate Bathroom

FC 5-205.15(B)*

Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, leaking pipe secured with duct tape under handwash sink # 2

FC 6-501.11*

Maintenance and Operation; Repairing: Facility not in good repair, counter top edge damaged

FC 6-501.11*

Maintenance and Operation; Repairing: Facility not in good repair, baseboard tiles damaged

Chemical Storage Cage

No Violation Noted

Can Opener Table

FC 4-601.11(A)

Cleaning of Equipment and Utensils, Objective: Food contact surface dirty, can opener dirty

Refrigerator # 1

FC 3-501.16(B)*

Limitation of Growth of Organisms, Temperature and Time Control: Refrigerator temperature recorded at 45°F

FC 4-501.11(A)*

Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, refrigerator gages not functioning properly

FC 4-501.11(A)

Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, refrigerator gasket damaged

Refrigerator # 2

FC 3-501.16(B)

Limitation of Growth of Organisms, Temperature and Time Control: Refrigerator temperature recorded at 46°F

FC 4-501.11(A)	Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, refrigerator gages not functioning properly
<i>Ice Machines</i>	
	No Violations Noted
<i>Vegetable Chest # 3</i>	
	No Violation Noted
<i>Milk Chest # 4</i>	
	No Violation Noted
<i>Freezer # 5</i>	
	No Violation Noted
<i>Bread Refrigerator # 6</i>	
FC 4-501.11(A)	Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, one light shield damaged
<i>Tray Prep Area</i>	
FC 5-202.12(A)*	Plumbing System, Design: Handwashing sinks water temperature recorded at 142°F
FC 6-501.11	Maintenance and Operation; Repairing: Facility not in good repair, one light fixture not functioning properly
FC 5-205.15(B)	Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, handwash sink leaking
<i>Kettle Area</i>	
FC 6-501.11	Maintenance and Operation; Repairing: Facility not in good repair, floor grout damaged
FC 6-301.20	Numbers and Capacity; Handwashing Facilities: No waste receptacle provided for disposable towel for handwash sink
<i>3-Compartment Sink</i>	
FC 5-202.12(A)*	Plumbing System, Design: Handwashing sinks water temperature recorded at 144°F
FC 5-205.15(B)*	Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, water control handles leaking
FC 5-205.15(B)*	Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, sink fixture leaking
<i>Mechanical Warewashing Area</i>	
FC 4-501.11(A)*	Maintenance and Operation, Equipment: Equipment not maintained in a state of good repair, wash gage not functioning properly on the mechanical warewashing machine
FC 5-205.15(B)*	Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, mechanical warewashing machine leaking in several areas causing an extensive amount of standing water on the floor
FC 6-501.11*	Maintenance and Operation; Repairing: Facility not in good repair, floor tiles damaged
FC 6-501.11*	Maintenance and Operation; Repairing: Facility not in good repair, ceiling tile missing
FC 6-501.11*	Maintenance and Operation; Repairing: Facility not in good repair, hose wrapped with cloth like material
FC 6-501.11	Maintenance and Operation; Repairing: Facility not in good repair, wall paint damaged
FC 6-501.12(A)	Maintenance and Operation; Cleaning: Facility not cleaned properly, ceiling dirty

Tray Racks

FC 4-601.11(A)*

Cleaning of Equipment and Utensils, Objective: Food contact surface dirty, several trays dirty on drying rack

FC 4-202.11(A)(2)*

Design and Construction, Cleanability: Damaged food-contact surface no longer easily cleanable, several trays damaged on drying rack

Observations and Recommendations

- The inmate populations was 727 at the time of inspection
- Refinished shower # 64B in the 6-4 unit looked good. The Department looks forward to seeing the changes that will take place as other showers within the facility are refinished.
- The medical waste log was not available for review at the time of inspection. The individual in charge of maintaining the log was not in at that time, please ensure the log is being maintained in accordance with 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste.
- Mechanical warewashing machine is not designed to hold the thick insulated trays in the holding racks used at this correctional facility. This appears to be preventing trays from being appropriately cleaned and sanitized as evident by the residual food left on several trays during the course of the inspection. The Department recommends the facility use an alternative sanitization method until the appropriate mechanical warewashing machine that meets the needs of the facility is installed. In addition, trays are not allowed to air dry properly between uses. The Department recommends appropriate drying rack is used to allow tray to air dry completely between uses.
- The use of caulking to "repair" the leaking 3-compartment sink in the main kitchen is not a sufficient solution. An appropriate replacement or work-person like repair should be made.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please indicate next to each entry on the inspection report a plan of correction. Said plan of correction must be submitted within ten working days of receiving this report and should detail the specific steps that will be taken and the date of expected compliance. The plan of correction should be submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Community Sanitation Regulations" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X - Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Lauren Molotnikov

Environmental Health Inspector, CSP, BEH

cc: Suzanne K. Condon, Associate Commissioner, Director, BEH
Steven Hughes, Director, CSP, BEH
JudyAnn Bigby, MD, Secretary, Executive Office of Health and Human Services
Luis S. Spencer, Commissioner, DOC
Eugene Sumpter, Superintendent
Deputy Michael Chisholm, EHSO
Boston Public Health Commission
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Mary Elizabeth Heffernan, EOPS