

October 19, 2022

Mr. Michael Lane  
Environmental, Health & Safety Manager  
Office of Court Management/ Facilities Management & Capital Planning Lowell District Court  
41 Hurd Street  
Lowell, MA 01852

Ref: Indoor Air Quality & Microbial Assessment – Visit 14  
Springfield Court Complex  
Roderick L. Ireland Courthouse, 50 State Street, Springfield, MA &  
Springfield Housing & Juvenile Courthouse, 80 State Street, Springfield, MA  
TRC Project 499949

Dear Mr. Lane:

On October 5, 2022, TRC Environmental Corporation (TRC) conducted a limited indoor air quality and microbial assessment at the above-referenced sites. TRC conducted the following scope of work:

- Visual inspection of up to sixty (60) locations between the two buildings;
- Direct-reading measurements of selected indoor air quality parameters including temperature, relative humidity, carbon monoxide (CO), and carbon dioxide (CO<sub>2</sub>); airborne particulate as PM<sub>10</sub> (particles with aerodynamic diameters of approximately 10 microns or less); total volatile organic compounds (VOC's); and
- Sampling for airborne concentrations of total fungal (mold)<sup>1</sup> spores in eighteen (18) indoor locations.

The site observations, test methods used, results and conclusions, and recommendations are presented below. A copy of the laboratory analytical report and the sample location drawings are included as attachments to this report.

## INVESTIGATIVE STRATEGY

### Visual Inspection

The readily accessible areas of the above referenced property were visually evaluated for evidence of water staining, water damage, and suspect fungal growth (mold). A reasonable effort was made to identify fungal-impacted building materials.

### Carbon Dioxide, Carbon Monoxide, Temperature and Relative Humidity

TRC used a TSI® 7575X Q-Trak to monitor relative humidity, temperature, carbon monoxide (CO), and carbon dioxide (CO<sub>2</sub>) levels.

---

<sup>1</sup> For the purposes of this report, the terms “mold” and “fungi” may be used interchangeably

- *Carbon Dioxide* - Carbon dioxide is exhaled by people and is a useful indicator of adequate make-up (fresh) air and supply per occupant. The American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) Standard 62.1-2019, Ventilation for Acceptable Indoor Air Quality, recommends the difference between indoor and outdoor CO<sub>2</sub> concentrations be maintained at 700 parts per million (ppm) or less. Maintaining this condition equates to approximately 15 cubic feet per minute of supply air per occupant. Under this condition, a substantial majority of visitors entering a space will be satisfied with respect to human bioeffluents (body odor). The Massachusetts Department of Public Health (MA DPH) uses a guideline of 800 ppm of CO<sub>2</sub> for publicly occupied buildings<sup>2</sup>. Note that while indoor CO<sub>2</sub> levels are useful for evaluating the outdoor air ventilation provided to a building, these levels are typically well below concentrations that might pose a CO<sub>2</sub>-related health risk (greater than 5,000 ppm). Ambient concentrations of CO<sub>2</sub> generally range from 300 - 500 ppm.
- *Carbon Monoxide* - Carbon monoxide is a colorless, odorless gas that can cause fatigue or drowsiness, nausea, headache, and difficulty breathing when present at elevated levels. ASHRAE Standard 62.1-2019 recommends carbon monoxide concentrations less than 9 ppm indoors as an eight-hour average.
- *Temperature and Relative Humidity* - ASHRAE Standard 55-2020, Thermal Environmental Conditions for Human Occupancy bases occupant thermal comfort on a combination of metabolic rate, clothing insulation, air temperature (dry bulb temperature as a substitute for operative temperature), radiant temperature, air speed, and humidity. Conditions are considered to be satisfactory when a substantial majority of occupants (80% or more) are not expressing dissatisfaction with thermal comfort.

ASHRAE standard 62.1-2019 Ventilation for Acceptable Indoor Air Quality recommends that the relative humidity be maintained below 65%.

#### Measurement of Airborne Particulate Matter

A TSI® DustTrak DRX Aerosol Monitor was used to monitor airborne particulate matter of approximately 10 micrometers or less in diameter (PM<sub>10</sub>).

Airborne particulate in indoor environments originates from various sources including building materials and furnishings, occupant activities, cleaning, construction, and renovation activities, and from outdoors. High concentrations of airborne dust may cause irritation of the eyes, skin, and respiratory tract.

The U.S. EPA has established a health-based National Ambient Air Quality Standard (NAAQS) for PM<sub>10</sub> to evaluate outdoor air quality. This is not intended to evaluate worker exposure but is meant to protect the health of sensitive individuals within the general population. The NAAQS is based on rolling-24-hour average concentrations over a 3-day period and as such, is not directly comparable to individual PM measurements taken during this assessment; however, the NAAQS

---

<sup>2</sup> MA DPH “Carbon Dioxide and Its Use in Evaluating Adequacy of Ventilation in Buildings”, [www.mass.gov/eohhs/docs/dph/environmental/iaq/appendices/carbon-dioxide.pdf](http://www.mass.gov/eohhs/docs/dph/environmental/iaq/appendices/carbon-dioxide.pdf)

is provided in this report as a benchmark. The NAAQS for PM<sub>10</sub> is 0.150 milligrams per cubic meter of air (mg/m<sup>3</sup>) measured as a 24-hour average concentration.

The OSHA Permissible Exposure Limit (PEL) for occupational exposure to total dust is 15 mg/m<sup>3</sup>, and for the respirable dust fraction, 5 mg/m<sup>3</sup>, both as 8-hour average concentrations.

The instrument is calibrated approximately annually by the manufacturer and is zeroed prior to use in the field.

#### Measurement of Total Volatile Organic Compounds (VOCs)

A ppbRAE Model PGM-7240, ppbRAE 3000 photo-ionizing detector (PID) (or similar instrument) was used to monitor VOCs. VOC measurements were performed to determine if unusually elevated concentrations of this group of air contaminants existed at the monitored locations. VOCs have many sources, including, but not limited to the evaporation of paint solvents; adhesives; and office or personal products that are used in the building, such as cosmetic fragrances, air fresheners and deodorizing and sanitizing products.

Although the instrument used in this study is a useful screening method for detecting indoor VOCs, it provides no information on the identities and relative amounts of individual compounds that may be present. If indoor VOC concentrations are significantly and consistently greater than the outdoor VOC concentration, then one or more indoor VOC sources may be present.

The U.S. Green Building Council Leadership in Energy and Environmental Design (USGBC LEED) for New Construction-2009 requirements specify a maximum VOC concentration of 0.500 milligrams per cubic meter of air (mg/m<sup>3</sup>) in newly constructed areas and is used in this report as a guideline for evaluating indoor air quality. Assuming an average VOC molecular weight similar to that of n-hexane, this corresponds to approximately 0.140 ppm VOCs.

The instrument was calibrated prior to use in the field using standard isobutylene calibration gas.

#### Microbial Sampling – Air Samples

Sampling for airborne concentrations of total fungal spores was conducted using Air-O-Cell sampling cassettes. Samples were collected at 15 liters of air per minute for five-minute sampling periods using a high-volume sampling pump. Airborne particulates were drawn through the cassette and directly impacted onto an adhesive collection media. The samples were shipped to Hayes Microbial Consulting of Midlothian, Virginia where they were analyzed to determine the quantity and identity of fungal spore types using bright field microscopy (magnification 300x and 600x). Hayes Microbial participates in the American Industrial Hygiene Association (AIHA) Environmental Microbiology Laboratory Accreditation Program (EMLAP), certification #188863. The Air-O-Cell cassette collects both viable and non-viable fungal spores, and the laboratory can identify some of the collected spores down to the genus level.

TRC collected representative air samples in selected indoor locations and also outdoors, for comparison purposes.

There is currently little information available on total airborne fungal spore dose-response relationships, and there are no recommended allowable exposure limits established for airborne spores. The American Conference of Governmental Industrial Hygienists (ACGIH) publication *Bioaerosols: Assessment and Control*, indicates that an exposure may be considered unusual when indoor concentrations are significantly higher than those outdoors, or when the types of mold detected indoors vs. outdoors differ markedly.

## RESULTS

### Visual Inspection

On the day of this assessment, no suspect fungal growth was observed in any of the areas inspected. Horizontal surfaces appeared to be clean of any dust or debris.

### Indoor Air Quality Measurements

Results of the indoor air quality measurements are presented in the table below. The results are presented in the following units: temperature measurements are presented in degrees Fahrenheit (°F); relative humidity measurements are presented as percent relative humidity (%); the CO<sub>2</sub>, CO, and VOC measurements are presented in concentration units of parts per million parts of air, by volume (ppm); and PM<sub>10</sub> measurements are presented in concentration units of milligrams per cubic meter of air (mg/m<sup>3</sup>).

Indoor Air Quality Measurements Springfield Court Complex, 50 & 80 State Street, Springfield, Massachusetts October 5, 2022							
Test #	Location	Temp (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Airborne PM <sub>10</sub> (mg/m <sup>3</sup> )	Volatile Organic Compounds (ppm)
Roderick L. Ireland Courthouse, 50 State Street, Springfield, MA							
001	PC3 – Probate Court #3	71.7	48.4	477	ND (<3)	ND (<0.001)	ND (<0.020)
002	416 – Judges Lobby	71.2	42.5	487	ND (<3)	0.023	ND (<0.020)
003	252 – Mens Room by Elevator	71.6	44.1	545	ND (<3)	0.004	ND (<0.020)
004	444 – Office in Secretary Pool	71.7	41.1	517	ND (<3)	0.001	ND (<0.020)
005	409 – Copy Room, ROD	71.2	40.4	449	ND (<3)	0.002	ND (<0.020)

<b>Indoor Air Quality Measurements</b> <b>Springfield Court Complex, 50 &amp; 80 State Street, Springfield, Massachusetts</b> <b>October 5, 2022</b>							
<b>Test #</b>	<b>Location</b>	<b>Temp (°F)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Carbon Monoxide (ppm)</b>	<b>Airborne PM<sub>10</sub> (mg/m<sup>3</sup>)</b>	<b>Volatile Organic Compounds (ppm)</b>
006	407 – Empty Room, ROD	70.6	40.9	447	ND (<3)	0.002	ND (<0.020)
007	350 – Office in District Attorneys	71.4	47.5	509	ND (<3)	ND (<0.001)	ND (<0.020)
008	Superior Courtroom #5	71.5	47.2	472	ND (<3)	0.002	ND (<0.020)
009	374 – Jury Room	72.0	47.2	492	ND (<3)	0.002	ND (<0.020)
010	347A – Judges Lobby	72.4	47.2	527	ND (<3)	0.002	ND (<0.020)
011	311 – Training Room in Law Library	71.8	49.4	581	ND (<3)	0.001	ND (<0.020)
012	303 – Office in Secretary Pool	70.9	48.2	581	ND (<3)	0.002	ND (<0.020)
013	260 – Conference Room	70.0	48.4	526	ND (<3)	0.002	ND (<0.020)
014	249B – Judges Lobby	69.1	51.7	552	ND (<3)	0.001	ND (<0.020)
015	254 – Chief Court Officer	71.8	50.4	590	ND (<3)	0.002	ND (<0.020)
016	221 - Vault	73.6	47.0	585	ND (<3)	0.002	ND (<0.020)
017	207B – Judges Lobby	70.3	48.4	552	ND (<3)	0.002	ND (<0.020)
018	261 – Northeast Conference Room	67.8	52.3	594	ND (<3)	0.002	ND (<0.020)

<b>Indoor Air Quality Measurements</b> <b>Springfield Court Complex, 50 &amp; 80 State Street, Springfield, Massachusetts</b> <b>October 5, 2022</b>							
<b>Test #</b>	<b>Location</b>	<b>Temp (°F)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Carbon Monoxide (ppm)</b>	<b>Airborne PM<sub>10</sub> (mg/m<sup>3</sup>)</b>	<b>Volatile Organic Compounds (ppm)</b>
019	167 – District Court of Probation, Rear Desks	70.5	50.6	609	ND (<3)	0.003	ND (<0.020)
020	155 – Office, District Court of Probation	70.6	50.8	574	ND (<3)	ND (<0.001)	ND (<0.020)
021	175 – Womens Room	71.3	49.0	637	ND (<3)	0.015	ND (<0.020)
022	101 – Office in Parking Tickets	70.1	50.5	571	ND (<3)	0.002	ND (<0.020)
023	132 – Office in Court Service Center	73.0	48.0	602	ND (<3)	0.001	ND (<0.020)
024	133 – Office in Court Service Center	73.1	47.1	578	ND (<3)	0.001	ND (<0.020)
025	G55 - Office	73.7	48.4	698	ND (<3)	0.005	ND (<0.020)
026	G42 – Mechanical Room	72.1	49.9	497	ND (<3)	0.007	ND (<0.020)
027	G39 – Storage Room	72.8	47.2	578	ND (<3)	0.010	ND (<0.020)
028	G27C – Mail Room Break Room	72.7	48.4	569	ND (<3)	0.004	ND (<0.020)
029	G02 – Janitors Room	70.7	50.4	525	ND (<3)	0.004	ND (<0.020)
030	G54 – Snack Bar	72.8	50.3	616	ND (<3)	0.005	ND (<0.020)
031	Outdoor – Front Entrance 50 State Street	59.8	63.3	404	ND (<3)	0.013	ND (<0.020)

<b>Indoor Air Quality Measurements</b> <b>Springfield Court Complex, 50 &amp; 80 State Street, Springfield, Massachusetts</b> <b>October 5, 2022</b>							
<b>Test #</b>	<b>Location</b>	<b>Temp (°F)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Carbon Monoxide (ppm)</b>	<b>Airborne PM<sub>10</sub> (mg/m<sup>3</sup>)</b>	<b>Volatile Organic Compounds (ppm)</b>
<b>Springfield Housing &amp; Juvenile Courthouse, 80 State Street, Springfield, MA</b>							
032	Outdoors - Front 80 State Street	57.4	78.6	399	ND (<3)	0.049	ND (<0.020)
033	318 – Hallway	66.5	61.5	450	ND (<3)	0.005	ND (<0.020)
034	305 – Office	69.2	56.3	462	ND (<3)	0.003	ND (<0.020)
035	307 – Lunch Room/ Conference Room	69.9	54.5	551	ND (<3)	0.003	ND (<0.020)
036	235 – Housing Court #1	66.6	54.9	422	ND (<3)	0.002	ND (<0.020)
037	228 – Waiting Area	67.7	57.5	541	ND (<3)	0.003	ND (<0.020)
038	214 – Waiting Area	69.2	54.6	487	ND (<3)	0.004	ND (<0.020)
039	115 – Office by Restrooms	71.0	51.4	696	ND (<3)	0.004	ND (<0.020)
040	102 - Parking Tickets	72.2	50.2	763	ND (<3)	0.006	ND (<0.020)
041	133 – Office of Clerk Magistrate	72.2	48.9	666	ND (<3)	0.007	ND (<0.020)
042	130 – Office/ Conference Room	70.4	50.2	619	ND (<3)	0.002	ND (<0.020)
043	124 – Waiting Area	71.4	51.2	734	ND (<3)	0.005	ND (<0.020)
044	152 – Juvenile Courtroom #2	71.9	52.1	638	ND (<3)	0.005	ND (<0.020)

<b>Indoor Air Quality Measurements</b> <b>Springfield Court Complex, 50 &amp; 80 State Street, Springfield, Massachusetts</b> <b>October 5, 2022</b>							
<b>Test #</b>	<b>Location</b>	<b>Temp (°F)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Carbon Monoxide (ppm)</b>	<b>Airborne PM<sub>10</sub> (mg/m<sup>3</sup>)</b>	<b>Volatile Organic Compounds (ppm)</b>
045	151 – Hallway to Conference Rooms	72.1	50.9	819	ND (<3)	0.003	ND (<0.020)
046	331 – Employee Lounge	71.6	49.6	510	ND (<3)	0.003	ND (<0.020)
047	338 – Jury/ Clerical Probation	71.5	50.9	524	ND (<3)	0.004	ND (<0.020)
048	223 – Office in Court Clinic	73.1	49.5	477	ND (<3)	0.001	ND (<0.020)
049	328 – Court Clinic	73.4	48.2	487	ND (<3)	0.003	ND (<0.020)
050	226 – Judges Lobby	72.6	48.2	488	ND (<3)	0.005	ND (<0.020)
051	238 – Hall Outside to 240	71.9	49.3	501	ND (<3)	0.002	ND (<0.020)
052	251 – Office in Probation	71.5	49.5	450	ND (<3)	0.008	ND (<0.020)
053	243 – Main Area in Probation	71.2	49.9	434	ND (<3)	0.003	ND (<0.020)
054	B04 – Files/ Janitor Storage	70.9	49.5	477	ND (<3)	0.003	ND (<0.020)
055	Cage, Outside B01/B02	70.1	50.5	471	ND (<3)	0.010	ND (<0.020)
056	B27 – Judges Lobby/ Office	70.3	50.4	558	ND (<3)	0.004	ND (<0.020)
057	B20 – Old Cubicle Area	70.6	51.1	547	ND (<3)	0.006	ND (<0.020)



Indoor Air Quality Measurements Springfield Court Complex, 50 & 80 State Street, Springfield, Massachusetts October 5, 2022							
Test #	Location	Temp (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Airborne PM <sub>10</sub> (mg/m <sup>3</sup> )	Volatile Organic Compounds (ppm)
058	B23 – Judges Lobby/ Basement Office	72.1	50.8	610	ND (<3)	0.004	ND (<0.020)
059	B44 – B39 Lock-up Area Cell	71.6	50.5	671	ND (<3)	0.004	ND (<0.020)
060	B19 - Mens Room	71.1	51.1	547	ND (<3)	0.002	ND (<0.020)
Desired Comfort Range		~67 to 82	Less than 60 to 65	Less than 800 to ~1,100	< 5 to < 9	≤ 0.150	≤ 0.140
See Attachment B – Floor Plan for location of measurements ppm = parts per million parts of air, by volume mg/m <sup>3</sup> = milligrams per cubic meter of air ND = non-detect, below reliable limit of quantification or detection							
REFERENCE VALUES							
Carbon Dioxide (CO <sub>2</sub> ):		ASHRAE maximum recommended CO <sub>2</sub> level indicating adequate supply of outdoor air = outdoor concentration + 700 ppm (i.e., 1,100 ppm); MA DPH maximum recommended CO <sub>2</sub> level = 800 ppm					
Carbon Monoxide (CO):		USGBC LEED (2009) 9 ppm, if outdoor measurement no greater than 2 ppm above outdoors					
Temperature range guidelines based on ASHRAE 55-2020, at various levels of relative humidity:							
<u>Relative Humidity</u>		<u>Winter Temperature</u>		<u>Summer Temperature</u>			
< 20%		70 to 79 °F		76 to 83 °F			
20 to 40%		69 to 78 °F		75 to 82 °F			
40 to 60%		68 to 77 °F		74 to 81 °F			

### ***Temperature and Relative Humidity.***

Temperatures were generally within or slightly below recommended comfort ranges for seasonal occupancy at the observed relative humidity levels.

All relative humidity measurements collected in the Roderick L. Ireland Courthouse were below 65%. As we head into the heating season, the use of dehumidifying equipment and actions to

reduce indoor humidity levels throughout the building to improve occupant comfort and for optimum building conditions and maintenance will become less necessary.

With all of the relative humidity measurements below the acceptable range, no corrective measures are required based on the temperature and relative humidity measurements in this building.

#### ***Carbon Dioxide.***

The average CO<sub>2</sub> concentrations throughout the buildings ranged from 422 to 819 ppm and outdoor concentrations ranged from 399 to 404 ppm. The average CO<sub>2</sub> concentrations during the current occupancy conditions remained below the ASHRAE guideline (i.e., the outdoor concentration of approximately 400 ppm + 700 ppm). All CO<sub>2</sub> measurements in the Roderick L. Ireland Courthouse, except for the one taken in 151 – Hallway Outside Conference Rooms, were also below the more stringent MA DPH guideline of 800 ppm. All the CO<sub>2</sub> measurements represent favorable findings, reflecting efforts to maintain good ventilation within the buildings.

#### ***Carbon Monoxide.***

The CO measurements were non-detect (< 3 ppm) and were within the recommended indoor air quality guideline. No corrective measures are indicated based on the CO measurements.

#### ***Total Volatile Organic Compounds (VOCs).***

All VOC measurements throughout the buildings were non-detect (<0.020 ppm). All VOC measurements were below the desired comfort range and occupational exposure limits for common VOCs that are likely to be present in buildings. Therefore, no corrective measures are recommended at this time. Note that hand sanitizers and sanitizing wipes may be a source of temporary increases in VOC concentrations.

#### ***Airborne Particulate Matter.***

The average PM<sub>10</sub> measurements throughout the buildings ranged from ND (<0.001 mg/m<sup>3</sup>) to 0.023 mg/m<sup>3</sup> and were below the guideline of 0.150 mg/m<sup>3</sup>. No corrective measures are indicated based on the PM<sub>10</sub> measurements.

#### ***Microbial Sampling.***

The results of air sampling for mold are presented in the table below. The air sampling results are presented in concentration units of spores per cubic meter of air (spores/m<sup>3</sup>). The laboratory analytical report is included as Attachment A.

<b>Microbial Sampling Results</b> <b>Springfield Court Complex, 50 &amp; 80 State Street, Springfield, Massachusetts</b> <b>October 5, 2022</b>				
Sample Number	Location	Sample Type	Mold Detected (spores/m <sup>3</sup> )	Interpretation
<b>Roderick L. Ireland Courthouse, 50 State Street, Springfield, MA</b>				
34922145	Probate Courtroom #3	Air	13	See Comment 1
34922138	409 - Registry of Deeds	Air	27	See Comment 1
34922136	Superior Courtroom #5	Air	13	See Comment 1
34922148	347A - Judges Lobby	Air	40	See Comment 1
34922126	249B - Judges Lobby	Air	13	See Comment 1
34922129	221 - Vault	Air	26	See Comment 1
34922137	155 - Office	Air	13	See Comment 1
34922128	101 - Office in Parking	Air	27	See Comment 1
34922133	G55 - Office	Air	26	See Comment 1
34922135	Outdoors Front 50 State Street	Air	1,267	-----
<b>Springfield Housing &amp; Juvenile Courthouse, 80 State Street, Springfield, MA</b>				
34922134	Outdoors, Front 80 State Street	Air	413	-----
34922127	307 - Lunch room	Air	13	See Comment 1
34922132	228 - Waiting Area	Air	26	See Comment 1
34922168	115 - Office	Air	13	See Comment 1
34922130	133 - Office of Clerk Magistrate	Air	27	See Comment 1
34922131	124 - Waiting Area	Air	13	See Comment 1
34922166	331 - Employees Lounge	Air	40	See Comment 1
34922179	226 - Judges Lobby	Air	13	See Comment 1
34922157	B04 - Basement File Storage	Air	26	See Comment 1
34922155	B27 - Judges Lobby	Air	13	See Comment 1
Comment 1 – Indoor concentrations were below the concurrent outdoor concentration, and the types of spores identified were also detected outdoors or are commonly detected outdoors. These results are not suggestive of an indoor mold source.				

In all the test locations, the air sample results indicated total mold spore concentrations were below the concurrent outdoor concentration, and the types of mold detected indoors were similar to spore types that were or are commonly detected outdoors. Thus, no indoor mold source was indicated in these areas based on the air sampling results.

It is important to note that construction materials, personal belongings, and indoor environments (including indoor air) are normally not sterile. Therefore, no structure can be completely free of microbial organisms including mold. However, under normal circumstances, commonly accepted industry guidelines suggest that the levels of fungi in the indoor environment should be generally similar to (or lower than) the outdoor air outside of the property. It should be understood that natural dust deposition also contains some amount of fungal spores.

## RECOMMENDATIONS

Based on the findings of this assessment, TRC recommends the following for consideration:

1. No corrective measures are required based on measurements of temperature, carbon dioxide, carbon monoxide, PM<sub>10</sub>, or TVOC's.
2. TRC will continue to observe relative humidity through the fall season and will alert building management if any unusual levels are noted. Efforts to maintain relative humidity to levels below 65% are no longer necessary this season, given the lower outdoor temperature and relative humidity conditions.
3. Continue to operate ventilation equipment to introduce the greatest amount of outdoor air feasible based on the equipment parameters and seasonal conditions. This will provide the greatest safety for building occupants and will also help to quickly dilute the air when disinfectant wipes, cleaners and hand sanitizers are used. Routine preventative maintenance of heating, ventilating and air-conditioning equipment should also be emphasized.

## CONDITIONS AND LIMITATIONS

The visual inspection performed by TRC is limited to representative areas that were accessible at the time of inspection. Destructive and/or invasive inspections were not within the scope of our investigation. The sampling results reflect conditions at the time of sampling.

TRC has performed the tasks set forth above in a thorough and professional manner consistent with industry standards. TRC cannot guarantee and does not warrant that this limited assessment has revealed all potential adverse environmental conditions affecting the site.

No expressed or implied representation or warranty is included in this report except that the services were performed within the limits of the scope of work authorized by the client and the encountered site conditions.

TRC appreciates the opportunity to provide you with consulting services. If you have any questions or comments, please contact us. We look forward to working with you on future endeavors.

Very Truly Yours,  
**TRC**

*Denise Houseman*

Denise Houseman  
Industrial Hygienist



Robert King, CSP, CIH (1982-2021)  
Senior EHS Engineer

Enc.: Attachment A – Laboratory Results and Chain of Custody  
Attachment B – Sample Location Drawings

**ATTACHMENT A – LABORATORY RESULTS AND CHAIN OF CUSTODY**

Analysis Report prepared for

## TRC Companies

**814 Broad Street  
Weymouth, MA 02189**

**Phone: (781) 337-0016**


**499949**  
Springfield District Court  
50 & 80 State Street  
Springfield, MA

Collected: **October 5, 2022**  
Received: **October 6, 2022**  
Reported: **October 6, 2022**

We would like to thank you for trusting Hayes Microbial for your analytical needs!  
We received 20 samples by FedEx in good condition for this project on October 6th, 2022.

The results in this analysis pertain only to this job, collected on the stated date, and should not be used in the interpretation of any other job. This report may not be duplicated, except in full, without the written consent of Hayes Microbial Consulting, LLC..

This laboratory bears no responsibility for sample collection activities, analytical method limitations, or your use of the test results. Interpretation and use of test results are your responsibility. Any reference to health effects or interpretation of mold levels is strictly the opinion of Hayes Microbial. In no event, shall Hayes Microbial or any of its employees be liable for lost profits or any special, incidental or consequential damages arising out of the use of these test results.



Steve Hayes, BSMT(ASCP)  
Laboratory Director  
Hayes Microbial Consulting, LLC.



EPA Laboratory ID: VA01419



Lab ID: #188863



DPH License: #PH-0198

**Denise Houseman**  
**TRC Companies**

814 Broad Street  
Weymouth, MA 02189  
(781) 337-0016

**499949**

Springfield District Court  
50 & 80 State Street  
Springfield, MA

**#22039542**

**Spore Trap**  
SOP - HMC#101

Sample Number	1	34922145		2	34922138		3	34922136		4	34922148	
Sample Name	Probate Courtroom #3			409 - Registry of Deeds			Superior Courtroom #5			347A - Judges Lobby		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>		
Background	2			2			2			2		
Fragments	ND			ND			ND			ND		
Organism	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total
Alternaria												
Ascospores	1	13	100.0%	2	27	100.0%				2	27	66.7%
Aspergillus Penicillium												
Basidiospores							1	13	100.0%			
Bipolaris Drechslera												
Chaetomium												
Cladosporium										1	13	33.3%
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes												
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
Total	1	13	100%	2	27	100%	1	13	100%	3	40	100%

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: Oct 5, 2022

Received: Oct 6, 2022

Reported: Oct 6, 2022

Project Analyst:  
Ramesh Poluri, PhD

*P. Ramesh*

Date:  
**10 - 06 - 2022**

Reviewed By:  
Steve Hayes, BSMT

*Stephen N. Hayes*

Date:  
**10 - 06 - 2022**

3005 East Boundary Terrace, Suite F. Midlothian, VA. 23112

(804) 562-3435

contact@hayesmicrobial.com

Page: 2 of 8



Sample Number	5	34922126		6	34922129		7	34922137		8	34922128	
Sample Name	<b>249B - Judges Lobby</b>			<b>221 - Vault</b>			<b>155 - Office</b>			<b>101 - Office in Parking</b>		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>		
Background	2			1			2			2		
Fragments	ND			ND			ND			ND		
<b>Organism</b>	<b>Raw Count</b>	<b>Count / m<sup>3</sup></b>	<b>% of Total</b>	<b>Raw Count</b>	<b>Count / m<sup>3</sup></b>	<b>% of Total</b>	<b>Raw Count</b>	<b>Count / m<sup>3</sup></b>	<b>% of Total</b>	<b>Raw Count</b>	<b>Count / m<sup>3</sup></b>	<b>% of Total</b>
Alternaria												
Ascospores	1	13	100.0%	1	13	50.0%	1	13	100.0%	2	27	100.0%
Aspergillus Penicillium												
Basidiospores				1	13	50.0%						
Bipolaris Drechslera												
Chaetomium												
Cladosporium												
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes												
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
<b>Total</b>	<b>1</b>	<b>13</b>	<b>100%</b>	<b>2</b>	<b>26</b>	<b>100%</b>	<b>1</b>	<b>13</b>	<b>100%</b>	<b>2</b>	<b>27</b>	<b>100%</b>

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **Oct 5, 2022**

Received: **Oct 6, 2022**

Reported: **Oct 6, 2022**

Project Analyst:  
 Ramesh Poluri, PhD

*P. Ramesh*

Date:  
**10 - 06 - 2022**

Reviewed By:  
 Steve Hayes, BSMT

*Stephen N. Hayes*

Date:  
**10 - 06 - 2022**

**Denise Houseman**  
**TRC Companies**

814 Broad Street  
Weymouth, MA 02189  
(781) 337-0016

**499949**

Springfield District Court  
50 & 80 State Street  
Springfield, MA

**#22039542**

**Spore Trap**  
SOP - HMC#101

Sample Number	9	34922133		10	34922135		11	34922134		12	34922127	
Sample Name	<b>G55 - Office</b>			<b>Outdoors - Front 50 State St</b>			<b>Outdoors - Front 80 State St</b>			<b>307 - Lunch room</b>		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>		
Background	2			2			2			2		
Fragments	ND			ND			ND			ND		
Organism	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total
Alternaria												
Ascospores	1	13	50.0%	74	987	77.9%	20	267	64.5%	1	13	100.0%
Aspergillus Penicillium				2	27	2.1%						
Basidiospores				18	240	18.9%	6	80	19.4%			
Bipolaris Drechslera												
Chaetomium												
Cladosporium	1	13	50.0%	1	13	1.1%	4	53	12.9%			
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes							1	13	3.2%			
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
Total	2	26	100%	95	1267	100%	31	413	100%	1	13	100%

Water Damage Indicator

Common Allergen

Slightly Higher than Baseline

Significantly Higher than Baseline

Ratio Abnormality



Collected: **Oct 5, 2022**

Received: **Oct 6, 2022**

Reported: **Oct 6, 2022**

Project Analyst:  
Ramesh Poluri, PhD

*P. Ramesh*

Date:  
**10 - 06 - 2022**

Reviewed By:  
Steve Hayes, BSMT

*Stephen N. Hayes*

Date:  
**10 - 06 - 2022**

3005 East Boundary Terrace, Suite F. Midlothian, VA. 23112

(804) 562-3435

contact@hayesmicrobial.com

Page: 4 of 8

**Denise Houseman**  
**TRC Companies**

814 Broad Street  
Weymouth, MA 02189  
(781) 337-0016

**499949**

Springfield District Court  
50 & 80 State Street  
Springfield, MA

**#22039542**

**Spore Trap**  
SOP - HMC#101

Sample Number	13	34922132		14	34922168		15	34922130		16	34922131	
Sample Name	<b>228 - Waiting Area</b>			<b>115 - Office</b>			<b>133 - Office of Clerk Magistrate</b>			<b>124 - Waiting Area</b>		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>			13 spores/m <sup>3</sup>		
Background	2			2			2			2		
Fragments	ND			ND			ND			ND		
Organism	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total	Raw Count	Count / m <sup>3</sup>	% of Total
Alternaria												
Ascospores	1	13	50.0%	1	13	100.0%	2	27	100.0%			
Aspergillus Penicillium												
Basidiospores												
Bipolaris Drechslera												
Chaetomium												
Cladosporium	1	13	50.0%							1	13	100.0%
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes												
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
Total	2	26	100%	1	13	100%	2	27	100%	1	13	100%

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **Oct 5, 2022**

Received: **Oct 6, 2022**

Reported: **Oct 6, 2022**

Project Analyst:  
Ramesh Poluri, PhD

*P. Ramesh*

Date:  
**10 - 06 - 2022**

Reviewed By:  
Steve Hayes, BSMT

*Stephen N. Hayes*

Date:  
**10 - 06 - 2022**

**Denise Houseman**  
**TRC Companies**

814 Broad Street  
Weymouth, MA 02189  
(781) 337-0016

**499949**

Springfield District Court  
50 & 80 State Street  
Springfield, MA

**#22039542**

**Spore Trap**  
SOP - HMC#101

Sample Number	17	34922166		18	34922179		19	34922157		20	34922155	
Sample Name	331 - Employees Lounge			226 - Judges Lobby			B04 - Basement File Storage			B27 - Judges Lobby		
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter		
Reporting Limit	13 spores/m³			13 spores/m³			13 spores/m³			13 spores/m³		
Background	2			2			2			2		
Fragments	ND			ND			ND			ND		
Organism	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total	Raw Count	Count / m³	% of Total
Alternaria												
Ascospores	2	27	66.7%	1	13	100.0%	1	13	50.0%	1	13	100.0%
Aspergillus Penicillium												
Basidiospores	1	13	33.3%				1	13	50.0%			
Bipolaris Drechslera												
Chaetomium												
Cladosporium												
Curvularia												
Epicoccum												
Fusarium												
Memnoniella												
Myxomycetes												
Pithomyces												
Stachybotrys												
Stemphylium												
Torula												
Ulocladium												
Total	3	40	100%	1	13	100%	2	26	100%	1	13	100%

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **Oct 5, 2022**

Received: **Oct 6, 2022**

Reported: **Oct 6, 2022**

Project Analyst:  
Ramesh Poluri, PhD

*P. Ramesh*

Date:  
**10 - 06 - 2022**

Reviewed By:  
Steve Hayes, BSMT

*Stephen N. Hayes*

Date:  
**10 - 06 - 2022**

## Spore Trap Information

<b>Reporting Limit</b>	The Reporting Limit is the lowest number of spores that can be detected based on the total volume of the sample collected and the percentage of the slide that is counted. At Hayes Microbial, 100% of the slide is read so the LOD is based solely on the total volume. Raw spore counts that exceed 500 spores will be estimated.
<b>Blanks</b>	Results have not been corrected for field or laboratory blanks.
<b>Background</b>	<p>The Background is the amount of debris that is present in the sample. This debris consists of skin cells, dirt, dust, pollen, drywall dust and other organic and non-organic matter. As the background density increases, the likelihood of spores, especially small spores such as those of <i>Aspergillus</i> and <i>Penicillium</i> may be obscured. The background is rated on a scale of 1 to 5 and each level is determined as follows:</p> <p><b>NBD:</b> No background detected due to possible pump or cassette malfunction. Recollect sample. (Field Blanks will display NBD)</p> <p><b>1 :</b> &lt;5% of field occluded. No spores will be uncountable.</p> <p><b>2 :</b> 5-25% of field occluded.</p> <p><b>3 :</b> 25-75% of field occluded.</p> <p><b>4 :</b> 75-90% of field occluded.</p> <p><b>5 :</b> &gt;90% of field occluded. Suggested recollection of sample.</p>
<b>Fragments</b>	Fragments are small pieces of fungal mycelium or spores. They are not identifiable as to type and when present in very large numbers, may indicate the presence of mold amplification.
<b>Control Comparisons</b>	There are no national standards for the numbers of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should not exceed those that are present outdoors at any given time. There will always be some mold spores present in "normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.
<div>Water Damage Indicator</div> <div>Common Allergen</div> <div>Slightly Higher than Baseline</div> <div>Significantly Higher than Baseline</div> <div>Ratio Abnormality</div>	<p><b>Blue:</b> These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.</p> <p><b>Green:</b> Although all molds are potential allergens, these are the most common allergens that may be found indoors.</p> <p><b>Orange:</b> The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.</p> <p><b>Red:</b> The spore count is significantly higher than the baseline count and probably indicates a source of contamination.</p> <p><b>Violet:</b> The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.</p>
<b>Color Coding</b>	Fungi that are present in indoor samples at levels lower than 200 per cubic meter are not color coded on the report, unless they are one of the water damage indicators.

## Organism Descriptions

Ascospores	<b>Habitat:</b> A large group consisting of more than 3000 species of fungi. Common plant pathogens and outdoor numbers become very high following rain. Most of the genera are indistinguishable by spore trap analysis and are combined on the report. <b>Effects:</b> Health affects are poorly studied, but many are likely to be allergenic.
Aspergillus Penicillium	<b>Habitat:</b> The most common fungi isolated from the environment. Very common in soil and on decaying plant material. Are able to grow well indoors on a wide variety of substrates. <b>Effects:</b> This group contains common allergens and many can cause hypersensitivity pneumonitis. They may cause extrinsic asthma, and many are opportunistic pathogens. Many species produce mycotoxins which may be associated with disease in humans and other animals. Toxin production is dependent on the species, the food source, competition with other organisms, and other environmental conditions.
Basidiospores	<b>Habitat:</b> A common group of Fungi that includes the mushrooms and bracket fungi. They are saprophytes and plant pathogens. In wet conditions they can cause structural damage to buildings. <b>Effects:</b> Common allergens and are also associated with hypersensitivity pneumonitis.
Cladosporium	<b>Habitat:</b> One of the most common genera worldwide. Found in soil and plant debris and on the leaf surfaces of living plants. The outdoor numbers are lower in the winter and often relatively high in the summer, especially in high humidity. The outdoor numbers often spike in the late afternoon and evening. Indoors, it can be found growing on textiles, wood, sheetrock, moist window sills and in HVAC supply ducts. <b>Effects:</b> A common allergen, producing more than 10 allergenic antigens and a common cause of hypersensitivity pneumonitis.
Myxomycetes	<b>Habitat:</b> Found on decaying plant material and as a plant pathogen. <b>Effects:</b> Some allergenic properties reported, but generally pose no health concerns to humans.



**TRC Companies**

814 Broad Street

Weymouth, MA 02189

N

SHIP: FEDEX - BOX 50  
DATE: 10-06-2022

MOLD



22039542

8123 4351 7738



Job Number: 499949	Job Name: Springfield District Court 50 & 80 State Street Springfield, MA	Phone: (781) 789-2985	Email: osmaracko@trccompanies.co
Dr: Olivia Smaracko <i>Denise Houseman</i>		Note: <i>dhouseman@trccompanies.com</i>	
Date Collected: <i>10/5/22</i>			

Analysis Type		Analysis Description	Turnaround	Accepted Media Types
Spore Trap	S	Identification & Enumeration of Fungal Spores	24 Hour	Air Cassettes, Impact Slides
	S+	Spore Trap Analysis with Dander, Fiber, and Pollen counts	24 Hour	Air Cassettes, Impact Slides
Direct ID	D	ID & Semi-Quantative Enumeration of spores and mycelium	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
	D+	Direct Analysis with Fully Quantitative spore count	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
Culture	C1	Identification & Enumeration of Mold only	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C2	Identification & Enumeration of Bacteria only	4 Day	Air Plate, Agar Plate, Swab, Bulk
	C3	Identification & Enumeration of Mold and Bacteria	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C5	Coliform Screen for Sewage Bacteria	2 Day	Agar Plate, Swab, Bulk
Particle	TPA	Total Particulate Analysis, ID & Count (Does Not Include Mold)	24 Hour	Air Cassettes, Impact Slides, Bio-Tape

Acc

#	Number	Sample	Analysis	Volume	Notes
1	34922145	Probate Courtroom #3	S	75 L	
2	34922138	409-Registry of Deeds	S	75 L	
3	34922136	Superior Courtroom #5	S	75 L	
4	34922148	347A-Judges Lobby	S	75 L	
5	34922126	249B-Judges Lobby	S	75 L	
6	34922129	221-Vault	S	75 L	
7	34922137	155-Office	S	75 L	
8	34922128	101-Office in Parking Ticket	S	75 L	
9	34922133	G-55-Office	S	75 L	
10	34922135	Outdoors-Front 50 State St	S	75 L	
11	34922134	Outdoors-Front 80 State St	S	75 L	
12	34922127	307-Lunch Room	S	75 L	
13	34922132	228-Waiting Area	S	75 L	
14	34922168	115-Office	S	75 L	
15	34922130	133-Office of Clerk Magliana	S	75 L	
16	34922131	124-Waiting Area	S	75 L	

Released by: <i>Denise Houseman</i>	Date: <i>10/5/22</i>	Received By: <i>EO</i>	Date: <i>10/6</i>
-------------------------------------	----------------------	------------------------	-------------------



**TRC Companies**

814 Broad Street

Weymouth, MA 02189

N

SHIP: FEDEX - BOX 50

DATE: 10-06-2022

MOLD



22039542

8123 4351 7738



Job Number: 499949	Job Name: Springfield District Court	e: (781) 789-2985	Email: osmaracko@trccompanies.co
pr: Olivia Smaracko	50 & 80 State Street		
Date Collected:	Springfield, MA	Note:	

Analysis Type		Analysis Description	Turnaround	Accepted Media Types
Spore Trap	S	Identification & Enumeration of Fungal Spores	24 Hour	Air Cassettes, Impact Slides
	S+	Spore Trap Analysis with Dander, Fiber, and Pollen counts	24 Hour	Air Cassettes, Impact Slides
Direct ID	D	ID & Semi-Quantative Enumeration of spores and mycelium	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
	D+	Direct Analysis with Fully Quantitative spore count	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
Culture	C1	Identification & Enumeration of Mold only	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C2	Identification & Enumeration of Bacteria only	4 Day	Air Plate, Agar Plate, Swab, Bulk
	C3	Identification & Enumeration of Mold and Bacteria	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C5	Coliform Screen for Sewage Bacteria	2 Day	Agar Plate, Swab, Bulk
Particle	TPA	Total Particulate Analysis, ID & Count (Does Not Include Mold)	24 Hour	Air Cassettes, Impact Slides, Bio-Tape

#	Number	Sample	Analysis	Volume	Notes
17	34922166	331- Employees Lounge	S	75 L	
18	34922179	226- Judges Lobby	S	75 L	
19	34922157	B04- Basement File Storage	S	75 L	
20	34922155	B27- Judges Lobby	S	75 L	
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					

Released by:	Date:	Received By: Eo	Date: 10/6
--------------	-------	-----------------	------------