

Customer Technical Standards Manual				
Section	Title	Comment from the SME Manual	Industry Comments	DER Comments
Section 4.1	Screening Process	If the EMT RDI study has unacceptable results per latest EDC approved version of IEEE 5447, show a Short Transfer Trip (STT) solution will be imposed.	On behalf of industry comment, if DTT will be enforced, what technologies will be used for DTT, is the developer responsible for miles of new fiber, or can inverters with SMART functionality avoid the cost of DTT by implementing it without any extra equipment?	NA
		Unique arrangements not explicitly defined within this document at Eversource's discretion. This includes a consideration of off-normal circuit configurations.	More clarity is needed on the specific "unique arrangements" that would require DTT	NA
			Proposed to be larger than 500 kW	NA
Section 4.2	Reduse Blocking	Eversource only. Reduse Blocking is not applicable to Eversource	Industry would like to more fully understand why there is such a difference in acceptable solutions between EDC's	NA
Section 5.0	DER Capacity- Feeder Limits	Larger amounts of generation may be interconnected at the expense of the interconnecting Customer by reconfiguring or replacing equipment on a feeder as necessary to accommodate the increased thermal loading. Larger generation can be interconnected to express feeders if proper cable size is used and a new feeder breaker position is available.	What project size would be considered a larger generator? >10 MW?	NA
		In all studied cases, the addition of the DER shall not cause any thermal criteria violations on feeders under normal (N-0) and contingency (N-1) operations where applicable. The following limitations should be considered for forward and reverse loadings. Please note that forward loading limitation is only applicable to ES applications.	Is load growth applied or omitted during calculations?	NA
Section 6.1	Remote Monitoring & Control Threshold Requirements	A recloser & a DER Gateway may be required for all sites ≥5000kW sites.	1. Proposal to make this larger than 500 kW. 2. On behalf of industry comment, need to clarify that this requirement is for NEW applications only and will not be enforced on post-ISA change requests, especially for projects post PTO. Is recloser required for BTM (non-export) applications with Eversource?	NA
Section 7.2	External Disconnects	The switch shall at minimum provide a visible break.	Proposed to cross-off visible break to a switch which is 'labeled'	NA
Section 8.4	Testing Points	The joint utilities may require additional protection and functionalities not listed here depending on the site configuration. For example, Self Protection Over-Voltage (GPOV) and inverter test/lock control function must be tested during the witness test.	NA	Agreed. This statement will be re-written to state that the test points within the inverter settings to be verified during Witness Tests.
Section 10	GSU Transformer Winding Configurations	Secondary Grounding Transformer	NA	No significant change here, but want to note that this is the case of GSOV issues. Both "effectively grounded" and "secondary grounding transformer" are the same thing. Not sure if EDCs are trying to state different pathways to achieving effective grounding. What's not stated is how the grounding after is used for heaters, which should include consideration of the load. Generally, supplemental grounding efforts are not necessary due to load providing grounding.
Section 12.2	Capacity Limit	The minimum forward loading of the transformer shall be considered for the Capacity limit assessment. Reverse power flow that will significantly add to the transformer insulation loss of life on a routine basis, based on the transformer specification and the insulation aging description in the latest version of IEEE Std. C57.91, will be evaluated. Any required transformer upgrades will be included in system modifications required to implement the DER facility.	NA	Good change as it reflects actual system conditions. The rest of the paragraph is very vague as to how often life will be assessed. We'd expect that only actual field measurements would be considered based on load profile over time. It may be instructive to look at the results of PMUs study on inverterport export if that's a concern being addressed here (probably not?). Evaluating the Thermal impacts of inverterport Export on Service Transformer.
Section 12.3	Transmission Ground Fault Protection	DTT may be used to disconnect the facility for transmission faults.	NA	See REC's paper Deconstructing DTT – DTT can be used on the transmission system to disconnect the substation, but DTT to the DER location should not be necessary. The feeder breakers can be opened upon detection of faults instead.
Section 14	Voltage Flicker & Rapid Voltage Change	During the Expedited Review process, voltage deviations of greater than 2.0% will prompt the application to be moved to a full system impact study.	NA	Why 2.0% and not 3.0% in line with IEEE 1547-2018? Language below is much preferred.
Section 16.3	Limiting Import & Export	A utility grade ANSI C37.30 is required for limit control functions. Class 1 resources (less than or equal to 40MW) on radial feeders shall not be subject to ANSI C37.30 relay requirements. For analysis related to fault conditions and risk of cascading concerns it is necessary to consider the full nameplate capacity of the inverter, therefore the limited export generation would NOT be used in the calculation/analysis of these conditions.	On behalf of industry comment, can we add "unless a utility-approved Certified Power Control System is allowed by the utility" NA NA	NA Does this need to be revised if some rule revisions are adopted re PCS export limitation? REC generally tries to note that this would be the case absent any manufacturer supplied test data that shows they can limit fault currents through some means.
Section 16.4	Charging Methods	If requesting to charge from the utility source, the utility may, in its sole discretion, elect to evaluate the charging aspect of the design as a load customer.	Clarification is needed on whether the additional study can be completed in parallel with the typical interconnection studies if desired	NA
Section 17	Significant vs Moderate Changes	Customer Impact vs Engineering Impact	1. On behalf of industry comment. We need more clarity on "Customer Impact" This is to broad and encompasses items that industry would not consider enough of an impact to prevent changes. 2. On behalf of industry comment, This needs to be qualified by some range (e.g., more than 32% of the remaining hosting capacity). This statement, as is, means ANY increase in kW AC (over 1 kW AC) is "Significant". It should also factor in whether this project is actually DRAB/NO additional hosting capacity. So, make any change in hosting capacity after considering upgrades paid for by the customer. Similarly "lasting delay" could mean 1 day of added delay. It needs to be material, and to allow for a minimal retask period (e.g., 20 BD or something, let's discuss).	NA
Section 18	Transient Overvoltage (TOV)	Transient overvoltage is of concern due to potential load rejection overvoltage (LORV) and Ground Fault Overvoltage (GFOV) by inverter based DER. There is a concern that during step changes in load (such as tripping of an upstream device) as well as single phase to ground fault condition, the proposed inverters may cause transient over voltage more than 2.2 pu.	NA	7.4.2 doesn't require limitation of voltage to 2.2pu, nor does the definition of effective grounding (which is 1.18pu over one cycle). I'd suggest editing this as shown.
		Eversource: The aggregate DER to minimum gross load ratio will be determined for the proposed feeder(s). If the ratio exceeds 135% then there is potential for transient overvoltage concerns and an EMT study may be required. If the EMT study is required and analysis determines that a TOV condition is caused by the DER, mitigation (a combination of mitigations, such as, but not limited to, Self Protection Overvoltage (GPOV) enabling on the inverter, reclosing grounding system, and Surge Arresters at PTO or Substation may be required.	NA	EMT seems unnecessary to accomplish this. UL 1943 30 inverters are tested to verify GPOV does not exceed 1.447 threshold. GPOV is mitigated by load (e.g. 1.2 pu load > 1% connected) or a resistively grounded grounding bank which considers load in the calculation of value.