

Can DX Smart Inverters Provide TX Voltage Support?

MA-TSRG

December 08, 2020

Samer Arafa

nationalgrid



National Grid's Solar and Storage Program

*Goal: Move from interconnecting DER to integrating it.
Reduce customer interconnection cost and time.*

[National Grid's Solar Website](#)





Promising Technologies We are Exploring

Key Areas of Research in the program	Partner	Share updates
Increasing Hosting Capacity-Interim Report	EPRI	Offered Q2, 2018
DC Arc flash study	EPRI	Offered Q3, 2018
Increasing Hosting Capacity-Smart Inverters	EPRI	Offered Q2, 2019
PV +Storage+ Load Management systems	Fraunhofer	Offered Q4, 2019
Field Performance Assessment of Advanced Grid Support Functions.	EPRI	Offered Q2, 2020
Can DER be used to resolve Transmission Issues?	EPRI	Q4, 2020
Risk of Islanding of Smart Inverters	NPPT	Q1, 2021
Distribution Resource Open Management Optimization System (DROMOS)	Sandia	Q2, 2021



Impact of High Penetration DER on Transmission

- The Duck Curve is the most popular example of the impact of excessive distribution generation on the transmission system
- The Farranti effect is a much less known issue.
- Can Distribution tools be used to address Transmission problems?




Source: US Census Bureau 2000



Source: ISO New England


DER for Substation Voltage Regulation

1. Local substation control using voltage reading



DER for System Support

2. System control using load forecast



In partnership with EPRI



Develop PV Deployment Scenarios for each Feeder Analyzed

- PV penetration?
- Smart Inverter penetration?

Examine the Distribution System Impacts and Mitigation Requirements


- Analyze Distribution System Impacts
- Assess Mitigation Measures

Estimate Impacts to Solar PV Generation

Evaluate the Costs and Benefits of using Advanced Inverters Compared to the Traditional Solution (Shunt Reactors)


- Analyze Costs for Each Feeder
- Analyze Total Costs And Benefits

7 SPII sites fall in the National Grid Central & Western Mass




Source: ISO New England


Two Sample Feeders chosen for their diversity




Modelling Methodology



Feeder 1 and Substation 1



Feeder 2 and Substation 2



Results are plotted per scenario

Two types of control needs:

- Load-level control
- Voltage-level control

MVAR Request:

- Range from 0.0 to 40.0MVAR

Load Level:


- Range from 25% to 100%

Generation Level:


- Range from 0% to 100%

Results include:

- Additional MVAR Capability Needed
- Real Power Curtailment
- Substation Apparent Power
- Substation Power Factor
- # of additional substation regulator tap changes
- # of Overloads Thermal limit of conductor and equipment
- # of Undervoltages $V_{dist} < 0.95$ p.u.
- # of Overvoltages $V_{dist} > 1.05$ p.u.




Substation 1 Results – Number of Undervoltages




Takeaway: Undervoltages worsen in conditions of high load, light generation, and increasing MVAR requests. Sub preforms better than Feeder only.

Based on results, mitigation efforts were applied: undervoltage > voltage regulator



Feeder 1 w/ mitigation Results – Number of Undervoltages



Takeaway: No undervoltages observed up to 10MVAR requested. This is technocritical upper limit adding one (1) regulator can provide.


Moving on to Substation 2

Feeder 2 Results – Number of Undervoltages



Takeaway: Undervoltages only occur at 12MVAR+

Based on results, mitigation efforts were applied: undervoltage > voltage regulator overload > reconductor



Feeder 2 w/ mitigation Results – Number of Undervoltages



Takeaway: No undervoltages observed up to 28MVAR requested. This is theoretical upper limit adding one (1) regulator can provide.



Summary of results

Substation	No mitigation	With mitigation		MW of DER	# of DER sites
Substation 1	0	10MVAR	168kVA voltage regulator	44.65	24
Substation 2	12 MVAR	24 MVAR	413.8kVA voltage regulator 1,100 ft re-conductoring	69.11	30

Results are based on a PV deployment scenario of:

- Only Large PV (950kW+) can participate in VAR voltage control
- All (existing + pending) PV will participate
- All Substation PV (including PV on parallel feeders) will participate


Opportunity Cost of Real Power



Power Factor was greater than 0.92, for most of the cases in the feeders studied. This translates to less than 2.5% of energy curtailment.

The Grid of the Future

- Grid management will become more granular, considering near real-time impacts and specific locational values and constraints to reliably manage an increasingly complex and dynamic system.
- Likely to create new opportunities for DER integrators.
- The modern grid operator will use integrated processes and tools to leverage Distributed Energy Resources (DER) as an efficient resource for customers and the resiliency of the grid.
- Communication and coordination managed through a common exchange.



Thank You

**All questions and comments
are welcome.**

Samer Arafa
Samer.Arafa@nationalgrid.com

Link to Paper:

<https://www.nationalgridus.com/massachusetts-solar/document-library>

CAN SMART INVERTERS ON THE
DISTRIBUTION CIRCUIT PROVIDE
TRANSMISSION VOLTAGE SUPPORT?

National Grid Solar Phase II Program Report



October 2020

Samples from Overseas

nationalgrid



Nodal Controllers is an example of TSO-DSO controls


In Ireland,



have partnered to introduce TSO-DSO nodal controllers to control wind sites in +/- Q operations

References:

- Joint workshop IEA PVPS TASK 14 & IEA ISGAN ANNEX 6, TSO-DSO engagement in Ireland and Northern Ireland, Séamus Power, 2015
- ISGAN Workshop, Interaction of DSO and TSO requirements on Distribution Networks, Tony Hearne, 2019



Source: EIRGRID

Power Potential, an innovation project from nationalgridESO





Table 1 Number of DERs considered per GSP and associated total MW rated value

GSP	DER number	Total MW
Bolney	8	92.15
Ninfield	6	108.13
Sellindge	4	32.50
Canterbury North	9	274.95
Richborough ^a	6	64.2

^aRichborough is a substation expected to be present by 2025 but which will not be considered for the Power Potential project trials.



Source: NationalGridESO Power Potential