



The Commonwealth of Massachusetts
 Executive Office of Health and Human Services
 Department of Public Health
 Bureau of Environmental Health
 Community Sanitation Program
 128 East Mountain Road, Westfield, MA 01085-1889
 Phone: 617-448-3373

MAURA T. HEALEY
 Governor

KIMBERLEY DRISCOLL
 Lieutenant Governor

KATHLEEN E. WALSH
 Secretary

ROBERT GOLDSTEIN, MD, PhD
 Commissioner

Tel: 617-624-6000
 www.mass.gov/dph

April 24, 2023

Nicholas Cocchi, Sheriff
 Western Massachusetts Recovery and Wellness Center
 155 Mill Street
 Springfield, MA 01108 (electronic copy)

Re: Facility Inspection - Western Massachusetts Recovery and Wellness Center, Springfield

Dear Sheriff Cocchi:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Minimum Requirements for the Management of Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 2013 Food Code; 105 CMR 500.000 Good Manufacturing Practices for Food; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; the Department's Community Sanitation Program (CSP) conducted an inspection of the Western Massachusetts Recovery and Wellness Center on April 20, 2023 accompanied by Diane Bator, Standards and Training Coordinator. Violations noted during the inspection are listed below including 8 repeat violations:

Should you have any questions, please don't hesitate to contact me.

Sincerely,

Scott Koczela
 Environmental Analyst, CSP, BEH

- cc: Robert Goldstein, MD, PhD, Commissioner, DPH
 Nalina Narain, Director, BEH
 Steven Hughes, Director, CSP, BEH
 Kathleen E. Walsh, Secretary, Executive Office of Health and Human Services (electronic copy)
 Carol A. Mici, Commissioner, DOC (electronic copy)
 Terrence Reidy, Secretary, EOPSS (electronic copy)
 Timothy Gotovich, Director, Policy Development and Compliance Unit (electronic copy)
 Anthony Scibielli, Superintendent (electronic copy)
 Diane Bator, Standards and Training Coordinator (electronic copy)
 Major Gary Trueman, EHSO (electronic copy)
 Helen R. Caulton Harris, H&HS, Director, Springfield Board of Health (electronic copy)
 Clerk, Massachusetts House of Representatives (electronic copy)
 Clerk, Massachusetts Senate (electronic copy)

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

LOBBY

No Violations Noted

Officer's Station # 105

No Violations Noted

Central Control # 106

No Violations Noted

Captain's Office # 107

No Violations Noted

Mail Room # 103

No Violations Noted

Male Bathroom

105 CMR 451.126
105 CMR 451.123

Hot Water: Hot water temperature recorded at 135⁰F at handwash sink
Maintenance: Ceiling vent dusty

Female Bathroom

No Violations Noted

Counselor's Office # 109

No Violations Noted

Janitor's Closet # 127

No Violations Noted

Group Room # 156

No Violations Noted

DAY REPORTING WING

Day Reporting Center # 151

No Violations Noted

Male Staff Locker Room # 146

No Violations Noted

Female Staff Locker Room # 147

No Violations Noted

MEDICAL

Lab # 142

No Violations Noted

Nursing Supervisor's Office # 141
No Violations Noted

Exam Room # 140
Unable to Inspect – In Use

Bathroom
No Violations Noted

Forensics # 139
No Violations Noted

Biohazard Storage # 138
No Violations Noted

Medical Records # 136
No Violations Noted

Nurse's Exam Room # 137
No Violations Noted

INTAKE/CLASSIFICATION AREA
No Violations Noted

Records # 149
No Violations Noted

Classification Manager's Office # 150
No Violations Noted

GROUND FLOOR

Education Office # 004
No Violations Noted

Resident Property # 002 (located in Stairwell)
No Violations Noted

Offices # 007/008
No Violations Noted

Female Bathroom
Unable to Inspect – In Use

Male Bathroom
No Violations Noted

Recreation Room # 009
No Violations Noted

Maintenance Room # 013
105 CMR 451.200 Food Storage, Preparation and Service: Food preparation not compliance with 105 CMR 590.000, interior of microwave oven dirty

Laundry Room # 019
105 CMR 451.353* Interior Maintenance: Washing machine # 1 out-of-order

Kitchen

Handwash Sink
No Violations Noted

Ventilation Hoods
No Violations Noted

Food Prep Area
No Violations Noted

Reach-in-Cooler
No Violations Noted

Handwash Sink (near Reach-in-Cooler)
No Violations Noted

Food Prep Sink (2-Compartment Sink)
No Violations Noted

Ice Machine
No Violations Noted

Walk-in-Freezer
No Violations Noted

Walk-in-Cooler
No Violations Noted

Kitchen Steward's Office # 37
No Violations Noted

Hallway (outside Steward's Office)
No Violations Noted

Dry Storage # 36
No Violations Noted

Dishwashing Area
No Violations Noted

Pot and Pan Storage
No Violations Noted

Janitor's Closet # 40
No Violations Noted

Inmate Bathroom
No Violations Noted

Office # 44
No Violations Noted

Training Room/Linen Storage # 45
No Violations Noted

Dining Hall
No Violations Noted

Storage # 25
No Violations Noted

Bathroom
No Violations Noted

Staff Break Room # 20
No Violations Noted

Storage # 27
No Violations Noted

Storage # 29
No Violations Noted

Janitor's Closet
No Violations Noted

HOUSING

1st Floor/ Women's Unit

Room # 111
No Violations Noted

Room # 112
No Violations Noted

Room # 113
No Violations Noted

Room # 114
No Violations Noted

Room # 115
Unable to Inspect – In Use

<i>Room # 116</i>	Unable to Inspect – In Use
<i>Officer's Station # 118</i>	No Violations Noted
<i>Janitor's Closet # 123</i>	No Violations Noted
<i>Resident's Bathroom # 124</i> 105 CMR 451.130*	Hot Water: Shower water temperature recorded at 125°F in shower # 4
Day Room	No Violations Noted
<i>Office # 120</i>	No Violations Noted
<i>Laundry</i>	No Violations Noted
<u>2nd Floor</u>	
<i>Group Room # 202</i>	No Violations Noted
<i>Room # 204</i>	No Violations Noted
<i>Room # 205</i>	No Violations Noted
<i>Room # 206</i>	No Violations Noted
<i>Room # 207</i>	No Violations Noted
<i>Room # 208</i>	No Violations Noted
<i>Room # 209</i>	No Violations Noted
<i>Janitor's Closet # 210</i>	No Violations Noted
<i>Storage # 212</i>	No Violations Noted

<i>Room # 213</i>	No Violations Noted
<i>Room # 214</i>	No Violations Noted
<i>Room # 215</i>	No Violations Noted
<i>Offices # 216/217/218</i>	No Violations Noted
<i>Staff Bathroom # 219</i>	No Violations Noted
<i>Resident's Bathroom # 222</i>	
105 CMR 451.123*	Maintenance: Soap scum on walls in shower # 1
105 CMR 451.123	Maintenance: Soap scum on floor in shower # 1, 2, and 3
105 CMR 451.126	Hot Water: Hot water temperature recorded at 135 ⁰ F at handwash sink # 1
105 CMR 451.130	Hot Water: Shower water temperature recorded at 120 ⁰ F at shower # 5
105 CMR 451.123	Maintenance: Mold observed on bench in shower # 5
<i>Offices # 223/224/225</i>	No Violations Noted
<i>Room # 226</i>	No Violations Noted
<i>Room # 227</i>	No Violations Noted
<i>Room # 228</i>	No Violations Noted
<i>Day Room # 229</i>	No Violations Noted
<i>Laundry Room</i>	No Violations Noted
<i>Room # 232</i>	No Violations Noted
<i>Janitor's Closet # 233</i>	No Violations Noted
<i>Room # 234</i>	No Violations Noted
<i>Room # 235</i>	Unable to Inspect – In Use

Office # 237

No Violations Noted

Resident's Bathroom # 238

105 CMR 451.123*

105 CMR 451.130*

Maintenance: Soap scum on walls in shower # 5

Hot Water: Shower water temperature recorded at 124⁰F in shower # 6

Offices # 240/242/243

No Violations Noted

Group Room # 245

No Violations Noted

Day Room # 246

No Violations Noted

Officer's Station # 247

No Violations Noted

3rd Floor

Group Room # 302

No Violations Noted

Room # 303

No Violations Noted

Room # 304

No Violations Noted

Room # 305

No Violations Noted

Room # 306

No Violations Noted

Room # 307

No Violations Noted

Room # 308

No Violations Noted

Janitor's Closet # 309

105 CMR 451.353

Interior Maintenance: Ceiling vent dusty

Storage # 311

No Violations Noted

Room # 312

No Violations Noted

<i>Room # 313</i>	No Violations Noted
<i>Room # 314</i>	No Violations Noted
<i>Offices # 315/316/317</i>	No Violations Noted
<i>Staff Bathroom # 318</i>	No Violations Noted
<i>Resident's Bathroom # 321</i>	
105 CMR 451.123*	Maintenance: Soap scum on floor in shower # 1
105 CMR 451.123	Maintenance: Soap scum on walls in shower # 2 and 3
105 CMR 451.130*	Hot Water: Shower water temperature recorded at 135 ⁰ F in shower #5
105 CMR 451.126	Hot Water: Hot water temperature recorded at 135 ⁰ F at handwash sink # 1
105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, handwash sink # 3 damaged
<i>Office # 322</i>	No Violations Noted
<i>Unit Manager's Office # 323</i>	No Violations Noted
<i>Office # 324</i>	No Violations Noted
<i>Room # 325</i>	No Violations Noted
<i>Room # 326</i>	
105 CMR 451.353	Interior Maintenance: Pillow damaged on bed
<i>Room # 327</i>	No Violations Noted
<i>Room # 328</i>	No Violations Noted
<i>Room # 330</i>	No Violations Noted
<i>Janitor's Closet # 331</i>	No Violations Noted
<i>Room # 332</i>	
105 CMR 451.353	Interior Maintenance: Pillow damaged on bed
<i>Room # 333</i>	No Violations Noted

Office # 335

No Violations Noted

Resident's Bathroom # 336

105 CMR 451.130

105 CMR 451.130*

Plumbing: Plumbing not maintained in good repair, handwash sink # 3 damaged
Hot Water: Shower water temperature recorded at 125⁰F in shower # 5

Offices # 338/340/341

No Violations Noted

Group Room # 343

No Violations Noted

Day Room # 344

No Violations Noted

Officer's Station # 345

No Violations Noted

Observations and Recommendations

1. The inmate population was 71 at the time of inspection.
2. Hot water temperature range for showers is 100⁰F to 112⁰F.
3. Hot water temperature range for handwash sinks is 110⁰F to 130⁰F.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment Regulations or download a copy, please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Retail food". Then under DPH Regulations and FDA Code click "Merged Food Code" or "105 CMR 590.000 - State Sanitary Code Chapter X - Minimum Sanitation Standards for Food Establishments".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Program regulations". Then under Food Processing click "105 CMR 500.000: Good Manufacturing Practices for Food".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Scott Koczela
Environmental Analyst, CSP, BEH